



**DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY  
DEPARTMENT OF WATER SERVICES  
3900 Donaldson Pl, N.W. WASHINGTON DC 20016**

**Lead and Copper Compliance Report  
January - June 2006**

The District of Columbia Water and Sewer Authority (WASA) is below the lead action level at 0.010 mg/L for first draw samples and below the copper action level at 0.098 mg/L for first draw samples during the first semester 2006 compliance period. Table 1 summarizes the compliance results for the monitoring period January through June 2006.

**Table 1. January - June 2006 Lead and Copper Compliance Results**

<b>Number of Samples</b>		
Total		110
Compliance		104
Invalidated		6
<b>90th Percentile Concentrations</b>		
	<u>1<sup>st</sup> Draw</u>	<u>2nd Draw</u>
Lead mg/L	0.010	0.012
Copper mg/L	0.098	0.036
<b>Service Line Materials</b>		
Full Lead		82%
Partial Lead		18%

The appendices contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
  - Table A.1 Lead Results
  - Table A.2 Copper Results
- Appendix B: Sampling and Customer Data
- Appendix C: Customer Sample Kit Distribution List
- Appendix D: Non-Compliance Lead Data
  - Table D.1 Customer Requested Lead Samples
  - Table D.2 Lead Service Line Replacement Samples
- Appendix E: Sample Invalidation Request and EPA Response dated June 30, 2006
- Appendix F: Locations Removed from Routine List

WASA collected samples from February through May 2006. A total of 18 samples were excluded from the 2006 compliance report: 12 samples used for 2005 compliance (refer to July through December 2005 report for these sample results) and 6 samples invalidated this semester (Appendix E).

## Appendix A – Lead and Copper Compliance Data

**Table A.1 Lead Results**

<b>No.</b>	<b>Address</b>	<b>Lead (mg/L) 1st Draw</b>	<b>Lead (mg/L) 2nd Draw</b>
1	106 7TH ST NE	0.000	0.000
2	1346 Madison St NW	0.000	0.000
3	202 11th St SE	0.000	0.000
4	3104 Hawthorne St NW	0.000	0.000
5	3434 30th St NW	0.000	0.000
6	3439 24TH ST SE	0.000	0.000
7	1706 NEW JERSEY AVE NW	0.000	0.001
8	517 4th St SE	0.001	0.000
9	1315 FRANKLIN ST NE	0.001	0.001
10	2016 4TH ST NE	0.001	0.001
11	3913 8TH ST NW	0.001	0.001
12	1341 Massachusetts Ave SE	0.001	0.001
13	2823 28TH ST NW	0.001	0.001
14	4206 10th St NE	0.001	0.000
15	4518 14TH ST NW	0.001	0.000
16	2007 37TH ST NW	0.001	0.001
17	3601 WARREN ST NW	0.001	0.002
18	1812 M St NE	0.001	0.001
19	2702 P ST NW	0.001	0.000
20	4332 BRANDYWINE ST NW	0.001	0.001
21	1380 E ST NE	0.001	0.002
22	143 UHLAND TER NE	0.001	0.009
23	1115 PARK ST NE	0.001	0.001
24	3706 35th St NW	0.001	0.002
25	4410 New Hampshire Ave NW	0.001	0.002
26	834 Delafield Pl NW	0.001	0.001
27	1228 CARROLLSBURG PL SW	0.002	0.001
28	6213 7TH ST NW	0.002	0.003
29	1016 DOUGLAS ST NE	0.002	0.003
30	1825 L ST NE	0.002	0.001
31	2830 BRENTWOOD RD NE	0.002	0.002
32	5318 9TH ST NW	0.002	0.003
33	1427 N CAROLINA AVE NE	0.002	0.002
34	3720 NORTHAMPTON ST NW	0.002	0.002

35	3973 HARRISON ST NW	0.002	0.005
36	712 JEFFERSON ST NW	0.002	0.002
37	607 ATLANTIC ST SE	0.002	0.003
38	4718 Sheriff Rd NE	0.002	0.002
39	805 LONGFELLOW ST NW	0.002	0.002
40	1671 Rosedale St NE	0.002	0.002
41	2118 14th St SE	0.002	0.002
42	623 Morton PI NE	0.002	0.003
43	3218 MORRISON ST NW	0.002	0.004
44	3215 Mckinley St NW	0.002	0.009
45	1351 Montague St NW	0.002	0.002
46	3218 MACOMB ST NW	0.002	0.007
47	3827 VEAZEY ST NW	0.002	0.001
48	1008 MARYLAND AVE NE	0.002	0.002
49	1746 KENYON ST NW	0.003	0.002
50	3211 Central Ave NE	0.003	0.002
51	5405 39TH ST NW	0.003	0.008
52	144 Tennessee Ave NE	0.003	0.014
53	5324 COLORADO AVE NW	0.003	0.001
54	211 RANDOLPH PL NE	0.003	0.002
55	3301 BROWN St NW	0.003	0.014
56	2404 3rd St NE	0.003	0.001
57	518 Varnum St NW	0.003	0.002
58	4818 8TH ST NW	0.003	0.003
59	1222 HAMILTON ST NW	0.003	0.003
60	3917 LIVINGSTON ST NW	0.003	0.012
61	3618 PORTER ST NW	0.004	0.005
62	1400 FLORAL ST NW	0.004	0.008
63	3201 Porter St NW	0.004	0.001
64	3550 ALBEMARLE ST NW	0.004	0.002
65	4609 30TH ST NW	0.004	0.003
66	4131 YUMA ST NW	0.004	0.006
67	424 Luray PI NW	0.004	0.013
68	228 V ST NE	0.004	0.006
69	1241 JACKSON ST NE	0.004	0.008
70	4401 5TH ST NW	0.004	0.003
71	3202 38TH ST NW	0.004	0.002
72	1412 N Carolina Ave NE	0.005	0.003
73	1353 JEFFERSON ST NW	0.005	0.005
74	4304 Fessenden St NW	0.005	0.013
75	403 K St NE	0.005	0.006

76	3014 Channing St NE	0.005	0.003
77	1506 ALLISON ST NW	0.005	0.005
78	4326 FOREST LN NW	0.005	0.005
79	3809 ALTON PL NW	0.005	0.012
80	618 OTIS PL NW	0.005	0.003
81	1614 Allison St NW	0.005	0.010
82	3412 GARRISON ST NW	0.006	0.007
83	641 Gallatin St NW	0.006	0.004
84	3531 16TH ST NW	0.006	0.002
85	1863 MONROE ST NW	0.007	0.002
86	3424 PORTER ST NW	0.007	0.012
87	821 BUCHANAN ST NW	0.007	0.009
88	1320 Delafield PI NW	0.008	0.010
89	1203 Quincy St NW	0.008	0.002
90	1533 Constitution Ave NE	0.008	0.002
91	5121 ILLINOIS AVE NW	0.008	0.002
92	3634 WARDER ST NW	0.010	0.009
93	4622 15TH ST NW	0.010	0.009
<b>94<sup>1</sup></b>	4418 14th St NE	<b>0.010</b>	0.012
95	2418 3RD ST NE	0.011	0.016
96	4305 38TH ST NW	0.011	0.010
97	3526 Park PI NW	0.011	0.013
98	1649 HARVARD ST NW	0.012	0.020
99	514 13th St SE	0.012	0.010
100	302 RITTENHOUSE ST NW	0.016	0.028
101	4429 3rd St NW	0.016	0.005
102	5229 7TH ST NW	0.017	0.015
103	4703 Macarthur Blvd NW	0.026	0.007
104	1334 HEMLOCK ST NW	0.171	0.010

Notes: results expressed as “0.000” may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

<sup>1</sup>Bolded data represents 1<sup>st</sup> draw 90<sup>th</sup> percentile.

**Table A.2 Copper Results**

<b>No.</b>	<b>Address</b>	<b>Copper (mg/L) 1st Draw</b>	<b>Copper (mg/L) 2nd Draw</b>
1	3706 35th St NW	0.004	0.003
2	3720 NORTHAMPTON ST NW	0.004	0.004
3	2016 4TH ST NE	0.006	0.005
4	4718 Sheriff Rd NE	0.006	0.007
5	712 JEFFERSON ST NW	0.006	0.007
6	143 UHLAND TER NE	0.006	0.008
7	4518 14TH ST NW	0.007	0.007
8	302 RITTENHOUSE ST NW	0.007	0.008
9	3211 Central Ave NE	0.007	0.008
10	5229 7TH ST NW	0.008	0.006
11	3439 24TH ST SE	0.008	0.008
12	3634 WARDER ST NW	0.008	0.012
13	805 LONGFELLOW ST NW	0.009	0.009
14	1812 M St NE	0.010	0.011
15	1346 Madison St NW	0.011	0.007
16	3412 GARRISON ST NW	0.011	0.007
17	403 K St NE	0.011	0.008
18	1412 N Carolina Ave NE	0.011	0.012
19	1671 Rosedale St NE	0.011	0.013
20	834 Delafield PI NW	0.011	0.021
21	3973 HARRISON ST NW	0.012	0.005
22	6213 7TH ST NW	0.013	0.008
23	211 RANDOLPH PL NE	0.013	0.010
24	5318 9TH ST NW	0.013	0.014
25	1380 E ST NE	0.013	0.016
26	4609 30TH ST NW	0.015	0.015
27	3434 30th St NW	0.017	0.003
28	5121 ILLINOIS AVE NW	0.017	0.005
29	514 13th St SE	0.017	0.008
30	3424 PORTER ST NW	0.017	0.009
31	3215 Mckinley St NW	0.017	0.010
32	2702 P ST NW	0.018	0.006
33	5324 COLORADO AVE NW	0.018	0.006
34	1203 Quincy St NW	0.019	0.011
35	4305 38TH ST NW	0.019	0.015
36	2118 14th St SE	0.020	0.010
37	4304 Fessenden St NW	0.021	0.007
38	1825 L ST NE	0.021	0.013

39	1427 N CAROLINA AVE NE	0.021	0.014
40	641 Gallatin St NW	0.022	0.011
41	3526 Park PI NW	0.023	0.015
42	1341 Massachusetts Ave SE	0.023	0.016
43	518 Varnum St NW	0.023	0.019
44	1533 Constitution Ave NE	0.024	0.008
45	4326 FOREST LN NW	0.024	0.008
46	3601 WARREN ST NW	0.024	0.012
47	3201 Porter St NW	0.024	0.030
48	3917 LIVINGSTON ST NW	0.025	0.009
49	4410 New Hampshire Ave NW	0.025	0.020
50	1706 NEW JERSEY AVE NW	0.026	0.010
51	821 BUCHANAN ST NW	0.026	0.014
52	3014 Channing St NE	0.028	0.009
53	1351 Montague St NW	0.028	0.020
54	1649 HARVARD ST NW	0.030	0.020
55	1315 FRANKLIN ST NE	0.032	0.015
56	618 OTIS PL NW	0.032	0.016
57	4418 14th St NE	0.033	0.015
58	2418 3RD ST NE	0.033	0.019
59	4131 YUMA ST NW	0.034	0.008
60	517 4th St SE	0.034	0.009
61	4622 15TH ST NW	0.034	0.010
62	1241 JACKSON ST NE	0.034	0.013
63	1115 PARK ST NE	0.034	0.016
64	3550 ALBEMARLE ST NW	0.035	0.010
65	2823 28TH ST NW	0.036	0.020
66	4429 3rd St NW	0.037	0.015
67	1863 MONROE ST NW	0.038	0.018
68	2830 BRENTWOOD RD NE	0.039	0.026
69	1353 JEFFERSON ST NW	0.040	0.032
70	3913 8TH ST NW	0.040	0.035
71	1222 HAMILTON ST NW	0.041	0.031
72	144 Tennessee Ave NE	0.043	0.012
73	1334 HEMLOCK ST NW	0.043	0.027
74	2007 37TH ST NW	0.044	0.009
75	1746 KENYON ST NW	0.044	0.087
76	1016 DOUGLAS ST NE	0.052	0.037
77	1400 FLORAL ST NW	0.055	0.010
78	424 Luray PI NW	0.055	0.012
79	3531 16TH ST NW	0.058	0.012

80	607 ATLANTIC ST SE	0.059	0.043
81	3809 ALTON PL NW	0.061	0.012
82	3104 Hawthorne St NW	0.061	0.020
83	3218 MORRISON ST NW	0.065	0.019
84	4401 5TH ST NW	0.065	0.030
85	3618 PORTER ST NW	0.070	0.024
86	1320 Delafield PI NW	0.071	0.014
87	5405 39TH ST NW	0.071	0.023
88	1228 CARROLLSBURG PL SW	0.073	0.081
89	3827 VEAZEY ST NW	0.075	0.004
90	228 V ST NE	0.078	0.016
91	106 7TH ST NE	0.079	0.055
92	2404 3rd St NE	0.083	0.012
93	1506 ALLISON ST NW	0.087	0.060
<b>94</b> <sup>1</sup>	4332 BRANDYWINE ST NW	<b>0.098</b>	0.067
95	3202 38TH ST NW	0.099	0.026
96	1614 Allison St NW	0.100	0.007
97	1008 MARYLAND AVE NE	0.108	0.038
98	623 Morton PI NE	0.112	0.029
99	4818 8TH ST NW	0.112	0.060
100	3301 BROWN St NW	0.117	0.037
101	202 11th St SE	0.130	0.009
102	4703 Macarthur Blvd NW	0.139	0.036
103	4206 10th St NE	0.142	0.025
104	3218 MACOMB ST NW	0.161	0.014

<sup>1</sup>Bolded data represents 1<sup>st</sup> draw 90<sup>th</sup> percentile.



## Appendix B – Customer Information and Sample Data

1008 MARYLAND AVE NE Washington, DC 20002  
DENISE PARKS; 2025435035

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0024
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.0024
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.108
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.038
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

1016 DOUGLAS ST NE Washington, DC 20018  
PEGGY HACKETT; 5262667

Pipe Material: Partial Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0016
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.0029
Received at WAD:	3/31/2006	Copper (mg/L) 1st Draw:	0.052
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.037
Date received from Aqueduct:	4/28/2006	Iron (mg/L) 1st Draw:	0.012
Date Letter Sent to Customer:	04/28/06	Iron (mg/L) 2nd Draw:	<0.01

106 7TH ST NE Washington, DC 20002  
LAURA SALARANO;

Pipe Material: Lead

Bottle Drop OffDate:	5/18/2006	Lead (mg/L) 1st Draw:	<0.0005
Collection Date:	5/19/2006	Lead (mg/L) 2nd Draw:	<0.0005
Received at WAD:	5/23/2006	Copper (mg/L) 1st Draw:	0.079
Analysis Date:	5/30/2006	Copper (mg/L) 2nd Draw:	0.055
Date received from Aqueduct:	6/1/2006	Iron (mg/L) 1st Draw:	0.026
Date Letter Sent to Customer:	6 /5 /06	Iron (mg/L) 2nd Draw:	0.032

1115 PARK ST NE Washington, DC 20011  
JENNIFER POPOVIC; 2025127151

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0013
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.0009
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.034
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.016
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

1203 Quincy St NW Washington, DC 200115768  
JUANITA HARLEY; (202) 726-0604

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0078
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0018
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.019
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.011
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.484
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.058

1222 HAMILTON ST NW Washington, DC 20011  
GENEVA JONES; 2027231443

Pipe Material: Partial Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0032
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.003
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.041
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.031
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.016

1228 CARROLLSBURG PL SW Washington, DC 20024  
JENNIFER LAKE; 2158757

Pipe Material: Partial Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0015
Collection Date:	2/9/2006	Lead (mg/L) 2nd Draw:	0.001
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.073
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.081
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	0.062
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	0.022

1241 JACKSON ST NE Washington, DC 20017  
MELODIE KATE; 2025187983

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0042
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.008
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.034
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.013
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0.047
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0.026

1315 FRANKLIN ST NE Washington, DC  
VIRGINIA LYONS; 2028325666

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0006
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0006
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.032
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.015
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

1320 Delafield Pl NW Washington, DC 200114419  
JAMES DAVIS; 2028822231

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0077
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0097
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.071
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.014
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.047
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.023

1334 HEMLOCK ST NW Washington, DC 20012  
JACK PIORKO; 2028296144

Pipe Material: Partial Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.171
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.0099
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.043
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.027
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	<0.01

1341 Massachusetts Ave SE Washington, DC 20003  
CARMEN COMIN; 5478303

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0007
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.0005
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.023
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.016
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	<0.01

1346 Madison St NW Washington, DC 200117841  
PHUOC PHAM; 2024914473

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	<0.0005
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.011
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

1351 Montague St NW Washington, DC 200112875  
DAVID DOMENICI; 2127978250

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0023
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0018
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.028
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.02
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.01

1353 JEFFERSON ST NW Washington, DC 20011  
ROSSELYN ABITBOL; 2025450639

Pipe Material: Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0046
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.0051
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.04
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.032
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	0.01

1380 E ST NE Washington, DC  
GLORIA ROBERTS; 2024424428

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0012
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0017
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.013
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.016
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

1400 FLORAL ST NW Washington, DC 20012  
RUTH JOHNSON; 2028295426

Pipe Material: Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0035
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.0081
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.055
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	<0.01

1412 N Carolina Ave NE Washington, DC  
Heather Scott;

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0046
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0027
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.011
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.055
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.046

1427 N CAROLINA AVE NE Washington, DC  
CHARLOTTE TAYLOR; 5441115

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0019
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0021
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.021
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.014
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

143 UHLAND TER NE Washington, DC 20002  
IDA JACKSON; 2028325337

Pipe Material: Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0012
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.0094
Received at WAD:	2/16/2006	Copper (mg/L) 1st Draw:	0.006
Analysis Date:	2/23/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	0

144 Tennessee Ave NE Washington, DC 200026426  
JERRY REHM; 2024799734

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0026
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0137
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.043
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.011
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	<0.01

1506 ALLISON ST NW Washington, DC  
LEIGH VERBOIS; 2023671414

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.005
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.0054
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.087
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.06
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0.04
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0.02

1533 Constitution Ave NE Washington, DC 200026525  
ALESSANDRO GRAVINA;

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0079
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0018
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.024
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	<0.01

1614 Allison St NW Washington, DC 200114214  
JEAN KORNFELD; (202) 722-5089

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0054
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0098
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.1
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.024

1649 HARVARD ST NW Washington, DC 20016  
WILLIAM GORDON; 2022340053

Pipe Material: Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0117
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.0204
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.03
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.02
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	0.192
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	0.154

1671 Rosedale St NE Washington, DC 200024525  
SHYU PATRICIA VERMILLION BRYCE D; (202) 463-2203

Pipe Material: Lead

Bottle Drop OffDate:		Lead (mg/L) 1st Draw:	0.0021
Collection Date:	5/17/2006	Lead (mg/L) 2nd Draw:	0.002
Received at WAD:	5/17/2006	Copper (mg/L) 1st Draw:	0.011
Analysis Date:	5/24/2006	Copper (mg/L) 2nd Draw:	0.013
Date received from Aqueduct:	5/26/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/30/06	Iron (mg/L) 2nd Draw:	<0.01

1706 NEW JERSEY AVE NW Washington, DC  
JOEL MARTIN; 2022741882

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	<0.0005
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0007
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.026
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0.054

1746 KENYON ST NW Washington, DC 20010  
JAMES YEAGER; 7871986

Pipe Material: Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0025
Collection Date:	2/9/2006	Lead (mg/L) 2nd Draw:	0.0015
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.044
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.087
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	0.089
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	0.015

1812 M St NE Washington, DC 200022010  
ANITA ELLIOT; (202) 397-5728

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0011
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0012
Received at WAD:	5/17/2006	Copper (mg/L) 1st Draw:	0.01
Analysis Date:	5/24/2006	Copper (mg/L) 2nd Draw:	0.011
Date received from Aqueduct:	5/26/2006	Iron (mg/L) 1st Draw:	0.034
Date Letter Sent to Customer:	05/30/06	Iron (mg/L) 2nd Draw:	0.056

1825 L ST NE Washington, DC 20002  
SAINTA HAYWOOD; 2024916841

Pipe Material: Partial Lead

Bottle Drop OffDate:	2/7/2006	Lead (mg/L) 1st Draw:	0.0017
Collection Date:	2/8/2006	Lead (mg/L) 2nd Draw:	0.001
Received at WAD:	2/10/2006	Copper (mg/L) 1st Draw:	0.021
Analysis Date:	2/15/2006	Copper (mg/L) 2nd Draw:	0.013
Date received from Aqueduct:	3/2/2006	Iron (mg/L) 1st Draw:	0.02
Date Letter Sent to Customer:	03/07/06	Iron (mg/L) 2nd Draw:	0.024

1863 MONROE ST NW Washington, DC 20010  
ALBERTA EDWARDS; 2023327464

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0068
Collection Date:	3/27/2006	Lead (mg/L) 2nd Draw:	0.0019
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.038
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.018
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0



2007 37TH ST NW Washington, DC 20007  
STEVE POLITYKA; 2029654714

Pipe Material: Lead

Bottle Drop OffDate:	3/7/2006	Lead (mg/L) 1st Draw:	0.0008
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0013
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.044
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.012
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

2016 4TH ST NE Washington, DC 20020  
WARREN THOMAS; 8327420

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0006
Collection Date:	3/9/2006	Lead (mg/L) 2nd Draw:	0.0006
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.006
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.005
Date received from Aqueduct:	4/7/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

202 11th St SE Washington, DC 20011  
MONK TOPPING; 5447036

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	<0.0005
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.13
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

211 RANDOLPH PL NE Washington, DC 20002  
TUNA MECIT; 8321051

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0028
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0016
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.013
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.013
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	<0.01

2118 14th St SE Washington, DC 200204802  
ALFREDA SMITH; (202) 678-7424

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0021
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0022
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.02
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

228 V ST NE Washington, DC 20002  
TIA BUTLER; 5267107

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2003	Lead (mg/L) 1st Draw:	0.0039
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0062
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.078
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.016
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

2404 3rd St NE Washington, DC 200021114  
TERRANLC JOSEPH; 2029570827

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.003
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0008
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.083
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.026

2418 3RD ST NE Washington, DC 20005  
MARY ELLEN SLAYTER; 9057067

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0105
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0161
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.033
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.019
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

2702 P ST NW Washington, DC 20007  
CHRIS DIETRICH; 2023370555

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0012
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	<0.0005
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.018
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.006
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.151
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	<0.01

2823 28TH ST NW Washington, DC 20008  
OLIVIA MORGAN;

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0007
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0006
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.036
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.02
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	<0.01

2830 BRENTWOOD RD NE Washington, DC 20018  
PAUL BAKER; 2026350413

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0017
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0019
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.039
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.026
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	<0.01

3014 Channing St NE Washington, DC 200181545  
MARY MYERS; 2028329423

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0048
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0032
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.028
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.046
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.048

302 RITTENHOUSE ST NW Washington, DC 20011  
GLYNN LEWIS; 2022913309

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0156
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0278
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.007
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0.202
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.223

3104 Hawthorne St NW Washington, DC 200083539  
ANNE KEISER; (202) 333-4938

Pipe Material: Partial Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	5/11/2006	Copper (mg/L) 1st Draw:	0.061
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.02
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.034
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.031

3201 Porter St NW Washington, DC 200083212  
EDWARD M & M A LEVIN; (202) 363-0558

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0037
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0014
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.024
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.03
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

3202 38TH ST NW Washington, DC 20016  
JAINE W APARISU; 2022625880

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0044
Collection Date:	3/9/2006	Lead (mg/L) 2nd Draw:	0.0016
Received at WAD:	3/23/2006	Copper (mg/L) 1st Draw:	0.099
Analysis Date:	3/29/2006	Copper (mg/L) 2nd Draw:	0.026
Date received from Aqueduct:	4/27/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	4 /28/06	Iron (mg/L) 2nd Draw:	0

3211 Central Ave NE Washington, DC 200182623  
MW FREEMAN; (202) 269-0627

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0025
Collection Date:	5/5/2006	Lead (mg/L) 2nd Draw:	0.0024
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.007
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	<0.01

3215 Mckinley St NW Washington, DC 200151634  
DAVID SHOTT JUSTIN; 2028246374

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0021
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0086
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.017
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.184
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.114

3218 MACOMB ST NW Washington, DC 20008  
JOHN BUNTIN; 2023639609

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0023
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0074
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.161
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.014
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3218 MORRISON ST NW Washington, DC 20015  
MARGARET SOLLEE; 2023971212

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0021
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0043
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.065
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.019
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3301 BROWN St NW Washington, DC 20010  
PETER WILSON; 2343301

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0029
Collection Date:	3/27/2006	Lead (mg/L) 2nd Draw:	0.0139
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.117
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.037
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0.018

3412 GARRISON ST NW Washington, DC 20015  
FRANCIS TOLAND; 3634343

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0056
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0071
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.011
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.204
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.043

3424 PORTER ST NW Washington, DC 20016  
ANTHONY QUANTON; 2023632382

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0073
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0117
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.017
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0.16
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.078

3434 30th St NW Washington, DC 200083248  
DAVID ALLEN GRIMSTED; (202) 966-3264

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	<0.0005
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.017
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.003
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.014
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.021

3439 24TH ST SE Washington, DC 20020  
SHIRLEY ROSEBORO; 2026784991

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0
Collection Date:	3/6/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.008
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3526 Park Pl NW Washington, DC 200101720  
PAULA ROBINSON; 2027264458

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0112
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0134
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.023
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.015
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.045
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.074

3531 16TH ST NW Washington, DC  
MARGO SMITH; 2028777164

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0064
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0018
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.058
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0.051
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	<0.01

3550 ALBEMARLE ST NW Washington, DC 20016  
DOROTHY LEVY; 2023646045

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0037
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0023
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.035
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	<0.01

3601 WARREN ST NW Washington, DC 20008  
JANICE RAHIMI; 2023639406

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.001
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0015
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.024
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.016
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.013

3618 PORTER ST NW Washington, DC 20016  
R C & PHILIP F CRONIN JR; 2029664823

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0035
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0052
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.07
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.024
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3634 WARDER ST NW Washington, DC 20010  
ANNIE HAWTHORNE-FORD; 8294731

Pipe Material: Lead

Bottle Drop OffDate:	3/7/2006	Lead (mg/L) 1st Draw:	0.0103
Collection Date:	3/9/2006	Lead (mg/L) 2nd Draw:	0.0091
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.008
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.043
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.257

3706 35th St NW Washington, DC 200163118  
MARCIA CAROLL; (202) 362-4029

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0013
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0015
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.004
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.003
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.033
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.032



3720 NORTHAMPTON ST NW Washington, DC 20015  
JANE BERNOT; 2013620854

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0019
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0021
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.004
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.004
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3809 ALTON PL NW Washington, DC 20008  
THOMAS CROWDER; 2025375045

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0052
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0116
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.061
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3827 VEAZEY ST NW Washington, DC 20016  
GERALD SMEENK; 2022448673

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0024
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.001
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.075
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.004
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

3913 8TH ST NW Washington, DC 20011  
LESTINA WALLACE; 2025459448

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0006
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0006
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.04
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.035
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

3917 LIVINGSTON ST NW Washington, DC  
LAWRENCE LOGAN; 2029662471

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0032
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0118
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.025
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

3973 HARRISON ST NW Washington, DC 20015  
MARY WHITMAN; 2023902662

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0019
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0046
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.012
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.005
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.243
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.384

403 K St NE Washington, DC 200023523  
KATRINA HARLOW; 2063038442

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0047
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0058
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.011
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

4131 YUMA ST NW Washington, DC 20016  
HEGRAIN ELISABETH; 2023642420

Pipe Material: Lead

Bottle Drop OffDate:	3/7/2006	Lead (mg/L) 1st Draw:	0.0038
Collection Date:	3/9/2006	Lead (mg/L) 2nd Draw:	0.0058
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.034
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

4206 10th St NE Washington, DC 200172121  
MICHAEL & SUZANNE CONSIDINE; 7033512094

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0008
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.142
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.025
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.026
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.029

424 Luray Pl NW Washington, DC 200102527  
LAWRENCE & INGRID PATRICK; (202) 722-2878

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0038
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0128
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.055
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.012
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

4304 Fessenden St NW Washington, DC 200164033  
AIJA C BLITTE; (202) 362-1231

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0046
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0132
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.021
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.038

4305 38TH ST NW Washington, DC 20016  
RICHARD ABBOTT; 2445267

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.011
Collection Date:	3/9/2006	Lead (mg/L) 2nd Draw:	0.0104
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.019
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.015
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0.47
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	<0.01

4326 FOREST LN NW Washington, DC 20007  
WILLIAM & SUSAN GRIDLEY; 6864186

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0052
Collection Date:	3/8/2006	Lead (mg/L) 2nd Draw:	0.0052
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.024
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.022
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.028

4332 BRANDYWINE ST NW Washington, DC 20016  
GEORGE SELIM; 2022445907

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0012
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.001
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.098
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.067
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.017
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.026

4401 5TH ST NW Washington, DC 20011  
KENNETH EYE;

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0043
Collection Date:	3/31/2006	Lead (mg/L) 2nd Draw:	0.0028
Received at WAD:	4/10/2006	Copper (mg/L) 1st Draw:	0.065
Analysis Date:	4/12/2006	Copper (mg/L) 2nd Draw:	0.03
Date received from Aqueduct:	4/13/2006	Iron (mg/L) 1st Draw:	0.045
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

4410 New Hampshire Ave NW Washington, DC 200114732  
FRANCES BETHEA; (202) 829-3571

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0013
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0015
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.025
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.02
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

4418 14th St NE Washington, DC 200172748  
CARL SUBLETT ETAL; (202) 529-8328

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0103
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0116
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.033
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.015
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.083
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.023

4429 3rd St NW Washington, DC 200117317  
ROSA SUBER; 2028657365

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0157
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0048
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.037
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.015
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.016
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.01

4518 14TH ST NW Washington, DC 20011  
LEROY ALBERTINI; 2499756

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0008
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	<0.0005
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.007
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0.044
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.038

4609 30TH ST NW Washington, DC 20008  
ARNOLD & VERA MAYER; 3636347

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.0038
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.003
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.015
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.015
Date received from Aqueduct:	4/6/2006	Iron (mg/L) 1st Draw:	0.015
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0

4622 15TH ST NW Washington, DC 20011  
JACK BOBO; 3013985525

Pipe Material: Lead

Bottle Drop OffDate:	3/6/2006	Lead (mg/L) 1st Draw:	0.01
Collection Date:	3/7/2006	Lead (mg/L) 2nd Draw:	0.0091
Received at WAD:	3/13/2006	Copper (mg/L) 1st Draw:	0.034
Analysis Date:	3/15/2006	Copper (mg/L) 2nd Draw:	0.01
Date received from Aqueduct:	4/5/2006	Iron (mg/L) 1st Draw:	0.03
Date Letter Sent to Customer:	04/10/06	Iron (mg/L) 2nd Draw:	0.014

4703 Macarthur Blvd NW Washington, DC 200071904  
SANDRA ROTTMANN; (202) 965-2202

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0258
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0074
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.139
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.036
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

4718 Sheriff Rd NE Washington, DC 200193705  
GWENDOLYN WRIGHT; 3960940

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0021
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0017
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.006
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	<0.01

4818 8TH ST NW Washington, DC 20011  
CHESTER FAGAN; 2022139949

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.003
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0029
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.112
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.06
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

5121 ILLINOIS AVE NW Washington, DC 20011  
CLEMENTE BATOES; 7233530

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0079
Collection Date:	3/27/2006	Lead (mg/L) 2nd Draw:	0.0019
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.017
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.005
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

514 13th St SE Washington, DC 20003  
KEVIN TALLEY; 2025461867

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0118
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0101
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.017
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

517 4th St SE Washington, DC 200034222  
SUSAN KELLY; 7038543439

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0005
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.034
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	<0.01

518 Varnum St NW Washington, DC 200114650  
DANIEL CHANG; 3012191393

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.003
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0017
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.023
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.019
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

5229 7TH ST NW Washington, DC 20011  
MARIA NELSON; 2022910661

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.017
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0147
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.008
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.006
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0.507
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	<0.01

5318 9TH ST NW Washington, DC 20011  
ANNIE WILLIAMS; 2027268071

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0017
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0028
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.013
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.014
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

5324 COLORADO AVE NW Washington, DC 20016  
MAYA PAABO; 2028822202

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0028
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0011
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.018
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.006
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0.203
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0.037

5405 39TH ST NW Washington, DC 20008  
DENIS ANDRZEJEWSKI; 3623176

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0026
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0076
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.071
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.023
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0



607 ATLANTIC ST SE Washington, DC 20032  
SHARON BECKLES;

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.002
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.0028
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.059
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.043
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

618 OTIS PL NW Washington, DC 20008  
SMITH PHYLLIS;

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0054
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.003
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.032
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.016
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0.041

6213 7TH ST NW Washington, DC 20011  
TANNA MCDOWELL; 2028299180

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0015
Collection Date:	3/29/2006	Lead (mg/L) 2nd Draw:	0.0033
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.013
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.008
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

623 Morton Pl NE Washington, DC 200023427  
VALERIE BURRIS; 2023031308

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0021
Collection Date:	5/2/2006	Lead (mg/L) 2nd Draw:	0.0028
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.112
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.029
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	<0.01

641 Gallatin St NW Washington, DC 200114025  
MARGARET LAGRRENA; 2028299328

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0061
Collection Date:	5/4/2006	Lead (mg/L) 2nd Draw:	0.0041
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.022
Analysis Date:	5/16/2006	Copper (mg/L) 2nd Draw:	0.011
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0.033
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0.011

712 JEFFERSON ST NW Washington, DC 20002  
DELORES WASHINGTON;

Pipe Material: Partial Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.002
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0022
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.006
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.007
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	<0.01

805 LONGFELLOW ST NW Washington, DC 20011  
AGNES COLEMAN; 8292306

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0021
Collection Date:	3/28/2006	Lead (mg/L) 2nd Draw:	0.0018
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.009
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.009
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	<0.01
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	<0.01

821 BUCHANAN ST NW Washington, DC 20011  
CHAD WHITEMAN;

Pipe Material: Lead

Bottle Drop OffDate:	3/27/2006	Lead (mg/L) 1st Draw:	0.0074
Collection Date:	3/30/2006	Lead (mg/L) 2nd Draw:	0.0089
Received at WAD:	4/5/2006	Copper (mg/L) 1st Draw:	0.026
Analysis Date:	4/11/2006	Copper (mg/L) 2nd Draw:	0.014
Date received from Aqueduct:	4/14/2006	Iron (mg/L) 1st Draw:	0.279
Date Letter Sent to Customer:	04/18/06	Iron (mg/L) 2nd Draw:	0

834 Delafield Pl NW Washington, DC 200114514  
ANTONIO CABRERA; (202) 248-4252

Pipe Material: Lead

Bottle Drop OffDate:	5/1/2006	Lead (mg/L) 1st Draw:	0.0014
Collection Date:	5/3/2006	Lead (mg/L) 2nd Draw:	0.0014
Received at WAD:	5/9/2006	Copper (mg/L) 1st Draw:	0.011
Analysis Date:	5/17/2006	Copper (mg/L) 2nd Draw:	0.021
Date received from Aqueduct:	5/19/2006	Iron (mg/L) 1st Draw:	0
Date Letter Sent to Customer:	05/24/06	Iron (mg/L) 2nd Draw:	0

**Intentionally Left Blank**

### Appendix C: Customer Sample Kit Distribution

No.	Address	Bottle Drop Date
1	1016 DOUGLAS ST NE	02/07/06
2	112 4TH ST #3 SE	02/07/06
3	1145 OATES ST NE	02/07/06
4	1214 SHEPHERD ST NW	02/07/06
5	1222 HAMILTON ST NW	02/07/06
6	1226 D ST NE	02/07/06
7	1228 CARROLLSBURG PL SW	02/07/06
8	1319 21st ST NW	02/07/06
9	1332 VERMONT AVE NW	02/07/06
10	1334 HEMLOCK ST NW	02/07/06
11	1340 V ST SE	02/07/06
12	1353 JEFFERSON ST NW	02/07/06
13	1400 FLORAL ST NW	02/07/06
14	1405 21ST ST NW	02/07/06
15	1407 MONTAGUE ST NW	02/07/06
16	143 UHLAND TER NE	02/07/06
17	1451 S ST NW	02/07/06
18	1527 33RD ST NW	02/07/06
19	1649 HARVARD ST NW	02/07/06
20	1746 KENYON ST NW	02/07/06
21	1802 35TH ST NW	02/07/06
22	1808 KEARNEY ST NE	02/07/06
23	1812 14TH ST SE	02/07/06
24	1825 L ST NE	02/07/06
25	1850 2ND ST NW	02/07/06
26	1929 SUMMIT PL NE	02/07/06
27	1931 SUMMIT PL NE	02/07/06
28	1937 SUMMIT PL NE	02/07/06
29	1956 BILTMORE ST NW	02/07/06
30	2007 37TH ST NW	03/06/06
31	2007 KLINGLE RD NW	03/06/06
32	2016 4TH ST NE	03/06/06
33	202 11th St SE	03/06/06
34	211 RANDOLPH PL NE	03/06/06
35	2111 S ST NW	03/06/06
36	2134 NEWPORT PL NW	03/06/06
37	2136 NEWPORT PL NW	03/06/06

38	2211 39TH ST NW	03/06/06
39	2237 CHESTER ST SE	03/06/06
40	2238 HALL PL NW	03/06/06
41	228 V ST NE	03/06/06
42	2418 3RD ST NE	03/06/06
43	2435 33RD ST SE	03/06/06
44	2634 GEORGIA AVE NW	03/06/06
45	2702 P ST NW	03/06/06
46	2823 28TH ST NW	03/06/06
47	2823 5TH ST NE	03/06/06
48	2830 BRENTWOOD RD NE	03/06/06
49	2846 VISTA ST NE	03/06/06
50	3009 7TH ST SE	03/06/06
51	302 RITTENHOUSE ST NW	03/06/06
52	3035 15TH ST NW	03/06/06
53	311 ELM ST NW	03/06/06
54	312 14TH ST NE	03/06/06
55	3202 38TH ST NW	03/06/06
56	3218 MACOMB ST NW	03/06/06
57	3218 MORRISON ST NW	03/06/06
58	322 TENNESSEE AVE NE	03/06/06
59	331 RALEIGH ST SE	03/06/06
60	3408 LOWELL ST NW	03/06/06
61	3412 GARRISON ST NW	03/06/06
62	3424 PORTER ST NW	03/06/06
63	3439 24TH ST SE	03/06/06
64	349 TENNESSEE AVE NE	03/06/06
65	3519 PORTER ST NW	03/06/06
66	3550 ALBEMARLE ST NW	03/06/06
67	3601 WARREN ST NW	03/06/06
68	3618 PORTER ST NW	03/06/06
69	3634 WARDER ST NW	03/06/06
70	3720 NORTHAMPTON ST NW	03/06/06
71	3809 ALTON PL NW	03/06/06
72	3827 VEAZEY ST NW	03/06/06
73	3835 BEECHER ST NW	03/06/06
74	3908 13TH ST NW	03/06/06
75	3973 HARRISON ST NW	03/06/06
76	4111 INGOMAR ST NW	03/06/06
77	4131 YUMA ST NW	03/06/06
78	4305 38TH ST NW	03/06/06

79	4306 CHESAPEAKE ST NW	03/06/06
80	4307 CHESAPEAKE ST NW	03/06/06
81	4326 FOREST LN NW	03/06/06
82	4327 IOWA AVE NW	03/06/06
83	4331 BRANDYWINE ST NW	03/06/06
84	4332 BRANDYWINE ST NW	03/06/06
85	434 15TH ST SE	03/06/06
86	4401 5TH ST NW	03/06/06
87	4413 GREENWICH PKWY NW	03/06/06
88	4518 14TH ST NW	03/06/06
89	4609 30TH ST NW	03/06/06
90	4616 HUNT PL NE	03/06/06
91	4622 15TH ST NW	03/06/06
92	1008 MARYLAND AVE NE	03/27/06
93	106 7TH ST NE	03/27/06
94	1115 PARK ST NE	03/27/06
95	1241 JACKSON ST NE	03/27/06
96	1315 FRANKLIN ST NE	03/27/06
97	1338 A ST SE	03/27/06
98	1341 Massachusetts Ave SE	03/27/06
99	1380 E ST NE	03/27/06
100	1409 35TH ST NW	03/27/06
101	1427 N CAROLINA AVE NE	03/27/06
102	1506 ALLISON ST NW	03/27/06
103	1706 NEW JERSEY AVE NW	03/27/06
104	1728 SEATON ST NW	03/27/06
105	1814 MONROE ST NW	03/27/06
106	1815 MONROE ST NW	03/27/06
107	1843 MONROE ST NW	03/27/06
108	1863 MONROE ST NW	03/27/06
109	205 TAYLOR ST NW	03/27/06
110	2300 MONROE ST NE	03/27/06
111	2724 36TH PL NW	03/27/06
112	2850 28th St NW	03/27/06
113	2912 S DAKOTA AVE NE	03/27/06
114	3030 44TH ST NW	03/27/06
115	3301 BROWN St NW	03/27/06
116	335 17TH PL NE	03/27/06
117	3531 16TH ST NW	03/27/06
118	3917 LIVINGSTON ST NW	03/27/06
119	4401 5TH ST NW	03/27/06

120	4550 30TH ST NW	03/27/06
121	4729 47TH ST NW	03/27/06
122	4818 8TH ST NW	03/27/06
123	4818 ILLINOIS AVE NW	03/27/06
124	4842 KANSAS AVE NW	03/27/06
125	501 UPSHUR ST NW	03/27/06
126	5105 14TH ST NW	03/27/06
127	5121 ILLINOIS AVE NW	03/27/06
128	5134 NEBRASKA AVE NW	03/27/06
129	514 13th St SE	03/27/06
130	5229 7TH ST NW	03/27/06
131	5301 RENO RD NW	03/27/06
132	5318 9TH ST NW	03/27/06
133	532 13TH ST SE	03/27/06
134	5324 COLORADO AVE NW	03/27/06
135	5404 39TH ST NW	03/27/06
136	5405 39TH ST NW	03/27/06
137	545 PARK RD NW	03/27/06
138	5717 SHERIER PL NW	03/27/06
139	607 ATLANTIC ST SE	03/27/06
140	608 Gallatin St NW	03/27/06
141	610 L ST NE	03/27/06
142	618 OTIS PL NW	03/27/06
143	6213 7TH ST NW	03/27/06
144	661 MARYLAND AVE NE	03/27/06
145	704 ALABAMA AVE SE	03/27/06
146	712 JEFFERSON ST NW	03/27/06
147	720 ALABAMA AVE SE	03/27/06
148	720 PARK RD NW	03/27/06
149	720 RHODE ISLAND AVE NE	03/27/06
150	728 FARRAGUT ST NW	03/27/06
151	729 11TH ST NE	03/27/06
152	747 GIRARD ST NW	03/27/06
153	765 GIRARD ST NW	03/27/06
154	805 LONGFELLOW ST NW	03/27/06
155	811 BUTTERNUT ST NW	03/27/06
156	817 DECATUR ST NW	03/27/06
157	821 BUCHANAN ST NW	03/27/06
158	833 DECATUR ST NW	03/27/06
159	835 3RD ST NE	03/27/06
160	909 HAMLIN ST NE	03/27/06



161	926 14TH ST SE	03/27/06
162	1029 4th St NE	05/01/06
163	1203 Quincy St NW	05/01/06
164	1221 Pleasant St SE	05/01/06
165	1222 Decatur St NW	05/01/06
166	1222 HAMILTON ST NW	05/01/06
167	1224 Irving St NW	05/01/06
168	1301 Michigan Ave NE	05/01/06
169	1320 Delafield Pl NW	05/01/06
170	1330 Quincy St NW	05/01/06
171	1339 Ives Pl SE	05/01/06
172	1346 Madison St NW	05/01/06
173	1351 Montague St NW	05/01/06
174	1354 W St SE	05/01/06
175	1365 Hamilton St NW	05/01/06
176	1410 D St SE	05/01/06
177	1412 N Carolina Ave NE	05/01/06
178	1436 S St NW	05/01/06
179	144 Tennessee Ave NE	05/01/06
180	1525 D St NE	05/01/06
181	1533 Constitution Ave NE	05/01/06
182	1603 Massachusetts Ave SE	05/01/06
183	1614 Allison St NW	05/01/06
184	1641 Irving St NW	05/01/06
185	1671 Rosedale St NE	05/01/06
186	1739 Seaton St NW	05/01/06
187	1749 Irving St NW	05/01/06
188	1808 37th St NW	05/01/06
189	1812 14TH ST SE	05/01/06
190	1845 Irving St NW	05/01/06
191	19 17th St SE	05/01/06
192	1920 Jackson St NE	05/01/06
193	207 Quackenbos St NW	05/01/06
194	2118 14th St SE	05/01/06
195	216 17th St NE	05/01/06
196	226 12th Pl NE	05/01/06
197	231 K St NE	05/01/06
198	234 Longfellow St NW	05/01/06
199	2404 3rd St NE	05/01/06
200	2446 Huidekoper Pl NW	05/01/06
201	2604 Rhode Island Ave NE	05/01/06

202	3013 Sherman Ave NW	05/01/06
203	3014 Channing St NE	05/01/06
204	3104 Hawthorne St NW	05/01/06
205	313 Aspen St NW	05/01/06
206	3201 Porter St NW	05/01/06
207	3211 Central Ave NE	05/01/06
208	3215 Mckinley St NW	05/01/06
209	3223 Georgia Ave NW	05/01/06
210	342 15th St SE	05/01/06
211	3434 30th St NW	05/01/06
212	3526 Park Pl NW	05/01/06
213	3665 13th St NW	05/01/06
214	37 R St NW	05/01/06
215	3706 35th St NW	05/01/06
216	3708 S St NW	05/01/06
217	3710 Huntington St NW	05/01/06
218	3973 HARRISON ST NW	05/01/06
219	403 K St NE	05/01/06
220	417 15th St SE	05/01/06
221	4204 New Hampshire Ave NW	05/01/06
222	4206 10th St NE	05/01/06
223	424 Luray Pl NW	05/01/06
224	4304 Fessenden St NW	05/01/06
225	439 Luray Pl NW	05/01/06
226	4410 New Hampshire Ave NW	05/01/06
227	4418 14th St NE	05/01/06
228	4429 3rd St NW	05/01/06
229	4610 15th St NW	05/01/06
230	4613 9th St NW	05/01/06
231	4627 49th St NW	05/01/06
232	4703 Macarthur Blvd NW	05/01/06
233	4711 9th St NW	05/01/06
234	4718 Sheriff Rd NE	05/01/06
235	4831 Nebraska Ave NW	05/01/06
236	507 Decatur St NW	05/01/06
237	5105 14TH ST NW	05/01/06
238	517 4th St SE	05/01/06
239	518 Varnum St NW	05/01/06
240	5409 13th St NW	05/01/06
241	5425 Kansas Ave NW	05/01/06
242	5433 Hawthorne Pl NW	05/01/06

243	618 Evarts St NE	05/01/06
244	623 Morton Pl NE	05/01/06
245	641 Gallatin St NW	05/01/06
246	812 Buchanan St NW	05/01/06
247	829 Euclid St NW	05/01/06
248	834 Delafield Pl NW	05/01/06
249	919 Constitution Ave NE	05/01/06
250	1812 M St NE	05/03/06
251	1029 4th St NE	05/15/06
252	1671 Rosedale St NE	05/17/06
253	507 Decatur St NW	05/22/06

## Appendix D: Non-Regulated Data

Appendix D presents the lead results of samples collected by customers requesting lead tests (D.1) and sample results of customers with partial service line replacements (D.2) . D.1 samples were collected between December 2005 and May 2006. D.2 samples were collected between January and May 2006

**Table D.1 Customer Service Samples**

No.	Address	Collection Date	Lead mg/L	
			Draw 1	Draw 2
1	1415 D St NE	3/19/2006	0.000	0.000
2	112 9th St SE	3/15/2006	0.000	0.001
3	1342 VERMONT AVE NW	3/21/2006	0.000	N/A
4	1488 Newton St NW	3/27/2006	0.000	0.000
5	6211 Utah Ave NW	5/7/2006	0.000	0.000
6	349 11th St SE	4/18/2006	0.000	N/A
7	4900 Hillbrook Ln NW	1/21/2006	0.000	0.001
8	4414 42nd St NW	5/28/2006	0.000	N/A
9	2026 E St NE	5/8/2006	0.000	0.001
10	2411 37th St NW	3/2/2006	0.000	0.000
11	429 1st St SE	4/1/2006	0.000	N/A
12	4254 Marne Pl NE	2/2/2006	0.000	0.000
13	2832 Northampton St NW	3/2/2006	0.000	0.000
14	1813 Gales St NE	4/2/2006	0.000	0.000
15	2032 Otis St NE	4/25/2006	0.000	0.000
16	1204 G St NE	12/29/2005	0.000	0.000
17	5833 Sherier Pl NW	4/5/2006	0.000	0.000
18	6630 Blair Rd NW	1/24/2006	0.000	0.000
19	1928 9th St NW	2/24/2006	0.000	0.000
20	6613 5th St NW	12/28/2005	0.000	0.000
21	1509 C St SE	12/7/2005	0.000	0.000
22	3931 Legation St NW	1/12/2006	0.000	0.000
23	1410 Webster St NW	12/7/2005	0.000	0.001
24	5624 Sherier Pl NW	4/17/2006	0.000	N/A
25	3065 Vista St NE	5/5/2006	0.000	0.000
26	1429 Alabama Ave SE	12/31/2005	0.000	0.000
27	4931 Brandywine St NW	1/30/2006	0.000	0.000
28	1829 Vermont Ave NW	12/23/2005	0.000	0.000
29	1618 32nd St NW	2/1/2006	0.000	0.000
30	3001 44th Pl NW	3/15/2006	0.000	0.000
31	4832 Brandywine St NW	12/7/2005	0.000	0.000
32	34 Kennedy St NE	4/12/2006	0.000	0.000
33	212 F St NE	2/28/2006	0.000	0.000
34	3003 O St NW	3/25/2006	0.000	0.000
35	2819 N Glade St NW	1/22/2006	0.000	0.001
36	1904 D St NE	3/16/2006	0.000	0.000
37	2705 30th St NE	3/26/2006	0.000	0.000

38	1328 Lawrence St NE	4/20/2006	0.000	N/A
39	1618 Eastern Ave NE	3/27/2006	0.000	0.000
40	3527 Albemarle St NW	2/21/2006	0.000	0.000
41	3175 18th St NW	5/26/2006	0.000	0.000
42	1647 1/2 Park Rd NW	3/22/2006	0.000	0.000
43	5922 Broad Branch Rd NW	12/12/2005	0.000	0.000
44	4840 Van Ness St NW	1/11/2006	0.000	0.000
45	3149 Adams Mill Rd NW	2/19/2006	0.000	0.000
46	4526 Eads Pl NE	3/23/2006	0.000	0.000
47	841 Marjone Ct. SE	12/14/2005	0.000	0.000
48	3634 Everett St NW	1/16/2006	0.000	0.000
49	445 15th St NE	1/17/2006	0.001	0.000
50	3327 R St NW	12/10/2005	0.001	0.000
51	4263 Hildreth St SE	1/26/2006	0.001	0.000
52	5309 B St SE	12/16/2005	0.001	0.000
53	2127 15th St SE	5/17/2006	0.001	0.001
54	1209 Jamaica St NE	3/7/2006	0.001	N/A
55	6021 3rd St NW	12/13/2005	0.001	0.000
56	4604 Kenmore Dr NW	12/19/2005	0.001	0.000
57	1624 Portal Dr NW	2/13/2006	0.001	0.002
58	4432 Butterworth Pl NW	4/26/2006	0.001	0.000
59	2818 Olive St NW	2/24/2006	0.001	0.000
60	7603 16th St NW	2/19/2006	0.001	0.000
61	3415 O St NW	12/20/2005	0.001	0.000
62	5241 42nd st.NW	12/7/2005	0.001	0.001
63	2414 Tracy Pl NW	4/6/2006	0.001	0.001
64	256 18th St SE	1/17/2006	0.001	0.000
65	1727 Church St NW	3/1/2006	0.001	0.001
66	1914 17th St NW	3/22/2006	0.001	0.000
67	2620 11th St NW	1/18/2006	0.001	0.001
68	1923 17th St NW	2/4/2006	0.001	0.000
69	927 E St NE	2/3/2006	0.001	0.000
70	4916 Macarthur Blvd NW	3/16/2006	0.001	0.001
71	6521 Barnaby St NW	2/24/2006	0.001	0.000
72	1731 Upshur St NW	4/17/2006	0.001	0.001
73	1532 Monroe St NE	2/23/2006	0.001	0.000
74	5132 Tilden St NW	2/27/2006	0.001	0.000
75	1123 Chicago St SE	1/31/2006	0.001	0.000
76	804 New Hampshire Ave NW	12/4/2005	0.001	0.001
77	333 17th St NE	12/30/2005	0.001	0.000
78	115 4th St SE	3/27/2006	0.001	0.002
79	2914 Upton St NW	12/18/2005	0.001	0.000
80	407 Warner St NW	2/21/2006	0.001	0.002
81	3312 Newark St NW	2/25/2006	0.001	0.004
82	4018 14th St NW	2/12/2006	0.001	0.001
83	1466 Belmont St NW	4/6/2006	0.002	0.001
84	518 Missouri Ave NW	2/1/2006	0.002	0.002

85	602 14th Pl NE	3/1/2006	0.002	N/A
86	4473 Sedgwick St NW	4/29/2006	0.002	0.002
87	4501 Foxhall Cres NW	3/13/2006	0.002	0.000
88	3731 9th St NW	12/2/2005	0.002	0.001
89	1710 Lanier Pl NW	12/27/2005	0.002	0.006
90	1340 31st St NW	2/12/2006	0.002	0.000
91	5079 Just St NE	3/8/2006	0.002	0.000
92	405 Richardson Pl NW	4/15/2006	0.002	0.004
93	417 D St NE	5/24/2006	0.002	0.000
94	2504 Cliffbourne Pl NW	3/29/2006	0.002	0.000
95	7 Snows Ct NW	4/18/2006	0.002	0.004
96	128 11th St NE	4/2/2006	0.002	0.002
97	3179 18th St NW	2/21/2006	0.002	0.003
98	3055 Porter St NW	5/3/2006	0.002	0.001
99	5410 Kansas Ave NW	12/18/2005	0.002	0.001
100	2620 11th St NW	1/30/2006	0.002	0.002
101	1243 G St NE	4/1/2006	0.002	0.000
102	8051 Parkside Ln NW	4/8/2006	0.002	0.003
103	3408 Reservoir Rd NW	2/24/2006	0.002	0.007
104	2334 19th St NW	5/22/2006	0.002	0.000
105	1828 Corcoran St NW	3/14/2006	0.002	0.001
106	3207 Cleveland Ave NW	1/9/2006	0.002	0.003
107	1246 Barnaby Ter SE	2/17/2006	0.002	0.000
108	1811 24th St NW	2/2/2006	0.002	0.010
109	428 13th St NE	4/30/2006	0.002	0.004
110	415 Independence Ave SE	1/30/2006	0.002	0.005
111	1409 Ames Pl NE	3/5/2006	0.002	0.008
112	3179 18th St NW	4/5/2006	0.002	0.002
113	1412 Kearney St NE	2/4/2006	0.002	0.018
114	1304 Geranium St NW	2/18/2006	0.002	0.007
115	1430 S St SE	2/22/2006	0.002	0.002
116	2276 Cathedral Ave NW	1/13/2006	0.002	0.001
117	1834 16th St NW	5/3/2006	0.002	0.003
118	3433 14th St NW	2/14/2006	0.002	0.000
119	3712 Ingomar St NW	1/17/2006	0.003	0.001
120	3319 Q St NW	3/4/2006	0.003	0.009
121	1492 Newton St NW	1/17/2006	0.003	0.007
122	525 9th St SE	3/29/2006	0.003	0.009
123	4110 Garrison St NW	1/10/2006	0.003	0.002
124	2228 Q St NW	4/2/2006	0.003	0.001
125	500 Aspen St NW	4/23/2006	0.003	0.002
126	1922 37th St NW	2/2/2006	0.003	0.003
127	3105 18th St NW	3/10/2006	0.003	0.002
128	5417 Illinois Ave NW	12/24/2005	0.003	0.013
129	2929 34th St. NW	2/21/2006	0.003	0.002
130	656 12TH ST NE	1/12/2006	0.003	0.004
131	4916 47th St NW	12/4/2005	0.003	0.002

132	1225 42nd St SE	2/20/2006	0.003	0.002
133	1613 22nd St SE	12/23/2005	0.003	0.001
134	162 Bryant St NW	4/14/2006	0.003	0.004
135	208 5th St SE	3/28/2006	0.003	0.015
136	3907 Harrison St NW	4/29/2006	0.004	0.003
137	4019 Marlboro Pl NW	2/2/2006	0.004	0.004
138	1368 E Capitol St NE	12/23/2005	0.004	0.004
139	409E St. SE	2/6/2006	0.004	0.001
140	1227 Jefferson St NW	1/7/2006	0.004	0.003
141	4915 43rd St NW	5/17/2006	0.004	0.005
142	914 KENNEDY ST NW	2/23/2006	0.004	0.004
143	1330 S St SE	4/11/2006	0.004	0.004
144	2215 Hall Pl NW	4/6/2006	0.004	0.004
145	565 15th St SE	12/11/2005	0.004	0.014
146	3138 Highland Pl NW	3/6/2006	0.004	0.020
147	5220 Chevy Chase Pkwy NW	5/10/2006	0.004	0.004
148	1700 E St SE	5/5/2006	0.004	0.011
149	2629 Woodley Pl NW	1/31/2006	0.004	0.004
150	3301 Newark St NW	2/9/2006	0.004	0.004
151	3803 Jenifer St NW	3/9/2006	0.004	0.019
152	5831 Sherier Pl NW	5/25/2006	0.005	0.014
153	1531 Olive St NE	3/12/2006	0.005	0.005
154	2323 20TH ST NW	1/11/2006	0.005	0.012
155	309 K St NE	1/26/2006	0.005	0.005
156	2904 18th St NW	3/15/2006	0.005	0.002
157	3813 10th St NW	4/11/2006	0.005	0.024
158	4416 Q St NW	1/24/2006	0.005	0.006
159	3111 HAWTHORNE ST NW	1/15/2006	0.005	0.002
160	5602 39th St NW	3/20/2006	0.005	0.005
161	1409 W VA AVE NE	12/22/2005	0.005	0.004
162	2828 6th St NE	1/19/2006	0.005	0.001
163	1847 47th Pl NW	12/14/2005	0.005	0.006
164	5118 5th St NW	2/9/2006	0.005	0.011
165	610 4th St NE	3/30/2006	0.005	0.004
166	1400 16th St NW	1/30/2006	0.005	0.000
167	4606 Kansas Ave NW	2/10/2006	0.005	0.001
168	333 17th St NE	2/27/2006	0.005	0.002
169	1331 Jefferson St NW	4/20/2006	0.005	0.004
170	3600 Albemarle St NW	2/8/2006	0.006	0.008
171	3821 W St NW	12/27/2005	0.006	0.006
172	5410 39th St NW	2/6/2006	0.006	0.011
173	1028 Quebec Pl NW	3/19/2006	0.006	0.001
174	4812 Georgia Ave NW	2/17/2006	0.006	0.007
175	1901 Kenyon St NW	12/28/2005	0.006	0.023
176	2923 Foxhall Rd NW	2/9/2006	0.006	0.013
177	5423 Hawthorne Pl NW	3/9/2006	0.006	0.021
178	1012 Taussig Pl NE	12/1/2005	0.006	0.005

179	227 Parker St NE	12/19/2005	0.006	0.002
180	4624 Tilden St NW	12/9/2005	0.006	0.014
181	5406 41st St NW	1/17/2006	0.007	0.007
182	207 F St NE	12/27/2005	0.007	0.009
183	1464 Belmont St NW	4/11/2006	0.007	0.002
184	1211 F St NE	3/5/2006	0.007	0.003
185	1325 Rittenhouse St NW	12/24/2005	0.007	0.000
186	1403 Varnum St NW	2/8/2006	0.007	0.015
187	4617 38th St NW	12/13/2005	0.007	0.014
188	500 G St NE	1/25/2006	0.007	0.001
189	2042 37th St NW	5/16/2006	0.007	0.011
190	4221 16th St NW	5/14/2006	0.007	0.018
191	1518 Kearney St NE	3/2/2006	0.007	0.015
192	3738 Jenifer St	12/8/2005	0.007	0.025
193	4835 Linnean Ave NW	4/25/2006	0.007	0.032
194	3123 Warder St NW	2/20/2006	0.007	0.002
195	1003 F St NE	4/13/2006	0.008	0.005
196	3220 Wheeler Rd SE	5/8/2006	0.008	0.006
197	3815 Legation St NW	1/30/2006	0.008	0.013
198	3815 Legation St NW	2/7/2006	0.008	0.013
199	912 Evarts St NE	3/15/2006	0.008	0.010
200	3734 Chesapeake St NW	4/6/2006	0.008	0.017
201	1412 Montague St NW	1/24/2006	0.008	0.008
202	3103 18th St NW	5/23/2006	0.008	0.004
203	1613 G St SE	4/3/2006	0.009	0.005
204	1520 Webster St NW	5/1/2006	0.009	0.019
205	3101 34th St NW	2/20/2006	0.009	0.006
206	3636 Warder St NW	3/14/2006	0.009	0.016
207	5303 Connecticut Ave NW	4/4/2006	0.010	0.005
208	4418 Lowell St NW	1/28/2006	0.010	0.003
209	4409 38th St NW	12/5/2005	0.010	0.004
210	1509 Caroline St NW	2/28/2006	0.010	0.002
211	6318 2nd St NW	1/26/2006	0.011	0.167
212	1425 Juniper St NW	3/17/2006	0.011	0.002
213	1732 1/2 Euclid St NW	3/17/2006	0.011	0.015
214	1609 30th St SE	3/28/2006	0.011	0.028
215	776 Lamont St NW	1/17/2006	0.011	0.007
216	4400 Cathedral Ave NW	2/27/2006	0.011	0.005
217	3912 Jenifer St NW	3/24/2006	0.012	0.045
218	1728 Poplar Ln NW	3/22/2006	0.013	0.004
219	3823 New Hampshire Ave NW	2/14/2006	0.013	0.004
220	4804 Alton Pl NW	4/8/2006	0.014	0.000
221	1311 K St SE	5/6/2006	0.014	0.002
222	3562 13th St NW	1/31/2006	0.014	0.002
223	17 Evarts St NE	1/5/2006	0.014	0.012
224	342 12th St SE	3/12/2006	0.016	0.002
225	2934 Glover Dr NW	2/9/2006	0.016	0.009



226	1410 D St NE	3/20/2006	0.017	0.121
227	749 Hobart Pl NW	1/4/2006	0.018	0.003
228	1119 D St NE	3/1/2006	0.019	0.006
229	3317 R St NW	5/23/2006	0.019	0.002
230	1831 Monroe St NE	3/27/2006	0.019	0.011
231	1313 D St NE	3/14/2006	0.021	0.009
232	1751 New Hampshire Ave NW	12/20/2005	0.025	0.042
233	3309 P St NW	2/16/2006	0.028	0.003
234	3545 Porter St NW	2/7/2006	0.042	0.019
235	1011 Bryant St NE	1/10/2006	0.048	0.005
236	4340 Garfield St NW	4/23/2006	0.050	0.011
237	3308 Brown St NW	4/24/2006	0.055	0.007
238	1605 Varnum St NW	1/13/2006	0.056	0.265
239	2007 Kalorama Rd NW	1/30/2006	0.079	0.042
240	1833 H St NE	2/23/2006	0.093	0.056
241	831 Allison St NW	3/6/2006	0.095	0.020
242	7420 12TH ST NW	12/1/2005	0.114	0.016
243	1604 23rd St SE	2/14/2006	0.126	0.034
244	412 Oklahoma Ave NE	4/11/2006	N/A	0.000
245	6161 31st Pl NW	4/9/2006	N/A	0.000

Notes:

Some customers did not provide samples for either the first draw or second draw. In these cases, the table lists "N/A".

Data reported as zero may be non-detect or less than 0.0005 mg/L.

**Table D.2: Samples Collected After Partial Replacements (January through May 2006)**

No.	Address	Pipe Replacement Date	Collection Date	Lead mg/L	
				Draw 1	Draw 2
1	1219 GIRARD ST NW	6/9/2005	2/1/2006	0.000	0.000
2	5517 39th St NW	6/16/2005	3/20/2006	0.000	0.000
3	1259 Van Buren St NW	1/13/2006	1/26/2006	0.000	0.000
4	1329 MONTELLO AVE NE	12/1/2005	1/9/2006	0.000	0.000
5	1246 I ST NE	12/8/2005	1/9/2006	0.000	0.002
6	423 6th St NE	7/16/2004	4/4/2006	0.000	0.000
7	613 Faraday Pl NE	1/13/2006	1/26/2006	0.001	0.000
8	308 Upshur St NW	10/15/2004	1/10/2006	0.001	0.001
9	1342 Kenyon St NW	10/28/2005	1/29/2006	0.001	0.001
10	217 5th St NE	9/26/2005	2/9/2006	0.001	0.000
11	227 14th St NE	10/28/2005	2/8/2006	0.001	0.000
12	4400 18th St NW	1/5/2006	2/13/2006	0.001	0.001
13	1341 Kenyon St NW	10/31/2005	1/29/2006	0.001	0.001
14	1215 Irving St NE	1/6/2006	2/8/2006	0.001	0.001
15	1112 D St NE	3/2/2006	3/16/2006	0.001	0.005
16	5601 2nd St NW	1/30/2006	3/18/2006	0.001	0.001
17	3712 Garfield St NW	2/21/2006	4/10/2006	0.001	0.001
18	158 U St NE	1/3/2006	2/28/2006	0.001	0.001
19	4350 P St NW	2/16/2006	2/21/2006	0.001	0.002
20	827 DECATUR ST NW	1/17/2006	1/26/2006	0.001	0.003
21	5315 8th St NW	1/5/2006	1/12/2006	0.001	0.001
22	630 G St NE	12/1/2005	2/8/2006	0.001	0.000
23	1100 8th St NE	12/13/2005	4/3/2006	0.001	0.002
24	30 Quincy Pl NW	12/19/2005	1/9/2006	0.001	0.001
25	5235 8th St NW	12/27/2005	1/10/2006	0.001	0.001
26	3005 O St NW	2/14/2006	2/20/2006	0.002	0.001
27	4700 Brooks St NE	7/15/2004	3/26/2006	0.002	0.000

28	3815 Upton St NW	1/21/2005	5/14/2006	0.002	0.001
29	2928 Macomb St NW	1/21/2006	3/15/2006	0.002	0.000
30	1301 Montello Ave NE	12/5/2005	2/27/2006	0.002	0.001
31	328 15th St NE	11/23/2005	1/3/2006	0.002	0.002
32	3013 15TH ST NE	12/22/2005	1/10/2006	0.002	0.001
33	1257 EVARTS ST NE	9/22/2003	1/2/2006	0.002	0.003
34	5009 8th St NW	12/21/2005	1/18/2006	0.002	0.001
35	1521 Elliott Pl NW	2/14/2006	2/24/2006	0.002	0.003
36	1205 Walter St SE	3/1/2006	3/29/2006	0.002	0.001
37	250 14th St NE	11/7/2005	2/13/2006	0.002	0.001
38	4421 VOLTA PL NW	7/21/2005	1/31/2006	0.002	0.004
39	1100 8th St NE	12/13/2005	2/12/2006	0.002	0.018
40	653 Acker Pl NE	12/6/2005	1/9/2006	0.002	0.004
41	701 Kentucky Ave SE	11/17/2004	1/23/2006	0.002	0.001
42	1424 Hamilton St NW	3/17/2005	2/7/2006	0.002	0.001
43	3135 Highland Pl NW	3/9/2006	3/13/2006	0.002	0.002
44	5002 5TH ST NW	12/28/2005	1/10/2006	0.002	0.007
45	720 L St NE	12/12/2005	1/18/2006	0.002	0.018
46	1723 HOBAN RD NW	7/6/2005	1/18/2006	0.002	0.001
47	169 U St NE	1/5/2006	1/10/2006	0.002	0.003
48	1232 Emerson St NW	2/1/2006	2/8/2006	0.002	0.004
49	7114 7th St NW	2/7/2006	2/17/2006	0.003	0.002
50	30 Sherman Cir NW	1/19/2006	1/31/2006	0.003	0.011
51	419 10th St NE	1/30/2006	2/13/2006	0.003	0.001
52	1315 E Capitol St SE	3/20/2006	3/23/2006	0.003	0.001
53	508 G ST NE	12/2/2005	1/9/2006	0.003	0.001
54	3415 Massachusetts Ave NW	1/30/2006	2/8/2006	0.003	0.005
55	3021 Newark St NW	6/21/2005	2/11/2006	0.003	0.005
56	17 Seaton Pl NW	12/8/2005	1/9/2006	0.003	0.000
57	3150 Highland Pl NW	3/10/2006	3/18/2006	0.003	0.001
58	318 14th St NE	11/1/2005	3/15/2006	0.003	0.005

59	716 L St NE	12/8/2005	1/9/2006	0.003	0.009
60	3010 O St NW	2/14/2006	2/16/2006	0.003	0.000
61	3532 Massachusetts Ave NW	1/30/2006	1/31/2006	0.003	0.002
62	152 U St NE	12/29/2005	1/10/2006	0.003	0.004
63	4610 43rd Pl NW	3/10/2006	3/20/2006	0.003	0.001
64	743 12th St SE	2/1/2006	2/8/2006	0.003	0.001
65	4615 Minnesota Ave NE	8/24/2004	1/25/2006	0.003	0.004
66	553 14th St SE	11/8/2005	3/13/2006	0.003	0.005
67	219 15th St NE	11/8/2005	1/6/2006	0.003	0.014
68	5615 2ND ST NW	1/27/2006	1/28/2006	0.003	0.002
69	3914 Jenifer St NW	3/27/2006	4/4/2006	0.003	0.003
70	2527 12th St NW	7/1/2005	2/25/2006	0.003	0.003
71	171 U St NE	1/5/2006	1/10/2006	0.003	0.003
72	1616 Varnum St NW	1/9/2006	3/23/2006	0.003	0.001
73	805 DECATUR ST NW	1/9/2006	1/11/2006	0.003	0.002
74	1210 Kearney St NE	12/21/2005	1/31/2006	0.003	0.002
75	3738 Jenifer St NW	3/29/2006	4/25/2006	0.004	0.003
76	2745 Woodley Pl NW	7/22/2005	4/27/2006	0.004	0.002
77	636 A St NE	2/8/2006	3/8/2006	0.004	0.003
78	220 9th St NE	2/6/2006	2/13/2006	0.004	0.002
79	3734 Jenifer St NW	3/29/2006	4/3/2006	0.004	0.003
80	727 13TH ST NE	11/30/2005	1/9/2006	0.004	0.008
81	3638 Veazey St NW	9/17/2003	3/21/2006	0.004	0.001
82	7717 14th St NW	3/14/2006	3/18/2006	0.004	0.002
83	823 Decatur St NW	1/13/2006	1/18/2006	0.004	0.002
84	1336 D St NE	3/10/2006	3/13/2006	0.004	0.002
85	4446 Q St NW	6/1/2004	3/21/2006	0.004	0.003
86	1923 12th St NW	1/11/2006	2/19/2006	0.004	0.001
87	3020 Macomb St NW	1/5/2006	1/10/2006	0.004	0.019
88	1508 Trinidad Ave NE	12/13/2005	1/9/2006	0.004	0.002
89	1216 Emerson St NW	1/26/2006	3/19/2006	0.004	0.004

90	37 Sherman Cir NW	1/17/2006	1/26/2006	0.004	0.011
91	62 V St NW	7/7/2004	2/23/2006	0.004	0.002
92	821 Decatur St NW	1/13/2006	1/18/2006	0.004	0.013
93	2858 28th St NW	10/24/2005	5/2/2006	0.004	0.001
94	928 Constitution Ave NE	1/10/2006	1/26/2006	0.004	0.002
95	164 U St NE	1/4/2006	1/12/2006	0.004	0.003
96	5335 43rd St NW	3/27/2006	4/19/2006	0.004	0.017
97	641 A St NE	2/7/2006	2/10/2006	0.005	0.006
98	212 Madison St NW	2/8/2006	2/10/2006	0.005	0.004
99	3911 Northampton St NW	3/30/2006	4/2/2006	0.005	0.011
100	2946 Macomb St NW	1/10/2006	3/16/2006	0.005	0.001
101	3009 32nd St NW	2/17/2006	2/28/2006	0.005	0.009
102	3005 32nd St NW	2/17/2006	2/24/2006	0.005	0.002
103	3102 Rodman St NW	3/6/2006	3/9/2006	0.005	0.013
104	3706 Morrison St NW	10/12/2005	2/19/2006	0.005	0.000
105	4807 Arkansas Ave NW	2/2/2006	2/8/2006	0.005	0.002
106	914 D St NE	2/15/2006	2/24/2006	0.005	0.005
107	3814 47TH ST NW	1/3/2006	1/12/2006	0.005	0.002
108	1112 E St NE	12/1/2005	1/9/2006	0.005	0.005
109	1254 Irving St NE	12/30/2005	1/10/2006	0.005	0.010
110	561 15th St SE	2/1/2006	2/22/2006	0.005	0.003
111	5422 39th St NW	3/10/2006	3/11/2006	0.005	0.002
112	3214 Stephenson Pl NW	9/22/2005	4/24/2006	0.005	0.004
113	1240 Kearney St NE	12/22/2005	2/27/2006	0.005	0.020
114	5520 39th St NW	3/16/2006	3/19/2006	0.006	0.004
115	5500 39th St NW	3/14/2006	3/15/2006	0.006	0.005
116	4611 43rd Pl NW	3/10/2006	3/21/2006	0.006	0.002
117	4891 Potomac Ave NW	2/6/2006	2/13/2006	0.006	0.006
118	170 U St NE	1/5/2006	1/10/2006	0.006	0.010
119	2214 Douglas St NE	1/11/2006	2/16/2006	0.006	0.002
120	3923 Jenifer St NW	3/27/2006	3/29/2006	0.006	0.012

121	209 10th St NE	3/7/2005	4/22/2006	0.006	0.000
122	1239 Walter St SE	3/10/2006	3/19/2006	0.006	0.007
123	15 SHERMAN CIR NW	1/21/2006	1/31/2006	0.006	0.015
124	2952 Macomb St NW	1/5/2006	2/15/2006	0.006	0.006
125	918 12th St NE	2/8/2006	2/10/2006	0.006	0.004
126	5810 Chevy Chase Pkwy NW	5/27/2005	4/27/2006	0.006	0.010
127	1226 Irving St NE	1/5/2006	2/13/2006	0.006	0.004
128	3820 Military Rd NW	2/21/2006	2/24/2006	0.007	0.003
129	613 A St NE	2/14/2006	2/17/2006	0.007	0.004
130	151 U St NE	12/29/2005	1/10/2006	0.007	0.005
131	2216 Perry St NE	1/3/2006	1/12/2006	0.007	0.006
132	1609 Varnum St NW	1/12/2006	1/26/2006	0.007	0.018
133	803 Decatur St NW	1/9/2006	1/13/2006	0.007	0.004
134	904 12th St NE	2/6/2006	2/7/2006	0.007	0.005
135	1507 Trinidad Ave NE	12/12/2005	1/9/2006	0.007	0.037
136	565 15th St SE	2/2/2006	3/22/2006	0.007	0.005
137	1519 Elliott Pl NW	2/15/2006	3/16/2006	0.007	0.001
138	149 U St NE	12/28/2005	1/10/2006	0.007	0.008
139	1245 Kearney St NE	12/27/2005	1/31/2006	0.007	0.009
140	513 14th St SE	11/1/2005	2/10/2006	0.007	0.001
141	1230 WALTER ST SE	3/9/2006	4/24/2006	0.007	0.007
142	3708 R St NW	5/9/2005	2/27/2006	0.007	0.001
143	29 Sherman Cir NW	1/19/2006	1/31/2006	0.007	0.007
144	5330 39TH St NW	2/21/2006	4/12/2006	0.007	0.006
145	1104 E St NE	11/30/2005	4/12/2006	0.007	0.000
146	5603 2nd St NW	1/30/2006	2/10/2006	0.007	0.005
147	753 12th St SE	2/1/2006	2/10/2006	0.007	0.007
148	5311 Connecticut Ave NW	4/6/2006	4/7/2006	0.007	0.002
149	1303 KEARNEY ST NE	12/28/2005	1/10/2006	0.007	0.004
150	632 G ST NE	12/1/2005	1/9/2006	0.007	0.002
151	3810 47th St NW	1/3/2006	1/12/2006	0.007	0.008

152	1613 LONGFELLOW ST NW	2/1/2005	2/1/2006	0.008	0.005
153	321 17th PL NE	11/15/2005	1/17/2006	0.008	0.004
154	3920 Northampton St NW	3/30/2006	3/31/2006	0.008	0.012
155	6315 2nd St NW	1/25/2006	1/26/2006	0.008	0.026
156	1303 Montello Ave NE	12/5/2005	1/12/2006	0.008	0.003
157	1504 Trinidad Ave NE	12/12/2005	1/18/2006	0.008	0.007
158	3030 44th St NW	2/24/2006	3/14/2006	0.008	0.010
159	224 Madison St NW	2/9/2006	2/17/2006	0.008	0.010
160	16 Sherman cir NW	1/21/2006	3/17/2006	0.008	0.015
161	3208 Highland Pl NW	3/14/2006	3/17/2006	0.008	0.002
162	1411 D St NE	3/15/2006	3/24/2006	0.008	0.003
163	1007 D St NE	2/28/2006	3/7/2006	0.009	0.014
164	3125 Central Ave NE	1/24/2006	3/22/2006	0.009	0.004
165	1306 Montello Ave NE	12/6/2005	1/18/2006	0.009	0.001
166	2952 MACOMB ST NW	1/5/2006	1/12/2006	0.009	0.175
167	5508 Broad Branch Rd NW	3/30/2006	4/2/2006	0.009	0.005
168	1222 Walter St SE	3/7/2006	3/12/2006	0.009	0.002
169	1021 Kearney St NE	12/16/2005	1/18/2006	0.009	0.175
170	20 Sherman Cir NW	1/20/2006	1/26/2006	0.009	0.002
171	1203 Kearney St NE	12/20/2005	1/10/2006	0.009	0.013
172	1227 Walter St SE	11/29/2004	3/11/2006	0.009	0.002
173	1227 Walter St SE	3/8/2006	3/11/2006	0.009	0.002
174	1418 44th St NW	6/17/2004	5/16/2006	0.009	0.018
175	1200 I ST NE	12/7/2005	1/18/2006	0.009	0.002
176	1314 Montello Ave NE	12/7/2005	1/9/2006	0.010	0.013
177	5230 5th St NW	12/30/2005	1/11/2006	0.010	0.007
178	3116 Rodman St NW	3/8/2006	3/12/2006	0.010	0.008
179	1232 Walter St SE	3/9/2006	3/12/2006	0.010	0.014
180	5308 8th St NW	1/3/2006	1/12/2006	0.010	0.015
181	324 17th Pl NE	11/17/2005	1/5/2006	0.010	0.018
182	163 U St NE	1/4/2006	1/12/2006	0.010	0.002

183	1216 Walter St SE	3/6/2006	3/10/2006	0.010	0.003
184	1420 D St NE	3/20/2006	3/27/2006	0.010	0.032
185	1221 D St NE	3/6/2006	3/8/2006	0.010	0.011
186	1611 Varnum St NW	1/12/2006	5/4/2006	0.010	0.004
187	2954 Macomb St NW	1/14/2006	1/31/2006	0.011	0.003
188	5508 39th St NW	3/14/2006	3/20/2006	0.011	0.003
189	1309 D St NE	3/7/2006	3/10/2006	0.011	0.037
190	41 Sherman Cir NW	1/13/2006	1/26/2006	0.011	0.031
191	1502 Trinidad Ave NE	12/12/2005	1/9/2006	0.011	0.201
192	5343 43rd St NW	3/27/2006	3/29/2006	0.011	0.012
193	1009 D St NE	2/28/2006	3/10/2006	0.011	0.007
194	1007 Irving St NE	12/28/2005	1/30/2006	0.011	0.002
195	7705 14th St NW	3/13/2006	3/16/2006	0.011	0.012
196	906 12th St SE	2/2/2006	2/8/2006	0.011	0.011
197	5425 39th St NW	3/10/2006	3/12/2006	0.011	0.006
198	121 10TH ST SE	11/1/2005	1/18/2006	0.011	0.018
199	3738 9th St NW	1/19/2006	1/26/2006	0.012	0.008
200	5312 8th St NW	1/4/2006	1/12/2006	0.012	0.004
201	1501 D St NE	11/29/2005	2/13/2006	0.012	0.013
202	4539 43rd Pl NW	3/9/2006	4/5/2006	0.012	0.008
203	1218 Walter St SE	3/6/2006	3/8/2006	0.012	0.015
204	811 Decatur St NW	1/10/2006	1/13/2006	0.012	0.006
205	1238 Kearney St NE	12/22/2005	1/18/2006	0.012	0.013
206	1611 Varnum St NW	1/12/2006	1/31/2006	0.012	0.021
207	835 Decatur St NW	1/19/2006	1/26/2006	0.012	0.089
208	1221 Walter St SE	3/7/2006	3/10/2006	0.013	0.107
209	517 G St NE	12/2/2005	1/9/2006	0.013	0.004
210	1203 D St NE	3/3/2006	3/16/2006	0.013	0.070
211	5517 Potomac Ave NW	2/15/2006	2/16/2006	0.013	0.014
212	176 U St NE	1/6/2006	1/12/2006	0.013	0.008
213	6901 Maple St NW	2/9/2006	2/17/2006	0.014	0.009



214	555 15th St SE	2/1/2006	2/8/2006	0.014	0.002
215	309 10th St NE	1/19/2006	1/31/2006	0.014	0.005
216	76 SEATON PL NW	12/21/2005	1/18/2006	0.014	0.004
217	648 A St NE	2/7/2006	2/13/2006	0.014	0.002
218	16 Seaton Pl NW	12/8/2005	1/27/2006	0.014	0.002
219	1020 Bryant St NE	1/6/2006	1/26/2006	0.014	0.004
220	2908 32nd St NW	2/16/2006	2/20/2006	0.015	0.008
221	3022 O St NW	2/21/2006	2/28/2006	0.015	0.026
222	1518 Trinidad Ave NE	12/19/2005	1/18/2006	0.015	0.095
223	49 Seaton Pl NW	12/20/2005	1/18/2006	0.016	0.021
224	505 12th St SE	1/26/2006	1/30/2006	0.016	0.009
225	332 14th St NE	11/3/2005	3/13/2006	0.016	0.029
226	408 10TH ST NE	1/25/2006	2/6/2006	0.016	0.007
227	921 12th St SE	2/2/2006	2/4/2006	0.016	0.001
228	5019 8TH ST NW	12/22/2005	1/30/2006	0.017	0.006
229	154 U St NE	12/30/2005	1/10/2006	0.017	0.013
230	3138 19th St NW	7/21/2005	3/15/2006	0.017	0.003
231	1319 D St NE	3/8/2006	3/10/2006	0.017	0.007
232	4621 Q St NW	12/20/2005	1/24/2006	0.017	0.017
233	5516 39th St NW	3/16/2006	3/17/2006	0.018	0.008
234	6915 6TH ST NW	1/25/2006	1/27/2006	0.018	0.014
235	3818 47TH ST NW	1/4/2006	1/6/2006	0.018	0.007
236	323 10th St NE	1/25/2006	1/31/2006	0.019	0.021
237	1616 Varnum St NW	1/9/2006	1/14/2006	0.019	0.001
238	123 U St NE	12/20/2005	1/10/2006	0.019	0.082
239	42 Seaton Pl NW	12/19/2005	1/18/2006	0.020	0.004
240	1211 Walter St SE	3/2/2006	3/7/2006	0.020	0.106
241	5319 Potomac Ave NW	2/14/2006	2/17/2006	0.020	0.003
242	1344 D St NE	3/13/2006	3/15/2006	0.020	0.008
243	115 U St NE	12/19/2005	2/6/2006	0.021	0.006
244	3020 O St NW	2/17/2006	2/28/2006	0.021	0.010

245	104 U St NE	12/16/2005	1/9/2006	0.021	0.041
246	1103 Kenyon St NW	10/26/2005	1/28/2006	0.021	0.021
247	1625 Varnum St NW	1/9/2006	1/17/2006	0.022	0.002
248	125 U St NE	12/20/2005	1/18/2006	0.022	0.005
249	19 SHERMAN CIR NW	1/20/2006	1/31/2006	0.023	0.039
250	816 Decatur St NW	1/17/2006	1/18/2006	0.023	0.017
251	5330 39th St NW	2/21/2006	2/24/2006	0.024	0.519
252	166 U St NE	1/4/2006	1/12/2006	0.024	0.004
253	3010 32nd St NW	2/21/2006	2/25/2006	0.025	0.025
254	1110 E St NE	11/30/2005	1/9/2006	0.025	0.010
255	1209 Walter St SE	3/2/2006	3/3/2006	0.026	0.040
256	5227 8TH ST NW	12/22/2005	1/18/2006	0.026	0.004
257	5507 Broad Branch Rd NW	3/31/2006	4/2/2006	0.027	0.011
258	150 U St NE	12/29/2005	1/15/2006	0.028	0.073
259	4907 Potomac Ave NW	2/6/2006	2/16/2006	0.028	0.014
260	113 U St NE	12/19/2005	1/18/2006	0.029	0.009
261	1338 D St NE	3/10/2006	3/17/2006	0.029	0.025
262	4700 Sedgwick St NW	1/4/2006	1/16/2006	0.030	0.017
263	132 SEATON PL NW	12/14/2005	1/9/2006	0.030	0.011
264	1018 D St NE	2/21/2006	2/25/2006	0.030	0.009
265	3728 9th St NW	1/21/2006	1/31/2006	0.030	0.057
266	565 15th St SE	2/2/2006	2/7/2006	0.031	0.030
267	1350 D St NE	3/14/2006	3/16/2006	0.034	0.018
268	205 Maryland Ave NE	3/2/2006	3/6/2006	0.035	0.203
269	111 SEATON PL NW	12/8/2005	1/9/2006	0.036	0.002
270	1317 D St NE	3/8/2006	3/9/2006	0.036	0.066
271	737 12th St SE	1/27/2006	1/28/2006	0.043	0.047
272	1102 E St NE	11/29/2005	1/9/2006	0.044	0.042
273	1300 Montello Ave NE	12/2/2005	1/9/2006	0.044	0.004
274	3726 9th St NW	1/24/2006	2/13/2006	0.045	0.002
275	3224 Highland Pl NW	3/16/2006	3/21/2006	0.046	0.001

276	1218 18TH ST NE	11/10/2005	1/31/2006	0.047	0.018
277	1348 D St NE	3/14/2006	3/18/2006	0.047	0.017
278	40 Sherman Cir NW	1/13/2006	1/26/2006	0.048	0.009
279	2032 Douglas St NE	1/19/2006	1/26/2006	0.049	0.012
280	162 U St NE	1/4/2006	1/12/2006	0.049	0.202
281	125 10th St SE	11/2/2005	1/1/2006	0.054	0.027
282	829 Decatur St NW	1/17/2006	1/19/2006	0.054	0.025
283	4511 Cathedral Ave NW	2/24/2006	2/26/2006	0.055	0.091
284	5611 2nd St NW	1/30/2006	1/31/2006	0.055	0.012
285	513 12th St SE	1/26/2006	2/17/2006	0.057	0.021
286	1305 Montello Ave NE	12/2/2005	1/9/2006	0.058	0.035
287	804 Decatur St NW	1/12/2006	1/15/2006	0.059	0.012
288	211 Rhode Island Ave NE	12/12/2005	1/9/2006	0.060	0.027
289	916 12th St NE	2/8/2006	2/9/2006	0.060	0.028
290	180 U St NE	1/6/2006	1/12/2006	0.063	0.027
291	1333 D St NE	3/9/2006	3/10/2006	0.066	0.011
292	1025 D St NE	3/1/2006	3/4/2006	0.070	0.022
293	1205 Emerson St NW	1/26/2006	1/27/2006	0.094	0.082
294	6313 2nd St NW	1/25/2006	1/26/2006	0.097	0.033
295	1211 Emerson St NW	1/30/2006	2/3/2006	0.101	0.012
296	921 2ND ST NE	11/23/2005	1/9/2006	0.102	0.318
297	31 Sherman Cir NW	1/19/2006	1/31/2006	0.104	0.025
298	5606 Broad Branch Rd NW	4/10/2006	4/13/2006	0.110	0.019
299	1217 Walter St SE	3/6/2006	3/9/2006	0.115	0.037
300	1116 D St NE	3/2/2006	3/6/2006	0.116	0.341
301	2905 32ND ST NW	2/17/2006	4/3/2006	0.134	0.012
302	1220 Emerson St NW	1/27/2006	2/2/2006	0.135	0.050
303	1012 BRYANT ST NE	1/10/2006	1/12/2006	0.140	0.123
304	1352 Kearney St NE	1/4/2006	1/12/2006	0.141	0.012
305	1228 Walter St SE	3/8/2006	3/9/2006	0.161	0.063
306	734 GALLATIN ST NW	12/28/2005	1/12/2006	0.233	0.502

307	1114 D St NE	3/2/2006	3/3/2006	0.294	0.018
308	527 12th St SE	1/26/2006	1/30/2006	0.317	0.017
309	1389 D St NE	3/22/2006	3/28/2006	0.461	0.070
310	1327 D St NE	3/9/2006	3/15/2006	0.484	0.010
311	1243 IRVING ST NE	1/3/2006	1/12/2006	0.506	0.055
312	5335 43rd St NW	3/27/2006	3/28/2006	0.513	0.289
313	3125 Central Ave NE	1/24/2006	1/31/2006	0.714	2.530
314	1230 Walter St SE	3/9/2006	3/10/2006	0.823	2.660
315	16 SHERMAN CIR NW	1/21/2006	1/31/2006	0.918	0.248
316	1226 Irving St NE	1/5/2006	1/12/2006	1.000	0.041
317	7106 7th St NW	2/9/2006	2/17/2006	1.050	1.200
318	1245 Kearney St NE	12/27/2005	1/18/2006	1.400	0.102
319	1118 7th St NE	1/10/2006	1/11/2006	2.710	0.814
320	2905 32nd St NW	2/17/2006	2/24/2006	4.400	0.124
321	178 U St NE	1/6/2006	1/12/2006	7.180	0.259
322	4621 Q St NW	12/20/2005	1/18/2006	7.810	0.140
323	5306 8th St NW	12/30/2005	1/10/2006	17.400	0.034
324	136 SEATON PL NW	12/16/2005	1/18/2006	25.800	0.031

Note:

Data reported as zero may be non-detect or less than 0.0005 mg/L.

**Appendix E: Sample Invalidation Request from WASA and EPA  
Invalidation Response**

## Letter E.1 – WASA Request for Sample Invalidation

June 27, 2006

Karen Johnson (3WP32)  
Chief, Safe Drinking Water Act Branch  
U.S. Environmental Protection Agency Region III  
1650 Arch Street  
Philadelphia, PA 19103-2029

Re: Request for Invalidation of First Semester 2006 Lead and Copper Rule (LCR)  
Compliance Monitoring Samples

Dear Ms. Johnson:

WASA requests the Environmental Protection Agency (EPA) invalidate six samples from the First Semester (January through June) 2006 LCR compliance calculations because new information determined that these sites no longer meet Tier 1 criteria. The following table lists the monitoring results and the justification for the invalidation request for each location. Further details of the reasons for invalidation follow the table. WASA will remove the addresses from the LCR routine monitoring list upon approval from EPA.

Address	Sample Collection Date	Lead (mg/L) <sup>1</sup>		Copper (mg/L)		Justification
		1 <sup>st</sup> Draw	2 <sup>nd</sup> Draw	1 <sup>st</sup> Draw	2 <sup>nd</sup> Draw	
112 4 <sup>th</sup> St SE	2/8/2006	0.001	0.000	0.010	0.007	Multi-residence
1332 Vermont Ave NW	2/8/2006	0.000	0.000	0.014	0.005	Multi-residence
1226 D St NW	2/8/2006	0.000	0.000	0.018	0.013	Prior Invalidation
1527 33 <sup>rd</sup> St NW	2/8/2006	0.002	0.003	0.008	0.028	Full Replacement
2211 39 <sup>th</sup> St NW	3/7/2006	0.003	0.000	0.010	0.019	Full Replacement
3835 Beecher St NW	3/8/2006	0.001	0.001	0.012	0.004	Full Replacement

### Multi-residence—112 4<sup>th</sup> St SE and 1332 Vermont Ave NW

WASA determined 112 4<sup>th</sup> St SE and 1332 Vermont Ave NW were no longer single-family homes required for Tier 1 status.

The customer at 112 4<sup>th</sup> St SE wrote their address as, “112 4<sup>th</sup> St SE, #3” on the Chain of Custody form. The customer at 1332 Vermont Ave NW wrote their name as, “1332 Vermont Ave Part”. These address differences were identified during WASA’s quality control process after sample submittal to the laboratory. WASA investigated each site and determined the buildings had multiple residences.

### Prior Invalidation — 1226 D St NE

<sup>1</sup> Results reported as “0.000” may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

WASA collected an LCR sample at 1226 D St NE on February 8, 2006. In response to EPA's February 22, 2006 letter, WASA reviewed the pipe materials of existing LCR addresses. WASA test pitted this address in March 2006 and found copper on the public and private sides of the property. WASA submitted a request to invalidate second semester-2005 compliance monitoring samples on March 27, 2006 based on this finding. EPA concurred with the non-Tier 1 status in a letter to WASA dated April 10, 2006.

Full Replacement — 1527 33<sup>rd</sup> St NW

WASA replaced the public portion of the service line at 1527 33<sup>rd</sup> St NW in March 2004. WASA did not record the private side material at the time of the public side replacement. WASA collected an LCR sample on February 8, 2006. WASA test pitted this address on March 7, 2006 and found copper on the public and private sides of the property.

Full Replacement — 2211 39<sup>th</sup> St NW and 3835 Beecher St NW

Current staff recalled WASA's predecessor agency replacing some lead service lines in the 2200 block of 39<sup>th</sup> St, NW and the 3800 block of Beecher St NW during the early 1990's. WASA test pitted two addresses located on those blocks because the locations are included in the current LCR monitoring program. WASA found full copper service lines at 2211 39<sup>th</sup> St NW and 3835 Beecher St NW.

Appendix A contains the laboratory reports for all addresses. Appendix B contains the Chain of Custody forms for all addresses. Appendix C contains the test pit reports for the four addresses noted as full replacements in the table.

If you have any further questions regarding this request, please contact Richard Giani at (202) 612-3441.

Sincerely,

Charles W Kiely  
Assistant General Manager, Consumer Services

cc: Stefania Shamet, Senior Assistant Regional Counsel  
Jerry Johnson, General Manager  
John Dunn, Chief Engineer/ Deputy General Manager  
Avis Russell, General Counsel  
Richard Giani, Manager, Water Quality

## Letter E.2 – EPA Invalidation of Six Lead and Copper Samples

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION III  
1650 Arch Street  
Philadelphia, Pennsylvania 19103-2029

June 30, 2006

Mr. Charles Kiely  
Assistant General Manager, Customer Services  
District of Columbia Water and Sewer Authority  
301 Bryant Street, NW  
Washington, DC 20001

Dear Mr. Kiely:

This letter is in response to your letter of June 28, 2006, that requests six samples from the January – June 2006 monitoring period be invalidated. The samples are listed in the enclosure to this letter.

Pursuant to 40 CFR 141.86(f), EPA may invalidate a lead or copper tap water sample if, among other things, EPA learns that the sample was taken from a site that did not meet the site selection criteria of 40 CFR 141.86. For purposes of 40 CFR 141.86(f), the term “invalidate” means that the sample should not be counted to determine the lead or copper 90<sup>th</sup> percentile levels under 40 CFR 141.80(c)(3) or toward meeting the minimum monitoring requirements of 40 CFR 141.80(c). Pursuant to 40 CFR 141.90(g), data collected in addition to those data which are required by the regulations should be reported within the first ten days following the end of the applicable monitoring period, even if that data is not used to calculate the lead or copper 90<sup>th</sup> percentile requirements.

EPA has reviewed WASA’s request and its supporting documentation and agrees that the six samples can be invalidated and should not be used to calculate the 90<sup>th</sup> percentile levels for lead or copper. A copy of EPA’s rationale for this decision is enclosed. WASA must collect the minimum number of samples required for the monitoring period. If WASA does not have the minimum number of samples required for the monitoring period, WASA must collect replacement samples to reach the minimum number of samples required for the monitoring period under 40 CFR 141.86(c) no later than 20 days from receipt of this letter, from appropriate Tier 1 locations. Replacement samples from the invalidated sample sites are not appropriate because the sites do not meet the tier 1 site selection requirements of 40 CFR 141.86(a)(3). Replacement samples taken after the end of the applicable monitoring period may not be



used to meet the monitoring requirements of a subsequent monitoring period. The replacement sample must be taken at locations other than those already used for sampling during the January – June 2006, monitoring period. (40 CFR 141.86(f)(4)).

If you have any questions, I can be reached at 215-814-5445.

Sincerely,

Karen D. Johnson, Chief  
Ground Water and Enforcement Branch

Enclosure

## ENCLOSURE 1

### Invalidation of samples submitted by WASA (DC 0000002) for January – June 2006 Compliance Monitoring Period for Lead and Copper

On June 28, 2006, the District of Columbia Water and Sewer Authority (WASA) submitted a request to invalidate 6 samples taken for compliance with the Lead and Copper Rule for the January – June 2006 compliance monitoring period. Pursuant to 40 CFR 141.90(a)(1), the water system must submit the results of all tap samples including the location and criteria under which the site was selected for the system's sampling pool. For the following sampling locations, WASA submitted chains of custody, laboratory results, and information relating to the service line such as test pit documentation. WASA did not submit information to show that any of the houses had copper pipes with lead solder installed after 1982 and before 1988 (DC lead ban effective date).

As stated in EPA and WASA's conference call of March 21, 2006, the best information available at the time of sampling and at the time of reporting must be used by WASA to identify tier 1 locations. Thus, if at the time of sampling, the best information available to WASA supports a determination that a particular sampling location qualifies as a tier 1 location, samples taken from that location may be analyzed with the intent to use them to determine the lead or copper 90<sup>th</sup> percentile levels under 40 CFR 141.80(c)(3) and toward meeting the minimum monitoring requirements of 40 CFR 141.86(c). However, if it is determined at a later date prior to reporting that the sampling location did not in fact qualify as a tier 1 location, then WASA should request invalidation of that sample under 141.86(f) prior to or at the time of reporting required by 40 CFR 141.90(a). EPA has reviewed WASA's information and has determined that the six samples should be invalidated pursuant to 40 CFR 141.86(f).

- 112 4<sup>th</sup> St, SE, sample collected on February 8, 2006
- 1332 Vermont Ave., NW, sample collected on February 8, 2006
- 1226 D Street, NE, sample collected on February 8, 2006
- 1527 33<sup>rd</sup> St., NW, sample collected on February 8, 2006
- 2211 39<sup>th</sup> St., NW, sample collected on March 7, 2006
- 2825 Beecher St., NW, sample collected on March 8, 2006

The requirements for invalidation are set out in 40 CFR 141.86(f). If one or more of four conditions listed in 40 CFR 141.86(f)(i-iv) are met, the state, or EPA, may invalidate a sample. Each address is discussed below.

#### **A. 112 4<sup>th</sup> St, SE, and 1332 Vermont Ave., NW**

EPA has found that the samples taken from these sites did not meet the site selection criteria of 40 CFR 141.86 (40 CFR 141.86(f)(1)(ii)). At the time of sampling, WASA believed that these addresses were single-family structures. However, the chains of

custody revealed that the occupant addresses indicated multi-unit dwellings. 40 CFR 141.86(a)(3) states that sites selected for a community water system's sampling pool ("tier 1 sampling sites") shall consist of single family structures. The samples taken at these sites must be invalidated, i.e., may not be counted to determine the lead or copper 90<sup>th</sup> percentile levels under 40 CFR 141.80(c)(3) or toward meeting the minimum monitoring requirements of 40 CFR 141.86(c).

**B. 1226 D Street, NE**

This location was determined not to meet the requirements of a tier 1 sampling locations in an April 10, 2006 letter from EPA to WASA. The location does not have a lead service line. WASA has submitted information to EPA showing that test-pits were conducted on the service lines for this address prior to the monitoring period. At the time of sampling for the January – June 2006 monitoring period, WASA was or should have been aware that this address had a non-lead service line for the public and private portion. Accordingly, the samples taken at this site must be invalidated, i.e., may not be counted to determine the lead or copper 90<sup>th</sup> percentile levels under 40 CFR 141.80(c)(3) or toward meeting the minimum monitoring requirements of 40 CFR 141.86(c).

**C. 1527 33<sup>rd</sup> St., NW**

In the June 28, 2006 letter, WASA provided information indicating that the public portion of the service line at this address was replaced in March 2004. WASA submitted test pit information from March 2006 indicating copper service material on both the public and private side of the service line. It must be noted that this address was not included in WASA's 2004 Lead Service Line Replacement Report. Accordingly, the samples taken at this site must be invalidated, i.e., may not be counted to determine the lead or copper 90<sup>th</sup> percentile levels under 40 CFR 141.80(c)(3) or toward meeting the minimum monitoring requirements of 40 CFR 141.86(c).

**D. 2211 39<sup>th</sup> St., NW and 2825 Beecher St., NW**

For 2211 39<sup>th</sup> St., NW and 2825 Beecher St., NW, WASA has submitted information to EPA showing that test-pits were conducted on the service lines for these addresses after the samples were collected, but prior to the end of the monitoring period. At the time of the sampling, the WASA's inventory showed that these addresses had lead service lines and thus qualified as tier 1 locations. Therefore the samples were sent for analysis. Upon consultation with staff familiar with service line replacement work done at or near these addresses by WASA's predecessor agency in the 1990's, test pits were ordered. The test pits revealed that both houses have copper service lines, on both the public and private portions. Accordingly, the samples taken at this site must be invalidated, i.e., may not be counted to determine the lead or copper 90<sup>th</sup> percentile levels under 40 CFR 141.80(c)(3) or toward meeting the minimum monitoring requirements of 40 CFR 141.86(c).

### Calculation of 90<sup>th</sup> Percentile for Lead and Copper

The invalidated samples cannot be used to compute the 90<sup>th</sup> percentile for the lead and copper samples. Further, replacement samples from the invalidated sample sites are not appropriate because the sites do not meet the tier 1 site selection requirements of 40 CFR 141.86(a)(3). 40 CFR 141.86(f)(4) requires the water system to collect replacement samples if they have not collected the minimum number of samples required for the monitoring period.

WASA is therefore required to collect replacement samples at six (6) tier 1 locations within 20 days of receipt of a letter from EPA that determines the invalidation. If WASA does not collect a sufficient number of samples within 20 days, they are subject to a violation of 40 CFR 141.86(c) for failure to collect the minimum number of samples required for a monitoring period. A 90<sup>th</sup> percentile value can still be calculated based on the number of samples collected, pursuant to a March 9, 2004 guidance memorandum "Compliance Calculation Under the Lead and Copper Rule" signed by Cynthia Dougherty, Director of the Office of Ground Water and Drinking Water.

## Appendix F – Homes removed from Routine List

	Address	Quadrant	Pipe Material	Comments
1	1110 45TH PL.	SE	Full Copper	Proven non tier 1
2	112 4TH ST.	SE	Lead	Converted into an apartment
3	1226 D ST	NE	Full Copper	Test pitted Copper 8-30-05
4	1228 CARROLISBURG PL	SW	Full Copper	Full replacement 3-16-06
5	1250 FLORIDA AVE	NE	Full Copper	Proven non tier 1
6	1326 A ST	SE	Full Copper	Full Replacement 11-04
7	1326 NORTH CAROLINA AVE	NE	Full Copper	Full Replacement 3-3-05
8	1332 VERMONT AVE	NW	Lead	Converted into an apartment
9	1338 A ST	SE	Full Copper	Full replacement complete on 3-29-06
10	1340 V ST.	SE	Lead	Customer does not want to participate
11	1419 SPRING RD	NW	Copper	Not Proven as Tier 1
12	1527 33RD ST	NW	Full Copper	Test Pit Copper 3-7-06
13	1626 19TH ST.	NW	Copper	Not proven as Tier 1
14	1803 MONROE ST	NW	Full Copper	Proven as non Tier 1
15	2017 BELMONT RD	NW	Full Copper	Full Replacement 6-7-05
16	208 5TH ST	SE	Copper	Not Proven as Tier 1
17	220 8TH ST	SE	Full Copper	Full Replacement 10-3-05
18	2208 12TH ST	NW	Full Copper	Test pitted copper 7-26-05
19	2211 39TH ST	NW	Full Copper	Test pitted copper 5-15-06
20	2305 38TH ST	NW	Copper	Public test pit copper 6-29-05. Private unknown
21	2448 HUIDEKOPER PL	NW	Full Copper	Old records indicate full replacement in 1996
22	2858 28TH ST	NW	Full Copper	Full Replacement 4-14-06
23	3035 15TH ST	NW	Full Copper	Full Replacement conducted by DWS
24	3250 HIGHLAND PL.	NW	Copper	Not Proven Tier 1
25	3342 18TH ST	NW	Full Copper	Full Replacement 2-10-04
26	3519 PORTER ST	NW	Full Copper	Full Replacement conducted by DWS
27	3815 JOCELYN ST.	NW	Full Copper	Private Replaced 12-21-05
28	3835 BEECHER ST	NW	Full Copper	Test pitted copper 5-12-06
29	406 9TH ST.	NE	Full Copper	Public replaced 3-3-06. Private side galvanized
30	4306 CHESAPEAKE ST	NW	Lead	Customer requested to be removed from sample list
31	440 3RD ST	NE	Copper	Test pitted copper 7-29-05
32	4450 VOLTA PL.	NW	Full Copper	Full Replacement 3-3-06
33	4828 7TH ST	NW	Brass	Test pitted Brass 5-8-06
34	4912 44TH ST	NW	Full Copper	Full Replacement 6-27-05
35	5134 NEBRASKA AVE	NW	Full Copper	Private Side Replaced by owner 3-28-06
36	5407 41ST ST	NW	Full Copper	Full Replacement 9-1-04
37	714 8TH ST	NE	Copper	Public side test pitted cu 9-29-05. Private side unknown
38	1937 Summit Pl,	NE	Unknown	Sampled by accident
39	4501 Yuma St	NW	Copper	Proven non Tier 1 3-14-06
40	621 L St	NE	Unknown	Not Proven Tier 1