



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY
DEPARTMENT OF WATER SERVICES
3900 Donaldson Pl, N.W. WASHINGTON DC 20016

Lead and Copper Compliance Report
July - December 2006

Table 1 summarizes the compliance results for the monitoring period July through December 2006.

Table 1. July - December 2006 Lead and Copper Compliance Results

Number of Samples	
Total	106
90th Percentile First Draw Concentrations	
Lead mg/L	0.012
Copper mg/L	0.078
Service Line Materials	
Full Lead	76%
Partial Lead	24%

The appendices contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results
- Appendix B: Non-Regulated Lead Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results
 - Table B.3 Customer Requested Lead Samples
 - Table B.4 Lead Service Line Replacement Samples
- Appendix C: Sample Kit Distribution
 - Table C.1 Sample Kit Distribution – July to December 2006
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned and Rejected for Compliance Analysis
 - Table C.4 Addresses Not Receiving Sample Kits July to December 2006
- Appendix D: Locations Removed from Routine List

Appendix A – Lead and Copper Compliance Data

Table A.1 Lead Results

No.	Address	Service Line Material	Lead (mg/L) 1st Draw
1	1104 TRINIDAD AVE NE	Full Lead	0.000
2	1133 Park St NE	Full Lead	0.000
3	119 11th St NE	Full Lead	0.000
4	1451 S ST NW	Partial Lead	0.000
5	202 11th St SE	Full Lead	0.000
6	2238 HALL PL NW	Full Lead	0.000
7	3913 8TH ST NW	Partial Lead	0.001
8	1315 FRANKLIN ST NE	Full Lead	0.001
9	1349 Wallach Pl NW	Full Lead	0.001
10	3218 MORRISON ST NW	Full Lead	0.001
11	4332 BRANDYWINE ST NW	Partial Lead	0.001
12	4518 14TH ST NW	Full Lead	0.001
13	1115 PARK ST NE	Partial Lead	0.001
14	1204 Longfellow St NW	Full Lead	0.001
15	1220 Kennedy St NW	Full Lead	0.001
16	1003 Quebec Pl NW	Full Lead	0.002
17	2007 37TH ST NW	Full Lead	0.002
18	3601 WARREN ST NW	Full Lead	0.002
19	1262 COLUMBIA RD NW	Full Lead	0.002
20	1319 21st ST NW	Full Lead	0.002
21	607 ATLANTIC ST SE	Full Lead	0.002
22	6213 7TH ST NW	Partial Lead	0.002
23	1814 MONROE ST NW	Partial Lead	0.002
24	1341 Massachusetts Ave SE	Partial Lead	0.002
25	5301 RENO RD NW	Partial Lead	0.002
26	926 14TH ST SE	Full Lead	0.002
27	1231 F St NE	Full Lead	0.002
28	1313 T St SE	Full Lead	0.002
29	765 GIRARD ST NW	Partial Lead	0.002
30	1010 10th St NE	Full Lead	0.002
31	2134 NEWPORT PL NW	Full Lead	0.002
32	5324 COLORADO AVE NW	Full Lead	0.002
33	1207 Trinidad Ave NE	Full Lead	0.003
34	3809 ALTON PL NW	Partial Lead	0.003
35	1346 Madison St NW	Full Lead	0.003

No.	Address	Service Line Material	Lead (mg/L) 1st Draw
36	1863 MONROE ST NW	Partial Lead	0.003
37	2702 P ST NW	Full Lead	0.003
38	3908 13TH ST NW	Full Lead	0.003
39	1843 MONROE ST NW	Partial Lead	0.003
40	2830 BRENTWOOD RD NE	Full Lead	0.003
41	1931 SUMMIT PL NE	Partial Lead	0.003
42	322 TENNESSEE AVE NE	Full Lead	0.003
43	1635 WEBSTER ST NW	Full Lead	0.003
44	909 HAMLIN ST NE	Full Lead	0.003
45	704 ALABAMA AVE SE	Full Lead	0.003
46	1222 HAMILTON ST NW	Partial Lead	0.003
47	3301 BROWN St NW	Partial Lead	0.004
48	349 TENNESSEE AVE NE	Full Lead	0.004
49	1626 E ST SE	Full Lead	0.004
50	1016 DOUGLAS ST NE	Partial Lead	0.004
51	5405 39TH ST NW	Full Lead	0.004
52	1331 Irving St NE	Full Lead	0.004
53	1339 Ives Pl SE	Full Lead	0.005
54	3618 PORTER ST NW	Full Lead	0.005
55	1319 POTOMAC AVE SE	Partial Lead	0.005
56	4622 15TH ST NW	Full Lead	0.005
57	1112 50th St NE	Full Lead	0.005
58	532 13TH ST SE	Full Lead	0.005
59	1956 BILTMORE ST NW	Full Lead	0.005
60	1971 BILTMORE ST NW	Full Lead	0.005
61	4111 INGOMAR ST NW	Full Lead	0.005
62	143 UHLAND TER NE	Full Lead	0.006
63	712 JEFFERSON ST NW	Partial Lead	0.006
64	1701 INDEPENDENCE AVE SE	Partial Lead	0.006
65	4413 GREENWICH PKWY NW	Full Lead	0.006
66	1937 BILTMORE ST NW	Full Lead	0.006
67	514 13th St SE	Full Lead	0.006
68	1808 KEARNEY ST NE	Partial Lead	0.006
69	4609 30TH ST NW	Partial Lead	0.006
70	4401 5TH ST NW	Full Lead	0.006
71	1420 S ST SE	Full Lead	0.006
72	119 16TH ST NE	Full Lead	0.007
73	1241 JACKSON ST NE	Partial Lead	0.007
74	1224 Irving St NW	Full Lead	0.007
75	821 BUCHANAN ST NW	Full Lead	0.007

No.	Address	Service Line Material	Lead (mg/L) 1st Draw
76	1400 FLORAL ST NW	Full Lead	0.007
77	4305 38TH ST NW	Full Lead	0.007
78	5318 9TH ST NW	Full Lead	0.007
79	1929 SUMMIT PL NE	Full Lead	0.008
80	2003 KLINGLE RD NW	Full Lead	0.008
81	1301 Michigan Ave NE	Full Lead	0.008
82	205 TAYLOR ST NW	Partial Lead	0.008
83	3827 VEAZEY ST NW	Full Lead	0.008
84	3408 LOWELL ST NW	Full Lead	0.009
85	1353 JEFFERSON ST NW	Full Lead	0.009
86	125 Madison St NW	Full Lead	0.010
87	1320 Delafield Pl NW	Full Lead	0.010
88	1212 E Capitol St NE	Full Lead	0.010
89	5229 7TH ST NW	Full Lead	0.010
90	134 Bryant St NW	Full Lead	0.011
91	3424 PORTER ST NW	Full Lead	0.011
92	4325 IOWA AVE NW	Full Lead	0.012
93	4331 BRANDYWINE ST NW	Full Lead	0.012
94	1240 D ST SE	Partial Lead	0.012
95¹	4131 YUMA ST NW	Full Lead	0.012
96	2418 3RD ST NE	Full Lead	0.012
97	4326 FOREST LN NW	Full Lead	0.013
98	1649 HARVARD ST NW	Full Lead	0.013
99	3550 ALBEMARLE ST NW	Full Lead	0.013
100	835 3RD ST NE	Full Lead	0.014
101	1612 V ST NW	Full Lead	0.015
102	4327 IOWA AVE NW	Full Lead	0.016
103	805 LONGFELLOW ST NW	Full Lead	0.016
104	1013 I St NE	Partial Lead	0.017
105	302 RITTENHOUSE ST NW	Full Lead	0.019
106	3412 GARRISON ST NW	Full Lead	0.020

Notes: All addresses meet Tier 1 criteria under 141.86(a)(3) as single family structures with either full or partial lead service lines based on WASA's customer information and service line inventory. Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

¹Bolded data represents 1st draw 90th percentile.

Table A.2 Copper Results

No.	Address	Service Line Material	Copper (mg/L) 1st Draw
1	5229 7 TH ST NW	Full Lead	0.008
2	1313 T St SE	Full Lead	0.008
3	1220 Kennedy St NW	Full Lead	0.009
4	1204 Longfellow St NW	Full Lead	0.010
5	4131 YUMA ST NW	Full Lead	0.010
6	4518 14 TH ST NW	Full Lead	0.010
7	119 11 th St NE	Full Lead	0.010
8	302 RITTENHOUSE ST NW	Full Lead	0.010
9	143 UHLAND TER NE	Full Lead	0.011
10	704 ALABAMA AVE SE	Full Lead	0.011
11	6213 7 TH ST NW	Partial Lead	0.011
12	1133 Park St NE	Full Lead	0.011
13	3412 GARRISON ST NW	Full Lead	0.011
14	909 HAMLIN ST NE	Full Lead	0.013
15	1262 COLUMBIA RD NW	Full Lead	0.013
16	1003 Quebec PI NW	Full Lead	0.013
17	1863 MONROE ST NW	Partial Lead	0.014
18	1339 Ives PI SE	Full Lead	0.015
19	4609 30 TH ST NW	Partial Lead	0.016
20	607 ATLANTIC ST SE	Full Lead	0.016
21	322 TENNESSEE AVE NE	Full Lead	0.017
22	1315 FRANKLIN ST NE	Full Lead	0.017
23	4331 BRANDYWINE ST NW	Full Lead	0.017
24	1104 TRINIDAD AVE NE	Full Lead	0.017
25	3908 13 TH ST NW	Full Lead	0.018
26	2134 NEWPORT PL NW	Full Lead	0.018
27	1808 KEARNEY ST NE	Partial Lead	0.018
28	3424 PORTER ST NW	Full Lead	0.019
29	3913 8 TH ST NW	Partial Lead	0.019
30	1635 WEBSTER ST NW	Full Lead	0.019
31	1207 Trinidad Ave NE	Full Lead	0.019
32	3618 PORTER ST NW	Full Lead	0.020
33	712 JEFFERSON ST NW	Partial Lead	0.020
34	1349 Wallach PI NW	Full Lead	0.020
35	532 13 TH ST SE	Full Lead	0.020
36	1929 SUMMIT PL NE	Full Lead	0.021
37	349 TENNESSEE AVE NE	Full Lead	0.021
38	4305 38 TH ST NW	Full Lead	0.021

No.	Address	Service Line Material	Copper (mg/L) 1 st Draw
39	4622 15 TH ST NW	Full Lead	0.021
40	1224 Irving St NW	Full Lead	0.021
41	1814 MONROE ST NW	Partial Lead	0.022
42	4413 GREENWICH PKWY NW	Full Lead	0.022
43	1341 Massachusetts Ave SE	Partial Lead	0.023
44	2702 P ST NW	Full Lead	0.024
45	821 BUCHANAN ST NW	Full Lead	0.024
46	1331 Irving St NE	Full Lead	0.024
47	835 3 RD ST NE	Full Lead	0.025
48	125 Madison St NW	Full Lead	0.025
49	1626 E ST SE	Full Lead	0.025
50	805 LONGFELLOW ST NW	Full Lead	0.026
51	2238 HALL PL NW	Full Lead	0.029
52	2007 37 TH ST NW	Full Lead	0.030
53	4111 INGOMAR ST NW	Full Lead	0.031
54	1301 Michigan Ave NE	Full Lead	0.033
55	1115 PARK ST NE	Partial Lead	0.033
56	1010 10 th St NE	Full Lead	0.033
57	1956 BILTMORE ST NW	Full Lead	0.033
58	3218 MORRISON ST NW	Full Lead	0.034
59	4326 FOREST LN NW	Full Lead	0.034
60	3827 VEAZEY ST NW	Full Lead	0.035
61	1240 D ST SE	Partial Lead	0.036
62	926 14 TH ST SE	Full Lead	0.037
63	1701 INDEPENDENCE AVE SE	Partial Lead	0.037
64	1420 S ST SE	Full Lead	0.038
65	3408 LOWELL ST NW	Full Lead	0.039
66	134 Bryant St NW	Full Lead	0.040
67	1937 BILTMORE ST NW	Full Lead	0.040
68	3809 ALTON PL NW	Partial Lead	0.041
69	5318 9 TH ST NW	Full Lead	0.041
70	5301 RENO RD NW	Partial Lead	0.042
71	1319 POTOMAC AVE SE	Partial Lead	0.042
72	1241 JACKSON ST NE	Partial Lead	0.044
73	3550 ALBEMARLE ST NW	Full Lead	0.045
74	1612 V ST NW	Full Lead	0.045
75	5405 39 TH ST NW	Full Lead	0.046
76	4325 IOWA AVE NW	Full Lead	0.047
77	1931 SUMMIT PL NE	Partial Lead	0.050
78	1649 HARVARD ST NW	Full Lead	0.052

No.	Address	Service Line Material	Copper (mg/L) 1 st Draw
79	1400 FLORAL ST NW	Full Lead	0.052
80	119 16 TH ST NE	Full Lead	0.056
81	2830 BRENTWOOD RD NE	Full Lead	0.058
82	1222 HAMILTON ST NW	Partial Lead	0.061
83	1319 21 st ST NW	Full Lead	0.061
84	205 TAYLOR ST NW	Partial Lead	0.061
85	765 GIRARD ST NW	Partial Lead	0.065
86	1016 DOUGLAS ST NE	Partial Lead	0.066
87	1112 50 th St NE	Full Lead	0.068
88	2003 KLINGLE RD NW	Full Lead	0.069
89	1451 S ST NW	Partial Lead	0.071
90	1353 JEFFERSON ST NW	Full Lead	0.072
91	5324 COLORADO AVE NW	Full Lead	0.074
92	202 11 th St SE	Full Lead	0.075
93	1971 BILTMORE ST NW	Full Lead	0.077
94	514 13 th St SE	Full Lead	0.077
95¹	3601 WARREN ST NW	Full Lead	0.078
96	1346 Madison St NW	Full Lead	0.082
97	1320 Delafield PI NW	Full Lead	0.085
98	1013 I St NE	Partial Lead	0.096
99	4401 5 TH ST NW	Full Lead	0.103
100	4332 BRANDYWINE ST NW	Partial Lead	0.104
101	2418 3 RD ST NE	Full Lead	0.105
102	3301 BROWN St NW	Partial Lead	0.109
103	4327 IOWA AVE NW	Full Lead	0.119
104	1231 F St NE	Full Lead	0.192
105	1843 MONROE ST NW	Partial Lead	0.240
106	1212 E Capitol St NE	Full Lead	0.307

Notes: All addresses meet Tier 1 criteria under 141.86(a)(3) as single family structures with either full or partial lead service lines based on WASA's customer information and service line inventory.

¹Bolded data represents 1st draw 90th percentile.

Appendix B: Non-Regulated Data

Appendix B presents second draw results from the July to December 2006 compliance sampling process (Tables B.1 and B.2). The appendix also presents the lead results of samples collected by customers requesting lead tests (Table B.3) and customers with partial service line replacements (Table B.4).

Table B.1 Second Draw Lead Results

No.	Address	Service Line Material	Lead (mg/L) 2nd Draw
1	2238 HALL PL NW	Full Lead	0.000
2	202 11th St SE	Full Lead	0.000
3	1451 S ST NW	Partial Lead	0.000
4	2702 P ST NW	Full Lead	0.000
5	1104 TRINIDAD AVE NE	Full Lead	0.000
6	1349 Wallach PI NW	Full Lead	0.000
7	119 11th St NE	Full Lead	0.000
8	1133 Park St NE	Full Lead	0.001
9	1341 Massachusetts Ave SE	Partial Lead	0.001
10	1315 FRANKLIN ST NE	Full Lead	0.001
11	4332 BRANDYWINE ST NW	Partial Lead	0.001
12	3218 MORRISON ST NW	Full Lead	0.001
13	1115 PARK ST NE	Partial Lead	0.001
14	4518 14TH ST NW	Full Lead	0.001
15	6213 7TH ST NW	Partial Lead	0.001
16	926 14TH ST SE	Full Lead	0.001
17	1262 COLUMBIA RD NW	Full Lead	0.002
18	607 ATLANTIC ST SE	Full Lead	0.002
19	1220 Kennedy St NW	Full Lead	0.002
20	1635 WEBSTER ST NW	Full Lead	0.002
21	1346 Madison St NW	Full Lead	0.002
22	1010 10th St NE	Full Lead	0.002
23	1814 MONROE ST NW	Partial Lead	0.002
24	1003 Quebec PI NW	Full Lead	0.002
25	5324 COLORADO AVE NW	Full Lead	0.002
26	2007 37TH ST NW	Full Lead	0.002
27	3601 WARREN ST NW	Full Lead	0.002
28	1339 Ives PI SE	Full Lead	0.002
29	765 GIRARD ST NW	Partial Lead	0.002
30	1319 21st ST NW	Full Lead	0.002
31	349 TENNESSEE AVE NE	Full Lead	0.002
32	1204 Longfellow St NW	Full Lead	0.002

No.	Address	Service Line Material	Lead (mg/L) 2nd Draw
33	704 ALABAMA AVE SE	Full Lead	0.003
34	3908 13TH ST NW	Full Lead	0.003
35	3913 8TH ST NW	Partial Lead	0.003
36	1956 BILTMORE ST NW	Full Lead	0.003
37	1313 T St SE	Full Lead	0.003
38	1971 BILTMORE ST NW	Full Lead	0.003
39	1843 MONROE ST NW	Partial Lead	0.003
40	909 HAMLIN ST NE	Full Lead	0.003
41	1207 Trinidad Ave NE	Full Lead	0.003
42	1222 HAMILTON ST NW	Partial Lead	0.003
43	1863 MONROE ST NW	Partial Lead	0.003
44	3301 BROWN St NW	Partial Lead	0.003
45	1937 BILTMORE ST NW	Full Lead	0.004
46	4622 15TH ST NW	Full Lead	0.004
47	1931 SUMMIT PL NE	Partial Lead	0.004
48	2830 BRENTWOOD RD NE	Full Lead	0.004
49	3809 ALTON PL NW	Partial Lead	0.004
50	1112 50th St NE	Full Lead	0.004
51	119 16TH ST NE	Full Lead	0.005
52	3827 VEAZEY ST NW	Full Lead	0.005
53	4111 INGOMAR ST NW	Full Lead	0.005
54	712 JEFFERSON ST NW	Partial Lead	0.005
55	2134 NEWPORT PL NW	Full Lead	0.005
56	821 BUCHANAN ST NW	Full Lead	0.005
57	1224 Irving St NW	Full Lead	0.005
58	4131 YUMA ST NW	Full Lead	0.005
59	1320 Delafield Pl NW	Full Lead	0.005
60	1331 Irving St NE	Full Lead	0.005
61	143 UHLAND TER NE	Full Lead	0.006
62	134 Bryant St NW	Full Lead	0.006
63	4609 30TH ST NW	Partial Lead	0.006
64	1929 SUMMIT PL NE	Full Lead	0.006
65	3412 GARRISON ST NW	Full Lead	0.006
66	1701 INDEPENDENCE AVE SE	Partial Lead	0.006
67	322 TENNESSEE AVE NE	Full Lead	0.006
68	1400 FLORAL ST NW	Full Lead	0.006
69	1808 KEARNEY ST NE	Partial Lead	0.007
70	1319 POTOMAC AVE SE	Partial Lead	0.007
71	532 13TH ST SE	Full Lead	0.007
72	125 Madison St NW	Full Lead	0.007

No.	Address	Service Line Material	Lead (mg/L) 2nd Draw
73	3550 ALBEMARLE ST NW	Full Lead	0.007
74	1231 F St NE	Full Lead	0.008
75	4413 GREENWICH PKWY NW	Full Lead	0.008
76	205 TAYLOR ST NW	Partial Lead	0.008
77	1013 I St NE	Partial Lead	0.009
78	5318 9TH ST NW	Full Lead	0.009
79	1241 JACKSON ST NE	Partial Lead	0.010
80	4401 5TH ST NW	Full Lead	0.011
81	1212 E Capitol St NE	Full Lead	0.011
82	1649 HARVARD ST NW	Full Lead	0.011
83	1016 DOUGLAS ST NE	Partial Lead	0.011
84	5405 39TH ST NW	Full Lead	0.012
85	1353 JEFFERSON ST NW	Full Lead	0.013
86	4325 IOWA AVE NW	Full Lead	0.013
87	5229 7TH ST NW	Full Lead	0.014
88	4326 FOREST LN NW	Full Lead	0.015
89	4331 BRANDYWINE ST NW	Full Lead	0.015
90	3618 PORTER ST NW	Full Lead	0.015
91	302 RITTENHOUSE ST NW	Full Lead	0.015
92	3408 LOWELL ST NW	Full Lead	0.015
93	514 13th St SE	Full Lead	0.015
94	3424 PORTER ST NW	Full Lead	0.016
95	1301 Michigan Ave NE	Full Lead	0.016
96	1240 D ST SE	Partial Lead	0.016
97	835 3RD ST NE	Full Lead	0.016
98	2418 3RD ST NE	Full Lead	0.017
99	4305 38TH ST NW	Full Lead	0.018
100	805 LONGFELLOW ST NW	Full Lead	0.018
101	4327 IOWA AVE NW	Full Lead	0.021
102	1626 E ST SE	Full Lead	0.022
103	1612 V ST NW	Full Lead	0.022
104	1420 S ST SE	Full Lead	0.026
105	5301 RENO RD NW	Partial Lead	0.028
106	2003 KLINGLE RD NW	Full Lead	0.030

Note: Results expressed as “0.0000” may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

Table B.2 Second Draw Copper Results

No.	Address	Service Line Material	Copper (mg/L) 2nd Draw
1	3618 PORTER ST NW	Full Lead	0.005
2	2702 P ST NW	Full Lead	0.006
3	3827 VEAZEY ST NW	Full Lead	0.006
4	3412 GARRISON ST NW	Full Lead	0.006
5	4111 INGOMAR ST NW	Full Lead	0.007
6	125 Madison St NW	Full Lead	0.007
7	5229 7 TH ST NW	Full Lead	0.008
8	4622 15 TH ST NW	Full Lead	0.008
9	1204 Longfellow St NW	Full Lead	0.008
10	821 BUCHANAN ST NW	Full Lead	0.008
11	1635 WEBSTER ST NW	Full Lead	0.009
12	1320 Delafield PI NW	Full Lead	0.009
13	4331 BRANDYWINE ST NW	Full Lead	0.009
14	5324 COLORADO AVE NW	Full Lead	0.009
15	3424 PORTER ST NW	Full Lead	0.009
16	3550 ALBEMARLE ST NW	Full Lead	0.009
17	119 11 th St NE	Full Lead	0.009
18	302 RITTENHOUSE ST NW	Full Lead	0.009
19	2007 37 TH ST NW	Full Lead	0.009
20	6213 7 TH ST NW	Partial Lead	0.010
21	3408 LOWELL ST NW	Full Lead	0.010
22	1220 Kennedy St NW	Full Lead	0.010
23	1133 Park St NE	Full Lead	0.010
24	704 ALABAMA AVE SE	Full Lead	0.010
25	1339 Ives PI SE	Full Lead	0.011
26	1313 T St SE	Full Lead	0.011
27	5405 39 TH ST NW	Full Lead	0.011
28	143 UHLAND TER NE	Full Lead	0.011
29	4518 14 TH ST NW	Full Lead	0.012
30	1612 V ST NW	Full Lead	0.012
31	4305 38 TH ST NW	Full Lead	0.012
32	909 HAMLIN ST NE	Full Lead	0.012
33	712 JEFFERSON ST NW	Partial Lead	0.012
34	1956 BILTMORE ST NW	Full Lead	0.012
35	1262 COLUMBIA RD NW	Full Lead	0.012
36	1010 10 th St NE	Full Lead	0.012
37	1349 Wallach PI NW	Full Lead	0.012

No.	Address	Service Line Material	Copper (mg/L) 2nd Draw
38	1420 S ST SE	Full Lead	0.013
39	4326 FOREST LN NW	Full Lead	0.013
40	119 16 TH ST NE	Full Lead	0.013
41	1626 E ST SE	Full Lead	0.013
42	514 13 th St SE	Full Lead	0.013
43	2003 KLINGLE RD NW	Full Lead	0.013
44	1400 FLORAL ST NW	Full Lead	0.013
45	1814 MONROE ST NW	Partial Lead	0.013
46	1104 TRINIDAD AVE NE	Full Lead	0.014
47	1929 SUMMIT PL NE	Full Lead	0.014
48	349 TENNESSEE AVE NE	Full Lead	0.014
49	4413 GREENWICH PKWY NW	Full Lead	0.014
50	1937 BILTMORE ST NW	Full Lead	0.014
51	532 13 TH ST SE	Full Lead	0.014
52	1331 Irving St NE	Full Lead	0.015
53	4609 30 TH ST NW	Partial Lead	0.015
54	926 14 TH ST SE	Full Lead	0.015
55	3908 13 TH ST NW	Full Lead	0.015
56	2134 NEWPORT PL NW	Full Lead	0.016
57	1863 MONROE ST NW	Partial Lead	0.016
58	1224 Irving St NW	Full Lead	0.017
59	607 ATLANTIC ST SE	Full Lead	0.017
60	3913 8 TH ST NW	Partial Lead	0.018
61	322 TENNESSEE AVE NE	Full Lead	0.018
62	202 11 th St SE	Full Lead	0.018
63	805 LONGFELLOW ST NW	Full Lead	0.018
64	1971 BILTMORE ST NW	Full Lead	0.019
65	2238 HALL PL NW	Full Lead	0.019
66	1207 Trinidad Ave NE	Full Lead	0.019
67	3218 MORRISON ST NW	Full Lead	0.020
68	1649 HARVARD ST NW	Full Lead	0.021
69	1341 Massachusetts Ave SE	Partial Lead	0.022
70	765 GIRARD ST NW	Partial Lead	0.023
71	1115 PARK ST NE	Partial Lead	0.025
72	1301 Michigan Ave NE	Full Lead	0.026
73	835 3 RD ST NE	Full Lead	0.026
74	1319 21 st ST NW	Full Lead	0.027
75	1353 JEFFERSON ST NW	Full Lead	0.027
76	4325 IOWA AVE NW	Full Lead	0.027
77	1003 Quebec Pl NW	Full Lead	0.027

No.	Address	Service Line Material	Copper (mg/L) 2nd Draw
78	5318 9 TH ST NW	Full Lead	0.029
79	134 Bryant St NW	Full Lead	0.029
80	1451 S ST NW	Partial Lead	0.030
81	1240 D ST SE	Partial Lead	0.030
82	1701 INDEPENDENCE AVE SE	Partial Lead	0.031
83	3601 WARREN ST NW	Full Lead	0.034
84	1016 DOUGLAS ST NE	Partial Lead	0.034
85	4131 YUMA ST NW	Full Lead	0.036
86	4327 IOWA AVE NW	Full Lead	0.036
87	1241 JACKSON ST NE	Partial Lead	0.036
88	3301 BROWN St NW	Partial Lead	0.036
89	1315 FRANKLIN ST NE	Full Lead	0.037
90	1112 50 th St NE	Full Lead	0.039
91	1808 KEARNEY ST NE	Partial Lead	0.041
92	3809 ALTON PL NW	Partial Lead	0.046
93	4332 BRANDYWINE ST NW	Partial Lead	0.054
94	1843 MONROE ST NW	Partial Lead	0.057
95	2418 3 RD ST NE	Full Lead	0.060
96	1231 F St NE	Full Lead	0.063
97	2830 BRENTWOOD RD NE	Full Lead	0.064
98	205 TAYLOR ST NW	Partial Lead	0.066
99	4401 5 TH ST NW	Full Lead	0.071
100	1222 HAMILTON ST NW	Partial Lead	0.076
101	5301 RENO RD NW	Partial Lead	0.078
102	1346 Madison St NW	Full Lead	0.085
103	1931 SUMMIT PL NE	Partial Lead	0.088
104	1319 POTOMAC AVE SE	Partial Lead	0.156
105	1212 E Capitol St NE	Full Lead	0.156
106	1013 I St NE	Partial Lead	0.256

Table B.3 Customer Service Samples

No.	Address	Collect Date	Lead (mg/L)		
			Draw 1	Draw 2	Draw 3
1 ¹	4320 Fessenden St NW	10/3/2004	0.001	0.002	
2 ¹	1318 E St NE	11/22/2004	0.020	0.002	
3 ¹	1737 Swann St NW	4/21/2005	0.005	0.020	
4 ¹	4615 Minnesota Ave NE	9/6/2005	0.008	0.011	
5 ¹	1224 Fairmont St NW	9/27/2005	0.008	0.008	
6 ¹	5050 Lowell St NW	4/16/2006	0.000	0.000	
7 ¹	1203 D St NE	5/20/2006	0.002	0.002	
8 ¹	626 Princeton PI NW	7/14/2006	0.009	0.007	
9 ¹	749 Butternut St NW	9/19/2006	15.533	6.091	
10 ¹	1365 IRIS ST NW	11/9/2006	0.000	0.000	
11 ¹	6126 Broad Branch Rd NW	11/25/2006	0.001	0.005	
12 ¹	1210 E St NE	12/28/2006	0.008	0.009	
13 ¹	1373 Quincy St NW	12/31/2006	0.001	0.001	
14 ³	1821 Corcoran St NE	9/16/2006	8.390	0.080	
15 ³	1821 Corcoran St NE	11/17/2006	0.003	0.003	0.001
16 ¹	127 T St NW	9/28/2005	0.009	0.008	
17 ¹	637 Keefer PI NW	11/23/2005	0.007	0.025	
18	826 Delafield St NE	3/31/2006	0.002	0.001	
19	2130 Leroy PI NW	4/17/2006	0.001	0.001	
20	316 Channing St NE	4/22/2006	0.000	0.000	
21	5105 14th St NW	5/4/2006	0.001	0.001	
22	2739 Woodley PI NW	5/7/2006	0.000	0.000	
23	1 Snows Ct NW	5/16/2006	0.002	0.002	
24	3802 24th St NE	5/21/2006	0.001	0.001	
25	1307 Delafield PI NW	5/25/2006	0.052	0.003	
26	415 Delafield PI NW	5/29/2006	0.001	0.001	
27	1635 1st St NW	6/1/2006	0.001	0.001	
28	2150 Newport PI NW	6/1/2006	0.010	0.008	
29	5216 Partridge Ln NW	6/3/2006	0.000	0.000	
30	3034 Dogwood St NW	6/4/2006	0.000	0.000	
31	1414 Webster St NW	6/6/2006	0.006	0.005	

32	2708 4th St NE	6/6/2006	0.000	0.000
33	4528 Eads Pl NE	6/7/2006	0.006	0.002
34	4911 Ashby St NW	6/7/2006	0.000	0.000
35	1116 D St NE	6/8/2006	0.001	0.000
36	1424 Webster St NW	6/9/2006	0.005	0.011
37	1734 Seaton St NW	6/10/2006	0.004	0.001
38	1616 32nd St NW	6/14/2006	0.002	0.000
39	1720 Seaton St NW	6/14/2006	0.009	0.002
40	324 Bryant St NE	6/16/2006	0.004	0.011
41	1512 Potomac Ave SE	6/17/2006	0.004	0.005
42	1805 Irving St NW	6/21/2006	0.011	0.019
43	3100 44th St NW	6/22/2006	0.006	0.019
44	125 10th St SE	6/28/2006	0.014	0.018
45	1760 Kilbourne Pl NW	6/29/2006	0.003	0.017
46	4621 Q St NW	6/29/2006	0.008	0.001
47	1885 Plymouth St NW	6/30/2006	0.019	0.067
48	3019 Macomb St NW	6/30/2006	0.003	0.004
49	320 S Carolina Ave SE	6/30/2006	0.008	0.016
50	1416 Buchanan St NW	7/4/2006	0.266	0.334
51	617 C St NE	7/4/2006	0.000	0.000
52	230 Peabody St NE	7/5/2006	0.000	0.000
53	3067 Canal St NW	7/5/2006	0.002	0.001
54	4605 Reno Rd NW	7/8/2006	0.000	0.000
55	1228 Walter St SE	7/12/2006	0.009	0.010
56	26 14th St NE	7/12/2006	0.002	0.002
57	4407 14th St NE	7/12/2006	0.005	0.002
58	1425 34th St NW	7/13/2006	0.000	0.000
59	107 5th St NE	7/14/2006	0.001	0.001
60	1631 Harvard St NW	7/14/2006	0.011	0.007
61	2321 Ontario Rd NW	7/14/2006	0.004	0.005
62	4916 47th St NW	7/14/2006	0.005	0.002
63	4213 16th St NW	7/15/2006	0.004	0.061
64	4326 Klingle St NW	7/15/2006	0.226	0.202
65	5416 30th Pl NW	7/15/2006	0.009	0.020

66	818 Delafield St NE	7/15/2006	0.001	0.000
67	1809 36th St NW	7/17/2006	0.005	0.009
68	1122 S Carolina Ave SE	7/18/2006	0.002	0.001
69	1400 E Capitol St NE	7/18/2006	0.001	0.000
70	3102 Cathedral Ave NW	7/18/2006	0.005	0.000
71	3338 Volta PI NW	7/18/2006	0.002	0.002
72	437 New Jersey Ave SE	7/18/2006	0.005	0.003
73	910 3rd St NE	7/18/2006	0.008	0.006
74	910 3rd St NE	7/18/2006	0.006	0.007
75	1222 V St SE	7/21/2006	0.017	0.007
76	4406 Volta PI NW	7/22/2006	0.000	0.000
77	1424 Oak St NW	7/23/2006	0.005	0.028
78	3929 Military Rd NW	7/23/2006	0.000	0.000
79	4528 49th St NW	7/24/2006	0.003	0.002
80	920 G St SE	7/24/2006	0.004	0.004
81	3234 Walbridge PI NW	7/25/2006	0.000	0.000
82	2021 H St NW	7/26/2006	0.004	0.005
83	3023 Newark St NW	7/26/2006	0.007	0.011
84	505 17th St SE	7/26/2006	0.000	0.000
85	643 F St NE	7/26/2006	0.001	0.000
86	1351 A St NE	7/27/2006	0.004	0.002
87	1344 Quincy St NW	7/28/2006	0.006	0.012
88	3320 Rowland PI NW	7/29/2006	0.007	0.008
89	1403 Webster St NW	7/30/2006	0.009	0.004
90	21 Quincy PI NE	7/30/2006	0.000	0.000
91	3308 Brown St NW	7/31/2006	0.014	0.003
92	407 4th St SE	7/31/2006	0.010	0.019
93	5061 Sherier PI NW	7/31/2006	0.005	0.010
94	1007 Quebec PI NW	8/1/2006	0.006	0.019
95	3379 Stephenson PI NW	8/1/2006	0.010	0.015
96	1349 G St SE	8/2/2006	0.001	0.000
97	1743 Massachusetts Ave SE	8/2/2006	0.002	0.003
98	336 16th St SE	8/2/2006	0.005	0.011
99	4426 Volta PI NW	8/2/2006	0.004	0.000

100	5210 Sherier PI NW	8/2/2006	0.002	0.002
101	2914 29th St NW	8/4/2006	0.000	0.000
102	4005 New Hampshire Ave NW	8/4/2006	0.001	0.011
103	3832 Garfield St NW	8/5/2006	0.000	0.000
104	1346 Leegate Rd NW	8/6/2006	0.001	0.000
105	6515 Utah Ave NW	8/8/2006	0.016	0.019
106	1315 Randolph St NE	8/9/2006	0.009	0.028
107	1318 Randolph St NE	8/10/2006	0.008	0.016
108	1662 Irving St NW	8/11/2006	0.008	0.013
109	2210 Rand PI NE	8/13/2006	0.000	0.000
110	3104 R St NW	8/13/2006	0.009	0.007
111	3229 Idaho Ave NW	8/13/2006	0.012	0.007
112	125 10th St SE	8/14/2006	0.020	0.001
113	5439 41st St NW	8/14/2006	0.010	0.009
114	668 MARYLAND AVE NE	8/14/2006	0.004	0.001
115	1433 Whittier St NW	8/16/2006	0.000	0.000
116	1429 Locust Rd NW	8/17/2006	0.006	0.009
117	719 A St NE	8/17/2006	0.001	0.000
118	1309 D St NE	8/18/2006	0.005	0.002
119	1316 C St NE	8/19/2006	0.002	0.003
120	2017 Kalorama Rd NW	8/22/2006	0.001	0.001
121	319 4th St SE	8/22/2006	0.014	0.010
122	3614 11th St NW	8/22/2006	0.000	0.000
123	1121 Oates St NE	8/24/2006	0.070	0.003
124	8 7th St SE	8/24/2006	0.000	0.000
125	3600 10th St NW	8/27/2006	0.004	0.004
126	640 Hobart PI NW	8/27/2006	0.011	0.012
127	4448 Reservoir Rd NW	9/2/2006	0.005	0.003
128	1429 Locust Rd NW	9/5/2006	0.001	0.000
129	1406 C St SE	9/6/2006	0.002	0.002
130	5913 32nd St NW	9/14/2006	0.008	0.003
131	4200 Fordham Rd NW	9/16/2006	0.000	0.000
132	3703 Legation St NW	9/20/2006	0.001	0.001
133	3215 35th St NW	9/22/2006	0.019	0.029

134	4326 Klinge St NW	9/24/2006	0.075	0.071	
135	6903 Maple St NW	9/24/2006	0.001	0.003	
136	1513 33rd St NW	9/27/2006	0.009	0.002	
137	2512 Ontario Rd NW	9/27/2006	0.005	0.007	
138	3740 Jenifer St NW	9/29/2006	0.015	0.016	
139	1332 Monroe St NE	10/2/2006	0.001	0.001	
140	433 Manor Pl NW	10/4/2006	0.001	0.001	
141	1304 C St SE	10/7/2006	0.009	0.031	
142	4409 7th St NW	10/10/2006	0.011	0.018	
143	3830 Harrison St NW	10/23/2006	0.005	0.019	
144	1215 33rd St NW	10/27/2006	0.003	0.007	
145	217 15th St SE	10/30/2006	0.010	0.007	
146	1008 Urell Pl NE	11/19/2006	0.271	0.001	
147	4917 Kansas Ave NW	12/18/2006	0.013	0.009	

General Note:

Data reported as zero may be non-detect or less than 0.0005 mg/L.

Footnote:

1) Test results received from the laboratory within the past 45 days.

Table B.4: Samples Collected After Partial Lead Service Line Replacements

No.	Service Address	Public Replacement Date	Collect Date	Lead (mg/L)		
				Draw 1	Draw 2	Draw 3
1	5800 Broad Branch Rd NW	4/10/2006	4/23/2006	0.004	0.004	
2	1022 Monroe St NE	5/3/2006	5/4/2006	0.007	0.003	
3	1701 Independence Ave SE	5/3/2006	5/5/2006	0.108	0.016	
4	5428 41st St NW	4/14/2006	5/5/2006	0.004	0.002	
5	1391 D St NE	3/22/2006	5/12/2006	0.004	0.002	
6	1222 Monroe St NE	5/10/2006	5/13/2006	0.003	0.003	
7	312 17th Pl NE	11/15/2005	5/14/2006	0.003	0.001	
8	1240 Monroe St NE	5/12/2006	5/15/2006	0.006	0.014	
9	814 Decatur St NW	1/13/2006	5/16/2006	0.003	0.004	
10	5015 8th St NW	12/22/2005	5/17/2006	0.007	0.001	
11	1005 8th St NE	10/14/2005	5/18/2006	0.009	0.001	
12	1244 Monroe St NE	5/16/2006	5/20/2006	0.003	0.003	
13	1267 Monroe St NE	5/17/2006	5/20/2006	0.009	0.008	
14	1300 Monroe St NE	5/19/2006	5/21/2006	0.014	0.003	
15	1302 Monroe St NE	5/19/2006	5/21/2006	0.008	0.007	
16	1327 Monroe St NE	5/20/2006	5/21/2006	0.072	0.038	
17	217 9th St NE	5/6/2006	5/21/2006	0.007	0.003	
18	1331 Monroe St NE	5/22/2006	5/23/2006	0.016	0.021	
19	1332 Monroe St NE	5/22/2006	5/23/2006	0.008	0.044	
20	115 6th St SE	8/2/2005	5/24/2006	0.011	0.032	
21	2949 Mills Ave NE	5/25/2006	5/25/2006	0.019	0.014	
22	1930 17th St NW	5/24/2006	5/26/2006	0.007	0.180	
23	1401 Monroe St NE	5/26/2006	5/31/2006	0.003	0.005	
24	3170 18th St NW	5/26/2006	6/1/2006	0.008	0.013	
25	1018 Irving St NE	12/29/2005	6/4/2006	0.007	0.002	
26	2931 Mills Ave NE	6/2/2006	6/5/2006	0.027	0.083	
27	3122 18th St NW	6/2/2006	6/5/2006	0.005	0.011	
28	1411 Monroe St NE	5/31/2006	6/6/2006	0.010	0.004	
29	3108 18th St NW	6/5/2006	6/6/2006	0.236	0.550	
30	5509 Broad Branch Rd NW	4/4/2006	6/6/2006	0.005	0.017	
31	2853 Mills Ave NE	6/6/2006	6/7/2006	0.014	0.012	
32	2903 Mills Ave NE	6/5/2006	6/8/2006	0.008	0.044	
33	1521 Monroe St NE	6/6/2006	6/9/2006	0.007	0.004	

No.	Service Address	Public Replacement Date	Collect Date	Lead (mg/L)		
				Draw 1	Draw 2	Draw 3
34	220 17th PI NE	6/14/2006	6/15/2006	0.025	0.054	
35	2401 Irving St NE	6/8/2006	6/16/2006	0.015	0.271	
36	216 17th PI NE	6/14/2006	6/17/2006	0.007	0.025	
37	1324 27th St NW	6/14/2006	6/18/2006	0.051	0.027	
38	1038 31st St NW	6/21/2006	6/19/2006	0.009	0.005	
39	1313 N Carolina Ave NE	6/16/2006	6/19/2006	0.004	0.004	
40	1616 Monroe St NE	6/9/2006	6/19/2006	0.020	0.019	
41	1715 18th St NW	6/1/2006	6/19/2006	0.005	0.006	
42	212 17th PI NE	6/13/2006	6/20/2006	0.060	0.064	
43	1614 Monroe St NE	6/13/2006	6/21/2006	0.003	0.002	
44	1335 N Carolina Ave NE	6/19/2006	6/22/2006	0.005	0.004	
45	1371 N Carolina Ave NE	6/21/2006	6/23/2006	0.250	0.021	
46	1379 N Carolina Ave NE	6/22/2006	6/23/2006	0.142	0.043	
47	1030 31st St NW	6/21/2006	6/24/2006	0.046	0.042	
48	1311 N Carolina Ave NE	6/16/2006	6/24/2006	0.001	0.001	
49	1373 N Carolina Ave NE	6/21/2006	6/24/2006	0.005	0.003	
50	1644 32nd St NW	6/20/2006	6/27/2006	0.021	0.024	
51	1364 N Carolina Ave NE	6/28/2006	6/29/2006	0.082	0.050	
52	1614 32nd St NW	6/23/2006	6/29/2006	0.003	0.002	
53	10 E St SE	6/21/2006	6/30/2006	0.002	0.000	
54	1027 31st St NW	6/28/2006	6/30/2006	0.003	0.003	
55	1352 N Carolina Ave NE	6/29/2006	6/30/2006	0.060	0.040	
56	1375 N Carolina Ave NE	6/21/2006	6/30/2006	0.002	0.004	
57	1726 Seaton St NW	6/28/2006	6/30/2006	0.003	0.005	
58	211 14th PI NE	7/5/2006	7/6/2006	0.019	0.149	
59	1363 A St NE	7/6/2006	7/7/2006	0.396	0.081	
60	215 14th PI NE	7/6/2006	7/7/2006	0.149	0.186	
61	212 14th PI NE	7/5/2006	7/8/2006	0.006	0.015	
62	213 14th PI NE	7/6/2006	7/8/2006	0.008	0.022	
63	1324 N Carolina Ave NE	7/7/2006	7/9/2006	0.010	0.018	
64	1328 N Carolina Ave NE	7/7/2006	7/9/2006	0.010	0.050	
65	1701 Seaton St NW	7/6/2006	7/9/2006	0.002	0.001	
66	1707 Seaton St NW	7/6/2006	7/9/2006	0.001	0.000	
67	1340 N Carolina Ave NE	7/5/2006	7/10/2006	0.006	0.021	

No.	Service Address	Public Replacement Date	Collect Date	Lead (mg/L)		
				Draw 1	Draw 2	Draw 3
68	1920 35th PI NW	7/10/2006	7/10/2006	0.369	0.021	
69	1912 35th PI NW	7/11/2006	7/11/2006	1.960	0.522	
70	1926 35th PI NW	7/7/2006	7/11/2006	0.024	0.037	
71	1314 N Carolina Ave NE	7/10/2006	7/12/2006	0.012	0.007	
72	1410 33rd St NW	7/10/2006	7/12/2006	0.013	0.002	
73	1914 35th PI NW	7/11/2006	7/12/2006	0.011	0.004	
74	1918 35th PI NW	7/10/2006	7/13/2006	0.011	0.010	
75	229 14th PI NE	7/10/2006	7/13/2006	0.214	0.199	
76	1418 N Carolina Ave NE	6/30/2006	7/14/2006	0.007	0.003	
77	227 14th PI NE	7/8/2006	7/14/2006	0.030	0.042	
78	253 14th PI NE	7/17/2006	7/14/2006	0.023	0.009	
79	727 Girard St NW	7/13/2006	7/15/2006	0.084	0.003	
80	1409 Ames PI NE	7/12/2006	7/17/2006	0.005	0.005	
81	717 Girard St NW	7/12/2006	7/17/2006	0.250	0.005	
82	1426 A St NE	7/12/2006	7/18/2006	0.008	0.003	
83	1913 35th PI NW	7/11/2006	7/18/2006	0.005	0.009	
84	1417 N Carolina Ave NE	7/14/2006	7/19/2006	0.672	0.068	
85	1427 Ames PI NE	7/18/2006	7/19/2006	0.033	0.006	
86	1520 A St NE	7/19/2006	7/20/2006	0.008	0.015	
87	1670 34th St NW	7/20/2006	7/21/2006	0.039	0.098	
88	1375 A St NE	7/8/2006	7/26/2006	0.014	0.010	
89	1423 Ames PI NE	7/18/2006	7/26/2006	0.005	0.004	
90	1430 Ames PI NE	7/17/2006	7/26/2006	0.005	0.005	
91	1526 A St NE	7/21/2006	7/27/2006	0.017	0.018	
92	3511 Center St NW	7/26/2006	7/27/2006	0.039	0.016	
93	2038 Allen PI NW	7/26/2006	7/28/2006	0.011	0.009	
94	726 Girard St NW	7/19/2006	7/28/2006	0.010	0.014	
95	1503 Constitution Ave NE	7/28/2006	7/29/2006	0.031	0.006	
96	759 Girard St NW	7/25/2006	7/30/2006	0.014	0.011	
97	5310 Dorsett PI NW	7/28/2006	7/31/2006	0.011	0.013	
98	6929 9th St NW	7/28/2006	7/31/2006	0.007	0.028	
99	1509 Constitution Ave NE	7/31/2006	8/1/2006	0.026	0.076	
100	5312 Carolina PI NW	7/31/2006	8/2/2006	0.010	0.038	
101	722 Girard St NW	7/18/2006	8/2/2006	0.021	0.014	

No.	Service Address	Public Replacement Date	Collect Date	Lead (mg/L)		
				Draw 1	Draw 2	Draw 3
102	1526 Constitution Ave NE	7/3/2006	8/3/2006	0.150	0.104	
103	1748 Seaton St NW	6/20/2006	8/3/2006	0.006	0.001	
104	225 17th St NE	7/24/2006	8/3/2006	0.005	0.004	
105	3502 Center St NW	7/1/2006	8/3/2006	0.022	0.043	
106	6930 9th St NW	7/31/2006	8/3/2006	0.006	0.004	
107	751 Girard St NW	7/24/2006	8/3/2006	0.004	0.007	
108	2040 Allen PI NW	7/25/2006	8/7/2006	0.003	0.004	
109	6928 9th St NW	7/27/2006	8/7/2006	0.114	0.015	
110	210 17th St NE	7/28/2006	8/8/2006	0.027	0.010	
111	1030 45th St NE	7/8/2006	8/9/2006	1.950	0.009	
112	1044 45th St NE	7/9/2006	8/9/2006	0.107	0.035	
113	1388 Morris Rd SE	7/9/2006	8/10/2006	0.108	0.060	
114	5319 Manning PI NW	8/3/2006	8/10/2006	0.011	0.006	
115	2028 Allen PI NW	7/28/2006	8/11/2006	0.008	0.004	
116	662 Columbia Rd NW	7/3/2006	8/11/2006	0.006	0.006	
117	1132 45th St NE	7/11/2006	8/12/2006	0.020	0.013	
118	2025 Allen PI NW	7/25/2006	8/12/2006	0.012	0.004	
119	544 Hobart PI NW	7/11/2006	8/13/2006	0.167	0.108	
120	1394 Morris Rd SE	8/14/2006	8/15/2006	0.013	0.031	
121	223 17th St NE	7/25/2006	8/15/2006	0.009	0.009	
122	650 Hobart PI NW	7/11/2006	8/15/2006	0.008	0.019	
123	3108 18TH ST NW	6/5/2006	8/16/2006	0.013	0.014	
124	5312 38th St NW	7/7/2006	8/16/2006	0.009	0.018	
125	4763 Indian Ln NW	7/15/2006	8/17/2006	0.003	0.004	
126	753 Harvard St NW	8/15/2006	8/17/2006	0.005	0.004	
127	1753 Lamont St NW	8/15/2006	8/18/2006	0.007	0.005	
128	755 Harvard St NW	8/15/2006	8/19/2006	0.017	0.007	
129	3506 Center St NW	7/1/2006	8/21/2006	0.010	0.005	
130	660 Columbia Rd NW	7/3/2006	8/22/2006	0.026	0.019	
131	721 Harvard St NW	8/22/2006	8/23/2006	0.063	0.009	
132	777 Harvard St NW	7/9/2006	8/23/2006	0.006	0.005	
133	1738 Lamont St NW	8/23/2006	8/24/2006	0.013	0.011	
134	1748 Lamont St NW	8/22/2006	8/25/2006	0.006	0.013	
135	3801 Jocelyn St NW	7/7/2006	8/26/2006	0.009	0.009	

No.	Service Address	Public Replacement Date	Collect Date	Lead (mg/L)		
				Draw 1	Draw 2	Draw 3
136	1746 Lamont St NW	8/22/2006	8/27/2006	0.750	0.017	
137	1759 Lamont St NW	8/14/2006	8/27/2006	0.006	0.002	
138	1928 35th PI NW	7/7/2006	8/28/2006	0.032	0.009	
139	2009 Kalorama Rd NW	8/17/2006	8/30/2006	0.024	0.018	
140	776 Harvard St NW	8/31/2006	9/1/2006	0.006	0.002	
141	772 Harvard St NW	8/29/2006	9/2/2006	0.018	0.008	
142	732 Hobart PI NW	9/6/2006	9/6/2006	7.180	0.349	
143 ³	1417 N Carolina Ave NE	7/14/2006	9/8/2006	0.001	0.001	0.001
144	739 Hobart PI NW	9/9/2006	9/11/2006	0.008	0.004	
145	1823 Phelps PI NW	9/12/2006	9/12/2006	0.011	0.009	
146	734 Hobart PI NW	9/6/2006	9/12/2006	0.014	0.014	
147	738 Hobart PI NW	9/9/2006	9/12/2006	0.008	0.024	
148	1214 Lamont St NW	9/15/2006	9/19/2006	0.006	0.003	
149	770 Hobart PI NW	9/20/2006	9/22/2006	0.034	0.012	
150	779 Hobart PI NW	9/22/2006	9/23/2006	0.076	0.074	
151	777 Hobart PI NW	9/22/2006	9/24/2006	0.110	0.033	
152	775 Hobart PI NW	9/21/2006	9/25/2006	0.107	0.109	
153	1410 Newton St NW	9/18/2006	9/26/2006	0.002	0.002	
154	1492 Newton St NW	9/26/2006	9/28/2006	0.007	0.020	
155	1021 Lamont St NW	9/26/2006	9/30/2006	0.007	0.005	
156	1489 Newton St NW	9/29/2006	9/30/2006	0.042	0.002	
157	752 Princeton PI NW	9/28/2006	9/30/2006	0.008	0.005	
158	1522 Newton St NW	9/27/2006	10/2/2006	0.003	0.003	
159	1518 Newton St NW	9/26/2006	10/5/2006	0.006	0.007	
160	747 Princeton PI NW	10/4/2006	10/9/2006	0.007	0.005	
161	1005 Lamont St NW	9/28/2006	10/10/2006	0.009	0.004	
162	738 Lamont St NW	9/27/2006	10/11/2006	0.016	0.006	
163	2039 Rosemont Ave NW	10/9/2006	10/14/2006	0.011	0.005	
164	776 Lamont St NW	10/10/2006	10/14/2006	0.052	0.005	
165	2031 Rosemont Ave NW	10/9/2006	10/16/2006	0.007	0.007	
166 ³	1030 45TH ST NE	7/8/2006	10/19/2006	0.014	0.026	0.004
167 ³	732 Hobart PI NW	9/6/2006	10/19/2006	0.016	0.020	0.003
168	780 Lamont St NW	10/11/2006	10/19/2006	0.034	0.007	
169	741 Princeton PI NW	10/4/2006	10/24/2006	0.015	0.011	

No.	Service Address	Public Replacement Date	Collect Date	Lead (mg/L)		
				Draw 1	Draw 2	Draw 3
170	765 Princeton PI NW	10/19/2006	10/24/2006	0.006	0.003	
171	1622 S St NW	10/20/2006	10/25/2006	0.008	0.007	
172	1714 New Hampshire Ave NW	10/19/2006	10/25/2006	0.483	0.009	
173	2037 Rosemont Ave NW	10/9/2006	10/25/2006	0.004	0.003	
174	636 Princeton PI NW	10/23/2006	10/25/2006	0.010	0.005	
175	737 Princeton PI NW	10/5/2006	10/25/2006	0.002	0.002	
176	746 Lamont St NW	9/28/2006	10/25/2006	0.005	0.006	
177	740 Princeton PI NW	10/2/2006	10/27/2006	0.002	0.005	
178	1727 S St NW	10/27/2006	10/29/2006	0.015	0.047	
179 ³	1912 35th PI NW	7/11/2006	10/30/2006	0.008	0.031	0.002
180	1913 New Hampshire Ave NW	10/26/2006	10/31/2006	0.014	0.003	
181	1915 New Hampshire Ave NW	10/26/2006	10/31/2006	0.055	0.065	
182	755 Princeton PI NW	10/12/2006	11/1/2006	0.004	0.003	
183	1748 S St NW	10/31/2006	11/3/2006	0.005	0.002	
184	624 Princeton PI NW	10/31/2006	11/14/2006	0.010	0.012	
185	1909 New Hampshire Ave NW	10/26/2006	11/15/2006	0.010	0.012	
186	1126 Chicago St SE	12/7/2006	12/9/2006	0.018	0.013	
187	1124 Chicago St SE	12/6/2006	12/10/2006	0.002	0.002	
188	609 Princeton PI NW	12/12/2006	12/13/2006	0.146	0.039	
189	1905 S St NW	12/12/2006	12/14/2006	0.007	0.002	

General Notes:

Data reported as zero may be non-detect or less than 0.0005 mg/L.

Collection dates may be reported as earlier than replacement date. WASA believes the customer recorded the date incorrectly because bottles are distributed at completion of replacement. Therefore the data are included in this table and not Table B.3.

Footnote:

- 1) When a sample has a lead concentration greater than 0.500 mg/L, WASA collects an additional three samples from the home. The Draw 3 sample represents the water from the main and is collected after running the cold water for at least 10 minutes.

Appendix C – Sample Kit Distribution

Tables C.1 and C.4 designate the sample sites as primary and secondary. Primary are those sites that participated prior to 2006, designated as ‘past participant’ in the 2006 LCR Plan. Secondary sites were added in the 2006 LCR Plan to provide extra addresses for possible sampling.

Table C.1 Sample Kit Distribution – July to December 2006

No.	Address	Primary/Secondary Site	Bottle Drop Date
1	202 11 th St SE	Primary	7/24/2006
2	1808 KEARNEY ST NE	Primary	7/24/2006
3	1812 14 TH ST SE	Primary	7/24/2006
4	1929 SUMMIT PL NE	Primary	7/24/2006
5	1937 BILTMORE ST NW	Primary	7/24/2006
6	1956 BILTMORE ST NW	Primary	7/24/2006
7	1971 BILTMORE ST NW	Primary	7/24/2006
8	2003 KLINGLE RD NW	Primary	7/24/2006
9	1802 35 TH ST NW	Primary	7/24/2006
10	2111 S ST NW	Primary	7/24/2006
11	2007 37 TH ST NW	Primary	7/24/2006
12	211 RANDOLPH PL NE	Primary	7/24/2006
13	2134 NEWPORT PL NW	Primary	7/24/2006
14	2237 CHESTER ST SE	Primary	7/24/2006
15	2238 HALL PL NW	Primary	7/24/2006
16	228 V ST NE	Primary	7/24/2006
17	2136 NEWPORT PL NW	Primary	7/24/2006
18	225 MISSISSIPPI AVE SE	Primary	7/24/2006
19	2007 KLINGLE RD NW	Primary	7/24/2006
20	1319 21 st ST NW	Primary	7/24/2006
21	2016 4 TH ST NE	Primary	7/24/2006
22	1145 OATES ST NE	Primary	7/24/2006
23	1746 KENYON ST NW	Primary	7/24/2006
24	1104 TRINIDAD AVE NE	Primary	7/24/2006
25	119 16 TH ST NE	Primary	7/24/2006
26	1262 COLUMBIA RD NW	Primary	7/24/2006
27	1319 POTOMAC AVE SE	Primary	7/24/2006
28	1353 JEFFERSON ST NW	Primary	7/24/2006
29	1400 FLORAL ST NW	Primary	7/24/2006
30	1612 V ST NW	Primary	7/24/2006
31	1649 HARVARD ST NW	Primary	7/24/2006
32	1214 SHEPHERD ST NW	Primary	7/24/2006

No.	Address	Primary/Secondary Site	Bottle Drop Date
33	1626 E ST SE	Primary	7/24/2006
34	1424 S ST SE	Primary	7/24/2006
35	1451 S ST NW	Primary	7/24/2006
36	143 UHLAND TER NE	Primary	7/24/2006
37	1420 S ST SE	Primary	7/24/2006
38	1407 MONTAGUE ST NW	Primary	7/24/2006
39	1635 WEBSTER ST NW	Primary	7/24/2006
40	821 BUCHANAN ST NW	Primary	8/25/2006
41	4131 YUMA ST NW	Primary	8/28/2006
42	331 RALEIGH ST SE	Primary	8/28/2006
43	3973 HARRISON ST NW	Primary	8/28/2006
44	4111 INGOMAR ST NW	Primary	8/28/2006
45	3424 PORTER ST NW	Primary	8/28/2006
46	3550 ALBEMARLE ST NW	Primary	8/28/2006
47	3618 PORTER ST NW	Primary	8/28/2006
48	3827 VEAZEY ST NW	Primary	8/28/2006
49	4230 FESSENDEN ST NW	Primary	8/28/2006
50	4305 38 TH ST NW	Primary	8/28/2006
51	4327 IOWA AVE NW	Primary	8/28/2006
52	2823 5 TH ST NE	Primary	8/28/2006
53	2830 BRENTWOOD RD NE	Primary	8/28/2006
54	2846 VISTA ST NE	Primary	8/28/2006
55	2435 33 RD ST SE	Primary	8/28/2006
56	3009 7 TH ST SE	Primary	8/28/2006
57	4307 CHESAPEAKE ST NW	Primary	8/28/2006
58	3634 WARDER ST NW	Primary	8/28/2006
59	3439 24 TH ST SE	Primary	8/28/2006
60	4326 FOREST LN NW	Primary	8/28/2006
61	311 ELM ST NW	Primary	8/28/2006
62	3408 LOWELL ST NW	Primary	8/28/2006
63	3720 NORTHAMPTON ST NW	Primary	8/28/2006
64	349 TENNESSEE AVE NE	Primary	8/28/2006
65	434 15 TH ST SE	Primary	8/28/2006
66	2702 P ST NW	Primary	8/28/2006
67	322 TENNESSEE AVE NE	Primary	8/28/2006
68	4413 GREENWICH PKWY NW	Primary	8/28/2006
69	3218 MACOMB ST NW	Primary	8/28/2006
70	4325 IOWA AVE NW	Primary	8/28/2006
71	3412 GARRISON ST NW	Primary	8/28/2006
72	2418 3 RD ST NE	Primary	8/28/2006

No.	Address	Primary/Secondary Site	Bottle Drop Date
73	3218 MORRISON ST NW	Primary	8/28/2006
74	3601 WARREN ST NW	Primary	8/28/2006
75	3908 13 TH ST NW	Primary	8/28/2006
76	4401 5 TH ST NW	Primary	8/28/2006
77	302 RITTENHOUSE ST NW	Primary	8/28/2006
78	1937 BILTMORE ST NW	Primary	8/28/2006
79	4331 BRANDYWINE ST NW	Primary	8/28/2006
80	1222 HAMILTON ST NW	Primary	9/25/2006
81	4818 ILLINOIS AVE NW	Primary	9/25/2006
82	4622 15 TH ST NW	Primary	9/25/2006
83	4609 30 TH ST NW	Primary	9/25/2006
84	4518 14 TH ST NW	Primary	9/25/2006
85	4507 13 TH ST NW	Primary	9/25/2006
86	1334 HEMLOCK ST NW	Primary	9/25/2006
87	4818 8 TH ST NW	Primary	9/25/2006
88	909 HAMLIN ST NE	Primary	9/25/2006
89	835 3 RD ST NE	Primary	9/25/2006
90	729 11 TH ST NE	Primary	9/25/2006
91	720 RHODE ISLAND AVE NE	Primary	9/25/2006
92	4616 HUNT PL NE	Primary	9/25/2006
93	1241 JACKSON ST NE	Primary	9/25/2006
94	1115 PARK ST NE	Primary	9/25/2006
95	1008 MARYLAND AVE NE	Primary	9/25/2006
96	5324 COLORADO AVE NW	Primary	9/25/2006
97	501 UPSHUR ST NW	Primary	9/25/2006
98	1016 DOUGLAS ST NE	Primary	9/25/2006
99	720 ALABAMA AVE SE	Primary	9/25/2006
100	811 BUTTERNUT ST NW	Primary	9/25/2006
101	5121 ILLINOIS AVE NW	Primary	9/25/2006
102	5229 7 TH ST NW	Primary	9/25/2006
103	926 14 TH ST SE	Primary	9/25/2006
104	704 ALABAMA AVE SE	Primary	9/25/2006
105	607 ATLANTIC ST SE	Primary	9/25/2006
106	532 13 TH ST SE	Primary	9/25/2006
107	514 13 th St SE	Primary	9/25/2006
108	1341 Massachusetts Ave SE	Primary	9/25/2006
109	1240 D ST SE	Primary	9/25/2006
110	5717 SHERIER PL NW	Primary	9/25/2006
111	805 LONGFELLOW ST NW	Primary	9/25/2006
112	5318 9 TH ST NW	Primary	9/25/2006

No.	Address	Primary/Secondary Site	Bottle Drop Date
113	5405 39 TH ST NW	Primary	9/25/2006
114	608 Gallatin St NW	Primary	9/25/2006
115	618 OTIS PL NW	Primary	9/25/2006
116	720 PARK RD NW	Primary	9/25/2006
117	747 GIRARD ST NW	Primary	9/25/2006
118	765 GIRARD ST NW	Primary	9/25/2006
119	1212 E Capitol St NE	Secondary	10/30/2006
120	1133 Park St NE	Secondary	10/30/2006
121	1207 Trinidad Ave NE	Secondary	10/30/2006
122	1204 Longfellow St NW	Secondary	10/30/2006
123	1203 Quincy St NW	Secondary	10/30/2006
124	119 11 th St NE	Secondary	10/30/2006
125	1211 Carrollsburg Pl SW	Secondary	10/30/2006
126	712 JEFFERSON ST NW	Primary	10/30/2006
127	1123 3 rd St NE	Secondary	10/30/2006
128	833 DECATUR ST NW	Primary	10/30/2006
129	1112 50 th St NE	Secondary	10/30/2006
130	1013 I St NE	Secondary	10/30/2006
131	1010 10 th St NE	Secondary	10/30/2006
132	1003 Quebec Pl NW	Secondary	10/30/2006
133	1217 Orren St NE	Secondary	10/30/2006
134	1312 V St SE	Secondary	10/30/2006
135	1121 C St SE	Secondary	10/30/2006
136	1931 SUMMIT PL NE	Primary	10/30/2006
137	1346 Madison St NW	Secondary	10/30/2006
138	106 7 TH ST NE	Secondary	10/30/2006
139	134 Bryant St NW	Secondary	10/30/2006
140	1339 Ives Pl SE	Secondary	10/30/2006
141	1331 Irving St NE	Secondary	10/30/2006
142	1330 Quincy St NW	Secondary	10/30/2006
143	1320 Delafield Pl NW	Secondary	10/30/2006
144	1302 Randolph St NW	Secondary	10/30/2006
145	1313 T St SE	Secondary	10/30/2006
146	1220 Kennedy St NW	Secondary	10/30/2006
147	1311 Floral St NW	Secondary	10/30/2006
148	6413 KANSAS AVE NE	Primary	10/30/2006
149	1301 Michigan Ave NE	Secondary	10/30/2006
150	125 Madison St NW	Secondary	10/30/2006
151	1231 F St NE	Secondary	10/30/2006
152	1224 Irving St NW	Secondary	10/30/2006

No.	Address	Primary/Secondary Site	Bottle Drop Date
153	1221 Pleasant St SE	Secondary	10/30/2006
154	1315 FRANKLIN ST NE	Secondary	10/30/2006
155	2634 GEORGIA AVE NW	Primary	10/30/2006
156	1216 Longfellow St NW	Secondary	10/30/2006
157	1351 Montague St NW	Secondary	10/30/2006
158	119 Kentucky Ave SE	Secondary	10/30/2006
159	1122 Oates St NE	Secondary	10/30/2006
160	1222 Decatur St NW	Secondary	10/30/2006
161	1231 17 th St NE	Secondary	10/30/2006
162	2823 28 TH ST NW	Primary	10/30/2006
163	1224 5 th St NE	Secondary	10/30/2006
164	1405 21 ST ST NW	Primary	10/30/2006
165	817 DECATUR ST NW	Primary	10/30/2006
166	1317 Otis St NE	Secondary	10/30/2006
167	101 14 th St NE	Secondary	10/30/2006
168	335 17 TH PL NE	Primary	10/30/2006
169	1339 U St SE	Secondary	10/30/2006
170	661 MARYLAND AVE NE	Primary	10/30/2006
171	1349 Wallach Pl NW	Secondary	10/30/2006
172	312 14 TH ST NE	Primary	10/30/2006
173	1863 MONROE ST NW	Primary	10/30/2006
174	545 PARK RD NW	Primary	10/30/2006
175	5301 RENO RD NW	Primary	10/30/2006
176	4332 BRANDYWINE ST NW	Primary	10/30/2006
177	3913 8 TH ST NW	Primary	10/30/2006
178	3809 ALTON PL NW	Primary	10/30/2006
179	3301 BROWN St NW	Primary	10/30/2006
180	3202 38 TH ST NW	Primary	10/30/2006
181	1202 Staples St NE	Secondary	10/30/2006
182	205 TAYLOR ST NW	Primary	10/30/2006
183	5404 39 TH ST NW	Primary	10/30/2006
184	1850 2 ND ST NW	Primary	10/30/2006
185	1843 MONROE ST NW	Primary	10/30/2006
186	1839 MONROE ST NW	Primary	10/30/2006
187	1815 MONROE ST NW	Primary	10/30/2006
188	1814 MONROE ST NW	Primary	10/30/2006
189	1701 INDEPENDENCE AVE SE	Primary	10/30/2006
190	6213 7 TH ST NW	Primary	10/30/2006
191	3030 44 TH ST NW	Primary	10/30/2006

Table C.2 Sample Kits Not Returned

Address	Bottle Drop Date
1937 BILTMORE ST NW	7/24/2006
2136 NEWPORT PL NW	7/24/2006
225 MISSISSIPPI AVE SE	7/24/2006
2111 S ST NW	7/24/2006
2237 CHESTER ST SE	7/24/2006
211 RANDOLPH PL NE	7/24/2006
228 V ST NE	7/24/2006
2007 KLINGLE RD NW	7/24/2006
1812 14TH ST SE	7/24/2006
1802 35TH ST NW	7/24/2006
1746 KENYON ST NW	7/24/2006
1407 MONTAGUE ST NW	7/24/2006
1214 SHEPHERD ST NW	7/24/2006
1424 S ST SE	7/24/2006
2016 4TH ST NE	7/24/2006
3720 NORTHAMPTON ST NW	8/28/2006
4230 FESSENDEN ST NW	8/28/2006
3218 MACOMB ST NW	8/28/2006
434 15TH ST SE	8/28/2006
2823 5TH ST NE	8/28/2006
5717 SHERIER PL NW	9/25/2006
1008 MARYLAND AVE NE	9/25/2006
4616 HUNT PL NE	9/25/2006
729 11TH ST NE	9/25/2006
720 ALABAMA AVE SE	9/25/2006
811 BUTTERNUT ST NW	9/25/2006
501 UPSHUR ST NW	9/25/2006
5121 ILLINOIS AVE NW	9/25/2006
720 PARK RD NW	9/25/2006
608 Gallatin St NW	9/25/2006
106 7TH ST NE	10/30/2006
6413 KANSAS AVE NE	10/30/2006
1312 V St SE	10/30/2006
1311 Floral St NW	10/30/2006
1302 Randolph St NW	10/30/2006
1221 Pleasant St SE	10/30/2006
1217 Orren St NE	10/30/2006
1211 Carrollsburg PI SW	10/30/2006

Address	Bottle Drop Date
1203 Quincy St NW	10/30/2006
1123 3rd St NE	10/30/2006
1122 Oates St NE	10/30/2006
833 DECATUR ST NW	10/30/2006
119 Kentucky Ave SE	10/30/2006
545 PARK RD NW	10/30/2006
3202 38TH ST NW	10/30/2006
3030 44TH ST NW	10/30/2006
2823 28TH ST NW	10/30/2006
1850 2ND ST NW	10/30/2006
1839 MONROE ST NW	10/30/2006
1815 MONROE ST NW	10/30/2006
1405 21ST ST NW	10/30/2006
1330 Quincy St NW	10/30/2006
1121 C St SE	10/30/2006

Table C.3 Samples Returned and Rejected for Compliance Analysis

Address	Bottle Drop Date	Reject Reason
1145 OATES ST NE	7/24/2006	Bottles blank & no information
311 ELM ST NW	8/28/2006	Leaks during stagnation period
3634 WARDER ST NW	8/28/2006	No first & second draw marked on bottles
3973 HARRISON ST NW	8/28/2006	No chain of custody
2846 VISTA ST NE	8/28/2006	Re-used bottles
2435 33RD ST SE	8/28/2006	Refilled/reused sample bottles
3439 24TH ST SE	8/28/2006	Long stagnation time
3009 7TH ST SE	8/28/2006	Could not determine stagnation time
331 RALEIGH ST SE	8/28/2006	Used water in b/w 1st and 2nd draws
4307 CHESAPEAKE ST NW	8/28/2006	Home is vacant, owner living elsewhere
720 RHODE ISLAND AVE NE	9/25/2006	No information
1334 HEMLOCK ST NW	9/25/2006	Leak
4507 13TH ST NW	9/25/2006	No paper work & bottles not marked
4818 8TH ST NW	9/25/2006	Used water
4818 ILLINOIS AVE NW	9/25/2006	Rejected filter unit not bypassed during sampling
618 OTIS PL NW	9/25/2006	Bottles marked differently then data recorded
747 GIRARD ST NW	9/25/2006	Full copper reported by customer.
661 MARYLAND AVE NE	10/30/2006	Toilet flush
1339 U St SE	10/30/2006	Bottles not marked
335 17TH PL NE	10/30/2006	COC not filled out
101 14th St NE	10/30/2006	No start time
1317 Otis St NE	10/30/2006	Stagnation time
817 DECATUR ST NW	10/30/2006	No COC
2634 GEORGIA AVE NW	10/30/2006	No COC
1224 5th St NE	10/30/2006	Stagnation time not known
312 14TH ST NE	10/30/2006	Bottles not marked
1231 17th St NE	10/30/2006	Stagnation time
1222 Decatur St NW	10/30/2006	Full replacement reported
1351 Montague St NW	10/30/2006	No start time
1216 Longfellow St NW	10/30/2006	No COC
1202 Staples St NE	10/30/2006	Sample collection was different date
5404 39TH ST NW	10/30/2006	Leak

Table C.4 Addresses Not Receiving Sample Kits July to December 2006

Address	Primary/Secondary Site	Reason¹
1207 Hamilton St NW	Secondary	Sampling completed
1228 Florida Ave NE	Secondary	Sampling completed
1236 HAMILTON ST NW	Secondary	Sampling completed
1249 Kenyon St NW	Secondary	Sampling completed
131 Randolph Pl NW	Secondary	Sampling completed
1337 Newton St NW	Secondary	Sampling completed
1353 Iris St NW	Secondary	Sampling completed
1354 W St SE	Secondary	Sampling completed
1357 C St NE	Secondary	Sampling completed
1365 Hamilton St NW	Secondary	Sampling completed
1371 Kalmia Rd NW	Secondary	Sampling completed
1371 Potomac Ave SE	Secondary	Sampling completed
1380 E ST NE	Secondary	Sampling completed
1387 N Carolina Ave NE	Secondary	Sampling completed
1409 35TH ST NW	Secondary	Sampling completed
1410 D St SE	Secondary	Sampling completed
1412 N Carolina Ave NE	Secondary	Sampling completed
1412 S St NW	Secondary	Sampling completed
1412 Shepherd St NW	Secondary	Sampling completed
1413 Whittier St NW	Secondary	Sampling completed
1424 Perry Pl NW	Secondary	Sampling completed
1424 S ST NW	Secondary	Sampling completed
1427 A St SE	Secondary	Sampling completed
1427 N CAROLINA AVE NE	Secondary	Sampling completed
1429 Ives Pl SE	Secondary	Sampling completed
1435 22nd St SE	Secondary	Sampling completed
1436 S St NW	Secondary	Sampling completed
144 Tennessee Ave NE	Secondary	Sampling completed
149 Todd Pl NE	Secondary	Sampling completed
150 W St NW	Secondary	Sampling completed
1505 Lawrence St NE	Secondary	Sampling completed
1506 ALLISON ST NW	Secondary	Sampling completed
1523 D St SE	Secondary	Sampling completed
1524 31st St NW	Secondary	Sampling completed
1525 D St NE	Secondary	Sampling completed
1533 Constitution Ave NE	Secondary	Sampling completed
1534 D St NE	Secondary	Sampling completed
1603 Hobart St NW	Secondary	Sampling completed
1603 Massachusetts Ave SE	Secondary	Sampling completed
1614 Allison St NW	Secondary	Sampling completed
1614 D St SE	Secondary	Sampling completed
1619 G St SE	Secondary	Sampling completed
1622 G St SE	Secondary	Sampling completed
1628 Argonne Pl NW	Secondary	Sampling completed
1656 U St SE	Secondary	Sampling completed

Address	Primary/Secondary Site	Reason¹
1671 Rosedale St NE	Secondary	Sampling completed
1705 2nd St NE	Secondary	Sampling completed
1706 NEW JERSEY AVE NW	Secondary	Sampling completed
1707 Irving St NW	Secondary	Sampling completed
1713 Seaton St NW	Secondary	Sampling completed
1714 Massachusetts Ave SE	Secondary	Sampling completed
1724 1st St NW	Secondary	Sampling completed
1728 SEATON ST NW	Secondary	Sampling completed
1731 L St NE	Secondary	Sampling completed
1736 Bay St SE	Secondary	Sampling completed
1747 Irving St NW	Secondary	Sampling completed
1749 Irving St NW	Secondary	Sampling completed
1755 Lanier PI NW	Secondary	Sampling completed
1802 Kilbourne PI NW	Secondary	Sampling completed
1804 Kenyon St NW	Secondary	Sampling completed
1811 Lamont St NW	Secondary	Sampling completed
1812 M St NE	Secondary	Sampling completed
1825 L St NE	Primary	Construction in front of house during sampling
1826 Jackson St NE	Secondary	Sampling completed
1830 Kenyon St NW	Secondary	Sampling completed
1836 L St NE	Secondary	Sampling completed
1836 Massachusetts Ave SE	Secondary	Sampling completed
1838 Calvert St NW	Secondary	Sampling completed
19 17th St SE	Secondary	Sampling completed
1908 Biltmore St NW	Secondary	Sampling completed
1920 Jackson St NE	Secondary	Sampling completed
1921 1st St NE	Secondary	Sampling completed
201 13th St NE	Secondary	Sampling completed
2010 3rd St NE	Secondary	Sampling completed
207 Quackenbos St NW	Secondary	Sampling completed
2107 2nd St NE	Secondary	Sampling completed
2110 S St NW	Secondary	Sampling completed
2118 14th St SE	Secondary	Sampling completed
216 17th St NE	Secondary	Sampling completed
2212 38th St NW	Secondary	Sampling completed
2214 14th St NW	Secondary	Sampling completed
2216 1st St NW	Secondary	Sampling completed
223 14th PI NE	Secondary	Sampling completed
224 S Carolina Ave SE	Secondary	Sampling completed
224 Varnum St NW	Secondary	Sampling completed
226 12th PI NE	Secondary	Sampling completed
228 Randolph PI NE	Secondary	Sampling completed
229 Tennessee Ave NE	Secondary	Sampling completed
230 G St NE	Secondary	Sampling completed
2300 MONROE ST NE	Secondary	Sampling completed
231 K St NE	Secondary	Sampling completed

Address	Primary/Secondary Site	Reason¹
234 Longfellow St NW	Secondary	Sampling completed
2404 3rd St NE	Secondary	Sampling completed
2408 2nd St NE	Secondary	Sampling completed
2421 3rd St NE	Secondary	Sampling completed
2431 Ontario Rd NW	Secondary	Sampling completed
2519 Ontario Rd NW	Secondary	Sampling completed
2521 P St NW	Secondary	Sampling completed
256 15th St SE	Secondary	Sampling completed
2604 Rhode Island Ave NE	Secondary	Sampling completed
2724 36TH PL NW	Secondary	Sampling completed
2912 S DAKOTA AVE NE	Secondary	Sampling completed
2919 Bellevue Ter NW	Secondary	Sampling completed
2928 33rd PI NW	Secondary	Sampling completed
300 E St NE	Secondary	Sampling completed
3001 7th St NE	Secondary	Sampling completed
3003 Porter St NW	Secondary	Sampling completed
3013 Sherman Ave NW	Secondary	Sampling completed
3014 Channing St NE	Secondary	Sampling completed
3059 Porter St NW	Secondary	Sampling completed
3069 Canal St NW	Secondary	Sampling completed
3104 Hawthorne St NW	Secondary	Sampling completed
3105 34th St NW	Secondary	Sampling completed
313 16th St SE	Secondary	Sampling completed
313 Aspen St NW	Secondary	Sampling completed
317 9th St SE	Secondary	Sampling completed
317 Channing St NE	Secondary	Sampling completed
319 Ingraham St NW	Secondary	Sampling completed
32 Todd PI NE	Secondary	Sampling completed
3201 Porter St NW	Secondary	Sampling completed
3206 38th St NW	Secondary	Sampling completed
3211 Central Ave NE	Secondary	Sampling completed
3215 Mckinley St NW	Secondary	Sampling completed
3223 Georgia Ave NW	Secondary	Sampling completed
3232 Klingle Rd NW	Secondary	Sampling completed
3309 16th St NW	Secondary	Sampling completed
331 Upshur St NW	Secondary	Sampling completed
3336 Quesada St NW	Secondary	Sampling completed
336 Quackenbos St NE	Secondary	Sampling completed
339 Randolph St NW	Secondary	Sampling completed
3400 Holmead PI NW	Secondary	Sampling completed
3416 9th St NE	Secondary	Sampling completed
3418 Oliver St NW	Secondary	Sampling completed
342 15th St SE	Secondary	Sampling completed
3427 Oliver St NW	Secondary	Sampling completed
3428 Brown St NW	Secondary	Sampling completed
3431 S Dakota Ave NE	Secondary	Sampling completed
3434 30th St NW	Secondary	Sampling completed

Address	Primary/Secondary Site	Reason¹
3520 35th St NW	Secondary	Sampling completed
3521 17th St NE	Secondary	Sampling completed
3526 Park PI NW	Secondary	Sampling completed
3529 16th St NW	Secondary	Sampling completed
3530 Porter St NW	Secondary	Sampling completed
3531 16TH ST NW	Secondary	Sampling completed
3545 Hertford PI NW	Secondary	Sampling completed
3665 13th St NW	Secondary	Sampling completed
37 R St NW	Secondary	Sampling completed
3700 Quebec St NW	Secondary	Sampling completed
3704 Porter St NW	Secondary	Sampling completed
3706 35th St NW	Secondary	Sampling completed
3709 S St NW	Secondary	Sampling completed
3710 Huntington St NW	Secondary	Sampling completed
3710 Massachusetts Ave NW	Secondary	Sampling completed
3712 Brandywine St NW	Secondary	Sampling completed
3721 Windom PI NW	Secondary	Sampling completed
3811 5th St NW	Secondary	Sampling completed
3907 13th St NW	Secondary	Sampling completed
3912 Benton St NW	Secondary	Sampling completed
3917 8th St NW	Secondary	Sampling completed
3917 LIVINGSTON ST NW	Secondary	Sampling completed
4013 8th St NW	Secondary	Sampling completed
403 K St NE	Secondary	Sampling completed
409 S Carolina Ave SE	Secondary	Sampling completed
410 Farragut St NW	Secondary	Sampling completed
4105 5th St NW	Secondary	Sampling completed
4120 Grant St NE	Secondary	Sampling completed
416 7th St NE	Secondary	Sampling completed
417 15th St SE	Secondary	Sampling completed
42 Q St NE	Secondary	Sampling completed
420 Kenyon St NW	Secondary	Sampling completed
4204 New Hampshire Ave NW	Secondary	Sampling completed
4206 10th St NE	Secondary	Sampling completed
4210 Clay St NE	Secondary	Sampling completed
4211 Illinois Ave NW	Secondary	Sampling completed
4215 39th St NW	Secondary	Sampling completed
424 Luray PI NW	Secondary	Sampling completed
427 15th St SE	Secondary	Sampling completed
4304 Fessenden St NW	Secondary	Sampling completed
433 Hamilton St NW	Secondary	Sampling completed
4409 Lowell St NW	Secondary	Sampling completed
441 Quincy St NW	Secondary	Sampling completed
4410 New Hampshire Ave NW	Secondary	Sampling completed
4411 Illinois Ave NW	Secondary	Sampling completed
4415 3rd St NW	Secondary	Sampling completed
4418 14th St NE	Secondary	Sampling completed

Address	Primary/Secondary Site	Reason¹
4419 14th St NE	Secondary	Sampling completed
4423 Kane PI NE	Secondary	Sampling completed
4429 3rd St NW	Secondary	Sampling completed
4433 14th St NE	Secondary	Sampling completed
4456 Reservoir Rd NW	Secondary	Sampling completed
452 Newton PI NW	Secondary	Sampling completed
4531 Georgia Ave NW	Secondary	Sampling completed
4550 30TH ST NW	Secondary	Sampling completed
4610 15th St NW	Secondary	Sampling completed
4613 9th St NW	Secondary	Sampling completed
4627 49th St NW	Secondary	Sampling completed
4700 Georgia Ave NW	Secondary	Sampling completed
4703 Macarthur Blvd NW	Secondary	Sampling completed
4711 9th St NW	Secondary	Sampling completed
4718 Sheriff Rd NE	Secondary	Sampling completed
4729 47TH ST NW	Secondary	Sampling completed
4821 Illinois Ave NW	Secondary	Sampling completed
4832 46th St NW	Secondary	Sampling completed
4842 KANSAS AVE NW	Secondary	Sampling completed
4906 9th St NW	Secondary	Sampling completed
4926 Glenbrook Rd NW	Secondary	Sampling completed
502 Oglethorpe St NW	Secondary	Sampling completed
506 Irving St NW	Secondary	Sampling completed
5105 14TH ST NW	Secondary	Sampling completed
513 Florida Ave NE	Secondary	Sampling completed
517 4th St SE	Secondary	Sampling completed
518 Varnum St NW	Secondary	Sampling completed
519 Rock Crk Church Rd NW	Secondary	Sampling completed
52 Galveston PI SW	Secondary	Sampling completed
522 Park Rd NW	Secondary	Sampling completed
525 6th St SE	Secondary	Sampling completed
53 V St NW	Secondary	Sampling completed
5304 Reno Rd NW	Secondary	Sampling completed
5409 13th St NW	Secondary	Sampling completed
5817 7th St NW	Secondary	Sampling completed
605 Columbia Rd NW	Secondary	Sampling completed
605 ROCK CRK CHURCH RD NW	Secondary	Sampling completed
61 S St NW	Secondary	Sampling completed
610 G St SE	Secondary	Sampling completed
610 L ST NE	Secondary	Sampling completed
612 ROCK CRK CHURCH RD NW	Secondary	Sampling completed
617 Kenyon St NW	Secondary	Sampling completed
617 M St NE	Secondary	Sampling completed
618 Franklin St NE	Secondary	Sampling completed
619 12th St NE	Secondary	Sampling completed
619 Oneida PI NW	Secondary	Sampling completed
623 Morton PI NE	Secondary	Sampling completed

Address	Primary/Secondary Site	Reason ¹
630 15th St NE	Secondary	Sampling completed
631 Lamont St NW	Secondary	Sampling completed
636 ROCK CRK CHURCH RD NW	Secondary	Sampling completed
641 Gallatin St NW	Secondary	Sampling completed
701 Quincy St NW	Secondary	Sampling completed
702 9th St SE	Secondary	Sampling completed
721 16th St NE	Secondary	Sampling completed
728 FARRAGUT ST NW	Secondary	Sampling completed
736 Fairmont St NW	Secondary	Sampling completed
743 Gresham PI NW	Secondary	Sampling completed
744 Quebec PI NW	Secondary	Sampling completed
75 P St NW	Secondary	Sampling completed
760 Gresham PI NW	Secondary	Sampling completed
768 Irving St NW	Secondary	Sampling completed
7705 13th St NW	Secondary	Sampling completed
7721 14th St NW	Secondary	Sampling completed
780 Fairmont St NW	Secondary	Sampling completed
804 Delafield PI NW	Secondary	Sampling completed
81 O St NW	Secondary	Sampling completed
810 Savannah St SE	Secondary	Sampling completed
812 Buchanan St NW	Secondary	Sampling completed
823 Euclid St NW	Secondary	Sampling completed
826 Emerson St NW	Secondary	Sampling completed
829 Euclid St NW	Secondary	Sampling completed
834 Delafield PI NW	Secondary	Sampling completed
88 R St NW	Secondary	Sampling completed
905 Kent PI NE	Secondary	Sampling completed
916 Farragut St NW	Secondary	Sampling completed
924 Hamilton St NW	Secondary	Sampling completed
926 Hamilton St NW	Secondary	Sampling completed
927 Hamilton St NW	Secondary	Sampling completed

¹WASA maintains a list of approximately 450 addresses for sampling, ordered by primary and secondary status and service line material. WASA completed compliance sampling prior to sampling all sites on the list. The sites noted as “sampling completed” are those locations we did not sample because the number of compliance samples exceeded 100.

Appendix D – Homes removed from Routine List

No	Address	Reason
1	1111 3rd St NE	Home vacant, noted in 10/06 sampling
2	1123 3rd St NE	Home vacant - returned notification letter and bottles untouched
3	1222 Decatur St NW	Public replaced in 9/06; customer reported private side replaced 11/06
4	1228 Carrollsburg PI SW	Full replacement in 3/06
5	1324 N CAROLINA AVE NE	Full replacement in 7/06
6	1413 Whittier St NW	Test pit in 10/06 showed copper on public side and leading to private
7	1427 N CAROLINA AVE NE	Public replaced in 7/06, private side galvanized
8	1713 Seaton St NW	Public replaced in 7/06, private side copper
9	1728 SEATON ST NW	Public and private sides replaced 6/06
10	1815 MONROE ST NW	Does not want to participate
11	2111 S St NW	Converted to apartment building, noted in 7/06 sampling
12	2136 Newport PI NW	Does not want to participate
13	216 17th St NE	Test pit in 7/06 showed copper on public and private sides
14	225 Mississippi Ave SE	Returned pre-sampling letter, no 2005/2006 bottles
15	2823 5TH ST NE	Have not returned bottles in 2005 or 2006
16	3710 Massachusetts Ave NW	Test pit in 10/06 showed copper on public side and leading to private
17	439 Luray PI NW	Complete home renovation noted on 5/06 Chain of Custody
18	4456 Reservoir Rd NW	Test pit in 10/06 showed copper on public side and leading to private
19	61 S St NW	Test pit in 12/06 showed copper on public and private sides
20	618 Evarts St NE	Complete home renovation noted on 5/06 Chain of Custody
21	630 15th St NE	Public replaced in 9/06, private side galvanized
22	6413 Kansas Ave NE	Test pit in 11/06 showed copper on public and private sides
23	747 Girard St NW	Full replacement in 7/06, private side noted by customer 9/06
24	811 BUTTERNUT ST NW	Does not want to participate
25	919 Constitution Ave NE	Does not want to participate
26	720 RHODE ISLAND AVE NE	Commercial building, verified 12/06
27	2634 GEORGIA AVE NW	Commercial building, verified 12/06