



Lead and Copper Compliance Report January through June 2011

Table 1 summarizes the District of Columbia Water and Sewer Authority's (DC Water) Lead and Copper compliance results for the monitoring period January through June 2011.

Table 1. Lead and Copper Summary Data

Number of Samples	
Lead	103
Copper	102
90th Percentile First Draw Concentrations	
Lead mg/L	0.005
Copper mg/L	0.124
Service Line Materials	
Full Lead	76%
Partial Lead	24%

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned and Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Order
 - Table C.5 Sites with Compliance Results from January 2010 – December 2010 and No Results in January - June 2011

- 6308 8th St NW Missing Copper Analysis Explanation
- Appendix D: Revisions to Sample Pool
 - Table D.1 Sample Pool for July to December 2011 Monitoring Period
 - Table D.2 Site Changes - Sites Removed, Added, or Priority Status Changed
 - Table D.3 Pipe Material Changes
- Appendix E: Revisions to Customer Sample Form and Monitoring Results Letters
- Attachment 1: Washington Aqueduct Test Results for LCR Compliance
- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Complaint investigations
 - Lead profiles
 - Metals analysis from chromium sample events
 - Post-LSR
- Attachment 3: Washington Aqueduct Laboratory Email Notification of 6308 8th St NW Analysis Error; and Letter to Customer
- Attachment 4: Revised Sample Form/Chain of Custody
- Attachment 5: Certification of Consumer Tap Results and Revised Monitoring Result Letters for July – December 2011

Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No	Address	Service Line Material	Collection Date	Lead (mg/L) 1st Draw
1	1025 44th St NE	Lead	1/26/2011	0.0000
2	1706 NEW JERSEY AVE NW	Lead	1/27/2011	0.0000
3	2724 36TH PL NW	Lead	2/23/2011	0.0000
4	2830 BRENTWOOD RD NE	Lead	2/23/2011	0.0000
5	307 7th St NE	Lead	2/24/2011	0.0000
6	313 Aspen St NW	Lead	2/24/2011	0.0000
7	317 9th St SE	Lead	2/24/2011	0.0000
8	349 TENNESSEE AVE NE	Lead	2/24/2011	0.0000
9	4210 Clay St NE	Lead	2/24/2011	0.0000
10	6308 8th St NW	Lead	3/23/2011	0.0000
11	6105 Dix St NE	Lead	3/24/2011	0.0000
12	1619 G St SE	Partial Lead	4/24/2011	0.0000
13	1353 JEFFERSON ST NW	Partial Lead	4/26/2011	0.0000
14	1222 HAMILTON ST NW	Partial Lead	4/27/2011	0.0000
15	1319 POTOMAC AVE SE	Partial Lead	4/27/2011	0.0000
16	1420 Hamlin St NE	Partial Lead	4/27/2011	0.0000
17	1505 Lawrence St NE	Partial Lead	4/27/2011	0.0000
18	3913 8TH ST NW	Partial Lead	4/27/2011	0.0000
19	413 4th St SE	Partial Lead	4/27/2011	0.0000
20	4332 BRANDYWINE ST NW	Partial Lead	4/27/2011	0.0000
21	75 Bates St NW	Lead	5/17/2011	0.0000
22	617 6th St NE	Lead	5/18/2011	0.0000
23	3036 P St NW	Partial Lead	5/19/2011	0.0000
24	5316 28th St NW	Partial Lead	5/19/2011	0.0000
25	331 RALEIGH ST SE	Lead	2/23/2011	0.0005
26	4409 Lowell St NW	Lead	3/22/2011	0.0005
27	5318 9TH ST NW	Lead	3/24/2011	0.0005
28	308 9th St SE	Partial Lead	4/26/2011	0.0005
29	1331 Irving St NE	Lead	1/26/2011	0.0006
30	1315 FRANKLIN ST NE	Lead	1/27/2011	0.0006
31	3601 WARREN ST NW	Lead	2/25/2011	0.0006
32	4824 46th St NW	Lead	3/22/2011	0.0006
33	4926 Glenbrook Rd NW	Lead	3/22/2011	0.0006
34	2823 28TH ST NW	Partial Lead	4/26/2011	0.0006
35	1339 Ives Pl SE	Lead	4/27/2011	0.0006

No	Address	Service Line Material	Collection Date	Lead (mg/L) 1st Draw
36	3033 Bladensburg Rd NE	Lead	5/18/2011	0.0006
37	810 Savannah St SE	Lead	5/19/2011	0.0006
38	3631 Ordway St NW	Partial Lead	4/27/2011	0.0007
39	3907 13th St NW	Partial Lead	4/27/2011	0.0007
40	4429 3rd St NW	Partial Lead	4/27/2011	0.0007
41	753 Gresham Pl NW	Lead	5/18/2011	0.0008
42	1346 Madison St NW	Lead	1/26/2011	0.0009
43	228 V St NE	Lead	3/22/2011	0.0009
44	4307 CHESAPEAKE ST NW	Lead	3/23/2011	0.0009
45	524 Shepherd St NW	Lead	3/23/2011	0.0009
46	4818 8th St NW	Partial Lead	4/27/2011	0.0009
47	5612 14th St NW	Lead	5/18/2011	0.0009
48	1409 22nd St SE	Lead	1/27/2011	0.0010
49	1826 Jackson St NE	Lead	1/27/2011	0.0010
50	3908 13TH ST NW	Lead	2/23/2011	0.0010
51	336 Quackenbos St NE	Lead	2/24/2011	0.0010
52	3973 HARRISON ST NW	Lead	2/25/2011	0.0010
53	4305 38TH ST NW	Lead	3/22/2011	0.0011
54	3917 8th St NW	Partial Lead	4/27/2011	0.0011
55	87 S St NW	Lead	5/17/2011	0.0011
56	1150 Abbey Pl NE	Lead	1/26/2011	0.0012
57	1203 Quincy St NW	Partial Lead	4/27/2011	0.0012
58	3215 McKinley St NW	Partial Lead	4/28/2011	0.0012
59	632 Webster St NW	Lead	5/17/2011	0.0012
60	1424 S St NW	Lead	1/27/2011	0.0013
61	3232 Klinge Rd NW	Lead	2/24/2011	0.0013
62	1620 Webster St NW	Lead	1/25/2011	0.0014
63	118 Kentucky Ave SE	Lead	1/26/2011	0.0014
64	1808 KEARNEY ST NE	Partial Lead	4/27/2011	0.0014
65	3618 PORTER ST NW	Lead	2/24/2011	0.0015
66	2212 38th St NW	Lead	2/26/2011	0.0015
67	636 ROCK CRK CHURCH RD NW	Lead	3/23/2011	0.0015
68	6001 33rd St NW	Lead	3/24/2011	0.0015
69	4111 INGOMAR ST NW	Lead	2/25/2011	0.0016
70	3531 16TH ST NW	Partial Lead	4/26/2011	0.0016
71	8 N St SW	Lead	5/17/2011	0.0016
72	1011 Taylor St NE	Lead	1/25/2011	0.0019
73	4401 5TH ST NW	Lead	3/22/2011	0.0019
74	3211 Central Ave NE	Lead	2/23/2011	0.0020
75	2435 33RD ST SE	Lead	2/25/2011	0.0020
76	5923 33rd St NW	Lead	3/23/2011	0.0020

No	Address	Service Line Material	Collection Date	Lead (mg/L) 1st Draw
77	912 Emerson St NW	Lead	5/18/2011	0.0020
78	3612 34th St NW	Lead	2/23/2011	0.0021
79	3301 BROWN St NW	Partial Lead	4/27/2011	0.0021
80	4310 37th St NW	Lead	3/23/2011	0.0022
81	3206 38th St NW	Lead	2/24/2011	0.0024
82	5517 7th St NW	Lead	5/19/2011	0.0024
83	5122 Cathedral Ave NW	Lead	3/22/2011	0.0026
84	3431 S Dakota Ave NE	Lead	2/25/2011	0.0027
85	702 9th St SE	Lead	4/27/2011	0.0027
86	7129 Georgia Ave NW	Lead	5/17/2011	0.0028
87	5234 Illinois Ave NW	Lead	4/27/2011	0.0032
88	143 UHLAND TER NE	Lead	1/26/2011	0.0033
89	1014 Douglas St NE	Lead	1/26/2011	0.0038
90	322 TENNESSEE AVE NE	Lead	2/24/2011	0.0038
91	144 Tennessee Ave NE	Lead	1/26/2011	0.0041
92	4418 14th St NE	Lead	5/18/2011	0.0042
93	3727 T St NW	Lead	2/23/2011	0.0049
94	5226 7th St NW	Lead	3/22/2011	0.0050
95	125 Madison St NW	Lead	1/25/2011	0.0053
96	1003 Quebec Pl NW	Lead	1/25/2011	0.0056
97	1802 35TH ST NW	Partial Lead	4/26/2011	0.0056
98	1611 Webster St NW	Lead	1/26/2011	0.0068
99	1623 U St SE	Lead	1/25/2011	0.0088
100	302 RITTENHOUSE ST NW	Partial Lead	4/27/2011	0.0108
101	4703 Macarthur Blvd NW	Lead	3/24/2011	0.0115
102	5731 3rd Pl NW	Lead	3/24/2011	0.0141
103	910 Farragut St NW	Lead	5/18/2011	0.0163

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.

Table A.2 First Draw Copper Results

No	Address	Service Line Material	Collection Date	Copper (mg/L) 1st Draw
1	4824 46th St NW	Lead	3/22/2011	0.003
2	636 ROCK CRK CHURCH RD NW	Lead	3/23/2011	0.003
3	1619 G St SE	Partial Lead	4/24/2011	0.004
4	1339 Ives Pl SE	Lead	4/27/2011	0.004
5	6105 Dix St NE	Lead	3/24/2011	0.005
6	912 Emerson St NW	Lead	5/18/2011	0.005
7	5226 7th St NW	Lead	3/22/2011	0.006
8	5731 3rd Pl NW	Lead	3/24/2011	0.006
9	308 9th St SE	Partial Lead	4/26/2011	0.007
10	1222 HAMILTON ST NW	Partial Lead	4/27/2011	0.007
11	810 Savannah St SE	Lead	5/19/2011	0.007
12	1331 Irving St NE	Lead	1/26/2011	0.008
13	1826 Jackson St NE	Lead	1/27/2011	0.008
14	4305 38TH ST NW	Lead	3/22/2011	0.008
15	2724 36TH PL NW	Lead	2/23/2011	0.010
16	3973 HARRISON ST NW	Lead	2/25/2011	0.010
17	1802 35TH ST NW	Partial Lead	4/26/2011	0.010
18	3215 McKinley St NW	Partial Lead	4/28/2011	0.011
19	313 Aspen St NW	Lead	2/24/2011	0.012
20	302 RITTENHOUSE ST NW	Partial Lead	4/27/2011	0.012
21	143 UHLAND TER NE	Lead	1/26/2011	0.014
22	317 9th St SE	Lead	2/24/2011	0.014
23	3913 8TH ST NW	Partial Lead	4/27/2011	0.014
24	4210 Clay St NE	Lead	2/24/2011	0.016
25	524 Shepherd St NW	Lead	3/23/2011	0.016
26	1203 Quincy St NW	Partial Lead	4/27/2011	0.016
27	1025 44th St NE	Lead	1/26/2011	0.018
28	1150 Abbey Pl NE	Lead	1/26/2011	0.018
29	331 RALEIGH ST SE	Lead	2/23/2011	0.018
30	228 V ST NE	Lead	3/22/2011	0.018
31	3531 16TH ST NW	Partial Lead	4/26/2011	0.018
32	1420 Hamlin St NE	Partial Lead	4/27/2011	0.018
33	3206 38th St NW	Lead	2/24/2011	0.019
34	3727 T St NW	Lead	2/23/2011	0.020
35	6001 33rd St NW	Lead	3/24/2011	0.020
36	3033 Bladensburg Rd NE	Lead	5/18/2011	0.021
37	1706 NEW JERSEY AVE NW	Lead	1/27/2011	0.022
38	2435 33RD ST SE	Lead	2/25/2011	0.022
39	413 4th St SE	Partial Lead	4/27/2011	0.022

No	Address	Service Line Material	Collection Date	Copper (mg/L) 1st Draw
40	5234 Illinois Ave NW	Lead	4/27/2011	0.022
41	3618 PORTER ST NW	Lead	2/24/2011	0.023
42	349 TENNESSEE AVE NE	Lead	2/24/2011	0.025
43	118 Kentucky Ave SE	Lead	1/26/2011	0.026
44	336 Quackenbos St NE	Lead	2/24/2011	0.026
45	4409 Lowell St NW	Lead	3/22/2011	0.026
46	125 Madison St NW	Lead	1/25/2011	0.027
47	4111 INGOMAR ST NW	Lead	2/25/2011	0.027
48	3431 S Dakota Ave NE	Lead	2/25/2011	0.028
49	4926 Glenbrook Rd NW	Lead	3/22/2011	0.029
50	144 Tennessee Ave NE	Lead	1/26/2011	0.030
51	322 TENNESSEE AVE NE	Lead	2/24/2011	0.030
52	1315 FRANKLIN ST NE	Lead	1/27/2011	0.031
53	4310 37th St NW	Lead	3/23/2011	0.032
54	4429 3rd St NW	Partial Lead	4/27/2011	0.032
55	1319 POTOMAC AVE SE	Partial Lead	4/27/2011	0.033
56	2212 38th St NW	Lead	2/26/2011	0.034
57	3601 WARREN ST NW	Lead	2/25/2011	0.035
58	307 7th St NE	Lead	2/24/2011	0.036
59	1011 Taylor St NE	Lead	1/25/2011	0.037
60	3232 Klinge Rd NW	Lead	2/24/2011	0.037
61	702 9th St SE	Lead	4/27/2011	0.038
62	4818 8th ST NW	Partial Lead	4/27/2011	0.041
63	4401 5TH ST NW	Lead	3/22/2011	0.043
64	1409 22nd St SE	Lead	1/27/2011	0.047
65	87 S St NW	Lead	5/17/2011	0.048
66	632 Webster St NW	Lead	5/17/2011	0.053
67	1353 JEFFERSON ST NW	Partial Lead	4/26/2011	0.055
68	1424 S ST NW	Lead	1/27/2011	0.056
69	7129 Georgia Ave NW	Lead	5/17/2011	0.056
70	3908 13TH ST NW	Lead	2/23/2011	0.057
71	1346 Madison St NW	Lead	1/26/2011	0.058
72	4418 14th St NE	Lead	5/18/2011	0.058
73	3301 BROWN St NW	Partial Lead	4/27/2011	0.059
74	1505 Lawrence St NE	Partial Lead	4/27/2011	0.060
75	4332 BRANDYWINE ST NW	Partial Lead	4/27/2011	0.060
76	617 6th St NE	Lead	5/18/2011	0.065
77	5122 Cathedral Ave NW	Lead	3/22/2011	0.067
78	4307 CHESAPEAKE ST NW	Lead	3/23/2011	0.067
79	3631 Ordway St NW	Partial Lead	4/27/2011	0.070
80	753 Gresham Pl NW	Lead	5/18/2011	0.072

No	Address	Service Line Material	Collection Date	Copper (mg/L) 1st Draw
81	8 N St SW	Lead	5/17/2011	0.073
82	3036 P St NW	Partial Lead	5/19/2011	0.073
83	3211 Central Ave NE	Lead	2/23/2011	0.077
84	1808 KEARNEY ST NE	Partial Lead	4/27/2011	0.078
85	3917 8th St NW	Partial Lead	4/27/2011	0.086
86	1620 Webster St NW	Lead	1/25/2011	0.089
87	3907 13th St NW	Partial Lead	4/27/2011	0.093
88	1611 Webster St NW	Lead	1/26/2011	0.096
89	75 Bates St NW	Lead	5/17/2011	0.096
90	1003 Quebec Pl NW	Lead	1/25/2011	0.103
91	2830 BRENTWOOD RD NE	Lead	2/23/2011	0.108
92	2823 28TH ST NW	Partial Lead	4/26/2011	0.124
93	910 Farragut St NW	Lead	5/18/2011	0.124
94	3612 34th St NW	Lead	2/23/2011	0.127
95	5923 33rd St NW	Lead	3/23/2011	0.131
96	1623 U St SE	Lead	1/25/2011	0.138
97	1014 Douglas St NE	Lead	1/26/2011	0.147
98	5318 9TH ST NW	Lead	3/24/2011	0.158
99	5517 7th St NW	Lead	5/19/2011	0.222
100	4703 Macarthur Blvd NW	Lead	3/24/2011	0.228
101	5612 14th St NW	Lead	5/18/2011	0.254
102	5316 28th St NW	Partial Lead	5/19/2011	0.312

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) The Washington Aqueduct laboratory made an error and did not analyze the samples from 6308 8th St NW for copper (see Appendix C for details). Therefore, Table A.2 has one less result than Table A.1.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No	Address	Service Line Material	Collection Date	Lead (mg/L) 2nd Draw
1	1025 44th St NE	Lead	1/26/2011	0.0000
2	1409 22nd St SE	Lead	1/27/2011	0.0000
3	1706 NEW JERSEY AVE NW	Lead	1/27/2011	0.0000
4	2724 36TH PL NW	Lead	2/23/2011	0.0000
5	2830 BRENTWOOD RD NE	Lead	2/23/2011	0.0000
6	3908 13TH ST NW	Lead	2/23/2011	0.0000
7	307 7th St NE	Lead	2/24/2011	0.0000
8	313 Aspen St NW	Lead	2/24/2011	0.0000
9	317 9th St SE	Lead	2/24/2011	0.0000
10	336 Quackenbos St NE	Lead	2/24/2011	0.0000
11	349 TENNESSEE AVE NE	Lead	2/24/2011	0.0000
12	4210 Clay St NE	Lead	2/24/2011	0.0000
13	4111 INGOMAR ST NW	Lead	2/25/2011	0.0000
14	4824 46th St NW	Lead	3/22/2011	0.0000
15	4926 Glenbrook Rd NW	Lead	3/22/2011	0.0000
16	6308 8th St NW	Lead	3/23/2011	0.0000
17	6105 Dix St NE	Lead	3/24/2011	0.0000
18	1619 G St SE	Partial Lead	4/24/2011	0.0000
19	1222 HAMILTON ST NW	Partial Lead	4/27/2011	0.0000
20	1319 POTOMAC AVE SE	Partial Lead	4/27/2011	0.0000
21	1339 Ives Pl SE	Lead	4/27/2011	0.0000
22	1420 Hamlin St NE	Partial Lead	4/27/2011	0.0000
23	1505 Lawrence St NE	Partial Lead	4/27/2011	0.0000
24	3631 Ordway St NW	Partial Lead	4/27/2011	0.0000
25	3913 8TH ST NW	Partial Lead	4/27/2011	0.0000
26	413 4th St SE	Partial Lead	4/27/2011	0.0000
27	4332 BRANDYWINE ST NW	Partial Lead	4/27/2011	0.0000
28	3215 Mckinley St NW	Partial Lead	4/28/2011	0.0000
29	75 Bates St NW	Lead	5/17/2011	0.0000
30	3036 P St NW	Partial Lead	5/19/2011	0.0000

No	Address	Service Line Material	Collection Date	Lead (mg/L) 2nd Draw
31	5923 33rd St NW	Lead	3/23/2011	0.0005
32	3033 Bladensburg Rd NE	Lead	5/18/2011	0.0005
33	1011 Taylor St NE	Lead	1/25/2011	0.0006
34	1346 Madison St NW	Lead	1/26/2011	0.0006
35	1315 FRANKLIN ST NE	Lead	1/27/2011	0.0007
36	3232 Klinge Rd NW	Lead	2/24/2011	0.0007
37	3431 S Dakota Ave NE	Lead	2/25/2011	0.0007
38	4307 CHESAPEAKE ST NW	Lead	3/23/2011	0.0007
39	308 9th St SE	Partial Lead	4/26/2011	0.0007
40	3907 13th St NW	Partial Lead	4/27/2011	0.0007
41	3601 WARREN ST NW	Lead	2/25/2011	0.0008
42	228 V ST NE	Lead	3/22/2011	0.0008
43	5612 14th St NW	Lead	5/18/2011	0.0008
44	753 Gresham Pl NW	Lead	5/18/2011	0.0008
45	1826 Jackson St NE	Lead	1/27/2011	0.0009
46	4409 Lowell St NW	Lead	3/22/2011	0.0009
47	524 Shepherd St NW	Lead	3/23/2011	0.0009
48	2823 28TH ST NW	Partial Lead	4/26/2011	0.0009
49	1203 Quincy St NW	Partial Lead	4/27/2011	0.0009
50	3917 8th St NW	Partial Lead	4/27/2011	0.0009
51	87 S St NW	Lead	5/17/2011	0.0009
52	1353 JEFFERSON ST NW	Partial Lead	4/26/2011	0.0010
53	3531 16TH ST NW	Partial Lead	4/26/2011	0.0010
54	3973 HARRISON ST NW	Lead	2/25/2011	0.0013
55	632 Webster St NW	Lead	5/17/2011	0.0013
56	1003 Quebec Pl NW	Lead	1/25/2011	0.0014
57	1331 Irving St NE	Lead	1/26/2011	0.0014
58	1808 KEARNEY ST NE	Partial Lead	4/27/2011	0.0014
59	617 6th St NE	Lead	5/18/2011	0.0014
60	2435 33RD ST SE	Lead	2/25/2011	0.0016
61	5517 7th St NW	Lead	5/19/2011	0.0016
62	4818 8th ST NW	Partial Lead	4/27/2011	0.0017
63	1014 Douglas St NE	Lead	1/26/2011	0.0018
64	4429 3rd St NW	Partial Lead	4/27/2011	0.0018
65	331 RALEIGH ST SE	Lead	2/23/2011	0.0019
66	1150 Abbey Pl NE	Lead	1/26/2011	0.0020
67	144 Tennessee Ave NE	Lead	1/26/2011	0.0020
68	3612 34th St NW	Lead	2/23/2011	0.0020
69	1802 35TH ST NW	Partial Lead	4/26/2011	0.0020
70	5316 28th St NW	Partial Lead	5/19/2011	0.0021
71	6001 33rd St NW	Lead	3/24/2011	0.0023

No	Address	Service Line Material	Collection Date	Lead (mg/L) 2nd Draw
72	2212 38th St NW	Lead	2/26/2011	0.0027
73	3206 38th St NW	Lead	2/24/2011	0.0028
74	4401 5TH ST NW	Lead	3/22/2011	0.0029
75	118 Kentucky Ave SE	Lead	1/26/2011	0.0030
76	1424 S ST NW	Lead	1/27/2011	0.0030
77	7129 Georgia Ave NW	Lead	5/17/2011	0.0030
78	8 N St SW	Lead	5/17/2011	0.0031
79	4310 37th St NW	Lead	3/23/2011	0.0032
80	4703 Macarthur Blvd NW	Lead	3/24/2011	0.0032
81	810 Savannah St SE	Lead	5/19/2011	0.0034
82	702 9th St SE	Lead	4/27/2011	0.0036
83	5234 Illinois Ave NW	Lead	4/27/2011	0.0039
84	3618 PORTER ST NW	Lead	2/24/2011	0.0043
85	1620 Webster St NW	Lead	1/25/2011	0.0044
86	912 Emerson St NW	Lead	5/18/2011	0.0048
87	4305 38TH ST NW	Lead	3/22/2011	0.0054
88	3301 BROWN St NW	Partial Lead	4/27/2011	0.0054
89	4418 14th St NE	Lead	5/18/2011	0.0055
90	1611 Webster St NW	Lead	1/26/2011	0.0058
91	636 ROCK CRK CHURCH RD NW	Lead	3/23/2011	0.0059
92	1623 U St SE	Lead	1/25/2011	0.0070
93	5226 7th St NW	Lead	3/22/2011	0.0070
94	125 Madison St NW	Lead	1/25/2011	0.0079
95	5122 Cathedral Ave NW	Lead	3/22/2011	0.0080
96	5731 3rd Pl NW	Lead	3/24/2011	0.0080
97	3727 T St NW	Lead	2/23/2011	0.0100
98	143 UHLAND TER NE	Lead	1/26/2011	0.0121
99	3211 Central Ave NE	Lead	2/23/2011	0.0136
100	910 Farragut St NW	Lead	5/18/2011	0.0142
101	302 RITTENHOUSE ST NW	Partial Lead	4/27/2011	0.0176
102	322 TENNESSEE AVE NE	Lead	2/24/2011	0.0287

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.
- 3) The second draw samples were rejected from 5318 9th St NW because they did not follow the sampling criteria as described in the instructions.

Table B.2 Second Draw Copper Results

No	Address	Service Line Material	Collection Date	Copper (mg/L) 2nd Draw
1	3618 PORTER ST NW	Lead	2/24/2011	0.002
2	3973 HARRISON ST NW	Lead	2/25/2011	0.003
3	4111 INGOMAR ST NW	Lead	2/25/2011	0.003
4	4824 46th St NW	Lead	3/22/2011	0.003
5	5731 3rd PI NW	Lead	3/24/2011	0.003
6	1339 Ives PI SE	Lead	4/27/2011	0.003
7	3431 S Dakota Ave NE	Lead	2/25/2011	0.004
8	228 V ST NE	Lead	3/22/2011	0.004
9	5226 7th St NW	Lead	3/22/2011	0.004
10	636 ROCK CRK CHURCH RD NW	Lead	3/23/2011	0.004
11	1420 Hamlin St NE	Partial Lead	4/27/2011	0.004
12	1826 Jackson St NE	Lead	1/27/2011	0.005
13	3601 WARREN ST NW	Lead	2/25/2011	0.005
14	4305 38TH ST NW	Lead	3/22/2011	0.005
15	6001 33rd St NW	Lead	3/24/2011	0.005
16	1409 22nd St SE	Lead	1/27/2011	0.006
17	331 RALEIGH ST SE	Lead	2/23/2011	0.006
18	1025 44th St NE	Lead	1/26/2011	0.007
19	118 Kentucky Ave SE	Lead	1/26/2011	0.007
20	1222 HAMILTON ST NW	Partial Lead	4/27/2011	0.007
21	702 9th St SE	Lead	4/27/2011	0.007
22	125 Madison St NW	Lead	1/25/2011	0.008
23	143 UHLAND TER NE	Lead	1/26/2011	0.008
24	3211 Central Ave NE	Lead	2/23/2011	0.008
25	336 Quackenbos St NE	Lead	2/24/2011	0.008
26	912 Emerson St NW	Lead	5/18/2011	0.008
27	313 Aspen St NW	Lead	2/24/2011	0.009
28	1319 POTOMAC AVE SE	Partial Lead	4/27/2011	0.009
29	1706 NEW JERSEY AVE NW	Lead	1/27/2011	0.010
30	3727 T St NW	Lead	2/23/2011	0.010
31	4310 37th St NW	Lead	3/23/2011	0.010
32	3531 16TH ST NW	Partial Lead	4/26/2011	0.010
33	3215 Mckinley St NW	Partial Lead	4/28/2011	0.010
34	1150 Abbey PI NE	Lead	1/26/2011	0.011
35	144 Tennessee Ave NE	Lead	1/26/2011	0.011
36	2435 33RD ST SE	Lead	2/25/2011	0.011
37	910 Farragut St NW	Lead	5/18/2011	0.011
38	3036 P St NW	Partial Lead	5/19/2011	0.011

No	Address	Service Line Material	Collection Date	Copper (mg/L) 2nd Draw
39	1011 Taylor St NE	Lead	1/25/2011	0.012
40	2724 36TH PL NW	Lead	2/23/2011	0.012
41	1619 G St SE	Partial Lead	4/24/2011	0.012
42	632 Webster St NW	Lead	5/17/2011	0.012
43	810 Savannah St SE	Lead	5/19/2011	0.012
44	1331 Irving St NE	Lead	1/26/2011	0.013
45	75 Bates St NW	Lead	5/17/2011	0.013
46	1623 U St SE	Lead	1/25/2011	0.014
47	4210 Clay St NE	Lead	2/24/2011	0.014
48	4409 Lowell St NW	Lead	3/22/2011	0.014
49	5122 Cathedral Ave NW	Lead	3/22/2011	0.014
50	302 RITTENHOUSE ST NW	Partial Lead	4/27/2011	0.014
51	413 4th St SE	Partial Lead	4/27/2011	0.015
52	4429 3rd St NW	Partial Lead	4/27/2011	0.015
53	4418 14th St NE	Lead	5/18/2011	0.015
54	3908 13TH ST NW	Lead	2/23/2011	0.016
55	307 7th St NE	Lead	2/24/2011	0.016
56	2212 38th St NW	Lead	2/26/2011	0.016
57	524 Shepherd St NW	Lead	3/23/2011	0.016
58	7129 Georgia Ave NW	Lead	5/17/2011	0.016
59	1424 S ST NW	Lead	1/27/2011	0.017
60	3301 BROWN St NW	Partial Lead	4/27/2011	0.018
61	3913 8TH ST NW	Partial Lead	4/27/2011	0.018
62	6105 Dix St NE	Lead	3/24/2011	0.019
63	5234 Illinois Ave NW	Lead	4/27/2011	0.019
64	4818 8th ST NW	Partial Lead	4/27/2011	0.021
65	1003 Quebec Pl NW	Lead	1/25/2011	0.022
66	1014 Douglas St NE	Lead	1/26/2011	0.022
67	3206 38th St NW	Lead	2/24/2011	0.023
68	87 S St NW	Lead	5/17/2011	0.023
69	5517 7th St NW	Lead	5/19/2011	0.023
70	1315 FRANKLIN ST NE	Lead	1/27/2011	0.024
71	4703 Macarthur Blvd NW	Lead	3/24/2011	0.024
72	308 9th St SE	Partial Lead	4/26/2011	0.024
73	3033 Bladensburg Rd NE	Lead	5/18/2011	0.026
74	4926 Glenbrook Rd NW	Lead	3/22/2011	0.028
75	617 6th St NE	Lead	5/18/2011	0.031
76	349 TENNESSEE AVE NE	Lead	2/24/2011	0.032
77	1802 35TH ST NW	Partial Lead	4/26/2011	0.032
78	1346 Madison St NW	Lead	1/26/2011	0.033
79	3232 Kingle Rd NW	Lead	2/24/2011	0.033

No	Address	Service Line Material	Collection Date	Copper (mg/L) 2nd Draw
80	3917 8th St NW	Partial Lead	4/27/2011	0.034
81	4401 5TH ST NW	Lead	3/22/2011	0.035
82	5923 33rd St NW	Lead	3/23/2011	0.037
83	1611 Webster St NW	Lead	1/26/2011	0.040
84	1203 Quincy St NW	Partial Lead	4/27/2011	0.042
85	2823 28TH ST NW	Partial Lead	4/26/2011	0.043
86	1353 JEFFERSON ST NW	Partial Lead	4/26/2011	0.046
87	8 N St SW	Lead	5/17/2011	0.046
88	1808 KEARNEY ST NE	Partial Lead	4/27/2011	0.049
89	4332 BRANDYWINE ST NW	Partial Lead	4/27/2011	0.051
90	753 Gresham Pl NW	Lead	5/18/2011	0.056
91	1620 Webster St NW	Lead	1/25/2011	0.059
92	1505 Lawrence St NE	Partial Lead	4/27/2011	0.059
93	3612 34th St NW	Lead	2/23/2011	0.061
94	4307 CHESAPEAKE ST NW	Lead	3/23/2011	0.061
95	3907 13th St NW	Partial Lead	4/27/2011	0.070
96	3631 Ordway St NW	Partial Lead	4/27/2011	0.081
97	2830 BRENTWOOD RD NE	Lead	2/23/2011	0.084
98	317 9th St SE	Lead	2/24/2011	0.085
99	5612 14th St NW	Lead	5/18/2011	0.116
100	322 TENNESSEE AVE NE	Lead	2/24/2011	0.120
101	5316 28th St NW	Partial Lead	5/19/2011	0.203

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) The second draw samples were rejected from 5318 9th St NW because they did not follow the sampling criteria as described in the instructions.
- 3) The Washington Aqueduct laboratory made an error and did not analyze the samples from 6308 8th St NW for copper (see Appendix C for details). Therefore, Table B.2 has one less result than Table B.1.

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No	Address	Bottle Drop Date
1	10 Evarts St NE	1/24/2011
2	10 S St NW	1/24/2011
3	1003 Otis St NE	1/24/2011
4	1003 Quebec Pl NW	1/24/2011
5	1010 10th St NE	1/24/2011
6	1011 Taylor St NE	1/24/2011
7	1014 Douglas St NE	1/24/2011
8	1025 44th St NE	1/24/2011
9	104 17th St SE	1/24/2011
10	108 Varnum St NW	1/24/2011
11	1106 Allison St NW	1/24/2011
12	1150 Abbey Pl NE	1/24/2011
13	118 Kentucky Ave SE	1/24/2011
14	119 16TH ST NE	1/24/2011
15	1212 E Capitol St NE	1/24/2011
16	125 Madison St NW	1/24/2011
17	1262 COLUMBIA RD NW	1/24/2011
18	1302 Randolph St NW	1/24/2011
19	1315 FRANKLIN ST NE	1/24/2011
20	1317 Otis St NE	1/24/2011
21	1320 Allison St NE	1/24/2011
22	1331 Irving St NE	1/24/2011
23	1334 Randolph St NE	1/24/2011
24	1339 U St SE	1/24/2011
25	1346 Madison St NW	1/24/2011
26	1357 C St NE	1/24/2011
27	1400 FLORAL ST NW	1/24/2011
28	1409 22nd St SE	1/24/2011
29	1424 S ST NW	1/24/2011
30	1429 Ives Pl SE	1/24/2011
31	143 UHLAND TER NE	1/24/2011
32	1434 Taylor St NW	1/24/2011
33	1436 S St NW	1/24/2011
34	144 Tennessee Ave NE	1/24/2011
35	15 Milmarson Pl NW	1/24/2011
36	1507 Buchanan St NW	1/24/2011
37	1525 D St NE	1/24/2011
38	1533 Upshur St NW	1/24/2011

No	Address	Bottle Drop Date
39	1611 Webster St NW	1/24/2011
40	1620 Webster St NW	1/24/2011
41	1623 U St SE	1/24/2011
42	1635 WEBSTER ST NW	1/24/2011
43	1703 D St NE	1/24/2011
44	1705 2nd St NE	1/24/2011
45	1706 NEW JERSEY AVE NW	1/24/2011
46	1826 Jackson St NE	1/24/2011
47	2007 37TH ST NW	1/24/2011
48	2107 2nd St NE	2/22/2011
49	2121 15th St NW	2/22/2011
50	213 49th St NE	2/22/2011
51	2138 O St NW	2/22/2011
52	2212 38th St NW	2/22/2011
53	2300 Woodridge St NE	2/22/2011
54	24 Evarts St NE	2/22/2011
55	2435 33RD ST SE	2/22/2011
56	258 15th St SE	2/22/2011
57	2604 Rhode Island Ave NE	2/22/2011
58	2649 Bowen Rd SE	2/22/2011
59	2724 36TH PL NW	2/22/2011
60	2830 BRENTWOOD RD NE	2/22/2011
61	307 7th St NE	2/22/2011
62	313 Aspen St NW	2/22/2011
63	317 9th St SE	2/22/2011
64	3206 38th St NW	2/22/2011
65	321 Aspen St NW	2/22/2011
66	3211 Central Ave NE	2/22/2011
67	3216 Klinge Rd NW	2/22/2011
68	3217 Georgia Ave NW	2/22/2011
69	3218 MACOMB ST NW	2/22/2011
70	3218 MORRISON ST NW	2/22/2011
71	322 TENNESSEE AVE NE	2/22/2011
72	3232 Klinge Rd NW	2/22/2011
73	331 RALEIGH ST SE	2/22/2011
74	331 Upshur St NW	2/22/2011
75	336 Quackenbos St NE	2/22/2011
76	3361 Stuyvesant Pl NW	2/22/2011
77	3400 Holmead Pl NW	2/22/2011
78	3427 Oliver St NW	2/22/2011
79	3431 S Dakota Ave NE	2/22/2011
80	349 TENNESSEE AVE NE	2/22/2011

No	Address	Bottle Drop Date
81	3511 Woodley Rd NW	2/22/2011
82	3601 WARREN ST NW	2/22/2011
83	3612 34th St NW	2/22/2011
84	3618 PORTER ST NW	2/22/2011
85	3706 35th St NW	2/22/2011
86	3710 Huntington St NW	2/22/2011
87	3727 T St NW	2/22/2011
88	3805 Blaine St NE	2/22/2011
89	3908 13TH ST NW	2/22/2011
90	3973 HARRISON ST NW	2/22/2011
91	410 Farragut St NW	2/22/2011
92	4111 INGOMAR ST NW	2/22/2011
93	4120 Grant St NE	2/22/2011
94	4131 YUMA ST NW	2/22/2011
95	416 7th St NE	2/22/2011
96	4210 Clay St NE	2/22/2011
97	2138 O St NW	3/21/2011
98	228 V ST NE	3/21/2011
99	4214 8th St NW	3/21/2011
100	424 Luray Pl NW	3/21/2011
101	4305 38TH ST NW	3/21/2011
102	4307 CHESAPEAKE ST NW	3/21/2011
103	4310 37th St NW	3/21/2011
104	4401 5TH ST NW	3/21/2011
105	4409 Lowell St NW	3/21/2011
106	4411 15th St NW	3/21/2011
107	4419 14th St NE	3/21/2011
108	449 S St NW	3/21/2011
109	452 Newton Pl NW	3/21/2011
110	4550 30TH ST NW	3/21/2011
111	4609 5th St NW	3/21/2011
112	4613 9th St NW	3/21/2011
113	4627 49th St NW	3/21/2011
114	4700 Georgia Ave NW	3/21/2011
115	4703 Macarthur Blvd NW	3/21/2011
116	4818 ILLINOIS AVE NW	3/21/2011
117	4821 Illinois Ave NW	3/21/2011
118	4824 46th St NW	3/21/2011
119	4926 Glenbrook Rd NW	3/21/2011
120	501 Webster St NW	3/21/2011
121	5024 7th St NW	3/21/2011
122	507 Alabama Ave SE	3/21/2011

No	Address	Bottle Drop Date
123	5122 Cathedral Ave NW	3/21/2011
124	5226 7th St NW	3/21/2011
125	5234 Illinois Ave NW	3/21/2011
126	524 Shepherd St NW	3/21/2011
127	5318 9TH ST NW	3/21/2011
128	5516 Kansas Ave NW	3/21/2011
129	5731 3rd Pl NW	3/21/2011
130	580 49th Pl NE	3/21/2011
131	5817 7th St NW	3/21/2011
132	5907 4th St NW	3/21/2011
133	5909 16th St NW	3/21/2011
134	5923 33rd St NW	3/21/2011
135	6001 33rd St NW	3/21/2011
136	6105 Dix St NE	3/21/2011
137	611 Roxboro Pl NW	3/21/2011
138	617 M St NE	3/21/2011
139	619 12th St NE	3/21/2011
140	621 Upshur St NW	3/21/2011
141	6210 8th St NW	3/21/2011
142	6308 8th St NW	3/21/2011
143	631 Lamont St NW	3/21/2011
144	636 ROCK CRK CHURCH RD NW	3/21/2011
145	641 Gallatin St NW	3/21/2011
146	104 15th St SE	4/25/2011
147	1203 Quincy St NW	4/25/2011
148	1211 Carrollsburg Pl SW	4/25/2011
149	1214 Evarts St NE	4/25/2011
150	1222 HAMILTON ST NW	4/25/2011
151	1238 HALF ST SW	4/25/2011
152	1319 POTOMAC AVE SE	4/25/2011
153	1339 Ives Pl SE	4/25/2011
154	1349 Wallach Pl NW	4/25/2011
155	1353 JEFFERSON ST NW	4/25/2011
156	1371 Monroe St NW	4/25/2011
157	1387 N Carolina Ave NE	4/25/2011
158	1412 Allison St NW	4/25/2011
159	1420 Hamlin St NE	4/25/2011
160	1427 Montague St NW	4/25/2011
161	1453 S St NW	4/25/2011
162	1505 Lawrence St NE	4/25/2011
163	1603 Massachusetts Ave SE	4/25/2011
164	1607 KEARNY ST NE	4/25/2011

No	Address	Bottle Drop Date
165	1619 G St SE	4/25/2011
166	1620 Hamlin St NE	4/25/2011
167	1671 Rosedale St NE	4/25/2011
168	1731 L St NE	4/25/2011
169	1736 Bay St SE	4/25/2011
170	1801 1st St NW	4/25/2011
171	1802 35TH ST NW	4/25/2011
172	1808 KEARNEY ST NE	4/25/2011
173	1811 Lamont St NW	4/25/2011
174	2118 14th St SE	4/25/2011
175	2132 37th St NW	4/25/2011
176	2214 1st St NW	4/25/2011
177	226 12th PI NE	4/25/2011
178	2305 Minnesota Ave SE	4/25/2011
179	2823 28TH ST NW	4/25/2011
180	302 RITTENHOUSE ST NW	4/25/2011
181	3036 P St NW	4/25/2011
182	308 9th St SE	4/25/2011
183	3215 Mckinley St NW	4/25/2011
184	3301 BROWN St NW	4/25/2011
185	3416 9th St NE	4/25/2011
186	3531 16TH ST NW	4/25/2011
187	3631 Ordway St NW	4/25/2011
188	3907 13th St NW	4/25/2011
189	3913 8TH ST NW	4/25/2011
190	3917 8th St NW	4/25/2011
191	413 4th St SE	4/25/2011
192	4327 IOWA AVE NW	4/25/2011
193	4332 BRANDYWINE ST NW	4/25/2011
194	4429 3rd St NW	4/25/2011
195	4818 8th ST NW	4/25/2011
196	517 4th St SE	4/25/2011
197	5234 Illinois Ave NW	4/25/2011
198	580 49th PI NE	4/25/2011
199	6213 7TH ST NW	4/25/2011
200	702 9th St SE	4/25/2011
201	75 P St NW	4/25/2011
202	804 Delafield PI NW	4/25/2011
203	821 BUCHANAN ST NW	4/25/2011
204	826 Emerson St NW	4/25/2011
205	834 Delafield PI NW	4/25/2011
206	926 Hamilton St NW	4/25/2011

No	Address	Bottle Drop Date
207	1217 Orren St NE	5/16/2011
208	1223 Pleasant St SE	5/16/2011
209	1301 Michigan Ave NE	5/16/2011
210	1337 Newton St NW	5/16/2011
211	1353 Iris St NW	5/16/2011
212	2300 MONROE ST NE	5/16/2011
213	25 17th St SE	5/16/2011
214	2913 Brandywine St NW	5/16/2011
215	3014 8th St SE	5/16/2011
216	3033 Bladensburg Rd NE	5/16/2011
217	3524 Park Pl NW	5/16/2011
218	3533 W Pl NW	5/16/2011
219	3634 WARDER ST NW	5/16/2011
220	417 15th St SE	5/16/2011
221	432 15th St SE	5/16/2011
222	4418 14th St NE	5/16/2011
223	4507 13TH ST NW	5/16/2011
224	4606 Sheriff Rd NE	5/16/2011
225	4718 Sheriff Rd NE	5/16/2011
226	4842 KANSAS AVE NW	5/16/2011
227	4906 9th St NW	5/16/2011
228	519 Rock Crk Church Rd NW	5/16/2011
229	53 P St NW	5/16/2011
230	5316 28th St NW	5/16/2011
231	5328 Kansas Ave NW	5/16/2011
232	536 Newton Pl NW	5/16/2011
233	5404 Kansas Ave NW	5/16/2011
234	5517 7th St NW	5/16/2011
235	5612 14th St NW	5/16/2011
236	6001 Nevada Ave NW	5/16/2011
237	608 Gallatin St NW	5/16/2011
238	610 L ST NE	5/16/2011
239	612 ROCK CRK CHURCH RD NW	5/16/2011
240	617 6th St NE	5/16/2011
241	619 Girard St NE	5/16/2011
242	6203 Piney Branch Rd NW	5/16/2011
243	632 Webster St NW	5/16/2011
244	644 Lamont St NW	5/16/2011
245	7129 Georgia Ave NW	5/16/2011
246	720 ALABAMA AVE SE	5/16/2011
247	728 FARRAGUT ST NW	5/16/2011
248	743 Gresham Pl NW	5/16/2011

No	Address	Bottle Drop Date
249	75 Bates St NW	5/16/2011
250	753 Gresham Pl NW	5/16/2011
251	760 Gresham Pl NW	5/16/2011
252	8 N St SW	5/16/2011
253	804 Delafield Pl NW	5/16/2011
254	81 O St NW	5/16/2011
255	810 Savannah St SE	5/16/2011
256	811 E St SE	5/16/2011
257	812 Buchanan St NW	5/16/2011
258	822 K St NE	5/16/2011
259	87 S St NW	5/16/2011
260	88 R St NW	5/16/2011
261	905 Kent Pl NE	5/16/2011
262	910 Farragut St NW	5/16/2011
263	912 Emerson St NW	5/16/2011
264	915 Farragut St NW	5/16/2011
265	915 Shepherd St NW	5/16/2011

Table C.2 Sample Kits Not Returned

No	Address	Bottle Drop Date
1	10 Evarts St NE	1/24/2011
2	10 S St NW	1/24/2011
3	104 15th St SE	4/25/2011
4	104 17th St SE	1/24/2011
5	1106 Allison St NW	1/24/2011
6	1211 Carrollsburg PI SW	4/25/2011
7	1217 Orren St NE	5/16/2011
8	1238 HALF ST SW	4/25/2011
9	1301 Michigan Ave NE	5/16/2011
10	1302 Randolph St NW	1/24/2011
11	1317 Otis St NE	1/24/2011
12	1320 Allison St NE	1/24/2011
13	1334 Randolph St NE	1/24/2011
14	1337 Newton St NW	5/16/2011
15	1349 Wallach PI NW	4/25/2011
16	1357 C St NE	1/24/2011
17	1371 Monroe St NW	4/25/2011
18	1387 N Carolina Ave NE	4/25/2011
19	1400 FLORAL ST NW	1/24/2011
20	1412 Allison St NW	4/25/2011
21	1427 Montague St NW	4/25/2011
22	1429 Ives PI SE	1/24/2011
23	1434 Taylor St NW	1/24/2011
24	1507 Buchanan St NW	1/24/2011
25	1607 KEARNY ST NE	4/25/2011
26	1703 D St NE	1/24/2011
27	1705 2nd St NE	1/24/2011
28	1736 Bay St SE	4/25/2011
29	1801 1st St NW	4/25/2011
30	1811 Lamont St NW	4/25/2011
31	2107 2nd St NE	2/22/2011
32	2118 14th St SE	4/25/2011
33	2121 15th St NW	2/22/2011
34	2132 37th St NW	4/25/2011
35	2214 1st St NW	4/25/2011
36	226 12th PI NE	4/25/2011

No	Address	Bottle Drop Date
37	2300 MONROE ST NE	5/16/2011
38	2300 Woodridge St NE	2/22/2011
39	24 Evarts St NE	2/22/2011
40	25 17th St SE	5/16/2011
41	258 15th St SE	2/22/2011
42	2604 Rhode Island Ave NE	2/22/2011
43	2649 Bowen Rd SE	2/22/2011
44	2913 Brandywine St NW	5/16/2011
45	3014 8th St SE	5/16/2011
46	321 Aspen St NW	2/22/2011
47	3216 Klinge Rd NW	2/22/2011
48	3217 Georgia Ave NW	2/22/2011
49	3218 MACOMB ST NW	2/22/2011
50	3218 MORRISON ST NW	2/22/2011
51	3361 Stuyvesant Pl NW	2/22/2011
52	3416 9th St NE	4/25/2011
53	3427 Oliver St NW	2/22/2011
54	3511 Woodley Rd NW	2/22/2011
55	3524 Park Pl NW	5/16/2011
56	3533 W Pl NW	5/16/2011
57	3634 WARDER ST NW	5/16/2011
58	3706 35th St NW	2/22/2011
59	3710 Huntington St NW	2/22/2011
60	4131 YUMA ST NW	2/22/2011
61	417 15th St SE	5/16/2011
62	424 Luray Pl NW	3/21/2011
63	4411 15th St NW	3/21/2011
64	4419 14th St NE	3/21/2011
65	4507 13TH ST NW	5/16/2011
66	452 Newton Pl NW	3/21/2011
67	4550 30TH ST NW	3/21/2011
68	4606 Sheriff Rd NE	5/16/2011
69	4700 Georgia Ave NW	3/21/2011
70	4818 ILLINOIS AVE NW	3/21/2011
71	4842 KANSAS AVE NW	5/16/2011
72	4906 9th St NW	5/16/2011
73	507 Alabama Ave SE	3/21/2011
74	5328 Kansas Ave NW	5/16/2011
75	536 Newton Pl NW	5/16/2011

No	Address	Bottle Drop Date
76	5404 Kansas Ave NW	5/16/2011
77	5817 7th St NW	3/21/2011
78	5907 4th St NW	3/21/2011
79	5909 16th St NW	3/21/2011
80	6001 Nevada Ave NW	5/16/2011
81	610 L ST NE	5/16/2011
82	611 Roxboro Pl NW	3/21/2011
83	612 ROCK CRK CHURCH RD NW	5/16/2011
84	617 M St NE	3/21/2011
85	619 Girard St NE	5/16/2011
86	728 FARRAGUT ST NW	5/16/2011
87	743 Gresham Pl NW	5/16/2011
88	75 P St NW	4/25/2011
89	812 Buchanan St NW	5/16/2011
90	88 R St NW	5/16/2011
91	915 Farragut St NW	5/16/2011
92	915 Shepherd St NW	5/16/2011

Table C.3 Samples Returned and Rejected for Compliance Analysis

No	Address	Bottle Drop Date	Reject Reason
1	1003 Otis St NE	1/24/2011	No sample collection time
2	1010 10th St NE	1/24/2011	Leaks in plumbing
3	108 Varnum St NW	1/24/2011	>18 hours stagnation
4	119 16TH ST NE	1/24/2011	Water used during stagnation period
5	1212 E Capitol St NE	1/24/2011	>18 hours stagnation
6	1214 Evarts St NE	4/25/2011	Ice maker in use
7	1223 Pleasant St SE	5/16/2011	Stagnation < 6 hours
8	1262 COLUMBIA RD NW	1/24/2011	Leaks in plumbing
9	1339 U St SE	1/24/2011	Chain of custody not provided
10	1353 Iris St NW	5/16/2011	Stagnation < 6 hours
11	1436 S St NW	1/24/2011	Ice maker in use
12	1453 S St NW	4/25/2011	Stagnation < 6 hours
13	15 Milmarson PI NW	1/24/2011	Leaks in plumbing
14	1525 D St NE	1/24/2011	Stagnation < 6 hours
15	1533 Upshur St NW	1/24/2011	Ice maker in use
16	1603 Massachusetts Ave SE	4/25/2011	Chain of custody incomplete
17	1620 Hamlin St NE	4/25/2011	Chain of custody incomplete
18	1635 WEBSTER ST NW	1/24/2011	Chain of custody incomplete
19	1671 Rosedale St NE	4/25/2011	Stagnation < 6 hours
20	1731 L St NE	4/25/2011	Stagnation < 6 hours
21	2007 37TH ST NW	1/24/2011	Draw # not marked on bottles
22	213 49th St NE	2/22/2011	Chain of custody incomplete
23	2138 O St NW	2/22/2011	>18 hours stagnation
24	2138 O St NW	3/21/2011	Multi-family
25	2305 Minnesota Ave SE	4/25/2011	Chain of custody incomplete
26	331 Upshur St NW	2/22/2011	Bottles not full
27	3400 Holmead PI NW	2/22/2011	Chain of custody incomplete
28	3805 Blaine St NE	2/22/2011	Chain of custody incomplete
29	410 Farragut St NW	2/22/2011	Chain of custody incomplete
30	4120 Grant St NE	2/22/2011	Stagnation unknown
31	416 7th St NE	2/22/2011	Water used during stagnation period
32	4214 8th St NW	3/21/2011	Stagnation < 6 hours
33	432 15th St SE	5/16/2011	Stagnation < 6 hours
34	4327 IOWA AVE NW	4/25/2011	Ice maker in use
35	449 S St NW	3/21/2011	Leaks in plumbing
36	4609 5th St NW	3/21/2011	No sample collection time

No	Address	Bottle Drop Date	Reject Reason
37	4613 9th St NW	3/21/2011	Chain of custody not provided
38	4627 49th St NW	3/21/2011	Water used during stagnation period
39	4718 Sheriff Rd NE	5/16/2011	Draw # not marked on bottles
40	4821 Illinois Ave NW	3/21/2011	Chain of custody incomplete
41	501 Webster St NW	3/21/2011	Stagnation unknown
42	5024 7th St NW	3/21/2011	Chain of custody incomplete
43	517 4th St SE	4/25/2011	Stagnation unknown
44	519 Rock Crk Church Rd NW	5/16/2011	Chain of custody not provided
45	5234 Illinois Ave NW	3/21/2011	>18 hours stagnation
46	53 P St NW	5/16/2011	Chain of custody not provided
47	5516 Kansas Ave NW	3/21/2011	Leaks in plumbing
48	580 49th PI NE	3/21/2011	>18 hours stagnation
49	580 49th PI NE	4/25/2011	Water used during stagnation period
50	608 Gallatin St NW	5/16/2011	Filter was not bypassed
51	619 12th St NE	3/21/2011	Chain of custody not provided
52	6203 Piney Branch Rd NW	5/16/2011	Chain of custody incomplete
53	621 Upshur St NW	3/21/2011	Chain of custody incomplete
54	6210 8th St NW	3/21/2011	Draw # not marked on bottles
55	6213 7TH ST NW	4/25/2011	>18 hours stagnation
56	631 Lamont St NW	3/21/2011	Draw # not marked on bottles
57	641 Gallatin St NW	3/21/2011	Leaks in plumbing
58	644 Lamont St NW	5/16/2011	Stagnation < 6 hours
59	720 ALABAMA AVE SE	5/16/2011	Ice maker in use
60	760 Gresham PI NW	5/16/2011	Draw # not marked on bottles
61	804 Delafield PI NW	4/25/2011	Stagnation < 6 hours
62	804 Delafield PI NW	5/16/2011	Chain of custody incomplete
63	81 O St NW	5/16/2011	Chain of custody incomplete
64	811 E St SE	5/16/2011	Chain of custody incomplete
65	821 BUCHANAN ST NW	4/25/2011	Multi-family
66	822 K St NE	5/16/2011	Ice maker and humidifier in use
67	826 Emerson St NW	4/25/2011	Stagnation < 6 hours
68	834 Delafield PI NW	4/25/2011	Water used during stagnation period
69	905 Kent PI NE	5/16/2011	Ice maker in use
70	926 Hamilton St NW	4/25/2011	Draw # not marked on bottles

Table C.4 Deviations from Sample Order

No	Address	Pipe Material	Priority	Sched Month	Deviation Reason
1	1207 Trinidad Ave NE	Partial Lead	Secondary	May	Not available
2	1623 Kennedy Pl NW	Lead	Primary	Jan	Customer no longer wants to participate in program
3	1649 HARVARD ST NW	Lead	Primary	Jan	Not available
4	1811 1st St NW	Lead	Primary	Jan	Customer no longer wants to participate in program
5	1812 M St NE	Partial Lead	Primary	Apr	Customer no longer wants to participate in program
6	2138 O St NW	Lead	Primary	Mar	Rejected first set of samples and customer sampled again
7	228 V ST NE	Lead	Primary	Feb	Not available
8	4423 Kane Pl NE	Lead	Primary	Mar	Home has broken pipe
9	4433 14th St NE	Lead	Primary	Mar	Customer no longer wants to participate in program
10	5234 Illinois Ave NW	Lead	Primary	Apr	Rejected first set of samples and customer sampled again
11	5613 30th St NW	Lead	Primary	Mar	Not available
12	580 49th Pl NE	Lead	Primary	Apr	Rejected first set of samples and customer sampled again
13	804 Delafield Pl NW	Lead	Primary	May	Rejected first set of samples and customer sampled again

Notes:

- 1) Service line material listings are representative of the pipe material known at the time the sample was collected.

Table C.5 Sites with Compliance Results from January 2010 – December 2010 and No Results in January - June 2011

No	Address	Explanation
1	10 S St NW	Samples not returned; see Table C.2
2	108 Varnum St NW	Samples rejected; see Table C.3
3	119 16TH ST NE	Samples rejected; see Table C.3
4	1202 Monroe St NW	Removed prior to the Jan - June 2011 sampling period
5	1211 Carrollsburg Pl SW	Samples not returned; see Table C.2
6	1212 E Capitol St NE	Samples rejected; see Table C.3
7	1214 Everts St NE	Samples rejected; see Table C.3
8	1339 U St SE	Samples rejected; see Table C.3
9	1400 FLORAL ST NW	Samples not returned; see Table C.2
10	1429 Ives Pl SE	Samples not returned; see Table C.2
11	1434 Taylor St NW	Samples not returned; see Table C.2
12	1436 S St NW	Samples rejected; see Table C.3
13	15 Milmarson Pl NW	Samples rejected; see Table C.3
14	1506 ALLISON ST NW	Removed prior to the Jan - June 2011 sampling period
15	1507 Buchanan St NW	Samples not returned; see Table C.2
16	1513 Pennsylvania Ave SE	Removed prior to the Jan - June 2011 sampling period
17	1525 D St NE	Samples rejected; see Table C.3
18	1603 Massachusetts Ave SE	Samples rejected; see Table C.3
19	1623 Kennedy Pl NW	Not sampled this period; see Table C.4
20	1635 WEBSTER ST NW	Samples rejected; see Table C.3
21	1649 HARVARD ST NW	Not sampled this period; see Table C.4
22	1703 D St NE	Samples not returned; see Table C.2
23	1705 2nd St NE	Samples not returned; see Table C.2
24	1736 Bay St SE	Samples not returned; see Table C.2
25	1812 M St NE	Not sampled this period; see Table C.4
26	2007 37TH ST NW	Samples rejected; see Table C.3
27	2121 15th St NW	Samples not returned; see Table C.2
28	213 49th St NE	Samples rejected; see Table C.3
29	2138 O St NW	Samples rejected; see Table C.3
30	2300 Woodridge St NE	Samples not returned; see Table C.2
31	2305 Minnesota Ave SE	Samples rejected; see Table C.3
32	258 15th St SE	Samples not returned; see Table C.2
33	3216 Klinge Rd NW	Samples not returned; see Table C.2
34	3218 MACOMB ST NW	Samples not returned; see Table C.2
35	3218 MORRISON ST NW	Samples not returned; see Table C.2
36	3361 Stuyvesant Pl NW	Samples not returned; see Table C.2
37	3416 9th St NE	Samples not returned; see Table C.2
38	3427 Oliver St NW	Samples not returned; see Table C.2

No	Address	Explanation
39	3706 35th St NW	Samples not returned; see Table C.2
40	3710 Huntington St NW	Samples not returned; see Table C.2
41	3805 Blaine St NE	Samples rejected; see Table C.3
42	410 Farragut St NW	Samples rejected; see Table C.3
43	4131 YUMA ST NW	Samples not returned; see Table C.2
44	416 7th St NE	Samples rejected; see Table C.3
45	424 Luray PI NW	Samples not returned; see Table C.2
46	4327 IOWA AVE NW	Samples rejected; see Table C.3
47	449 S St NW	Samples rejected; see Table C.3
48	4550 30TH ST NW	Samples not returned; see Table C.2
49	4609 5th St NW	Samples rejected; see Table C.3
50	4627 49th St NW	Samples rejected; see Table C.3
51	4700 Georgia Ave NW	Samples not returned; see Table C.2
52	4821 Illinois Ave NW	Samples rejected; see Table C.3
53	501 Webster St NW	Samples rejected; see Table C.3
54	507 Alabama Ave SE	Samples not returned; see Table C.2
55	517 4th St SE	Samples rejected; see Table C.3
56	5516 Kansas Ave NW	Samples rejected; see Table C.3
57	580 49th PI NE	Samples rejected; see Table C.3
58	5817 7th St NW	Samples not returned; see Table C.2
59	610 G St SE	Removed prior to the Jan - June 2011 sampling period
60	611 Roxboro PI NW	Samples not returned; see Table C.2
61	617 M St NE	Samples not returned; see Table C.2
62	621 Upshur St NW	Samples rejected; see Table C.3
63	6213 7TH ST NW	Samples rejected; see Table C.3
64	641 Gallatin St NW	Samples rejected; see Table C.3
65	804 Delafield PI NW	Samples rejected; see Table C.3
66	821 BUCHANAN ST NW	Samples rejected; see Table C.3

6308 8th St NW Missing Copper Analysis Explanation

The Washington Aqueduct (WA) Laboratory mistakenly analyzed the 1st draw and 2nd draw samples from 6308 8th St NW for only lead, instead of copper, lead, and iron. The samples were collected on March 23rd, 2011 and the WA notified DC Water of the error on May 18, 2011 (see Attachment 3 for email notification). To avoid future errors, the WA requested DC Water to modify the Chain of Custody to include “LCR” in the “Sample ID” field. DC Water revised the Chain of Custody form, which is included in Attachment 4 for EPA Region III’s review. The lead analysis result has been included in the compliance calculation (see Table A.1).

Appendix D: Revisions to Sample Pool

Table D.1 Sample Pool for July to December 2011 Monitoring Period

No.	Address	Pipe Material	Priority
1	10 Evarts St NE	Lead	Primary
2	10 S St NW	Lead	Primary
3	1003 Otis St NE	Lead	Primary
4	1003 Quebec Pl NW	Lead	Primary
5	1010 10th St NE	Lead	Primary
6	1011 Taylor St NE	Lead	Primary
7	1014 Douglas St NE	Lead	Primary
8	1025 44th St NE	Lead	Primary
9	108 Varnum St NW	Lead	Primary
10	1150 Abbey Pl NE	Lead	Primary
11	118 Kentucky Ave SE	Lead	Primary
12	119 16TH ST NE	Lead	Primary
13	1212 E Capitol St NE	Lead	Primary
14	125 Madison St NW	Lead	Primary
15	1262 COLUMBIA RD NW	Lead	Primary
16	1302 Randolph St NW	Lead	Primary
17	1315 FRANKLIN ST NE	Lead	Primary
18	1320 Allison St NE	Lead	Primary
19	1331 Irving St NE	Lead	Primary
20	1339 Ives Pl SE	Lead	Primary
21	1339 U St SE	Lead	Primary
22	1346 Madison St NW	Lead	Primary
23	1357 C St NE	Lead	Primary
24	1400 FLORAL ST NW	Lead	Primary
25	1409 22nd St SE	Lead	Primary
26	1424 S ST NW	Lead	Primary
27	1429 Ives Pl SE	Lead	Primary
28	143 UHLAND TER NE	Lead	Primary
29	1434 Taylor St NW	Lead	Primary
30	1436 S St NW	Lead	Primary
31	144 Tennessee Ave NE	Lead	Primary
32	1453 S St NW	Lead	Primary
33	15 Milmarson Pl NW	Lead	Primary
34	1507 Buchanan St NW	Lead	Primary
35	1525 D St NE	Lead	Primary
36	1533 Upshur St NW	Lead	Primary
37	1611 Webster St NW	Lead	Primary

No.	Address	Pipe Material	Priority
38	1620 Hamlin St NE	Lead	Primary
39	1620 Webster St NW	Lead	Primary
40	1623 U St SE	Lead	Primary
41	1635 WEBSTER ST NW	Lead	Primary
42	1649 HARVARD ST NW	Lead	Primary
43	1703 D St NE	Lead	Primary
44	1706 NEW JERSEY AVE NW	Lead	Primary
45	1826 Jackson St NE	Lead	Primary
46	2007 37TH ST NW	Lead	Primary
47	2107 2nd St NE	Lead	Primary
48	213 49th St NE	Lead	Primary
49	2212 38th St NW	Lead	Primary
50	228 V ST NE	Lead	Primary
51	24 Evarts St NE	Lead	Primary
52	2435 33RD ST SE	Lead	Primary
53	258 15th St SE	Lead	Primary
54	2649 Bowen Rd SE	Lead	Primary
55	2724 36TH PL NW	Lead	Primary
56	2830 BRENTWOOD RD NE	Lead	Primary
57	3033 Bladensburg Rd NE	Lead	Primary
58	307 7th St NE	Lead	Primary
59	313 Aspen St NW	Lead	Primary
60	317 9th St SE	Lead	Primary
61	3206 38th St NW	Lead	Primary
62	3211 Central Ave NE	Lead	Primary
63	3216 Klingen Rd NW	Lead	Primary
64	3218 MACOMB ST NW	Lead	Primary
65	3218 MORRISON ST NW	Lead	Primary
66	322 TENNESSEE AVE NE	Lead	Primary
67	3232 Klingen Rd NW	Lead	Primary
68	331 RALEIGH ST SE	Lead	Primary
69	331 Upshur St NW	Lead	Primary
70	336 Quackenbos St NE	Lead	Primary
71	3361 Stuyvesant Pl NW	Lead	Primary
72	3400 Holmead Pl NW	Lead	Primary
73	3427 Oliver St NW	Lead	Primary
74	3431 S Dakota Ave NE	Lead	Primary
75	349 TENNESSEE AVE NE	Lead	Primary
76	3511 Woodley Rd NW	Lead	Primary
77	3601 WARREN ST NW	Lead	Primary
78	3612 34th St NW	Lead	Primary
79	3618 PORTER ST NW	Lead	Primary

No.	Address	Pipe Material	Priority
80	3706 35th St NW	Lead	Primary
81	3710 Huntington St NW	Lead	Primary
82	3727 T St NW	Lead	Primary
83	3908 13TH ST NW	Lead	Primary
84	3973 HARRISON ST NW	Lead	Primary
85	410 Farragut St NW	Lead	Primary
86	4111 INGOMAR ST NW	Lead	Primary
87	4120 Grant St NE	Lead	Primary
88	4131 YUMA ST NW	Lead	Primary
89	416 7th St NE	Lead	Primary
90	4210 Clay St NE	Lead	Primary
91	4214 8th St NW	Lead	Primary
92	424 Luray Pl NW	Lead	Primary
93	4305 38TH ST NW	Lead	Primary
94	4307 CHESAPEAKE ST NW	Lead	Primary
95	4310 37th St NW	Lead	Primary
96	432 15th St SE	Lead	Primary
97	4401 5TH ST NW	Lead	Primary
98	4409 Lowell St NW	Lead	Primary
99	4411 15th St NW	Lead	Primary
100	4418 14th St NE	Lead	Primary
101	4419 14th St NE	Lead	Primary
102	4423 Kane Pl NE	Lead	Primary
103	449 S St NW	Lead	Primary
104	452 Newton Pl NW	Lead	Primary
105	4550 30TH ST NW	Lead	Primary
106	4609 5th St NW	Lead	Primary
107	4613 9th St NW	Lead	Primary
108	4627 49th St NW	Lead	Primary
109	4703 Macarthur Blvd NW	Lead	Primary
110	4718 Sheriff Rd NE	Lead	Primary
111	4821 Illinois Ave NW	Lead	Primary
112	4824 46th St NW	Lead	Primary
113	4926 Glenbrook Rd NW	Lead	Primary
114	501 Webster St NW	Lead	Primary
115	5024 7th St NW	Lead	Primary
116	507 Alabama Ave SE	Lead	Primary
117	5122 Cathedral Ave NW	Lead	Primary
118	519 Rock Crk Church Rd NW	Lead	Primary
119	5226 7th St NW	Lead	Primary
120	5234 Illinois Ave NW	Lead	Primary
121	524 Shepherd St NW	Lead	Primary

No.	Address	Pipe Material	Priority
122	53 P St NW	Lead	Primary
123	5318 9TH ST NW	Lead	Primary
124	5516 Kansas Ave NW	Lead	Primary
125	5517 7th St NW	Lead	Primary
126	5612 14th St NW	Lead	Primary
127	5613 30th St NW	Lead	Primary
128	5731 3rd Pl NW	Lead	Primary
129	580 49th Pl NE	Lead	Primary
130	5907 4th St NW	Lead	Primary
131	5909 16th St NW	Lead	Primary
132	5923 33rd St NW	Lead	Primary
133	6001 33rd St NW	Lead	Primary
134	608 Gallatin St NW	Lead	Primary
135	6105 Dix St NE	Lead	Primary
136	611 Roxboro Pl NW	Lead	Primary
137	617 6th St NE	Lead	Primary
138	617 M St NE	Lead	Primary
139	619 12th St NE	Lead	Primary
140	6203 Piney Branch Rd NW	Lead	Primary
141	621 Upshur St NW	Lead	Primary
142	6210 8th St NW	Lead	Primary
143	6308 8th St NW	Lead	Primary
144	632 Webster St NW	Lead	Primary
145	636 ROCK CRK CHURCH RD NW	Lead	Primary
146	641 Gallatin St NW	Lead	Primary
147	644 Lamont St NW	Lead	Primary
148	702 9th St SE	Lead	Primary
149	7129 Georgia Ave NW	Lead	Primary
150	720 ALABAMA AVE SE	Lead	Primary
151	75 Bates St NW	Lead	Primary
152	753 Gresham Pl NW	Lead	Primary
153	760 Gresham Pl NW	Lead	Primary
154	8 N St SW	Lead	Primary
155	804 Delafield Pl NW	Lead	Primary
156	81 O St NW	Lead	Primary
157	810 Savannah St SE	Lead	Primary
158	811 E St SE	Lead	Primary
159	822 K St NE	Lead	Primary
160	826 Emerson St NW	Lead	Primary
161	834 Delafield Pl NW	Lead	Primary
162	87 S St NW	Lead	Primary
163	905 Kent Pl NE	Lead	Primary

No.	Address	Pipe Material	Priority
164	910 Farragut St NW	Lead	Primary
165	912 Emerson St NW	Lead	Primary
166	926 Hamilton St NW	Lead	Primary
167	1203 Quincy St NW	Partial Lead	Primary
168	1211 Carrollsburg Pl SW	Partial Lead	Primary
169	1214 Evarts St NE	Partial Lead	Primary
170	1222 HAMILTON ST NW	Partial Lead	Primary
171	1223 Pleasant St SE	Partial Lead	Primary
172	1238 HALF ST SW	Partial Lead	Primary
173	1319 POTOMAC AVE SE	Partial Lead	Primary
174	1353 Iris St NW	Partial Lead	Primary
175	1353 JEFFERSON ST NW	Partial Lead	Primary
176	1387 N Carolina Ave NE	Partial Lead	Primary
177	1420 Hamlin St NE	Partial Lead	Primary
178	1505 Lawrence St NE	Partial Lead	Primary
179	1603 Massachusetts Ave SE	Partial Lead	Primary
180	1619 G St SE	Partial Lead	Primary
181	1671 Rosedale St NE	Partial Lead	Primary
182	1731 L St NE	Partial Lead	Primary
183	1802 35TH ST NW	Partial Lead	Primary
184	1808 KEARNEY ST NE	Partial Lead	Primary
185	2118 14th St SE	Partial Lead	Primary
186	2305 Minnesota Ave SE	Partial Lead	Primary
187	2823 28TH ST NW	Partial Lead	Primary
188	302 RITTENHOUSE ST NW	Partial Lead	Primary
189	3036 P St NW	Partial Lead	Primary
190	308 9th St SE	Partial Lead	Primary
191	3215 Mckinley St NW	Partial Lead	Primary
192	3301 BROWN St NW	Partial Lead	Primary
193	3416 9th St NE	Partial Lead	Primary
194	3531 16TH ST NW	Partial Lead	Primary
195	3631 Ordway St NW	Partial Lead	Primary
196	3907 13th St NW	Partial Lead	Primary
197	3913 8TH ST NW	Partial Lead	Primary
198	3917 8th St NW	Partial Lead	Primary
199	413 4th St SE	Partial Lead	Primary
200	4327 IOWA AVE NW	Partial Lead	Primary
201	4332 BRANDYWINE ST NW	Partial Lead	Primary
202	4429 3rd St NW	Partial Lead	Primary
203	4818 8th ST NW	Partial Lead	Primary
204	517 4th St SE	Partial Lead	Primary
205	5316 28th St NW	Partial Lead	Primary

No.	Address	Pipe Material	Priority
206	6213 7TH ST NW	Partial Lead	Primary
207	75 P St NW	Partial Lead	Primary
208	104 17th St SE	Lead	Secondary
209	1106 Allison St NW	Lead	Secondary
210	1317 Otis St NE	Lead	Secondary
211	1705 2nd St NE	Lead	Secondary
212	2121 15th St NW	Lead	Secondary
213	2214 1st St NW	Lead	Secondary
214	226 12th PI NE	Lead	Secondary
215	2300 Woodridge St NE	Lead	Secondary
216	2604 Rhode Island Ave NE	Lead	Secondary
217	2913 Brandywine St NW	Lead	Secondary
218	321 Aspen St NW	Lead	Secondary
219	3217 Georgia Ave NW	Lead	Secondary
220	3533 W PI NW	Lead	Secondary
221	3634 WARDER ST NW	Lead	Secondary
222	4507 13TH ST NW	Lead	Secondary
223	4606 Sheriff Rd NE	Lead	Secondary
224	4818 ILLINOIS AVE NW	Lead	Secondary
225	5328 Kansas Ave NW	Lead	Secondary
226	536 Newton PI NW	Lead	Secondary
227	5404 Kansas Ave NW	Lead	Secondary
228	5817 7th St NW	Lead	Secondary
229	6001 Nevada Ave NW	Lead	Secondary
230	619 Girard St NE	Lead	Secondary
231	743 Gresham PI NW	Lead	Secondary
232	88 R St NW	Lead	Secondary
233	915 Farragut St NW	Lead	Secondary
234	915 Shepherd St NW	Lead	Secondary
235	1207 Trinidad Ave NE	Partial Lead	Secondary
236	1301 Michigan Ave NE	Partial Lead	Secondary
237	1337 Newton St NW	Partial Lead	Secondary
238	1412 N Carolina Ave NE	Partial Lead	Secondary
239	1412 S St NW	Partial Lead	Secondary
240	1412 Shepherd St NW	Partial Lead	Secondary
241	1424 Perry PI NW	Partial Lead	Secondary
242	1424 S ST SE	Partial Lead	Secondary
243	1451 S ST NW	Partial Lead	Secondary
244	1523 D St SE	Partial Lead	Secondary
245	1533 Constitution Ave NE	Partial Lead	Secondary
246	1614 V St SE	Partial Lead	Secondary
247	1701 2nd St NE	Partial Lead	Secondary

No.	Address	Pipe Material	Priority
248	1736 Bay St SE	Partial Lead	Secondary
249	1749 Irving St NW	Partial Lead	Secondary
250	1755 Lanier PI NW	Partial Lead	Secondary
251	1802 Kilbourne PI NW	Partial Lead	Secondary
252	1814 MONROE ST NW	Partial Lead	Secondary
253	1825 L ST NE	Partial Lead	Secondary
254	1836 L St NE	Partial Lead	Secondary
255	1839 MONROE ST NW	Partial Lead	Secondary
256	1843 MONROE ST NW	Partial Lead	Secondary
257	1850 2ND ST NW	Partial Lead	Secondary
258	1863 MONROE ST NW	Partial Lead	Secondary
259	1908 Biltmore St NW	Partial Lead	Secondary
260	1931 SUMMIT PL NE	Partial Lead	Secondary
261	201 13th St NE	Partial Lead	Secondary
262	202 11th St SE	Partial Lead	Secondary
263	205 TAYLOR ST NW	Partial Lead	Secondary
264	2220 13th St SE	Partial Lead	Secondary
265	223 14th PI NE	Partial Lead	Secondary
266	2237 CHESTER ST SE	Partial Lead	Secondary
267	228 Randolph PI NE	Partial Lead	Secondary
268	230 G St NE	Partial Lead	Secondary
269	231 K St NE	Partial Lead	Secondary
270	234 Longfellow St NW	Partial Lead	Secondary
271	2408 2nd St NE	Partial Lead	Secondary
272	2928 33rd PI NW	Partial Lead	Secondary
273	3001 7th St NE	Partial Lead	Secondary
274	3030 44TH ST NW	Partial Lead	Secondary
275	3105 34th St NW	Partial Lead	Secondary
276	312 14TH ST NE	Partial Lead	Secondary
277	313 16th St SE	Partial Lead	Secondary
278	319 Ingraham St NW	Partial Lead	Secondary
279	32 Todd PI NE	Partial Lead	Secondary
280	3202 38TH ST NW	Partial Lead	Secondary
281	333 34th St NE	Partial Lead	Secondary
282	335 17TH PL NE	Partial Lead	Secondary
283	3428 Brown St NW	Partial Lead	Secondary
284	3721 Windom PI NW	Partial Lead	Secondary
285	3809 ALTON PL NW	Partial Lead	Secondary
286	42 Q St NE	Partial Lead	Secondary
287	420 Kenyon St NW	Partial Lead	Secondary
288	4215 39th St NW	Partial Lead	Secondary
289	441 Quincy St NW	Partial Lead	Secondary

No.	Address	Pipe Material	Priority
290	4616 HUNT PL NE	Partial Lead	Secondary
291	502 Oglethorpe St NW	Partial Lead	Secondary
292	506 Irving St NW	Partial Lead	Secondary
293	513 Florida Ave NE	Partial Lead	Secondary
294	514 13th St SE	Partial Lead	Secondary
295	518 Varnum St NW	Partial Lead	Secondary
296	522 Park Rd NW	Partial Lead	Secondary
297	53 V St NW	Partial Lead	Secondary
298	5301 RENO RD NW	Partial Lead	Secondary
299	5304 Reno Rd NW	Partial Lead	Secondary
300	5404 39TH ST NW	Partial Lead	Secondary
301	545 PARK RD NW	Partial Lead	Secondary
302	605 Columbia Rd NW	Partial Lead	Secondary
303	605 ROCK CRK CHURCH RD NW	Partial Lead	Secondary
304	617 Kenyon St NW	Partial Lead	Secondary
305	661 MARYLAND AVE NE	Partial Lead	Secondary
306	720 PARK RD NW	Partial Lead	Secondary
307	736 Fairmont St NW	Partial Lead	Secondary
308	765 GIRARD ST NW	Partial Lead	Secondary
309	7721 14th St NW	Partial Lead	Secondary
310	780 Fairmont St NW	Partial Lead	Secondary
311	817 DECATUR ST NW	Partial Lead	Secondary
312	833 DECATUR ST NW	Partial Lead	Secondary
313	924 Hamilton St NW	Partial Lead	Secondary

Table D.2 Site Changes - Sites Removed, Added, or Priority Status Changed

No.	Address	Pipe Material	Prior Status (Priority)	Revised Priority	Change
1	1339 Ives Pl SE	Lead	Secondary	Primary	Returned bottles this semester
2	1453 S St NW	Lead	Secondary	Primary	Returned bottles this semester
3	1620 Hamlin St NE	Lead	Secondary	Primary	Returned bottles this semester
4	3033 Bladensburg Rd NE	Lead	Secondary	Primary	Returned bottles this semester
5	432 15th St SE	Lead	Secondary	Primary	Returned bottles this semester
6	4418 14th St NE	Lead	Secondary	Primary	Returned bottles this semester
7	4718 Sheriff Rd NE	Lead	Secondary	Primary	Returned bottles this semester
8	519 Rock Crk Church Rd NW	Lead	Secondary	Primary	Returned bottles this semester
9	53 P St NW	Lead	Secondary	Primary	Returned bottles this semester
10	5517 7th St NW	Lead	Secondary	Primary	Returned bottles this semester
11	5612 14th St NW	Lead	Secondary	Primary	Returned bottles this semester
12	608 Gallatin St NW	Lead	Secondary	Primary	Returned bottles this semester
13	617 6th St NE	Lead	Secondary	Primary	Returned bottles this semester
14	6203 Piney Branch Rd NW	Lead	Secondary	Primary	Returned bottles this semester
15	632 Webster St NW	Lead	Secondary	Primary	Returned bottles this semester
16	644 Lamont St NW	Lead	Secondary	Primary	Returned bottles this semester
17	7129 Georgia Ave NW	Lead	Secondary	Primary	Returned bottles this semester
18	720 ALABAMA AVE SE	Lead	Secondary	Primary	Returned bottles this semester
19	75 Bates St NW	Lead	Secondary	Primary	Returned bottles this semester
20	753 Gresham Pl NW	Lead	Secondary	Primary	Returned bottles this semester
21	760 Gresham Pl NW	Lead	Secondary	Primary	Returned bottles this semester
22	8 N St SW	Lead	Secondary	Primary	Returned bottles this semester
23	81 O St NW	Lead	Secondary	Primary	Returned bottles this semester
24	810 Savannah St SE	Lead	Secondary	Primary	Returned bottles this semester
25	811 E St SE	Lead	Secondary	Primary	Returned bottles this semester
26	822 K St NE	Lead	Secondary	Primary	Returned bottles this semester
27	87 S St NW	Lead	Secondary	Primary	Returned bottles this semester
28	905 Kent Pl NE	Lead	Secondary	Primary	Returned bottles this semester
29	910 Farragut St NW	Lead	Secondary	Primary	Returned bottles this semester
30	912 Emerson St NW	Lead	Secondary	Primary	Returned bottles this semester
31	1223 Pleasant St SE	Partial Lead	Secondary	Primary	Returned bottles this semester
32	1353 Iris St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
33	5316 28th St NW	Partial Lead	Secondary	Primary	Returned bottles this semester
34	104 17th St SE	Lead	Primary	Secondary	No return last 2 sample periods
35	1106 Allison St NW	Lead	Primary	Secondary	No return last 2 sample periods
36	1317 Otis St NE	Lead	Primary	Secondary	No return last 2 sample periods
37	1705 2nd St NE	Lead	Primary	Secondary	No return last 2 sample periods
38	2121 15th St NW	Lead	Primary	Secondary	No return last 2 sample periods
39	2300 Woodridge St NE	Lead	Primary	Secondary	No return last 2 sample periods

No.	Address	Pipe Material	Prior Status (Priority)	Revised Priority	Change
40	2604 Rhode Island Ave NE	Lead	Primary	Secondary	No return last 2 sample periods
41	321 Aspen St NW	Lead	Primary	Secondary	No return last 2 sample periods
42	3217 Georgia Ave NW	Lead	Primary	Secondary	No return last 2 sample periods
43	4818 ILLINOIS AVE NW	Lead	Primary	Secondary	No return last 2 sample periods
44	5817 7th St NW	Lead	Primary	Secondary	No return last 2 sample periods
45	1736 Bay St SE	Partial Lead	Primary	Secondary	No return last 2 sample periods
46	1334 Randolph St NE	Lead	Primary	Removed	Home has leaks and customer unsure if they will fix
47	1623 Kennedy Pl NW	Lead	Primary	Removed	Request no participation
48	1811 1st St NW	Lead	Primary	Removed	Request no participation
49	2138 O St NW	Lead	Primary	Removed	Multi-family residence
50	3805 Blaine St NE	Lead	Primary	Removed	Request no participation
51	4433 14th St NE	Lead	Primary	Removed	Request no participation
52	4700 Georgia Ave NW	Lead	Primary	Removed	Request no participation
53	631 Lamont St NW	Lead	Primary	Removed	Request no participation
54	821 BUCHANAN ST NW	Lead	Primary	Removed	Multi-family residence
55	1812 M St NE	Partial Lead	Primary	Removed	Request no participation
56	104 15th St SE	Lead	Secondary	Removed	Did not return samples
57	1349 Wallach Pl NW	Lead	Secondary	Removed	Did not return samples
58	1371 Monroe St NW	Lead	Secondary	Removed	Did not return samples
59	1412 Allison St NW	Lead	Secondary	Removed	Did not return samples
60	1427 Montague St NW	Lead	Secondary	Removed	Did not return samples
61	1607 KEARNY ST NE	Lead	Secondary	Removed	Did not return samples
62	1801 1st St NW	Lead	Secondary	Removed	Did not return samples
63	1811 Lamont St NW	Lead	Secondary	Removed	Did not return samples
64	2132 37th St NW	Lead	Secondary	Removed	Did not return samples
65	2300 MONROE ST NE	Lead	Secondary	Removed	Did not return samples
66	25 17th St SE	Lead	Secondary	Removed	Did not return samples
67	3014 8th St SE	Lead	Secondary	Removed	Did not return samples
68	3524 Park Pl NW	Lead	Secondary	Removed	Did not return samples
69	417 15th St SE	Lead	Secondary	Removed	Did not return samples
70	4842 KANSAS AVE NW	Lead	Secondary	Removed	Did not return samples
71	4906 9th St NW	Lead	Secondary	Removed	Did not return samples
72	610 L ST NE	Lead	Secondary	Removed	Did not return samples
73	612 ROCK CRK CHURCH RD NW	Lead	Secondary	Removed	Did not return samples
74	728 FARRAGUT ST NW	Lead	Secondary	Removed	Did not return samples
75	812 Buchanan St NW	Lead	Secondary	Removed	Did not return samples
76	1217 Orren St NE	Partial Lead	Secondary	Removed	Did not return samples

Table D.3 Pipe Material Changes

Address	Previous Pipe Material	Revised Pipe Material	Reason for change
5316 28 th St NW	Lead	Partial Lead	Customer reported on May 2011 Chain of Custody that the private side was replaced in August 2010.