



Lead and Copper Compliance Report July through December 2012

Table 1 summarizes the District of Columbia Water and Sewer Authority's (DC Water) Lead and Copper compliance results for the monitoring period July through December 2012.

Table 1. Lead and Copper Summary Data

Number of Samples	
Total	105
90th Percentile First Draw Concentrations	
Lead mg/L	0.004
Copper mg/L	0.102
Service Line Materials	
Full Lead	78%
Partial Lead	22%

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned and Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Order
 - Table C.5 Sites with Compliance Results from July 2011 – June 2012 and No Results in July - Dec 2012

- Attachment 1: Washington Aqueduct Test Results for LCR Compliance
- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Post-lead service line replacement samples
 - Lead profiles
 - Research pipe loops
 - DC Water fountain samples
 - Other Research – Reservoir samples
- Attachment 3: Customer Letter Distribution Certification

Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No.	Address	Pipe Material	Collection Date	Lead 1st Draw (mg/L)
1	1706 NEW JERSEY AVE NW	Lead	7/26/2012	0.0000
2	317 9th St SE	Lead	7/25/2012	0.0000
3	213 49th St NE	Lead	7/25/2012	0.0000
4	2923 Cathedral AVE NW	Lead	7/25/2012	0.0000
5	3973 HARRISON ST NW	Lead	8/29/2012	0.0000
6	4926 Glenbrook Rd NW	Lead	8/28/2012	0.0000
7	4120 Grant St NE	Lead	8/29/2012	0.0000
8	3533 W PI NW	Lead	8/29/2012	0.0000
9	36 Florida Ave NW	Lead	8/28/2012	0.0000
10	1353 JEFFERSON ST NW	Partial Lead	9/25/2012	0.0000
11	1603 Massachusetts Ave SE	Partial Lead	9/25/2012	0.0000
12	6105 Dix St NE	Lead	10/2/2012	0.0000
13	75 Bates St NW	Lead	9/26/2012	0.0000
14	4332 BRANDYWINE ST NW	Partial Lead	10/24/2012	0.0000
15	3416 9th St NE	Partial Lead	10/25/2012	0.0000
16	333 34th St NE	Partial Lead	10/23/2012	0.0000
17	3036 P St NW	Partial Lead	10/23/2012	0.0000
18	413 4th St SE	Partial Lead	10/24/2012	0.0000
19	5316 28th St NW	Partial Lead	12/5/2012	0.0000
20	753 Gresham PI NW	Lead	11/29/2012	0.0000
21	6213 7TH ST NW	Partial Lead	10/24/2012	0.0005
22	1010 10th St NE	Lead	7/26/2012	0.0006
23	1025 44th St NE	Lead	7/25/2012	0.0006
24	4627 49th St NW	Lead	8/31/2012	0.0006
25	1635 WEBSTER ST NW	Lead	9/27/2012	0.0006
26	1319 POTOMAC AVE SE	Partial Lead	9/26/2012	0.0006
27	619 12th St NE	Lead	9/26/2012	0.0006
28	3913 8TH ST NW	Partial Lead	10/24/2012	0.0006
29	3218 MORRISON ST NW	Lead	11/28/2012	0.0006
30	4409 Lowell St NW	Lead	8/29/2012	0.0007
31	4214 8th St NW	Lead	8/29/2012	0.0007
32	1420 Hamlin St NE	Partial Lead	9/26/2012	0.0007
33	1505 Buchanan St NW	Lead	7/25/2012	0.0008
34	349 TENNESSEE AVE NE	Lead	8/29/2012	0.0008
35	905 Kent PI NE	Lead	9/25/2012	0.0008
36	780 Fairmont St NW	Partial Lead	10/23/2012	0.0008
37	611 Roxboro PI NW	Lead	12/5/2012	0.0008

No.	Address	Pipe Material	Collection Date	Lead 1st Draw (mg/L)
38	1424 S ST NW	Lead	7/25/2012	0.0010
39	331 RALEIGH ST SE	Lead	8/28/2012	0.0010
40	336 Quackenbos St NE	Lead	8/29/2012	0.0010
41	804 Delafield Pl NW	Lead	9/26/2012	0.0010
42	1203 Quincy St NW	Partial Lead	9/26/2012	0.0010
43	3710 Huntington St NW	Lead	8/29/2012	0.0011
44	4613 9th St NW	Lead	11/29/2012	0.0011
45	1318 Wallach Pl NW	Lead	7/25/2012	0.0012
46	501 Webster St NW	Lead	8/27/2012	0.0012
47	5923 33rd St NW	Lead	9/26/2012	0.0012
48	3202 38TH ST NW	Partial Lead	10/24/2012	0.0012
49	3216 Klinge Rd NW	Lead	8/29/2012	0.0013
50	322 TENNESSEE AVE NE	Lead	12/5/2012	0.0013
51	2212 38th St NW	Lead	12/10/2012	0.0013
52	1620 Webster St NW	Lead	7/24/2012	0.0014
53	4818 8th ST NW	Partial Lead	10/23/2012	0.0014
54	335 17TH PL NE	Partial Lead	10/24/2012	0.0014
55	3907 13th St NW	Partial Lead	10/22/2012	0.0014
56	424 Luray Pl NW	Lead	12/4/2012	0.0014
57	4307 CHESAPEAKE ST NW	Lead	8/30/2012	0.0015
58	87 S St NW	Lead	9/26/2012	0.0015
59	4111 INGOMAR ST NW	Lead	11/28/2012	0.0015
60	3218 MACOMB ST NW	Lead	8/28/2012	0.0016
61	4824 46th St NW	Lead	8/29/2012	0.0016
62	3917 8th St NW	Partial Lead	10/23/2012	0.0016
63	913 Hamlin St NE	Lead	9/24/2012	0.0017
64	605 Columbia Rd NW	Partial Lead	10/22/2012	0.0017
65	1378 Taylor St NW	Lead	7/24/2012	0.0018
66	3206 38th St NW	Lead	8/30/2012	0.0018
67	3215 Mckinley St NW	Partial Lead	10/24/2012	0.0018
68	4818 ILLINOIS AVE NW	Lead	11/29/2012	0.0018
69	531 Tennessee Ave NE	Lead	8/4/2012	0.0019
70	4418 14th St NE	Lead	8/28/2012	0.0019
71	1011 Taylor St NE	Lead	7/25/2012	0.0020
72	15 Milmarson Pl NW	Lead	7/26/2012	0.0020
73	2128 O ST NW	Lead	7/25/2012	0.0020
74	4401 5TH ST NW	Lead	8/29/2012	0.0020
75	2212 38th St NW	Lead	9/29/2012	0.0020
76	228 V ST NE	Lead	7/24/2012	0.0021
77	1808 KEARNEY ST NE	Partial Lead	9/26/2012	0.0021
78	3211 Central Ave NE	Lead	8/29/2012	0.0023
79	1434 Taylor St NW	Lead	12/4/2012	0.0023

No.	Address	Pipe Material	Collection Date	Lead 1st Draw (mg/L)
80	1519 Olive St NE	Lead	7/25/2012	0.0024
81	230 G St NE	Partial Lead	10/24/2012	0.0024
82	1357 C St NE	Lead	10/23/2012	0.0024
83	4131 YUMA ST NW	Lead	8/29/2012	0.0025
84	3706 35th St NW	Lead	8/30/2012	0.0025
85	5226 7th St NW	Lead	8/29/2012	0.0025
86	3727 T St NW	Lead	8/29/2012	0.0026
87	1826 Jackson St NE	Lead	7/25/2012	0.0027
88	636 ROCK CRK CHURCH RD NW	Lead	9/26/2012	0.0030
89	617 M St NE	Lead	9/26/2012	0.0030
90	8 N St SW	Lead	9/25/2012	0.0030
91	4550 30TH ST NW	Lead	8/29/2012	0.0032
92	10 S St NW	Lead	7/24/2012	0.0034
93	641 Gallatin St NW	Lead	9/26/2012	0.0035
94	119 16TH ST NE	Lead	7/25/2012	0.0036
95	1649 HARVARD ST NW	Lead	7/25/2012	0.0040
96	807 Buchanan St NW	Lead	9/25/2012	0.0043
97	619 Girard St NE	Lead	11/29/2012	0.0043
98	6210 8th St NW	Lead	9/27/2012	0.0044
99	1703 D St NE	Lead	7/23/2012	0.0045
100	5234 Illinois Ave NW	Lead	8/27/2012	0.0047
101	926 Hamilton St NW	Lead	9/25/2012	0.0062
102	1346 F St NE	Lead	7/24/2012	0.0069
103	144 Tennessee Ave NE	Lead	7/25/2012	0.0131
104	2435 33RD ST SE	Lead	7/25/2012	0.0179
105	4703 Macarthur Blvd NW	Lead	8/29/2012	0.0200

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.
- 4) 2212 38th St NW was mistakenly sampled twice. Both results are included in the table and 90th percentile calculation.

Table A.2 First Draw Copper Results

No.	Address	Pipe Material	Collection Date	Copper 1st Draw (mg/L)
1	1505 Buchanan St NW	Lead	7/25/2012	0.000
2	3706 35th St NW	Lead	8/30/2012	0.002
3	4214 8th St NW	Lead	8/29/2012	0.006
4	807 Buchanan St NW	Lead	9/25/2012	0.006
5	1434 Taylor St NW	Lead	12/4/2012	0.006
6	213 49th St NE	Lead	7/25/2012	0.007
7	3533 W PI NW	Lead	8/29/2012	0.007
8	636 ROCK CRK CHURCH RD NW	Lead	9/26/2012	0.007
9	6210 8th St NW	Lead	9/27/2012	0.007
10	6213 7TH ST NW	Partial Lead	10/24/2012	0.007
11	3416 9th St NE	Partial Lead	10/25/2012	0.007
12	4818 ILLINOIS AVE NW	Lead	11/29/2012	0.007
13	3973 HARRISON ST NW	Lead	8/29/2012	0.008
14	4120 Grant St NE	Lead	8/29/2012	0.008
15	5226 7th St NW	Lead	8/29/2012	0.008
16	926 Hamilton St NW	Lead	9/25/2012	0.008
17	619 Girard St NE	Lead	11/29/2012	0.008
18	611 Roxboro PI NW	Lead	12/5/2012	0.009
19	10 S St NW	Lead	7/24/2012	0.013
20	1635 WEBSTER ST NW	Lead	9/27/2012	0.013
21	3215 Mckinley St NW	Partial Lead	10/24/2012	0.013
22	804 Delafield PI NW	Lead	9/26/2012	0.014
23	780 Fairmont St NW	Partial Lead	10/23/2012	0.014
24	1378 Taylor St NW	Lead	7/24/2012	0.015
25	331 RALEIGH ST SE	Lead	8/28/2012	0.015
26	5234 Illinois Ave NW	Lead	8/27/2012	0.015
27	333 34th St NE	Partial Lead	10/23/2012	0.015
28	1603 Massachusetts Ave SE	Partial Lead	9/25/2012	0.016
29	6105 Dix St NE	Lead	10/2/2012	0.016
30	1826 Jackson St NE	Lead	7/25/2012	0.017
31	3710 Huntington St NW	Lead	8/29/2012	0.017
32	335 17TH PL NE	Partial Lead	10/24/2012	0.017
33	641 Gallatin St NW	Lead	9/26/2012	0.018
34	905 Kent PI NE	Lead	9/25/2012	0.018
35	531 Tennessee Ave NE	Lead	8/4/2012	0.019
36	349 TENNESSEE AVE NE	Lead	8/29/2012	0.019
37	619 12th St NE	Lead	9/26/2012	0.020
38	4613 9th St NW	Lead	11/29/2012	0.021
39	3913 8TH ST NW	Partial Lead	10/24/2012	0.022

No.	Address	Pipe Material	Collection Date	Copper 1st Draw (mg/L)
40	3206 38th St NW	Lead	8/30/2012	0.023
41	4409 Lowell St NW	Lead	8/29/2012	0.023
42	4926 Glenbrook Rd NW	Lead	8/28/2012	0.023
43	336 Quackenbos St NE	Lead	8/29/2012	0.023
44	3216 Klinge Rd NW	Lead	8/29/2012	0.023
45	1357 C St NE	Lead	10/23/2012	0.024
46	424 Luray Pl NW	Lead	12/4/2012	0.024
47	144 Tennessee Ave NE	Lead	7/25/2012	0.025
48	1203 Quincy St NW	Partial Lead	9/26/2012	0.025
49	413 4th St SE	Partial Lead	10/24/2012	0.025
50	1706 NEW JERSEY AVE NW	Lead	7/26/2012	0.026
51	1519 Olive St NE	Lead	7/25/2012	0.026
52	1025 44th St NE	Lead	7/25/2012	0.027
53	2923 Cathedral AVE NW	Lead	7/25/2012	0.027
54	1011 Taylor St NE	Lead	7/25/2012	0.028
55	1346 F St NE	Lead	7/24/2012	0.028
56	1649 HARVARD ST NW	Lead	7/25/2012	0.029
57	1010 10th St NE	Lead	7/26/2012	0.029
58	4111 INGOMAR ST NW	Lead	11/28/2012	0.029
59	4307 CHESAPEAKE ST NW	Lead	8/30/2012	0.032
60	4550 30TH ST NW	Lead	8/29/2012	0.033
61	4824 46th St NW	Lead	8/29/2012	0.033
62	3218 MORRISON ST NW	Lead	11/28/2012	0.033
63	4131 YUMA ST NW	Lead	8/29/2012	0.035
64	322 TENNESSEE AVE NE	Lead	12/5/2012	0.035
65	4627 49th St NW	Lead	8/31/2012	0.036
66	1353 JEFFERSON ST NW	Partial Lead	9/25/2012	0.037
67	1420 Hamlin St NE	Partial Lead	9/26/2012	0.037
68	2435 33RD ST SE	Lead	7/25/2012	0.040
69	228 V ST NE	Lead	7/24/2012	0.040
70	617 M St NE	Lead	9/26/2012	0.040
71	2212 38th St NW	Lead	12/10/2012	0.041
72	230 G St NE	Partial Lead	10/24/2012	0.042
73	87 S St NW	Lead	9/26/2012	0.043
74	119 16TH ST NE	Lead	7/25/2012	0.046
75	1424 S ST NW	Lead	7/25/2012	0.046
76	1703 D St NE	Lead	7/23/2012	0.047
77	4332 BRANDYWINE ST NW	Partial Lead	10/24/2012	0.047
78	913 Hamlin St NE	Lead	9/24/2012	0.050
79	1319 POTOMAC AVE SE	Partial Lead	9/26/2012	0.052
80	3036 P St NW	Partial Lead	10/23/2012	0.052
81	753 Gresham Pl NW	Lead	11/29/2012	0.052

No.	Address	Pipe Material	Collection Date	Copper 1st Draw (mg/L)
82	4818 8th ST NW	Partial Lead	10/23/2012	0.055
83	4418 14th St NE	Lead	8/28/2012	0.059
84	4401 5TH ST NW	Lead	8/29/2012	0.062
85	15 Milmarson Pl NW	Lead	7/26/2012	0.063
86	1318 Wallach Pl NW	Lead	7/25/2012	0.064
87	1620 Webster St NW	Lead	7/24/2012	0.065
88	3211 Central Ave NE	Lead	8/29/2012	0.066
89	317 9th St SE	Lead	7/25/2012	0.067
90	2128 O ST NW	Lead	7/25/2012	0.077
91	75 Bates St NW	Lead	9/26/2012	0.077
92	2212 38th St NW	Lead	9/29/2012	0.079
93	3218 MACOMB ST NW	Lead	8/28/2012	0.097
94	3917 8th St NW	Partial Lead	10/23/2012	0.097
95	501 Webster St NW	Lead	8/27/2012	0.102
96	1808 KEARNEY ST NE	Partial Lead	9/26/2012	0.104
97	3202 38TH ST NW	Partial Lead	10/24/2012	0.107
98	605 Columbia Rd NW	Partial Lead	10/22/2012	0.107
99	3727 T St NW	Lead	8/29/2012	0.116
100	8 N St SW	Lead	9/25/2012	0.124
101	3907 13th St NW	Partial Lead	10/22/2012	0.125
102	5923 33rd St NW	Lead	9/26/2012	0.131
103	36 Florida Ave NW	Lead	8/28/2012	0.204
104	4703 Macarthur Blvd NW	Lead	8/29/2012	0.215
105	5316 28th St NW	Partial Lead	12/5/2012	0.290

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) 2212 38th St NW was mistakenly sampled twice. Both results are included in the table and 90th percentile calculation.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
1	1706 NEW JERSEY AVE NW	Lead	7/26/2012	0.0000
2	317 9th St SE	Lead	7/25/2012	0.0000
3	213 49th St NE	Lead	7/25/2012	0.0000
4	1025 44th St NE	Lead	7/25/2012	0.0000
5	2923 Cathedral AVE NW	Lead	7/25/2012	0.0000
6	1505 Buchanan St NW	Lead	7/25/2012	0.0000
7	3973 HARRISON ST NW	Lead	8/29/2012	0.0000
8	4926 Glenbrook Rd NW	Lead	8/28/2012	0.0000
9	4120 Grant St NE	Lead	8/29/2012	0.0000
10	336 Quackenbos St NE	Lead	8/29/2012	0.0000
11	3533 W PI NW	Lead	8/29/2012	0.0000
12	36 Florida Ave NW	Lead	8/28/2012	0.0000
13	1635 WEBSTER ST NW	Lead	9/27/2012	0.0000
14	1603 Massachusetts Ave SE	Partial Lead	9/25/2012	0.0000
15	619 12th St NE	Lead	9/26/2012	0.0000
16	6105 Dix St NE	Lead	10/2/2012	0.0000
17	1420 Hamlin St NE	Partial Lead	9/26/2012	0.0000
18	75 Bates St NW	Lead	9/26/2012	0.0000
19	3913 8TH ST NW	Partial Lead	10/24/2012	0.0000
20	3416 9th St NE	Partial Lead	10/25/2012	0.0000
21	333 34th St NE	Partial Lead	10/23/2012	0.0000
22	3036 P St NW	Partial Lead	10/23/2012	0.0000
23	413 4th St SE	Partial Lead	10/24/2012	0.0000
24	3218 MORRISON ST NW	Lead	11/28/2012	0.0000
25	611 Roxboro PI NW	Lead	12/5/2012	0.0000
26	753 Gresham PI NW	Lead	11/29/2012	0.0000
27	4214 8th St NW	Lead	8/29/2012	0.0006
28	1319 POTOMAC AVE SE	Partial Lead	9/26/2012	0.0006
29	1353 JEFFERSON ST NW	Partial Lead	9/25/2012	0.0006
30	6213 7TH ST NW	Partial Lead	10/24/2012	0.0006

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
31	3215 Mckinley St NW	Partial Lead	10/24/2012	0.0006
32	3202 38TH ST NW	Partial Lead	10/24/2012	0.0007
33	5316 28th St NW	Partial Lead	12/5/2012	0.0007
34	4627 49th St NW	Lead	8/31/2012	0.0008
35	4409 Lowell St NW	Lead	8/29/2012	0.0008
36	905 Kent Pl NE	Lead	9/25/2012	0.0008
37	3710 Huntington St NW	Lead	8/29/2012	0.0009
38	1203 Quincy St NW	Partial Lead	9/26/2012	0.0009
39	4332 BRANDYWINE ST NW	Partial Lead	10/24/2012	0.0009
40	1010 10th St NE	Lead	7/26/2012	0.0010
41	424 Luray Pl NW	Lead	12/4/2012	0.0010
42	1620 Webster St NW	Lead	7/24/2012	0.0012
43	2128 O ST NW	Lead	7/25/2012	0.0012
44	1808 KEARNEY ST NE	Partial Lead	9/26/2012	0.0012
45	804 Delafield Pl NW	Lead	9/26/2012	0.0012
46	780 Fairmont St NW	Partial Lead	10/23/2012	0.0012
47	605 Columbia Rd NW	Partial Lead	10/22/2012	0.0013
48	3917 8th St NW	Partial Lead	10/23/2012	0.0013
49	4824 46th St NW	Lead	8/29/2012	0.0014
50	335 17TH PL NE	Partial Lead	10/24/2012	0.0014
51	531 Tennessee Ave NE	Lead	8/4/2012	0.0015
52	4307 CHESAPEAKE ST NW	Lead	8/30/2012	0.0015
53	331 RALEIGH ST SE	Lead	8/28/2012	0.0015
54	1424 S ST NW	Lead	7/25/2012	0.0018
55	4613 9th St NW	Lead	11/29/2012	0.0018
56	87 S St NW	Lead	9/26/2012	0.0019
57	1011 Taylor St NE	Lead	7/25/2012	0.0020
58	3907 13th St NW	Partial Lead	10/22/2012	0.0020
59	6210 8th St NW	Lead	9/27/2012	0.0021
60	322 TENNESSEE AVE NE	Lead	12/5/2012	0.0021
61	4111 INGOMAR ST NW	Lead	11/28/2012	0.0025
62	4131 YUMA ST NW	Lead	8/29/2012	0.0026
63	636 ROCK CRK CHURCH RD NW	Lead	9/26/2012	0.0026
64	913 Hamlin St NE	Lead	9/24/2012	0.0026
65	617 M St NE	Lead	9/26/2012	0.0028
66	4818 ILLINOIS AVE NW	Lead	11/29/2012	0.0029
67	1434 Taylor St NW	Lead	12/4/2012	0.0029
68	1649 HARVARD ST NW	Lead	7/25/2012	0.0030
69	10 S St NW	Lead	7/24/2012	0.0030
70	1519 Olive St NE	Lead	7/25/2012	0.0030
71	8 N St SW	Lead	9/25/2012	0.0031

No.	Address	Pipe Material	Collection Date	Lead 2nd Draw (mg/L)
72	1318 Wallach Pl NW	Lead	7/25/2012	0.0034
73	3211 Central Ave NE	Lead	8/29/2012	0.0034
74	4401 5TH ST NW	Lead	8/29/2012	0.0036
75	3706 35th St NW	Lead	8/30/2012	0.0036
76	119 16TH ST NE	Lead	7/25/2012	0.0040
77	1703 D St NE	Lead	7/23/2012	0.0040
78	15 Milmarson Pl NW	Lead	7/26/2012	0.0040
79	4703 Macarthur Blvd NW	Lead	8/29/2012	0.0040
80	2212 38th St NW	Lead	12/10/2012	0.0040
81	1378 Taylor St NW	Lead	7/24/2012	0.0043
82	5923 33rd St NW	Lead	9/26/2012	0.0043
83	641 Gallatin St NW	Lead	9/26/2012	0.0044
84	5234 Illinois Ave NW	Lead	8/27/2012	0.0045
85	1826 Jackson St NE	Lead	7/25/2012	0.0053
86	619 Girard St NE	Lead	11/29/2012	0.0058
87	144 Tennessee Ave NE	Lead	7/25/2012	0.0060
88	4818 8th ST NW	Partial Lead	10/23/2012	0.0063
89	3216 Klinge Rd NW	Lead	8/29/2012	0.0064
90	5226 7th St NW	Lead	8/29/2012	0.0069
91	1357 C St NE	Lead	10/23/2012	0.0074
92	3727 T St NW	Lead	8/29/2012	0.0077
93	4550 30TH ST NW	Lead	8/29/2012	0.0087
94	230 G St NE	Partial Lead	10/24/2012	0.0087
95	3206 38th St NW	Lead	8/30/2012	0.0091
96	3218 MACOMB ST NW	Lead	8/28/2012	0.0098
97	4418 14th St NE	Lead	8/28/2012	0.0104
98	1346 F St NE	Lead	7/24/2012	0.0125
99	2212 38th St NW	Lead	9/29/2012	0.0139
100	2435 33RD ST SE	Lead	7/25/2012	0.0158
101	228 V ST NE	Lead	7/24/2012	0.0171
102	807 Buchanan St NW	Lead	9/25/2012	0.0374

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as "0.0000" may have been reported by the laboratory as non-detect or < 0.0005 mg/L.
- 3) The second draw samples were rejected from three customers that submitted valid first draw samples because they did not follow the sampling criteria as described in the instructions.

Table B.2 Second Draw Copper Results

No.	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
1	1505 Buchanan St NW	Lead	7/25/2012	0.000
2	3706 35th St NW	Lead	8/30/2012	0.002
3	3973 HARRISON ST NW	Lead	8/29/2012	0.003
4	636 ROCK CRK CHURCH RD NW	Lead	9/26/2012	0.004
5	4818 ILLINOIS AVE NW	Lead	11/29/2012	0.004
6	4131 YUMA ST NW	Lead	8/29/2012	0.005
7	6213 7TH ST NW	Partial Lead	10/24/2012	0.005
8	3218 MORRISON ST NW	Lead	11/28/2012	0.005
9	3216 Klinge Rd NW	Lead	8/29/2012	0.006
10	3533 W PI NW	Lead	8/29/2012	0.006
11	4214 8th St NW	Lead	8/29/2012	0.006
12	424 Luray PI NW	Lead	12/4/2012	0.006
13	1434 Taylor St NW	Lead	12/4/2012	0.006
14	1620 Webster St NW	Lead	7/24/2012	0.007
15	1378 Taylor St NW	Lead	7/24/2012	0.007
16	3206 38th St NW	Lead	8/30/2012	0.007
17	5226 7th St NW	Lead	8/29/2012	0.007
18	1635 WEBSTER ST NW	Lead	9/27/2012	0.007
19	807 Buchanan St NW	Lead	9/25/2012	0.007
20	3416 9th St NE	Partial Lead	10/25/2012	0.007
21	4111 INGOMAR ST NW	Lead	11/28/2012	0.007
22	619 Girard St NE	Lead	11/29/2012	0.007
23	213 49th St NE	Lead	7/25/2012	0.008
24	1346 F St NE	Lead	7/24/2012	0.009
25	4550 30TH ST NW	Lead	8/29/2012	0.009
26	4120 Grant St NE	Lead	8/29/2012	0.009
27	641 Gallatin St NW	Lead	9/26/2012	0.009
28	6105 Dix St NE	Lead	10/2/2012	0.009
29	6210 8th St NW	Lead	9/27/2012	0.009
30	1826 Jackson St NE	Lead	7/25/2012	0.010
31	10 S St NW	Lead	7/24/2012	0.010
32	5234 Illinois Ave NW	Lead	8/27/2012	0.010
33	804 Delafield PI NW	Lead	9/26/2012	0.010
34	1706 NEW JERSEY AVE NW	Lead	7/26/2012	0.011
35	1420 Hamlin St NE	Partial Lead	9/26/2012	0.011
36	3913 8TH ST NW	Partial Lead	10/24/2012	0.011
37	119 16TH ST NE	Lead	7/25/2012	0.012
38	2435 33RD ST SE	Lead	7/25/2012	0.012
39	3218 MACOMB ST NW	Lead	8/28/2012	0.012

No.	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
40	3211 Central Ave NE	Lead	8/29/2012	0.012
41	336 Quackenbos St NE	Lead	8/29/2012	0.012
42	3727 T St NW	Lead	8/29/2012	0.012
43	619 12th St NE	Lead	9/26/2012	0.012
44	905 Kent Pl NE	Lead	9/25/2012	0.012
45	3036 P St NW	Partial Lead	10/23/2012	0.012
46	2212 38th St NW	Lead	12/10/2012	0.012
47	1010 10th St NE	Lead	7/26/2012	0.013
48	2923 Cathedral AVE NW	Lead	7/25/2012	0.013
49	1318 Wallach Pl NW	Lead	7/25/2012	0.013
50	4824 46th St NW	Lead	8/29/2012	0.013
51	333 34th St NE	Partial Lead	10/23/2012	0.013
52	1025 44th St NE	Lead	7/25/2012	0.014
53	531 Tennessee Ave NE	Lead	8/4/2012	0.014
54	4307 CHESAPEAKE ST NW	Lead	8/30/2012	0.014
55	780 Fairmont St NW	Partial Lead	10/23/2012	0.014
56	1011 Taylor St NE	Lead	7/25/2012	0.015
57	2212 38th St NW	Lead	9/29/2012	0.015
58	1603 Massachusetts Ave SE	Partial Lead	9/25/2012	0.015
59	3215 Mckinley St NW	Partial Lead	10/24/2012	0.015
60	322 TENNESSEE AVE NE	Lead	12/5/2012	0.015
61	228 V ST NE	Lead	7/24/2012	0.016
62	4818 8th ST NW	Partial Lead	10/23/2012	0.016
63	230 G St NE	Partial Lead	10/24/2012	0.016
64	144 Tennessee Ave NE	Lead	7/25/2012	0.017
65	3710 Huntington St NW	Lead	8/29/2012	0.017
66	1649 HARVARD ST NW	Lead	7/25/2012	0.018
67	317 9th St SE	Lead	7/25/2012	0.018
68	75 Bates St NW	Lead	9/26/2012	0.018
69	611 Roxboro Pl NW	Lead	12/5/2012	0.018
70	15 Milmarson Pl NW	Lead	7/26/2012	0.019
71	4418 14th St NE	Lead	8/28/2012	0.019
72	4332 BRANDYWINE ST NW	Partial Lead	10/24/2012	0.019
73	1519 Olive St NE	Lead	7/25/2012	0.020
74	87 S St NW	Lead	9/26/2012	0.020
75	413 4th St SE	Partial Lead	10/24/2012	0.020
76	4409 Lowell St NW	Lead	8/29/2012	0.022
77	4926 Glenbrook Rd NW	Lead	8/28/2012	0.022
78	36 Florida Ave NW	Lead	8/28/2012	0.022
79	4613 9th St NW	Lead	11/29/2012	0.022
80	1424 S ST NW	Lead	7/25/2012	0.023
81	4703 Macarthur Blvd NW	Lead	8/29/2012	0.027

No.	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
82	335 17TH PL NE	Partial Lead	10/24/2012	0.027
83	1703 D St NE	Lead	7/23/2012	0.028
84	1319 POTOMAC AVE SE	Partial Lead	9/26/2012	0.029
85	4627 49th St NW	Lead	8/31/2012	0.030
86	4401 5TH ST NW	Lead	8/29/2012	0.031
87	3202 38TH ST NW	Partial Lead	10/24/2012	0.032
88	913 Hamlin St NE	Lead	9/24/2012	0.038
89	331 RALEIGH ST SE	Lead	8/28/2012	0.041
90	1353 JEFFERSON ST NW	Partial Lead	9/25/2012	0.041
91	2128 O ST NW	Lead	7/25/2012	0.043
92	1357 C St NE	Lead	10/23/2012	0.044
93	1203 Quincy St NW	Partial Lead	9/26/2012	0.053
94	5923 33rd St NW	Lead	9/26/2012	0.066
95	617 M St NE	Lead	9/26/2012	0.072
96	3917 8th St NW	Partial Lead	10/23/2012	0.077
97	753 Gresham Pl NW	Lead	11/29/2012	0.082
98	3907 13th St NW	Partial Lead	10/22/2012	0.085
99	605 Columbia Rd NW	Partial Lead	10/22/2012	0.092
100	8 N St SW	Lead	9/25/2012	0.095
101	1808 KEARNEY ST NE	Partial Lead	9/26/2012	0.097
102	5316 28th St NW	Partial Lead	12/5/2012	0.131

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) The second draw samples were rejected from two customers that submitted valid first draw samples because they did not follow the sampling criteria as described in the instructions.

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No.	Address	Bottle Drop Off Date
1	10 S St NW	7/23/2012
2	1003 Otis St NE	7/23/2012
3	1010 10th St NE	7/23/2012
4	1011 Taylor St NE	7/23/2012
5	1014 Douglas St NE	7/23/2012
6	1025 44th St NE	7/23/2012
7	1106 Allison St NW	7/23/2012
8	119 16TH ST NE	7/23/2012
9	1212 E Capitol St NE	7/23/2012
10	125 Madison St NW	7/23/2012
11	1315 FRANKLIN ST NE	7/23/2012
12	1318 Wallach Pl NW	7/23/2012
13	1331 Irving St NE	7/23/2012
14	1339 U St SE	7/23/2012
15	1346 F St NE	7/23/2012
16	1346 Madison St NW	7/23/2012
17	1378 Taylor St NW	7/23/2012
18	1424 S ST NW	7/23/2012
19	1429 Ives Pl SE	7/23/2012
20	143 UHLAND TER NE	7/23/2012
21	1436 S St NW	7/23/2012
22	144 Tennessee Ave NE	7/23/2012
23	15 Milmarson Pl NW	7/23/2012
24	1505 Buchanan St NW	7/23/2012
25	1519 Olive St NE	7/23/2012
26	1520 Locust Rd NW	7/23/2012
27	1620 Hamlin St NE	7/23/2012
28	1620 Webster St NW	7/23/2012
29	1623 U St SE	7/23/2012
30	1635 WEBSTER ST NW	7/23/2012
31	1649 HARVARD ST NW	7/23/2012
32	1703 D St NE	7/23/2012
33	1705 2nd St NE	7/23/2012
34	1706 NEW JERSEY AVE NW	7/23/2012
35	1826 Jackson St NE	7/23/2012
36	2007 37TH ST NW	7/23/2012
37	203 Rock Creek Church Rd NW	7/23/2012
38	2107 2nd St NE	7/23/2012
39	2128 O ST NW	7/23/2012

No.	Address	Bottle Drop Off Date
40	213 49th St NE	7/23/2012
41	2212 38th St NW	7/23/2012
42	228 V ST NE	7/23/2012
43	2300 Woodridge St NE	7/23/2012
44	2435 33RD ST SE	7/23/2012
45	2830 BRENTWOOD RD NE	7/23/2012
46	2913 Brandywine St NW	7/23/2012
47	2923 Cathedral AVE NW	7/23/2012
48	307 7th St NE	7/23/2012
49	317 9th St SE	7/23/2012
50	531 Tennessee Ave NE	7/23/2012
51	1262 COLUMBIA RD NW	8/27/2012
52	3206 38th St NW	8/27/2012
53	3211 Central Ave NE	8/27/2012
54	3216 Klinge Rd NW	8/27/2012
55	3218 MACOMB ST NW	8/27/2012
56	322 TENNESSEE AVE NE	8/27/2012
57	3232 Klinge Rd NW	8/27/2012
58	331 RALEIGH ST SE	8/27/2012
59	331 Upshur St NW	8/27/2012
60	336 Quackenbos St NE	8/27/2012
61	3361 Stuyvesant PI NW	8/27/2012
62	3400 Holmead PI NW	8/27/2012
63	349 TENNESSEE AVE NE	8/27/2012
64	3533 W PI NW	8/27/2012
65	36 Florida Ave NW	8/27/2012
66	3612 34th St NW	8/27/2012
67	3706 35th St NW	8/27/2012
68	3710 Huntington St NW	8/27/2012
69	3727 T St NW	8/27/2012
70	3908 13TH ST NW	8/27/2012
71	3973 HARRISON ST NW	8/27/2012
72	4118 13TH ST NW	8/27/2012
73	4120 Grant St NE	8/27/2012
74	4131 YUMA ST NW	8/27/2012
75	416 7th St NE	8/27/2012
76	4214 8th St NW	8/27/2012
77	4307 CHESAPEAKE ST NW	8/27/2012
78	4401 5TH ST NW	8/27/2012
79	4409 Lowell St NW	8/27/2012
80	4411 15th St NW	8/27/2012
81	4418 14th St NE	8/27/2012
82	4550 30TH ST NW	8/27/2012

No.	Address	Bottle Drop Off Date
83	4627 49th St NW	8/27/2012
84	4703 Macarthur Blvd NW	8/27/2012
85	4718 Sheriff Rd NE	8/27/2012
86	4824 46th St NW	8/27/2012
87	4926 Glenbrook Rd NW	8/27/2012
88	501 Webster St NW	8/27/2012
89	5024 7th St NW	8/27/2012
90	5226 7th St NW	8/27/2012
91	5234 Illinois Ave NW	8/27/2012
92	524 10th St SE	8/27/2012
93	524 Shepherd St NW	8/27/2012
94	5318 9TH ST NW	8/27/2012
95	5517 7th St NW	8/27/2012
96	5612 14th St NW	8/27/2012
97	5613 30th St NW	8/27/2012
98	5731 3rd Pl NW	8/27/2012
99	1203 Quincy St NW	9/24/2012
100	1211 Carrollsburg Pl SW	9/24/2012
101	1222 HAMILTON ST NW	9/24/2012
102	1319 POTOMAC AVE SE	9/24/2012
103	1353 Iris St NW	9/24/2012
104	1353 JEFFERSON ST NW	9/24/2012
105	1387 N Carolina Ave NE	9/24/2012
106	1420 Hamlin St NE	9/24/2012
107	1424 S ST SE	9/24/2012
108	1603 Massachusetts Ave SE	9/24/2012
109	1614 V St SE	9/24/2012
110	1619 G St SE	9/24/2012
111	1635 WEBSTER ST NW	9/24/2012
112	1671 Rosedale St NE	9/24/2012
113	1731 L St NE	9/24/2012
114	1736 Bay St SE	9/24/2012
115	1808 KEARNEY ST NE	9/24/2012
116	1836 L St NE	9/24/2012
117	1908 Biltmore St NW	9/24/2012
118	1931 SUMMIT PL NE	9/24/2012
119	2212 38th St NW	9/24/2012
120	3601 WARREN ST NW	9/24/2012
121	4310 37th St NW	9/24/2012
122	580 49th Pl NE	9/24/2012
123	5907 4th St NW	9/24/2012
124	5923 33rd St NW	9/24/2012
125	6001 33rd St NW	9/24/2012

No.	Address	Bottle Drop Off Date
126	608 Gallatin St NW	9/24/2012
127	6105 Dix St NE	9/24/2012
128	617 6th St NE	9/24/2012
129	617 M St NE	9/24/2012
130	619 12th St NE	9/24/2012
131	621 Upshur St NW	9/24/2012
132	6210 8th St NW	9/24/2012
133	6308 8th St NW	9/24/2012
134	636 ROCK CRK CHURCH RD NW	9/24/2012
135	641 Gallatin St NW	9/24/2012
136	644 Lamont St NW	9/24/2012
137	702 9th St SE	9/24/2012
138	720 ALABAMA AVE SE	9/24/2012
139	75 Bates St NW	9/24/2012
140	8 N St SW	9/24/2012
141	804 Delafield PI NW	9/24/2012
142	807 Buchanan St NW	9/24/2012
143	811 E St SE	9/24/2012
144	834 Delafield PI NW	9/24/2012
145	87 S St NW	9/24/2012
146	905 Kent PI NE	9/24/2012
147	910 Farragut St NW	9/24/2012
148	912 Emerson St NW	9/24/2012
149	913 Hamlin St NE	9/24/2012
150	915 Farragut St NW	9/24/2012
151	926 Hamilton St NW	9/24/2012
152	10 Evarts St NE	10/22/2012
153	1003 Quebec PI NW	10/22/2012
154	108 Varnum St NW	10/22/2012
155	1302 Randolph St NW	10/22/2012
156	1320 Allison St NE	10/22/2012
157	1357 C St NE	10/22/2012
158	1400 FLORAL ST NW	10/22/2012
159	1409 22nd St SE	10/22/2012
160	1434 Taylor St NW	10/22/2012
161	1453 S St NW	10/22/2012
162	1525 D St NE	10/22/2012
163	1533 Upshur St NW	10/22/2012
164	201 13th St NE	10/22/2012
165	2121 15th St NW	10/22/2012
166	223 14th PI NE	10/22/2012
167	230 G St NE	10/22/2012
168	231 K St NE	10/22/2012

No.	Address	Bottle Drop Off Date
169	234 Longfellow St NW	10/22/2012
170	24 Evarts St NE	10/22/2012
171	258 15th St SE	10/22/2012
172	2604 Rhode Island Ave NE	10/22/2012
173	2928 33rd Pl NW	10/22/2012
174	302 RITTENHOUSE ST NW	10/22/2012
175	3030 44TH ST NW	10/22/2012
176	3036 P St NW	10/22/2012
177	32 Todd Pl NE	10/22/2012
178	3202 38TH ST NW	10/22/2012
179	3215 Mckinley St NW	10/22/2012
180	333 34th St NE	10/22/2012
181	335 17TH Pl NE	10/22/2012
182	3416 9th St NE	10/22/2012
183	3531 16TH ST NW	10/22/2012
184	3809 ALTON Pl NW	10/22/2012
185	3907 13th St NW	10/22/2012
186	3913 8TH ST NW	10/22/2012
187	3917 8th St NW	10/22/2012
188	413 4th St SE	10/22/2012
189	420 Kenyon St NW	10/22/2012
190	4327 IOWA AVE NW	10/22/2012
191	4332 BRANDYWINE ST NW	10/22/2012
192	4429 3rd St NW	10/22/2012
193	4818 8th ST NW	10/22/2012
194	502 Oglethorpe St NW	10/22/2012
195	514 13th St SE	10/22/2012
196	5316 28th St NW	10/22/2012
197	5404 39TH ST NW	10/22/2012
198	605 Columbia Rd NW	10/22/2012
199	6213 7TH ST NW	10/22/2012
200	780 Fairmont St NW	10/22/2012
201	817 DECATUR ST NW	10/22/2012
202	2649 Bowen Rd SE	11/26/2012
203	3033 Bladensburg Rd NE	11/26/2012
204	321 Aspen St NW	11/26/2012
205	3217 Georgia Ave NW	11/26/2012
206	3218 MORRISON ST NW	11/26/2012
207	3427 Oliver St NW	11/26/2012
208	3431 S Dakota Ave NE	11/26/2012
209	3511 Woodley Rd NW	11/26/2012
210	410 Farragut St NW	11/26/2012
211	4111 INGOMAR ST NW	11/26/2012

No.	Address	Bottle Drop Off Date
212	4210 Clay St NE	11/26/2012
213	424 Luray Pl NW	11/26/2012
214	432 15th St SE	11/26/2012
215	4419 14th St NE	11/26/2012
216	4423 Kane Pl NE	11/26/2012
217	449 S St NW	11/26/2012
218	452 Newton Pl NW	11/26/2012
219	4606 Sheriff Rd NE	11/26/2012
220	4609 5th St NW	11/26/2012
221	4613 9th St NW	11/26/2012
222	4818 ILLINOIS AVE NW	11/26/2012
223	507 Alabama Ave SE	11/26/2012
224	53 P St NW	11/26/2012
225	5301 RENO RD NW	11/26/2012
226	5328 Kansas Ave NW	11/26/2012
227	536 Newton Pl NW	11/26/2012
228	5404 Kansas Ave NW	11/26/2012
229	5516 Kansas Ave NW	11/26/2012
230	5817 7th St NW	11/26/2012
231	5909 16th St NW	11/26/2012
232	6001 Nevada Ave NW	11/26/2012
233	611 Roxboro Pl NW	11/26/2012
234	619 Girard St NE	11/26/2012
235	632 Webster St NW	11/26/2012
236	743 Gresham Pl NW	11/26/2012
237	753 Gresham Pl NW	11/26/2012
238	760 Gresham Pl NW	11/26/2012
239	81 O St NW	11/26/2012
240	810 Savannah St SE	11/26/2012
241	1434 Taylor St NW	12/3/2012
242	2212 38th St NW	12/3/2012
243	322 TENNESSEE AVE NE	12/3/2012
244	5316 28th St NW	12/3/2012

Table C.2 Sample Kits Not Returned

No.	Address	Bottle Drop Off Date
1	1003 Otis St NE	7/23/2012
2	1014 Douglas St NE	7/23/2012
3	1212 E Capitol St NE	7/23/2012
4	1331 Irving St NE	7/23/2012
5	1339 U St SE	7/23/2012
6	1346 Madison St NW	7/23/2012
7	1429 Ives Pl SE	7/23/2012
8	143 UHLAND TER NE	7/23/2012
9	1436 S St NW	7/23/2012
10	1520 Locust Rd NW	7/23/2012
11	1620 Hamlin St NE	7/23/2012
12	1623 U St SE	7/23/2012
13	1705 2nd St NE	7/23/2012
14	2107 2nd St NE	7/23/2012
15	2300 Woodridge St NE	7/23/2012
16	307 7th St NE	7/23/2012
17	322 TENNESSEE AVE NE	8/27/2012
18	3232 Klinge Rd NW	8/27/2012
19	3361 Stuyvesant Pl NW	8/27/2012
20	3612 34th St NW	8/27/2012
21	3908 13TH ST NW	8/27/2012
22	416 7th St NE	8/27/2012
23	4718 Sheriff Rd NE	8/27/2012
24	5024 7th St NW	8/27/2012
25	5517 7th St NW	8/27/2012
26	5612 14th St NW	8/27/2012
27	5613 30th St NW	8/27/2012
28	5731 3rd Pl NW	8/27/2012
29	1211 Carrollsburg Pl SW	9/24/2012
30	1353 Iris St NW	9/24/2012
31	1424 S ST SE	9/24/2012
32	1614 V St SE	9/24/2012
33	1619 G St SE	9/24/2012
34	1671 Rosedale St NE	9/24/2012
35	1736 Bay St SE	9/24/2012
36	1908 Biltmore St NW	9/24/2012
37	1931 SUMMIT PL NE	9/24/2012
38	3601 WARREN ST NW	9/24/2012
39	580 49th Pl NE	9/24/2012
40	5907 4th St NW	9/24/2012
41	6001 33rd St NW	9/24/2012

No.	Address	Bottle Drop Off Date
42	617 6th St NE	9/24/2012
43	621 Upshur St NW	9/24/2012
44	720 ALABAMA AVE SE	9/24/2012
45	811 E St SE	9/24/2012
46	910 Farragut St NW	9/24/2012
47	912 Emerson St NW	9/24/2012
48	915 Farragut St NW	9/24/2012
49	10 Evarts St NE	10/22/2012
50	1003 Quebec Pl NW	10/22/2012
51	108 Varnum St NW	10/22/2012
52	1320 Allison St NE	10/22/2012
53	1400 FLORAL ST NW	10/22/2012
54	1409 22nd St SE	10/22/2012
55	1434 Taylor St NW	10/22/2012
56	1453 S St NW	10/22/2012
57	1525 D St NE	10/22/2012
58	1533 Upshur St NW	10/22/2012
59	201 13th St NE	10/22/2012
60	2121 15th St NW	10/22/2012
61	234 Longfellow St NW	10/22/2012
62	24 Evarts St NE	10/22/2012
63	258 15th St SE	10/22/2012
64	2604 Rhode Island Ave NE	10/22/2012
65	2928 33rd Pl NW	10/22/2012
66	3030 44TH ST NW	10/22/2012
67	32 Todd Pl NE	10/22/2012
68	3531 16TH ST NW	10/22/2012
69	420 Kenyon St NW	10/22/2012
70	514 13th St SE	10/22/2012
71	5316 28th St NW	10/22/2012
72	5404 39TH ST NW	10/22/2012
73	817 DECATUR ST NW	10/22/2012
74	2649 Bowen Rd SE	11/26/2012
75	3033 Bladensburg Rd NE	11/26/2012
76	321 Aspen St NW	11/26/2012
77	3217 Georgia Ave NW	11/26/2012
78	3427 Oliver St NW	11/26/2012
79	3431 S Dakota Ave NE	11/26/2012
80	3511 Woodley Rd NW	11/26/2012
81	410 Farragut St NW	11/26/2012
82	4210 Clay St NE	11/26/2012
83	432 15th St SE	11/26/2012
84	4419 14th St NE	11/26/2012

No.	Address	Bottle Drop Off Date
85	4423 Kane Pl NE	11/26/2012
86	449 S St NW	11/26/2012
87	452 Newton Pl NW	11/26/2012
88	4606 Sheriff Rd NE	11/26/2012
89	4609 5th St NW	11/26/2012
90	507 Alabama Ave SE	11/26/2012
91	53 P St NW	11/26/2012
92	5301 RENO RD NW	11/26/2012
93	5328 Kansas Ave NW	11/26/2012
94	536 Newton Pl NW	11/26/2012
95	5404 Kansas Ave NW	11/26/2012
96	5516 Kansas Ave NW	11/26/2012
97	5909 16th St NW	11/26/2012
98	6001 Nevada Ave NW	11/26/2012
99	632 Webster St NW	11/26/2012
100	760 Gresham Pl NW	11/26/2012
101	81 O St NW	11/26/2012
102	810 Savannah St SE	11/26/2012

Table C.3 Samples Returned and Rejected for Compliance Analysis

No.	Address	Bottle Drop Off Date	Reject Reason
1	1106 Allison St NW	7/23/2012	Water used during stagnation
2	125 Madison St NW	7/23/2012	Ice maker, humidifier, or sprinkler on during stagnation
3	1315 FRANKLIN ST NE	7/23/2012	No Chain of Custody
4	1635 WEBSTER ST NW	7/23/2012	Water used during stagnation
5	2007 37TH ST NW	7/23/2012	Both bottles labeled 1st draw and same collect time
6	203 Rock Creek Church Rd NW	7/23/2012	Multi-family housing
7	2212 38th St NW	7/23/2012	Stagnation greater than 18 hours
8	2830 BRENTWOOD RD NE	7/23/2012	Ice maker, humidifier, or sprinkler on during stagnation
9	2913 Brandywine St NW	7/23/2012	Ice maker, humidifier, or sprinkler on during stagnation
10	1262 COLUMBIA RD NW	8/27/2012	No Chain of Custody
11	331 Upshur St NW	8/27/2012	Bottles not full
12	3400 Holmead PI NW	8/27/2012	Incomplete Chain of Custody
13	4118 13TH ST NW	8/27/2012	No Chain of Custody
14	4411 15th St NW	8/27/2012	Ice maker, humidifier, or sprinkler on during stagnation
15	524 10th St SE	8/27/2012	Ice maker, humidifier, or sprinkler on during stagnation
16	524 Shepherd St NW	8/27/2012	Water used during stagnation
17	5318 9TH ST NW	8/27/2012	Ice maker, humidifier, or sprinkler on during stagnation
18	1222 HAMILTON ST NW	9/24/2012	Incomplete Chain of Custody
19	1387 N Carolina Ave NE	9/24/2012	Water used during stagnation
20	1731 L St NE	9/24/2012	Leak in plumbing
21	1836 L St NE	9/24/2012	Bottles not marked 1st or 2nd draw
22	4310 37th St NW	9/24/2012	Ice maker, humidifier, or sprinkler on during stagnation
23	608 Gallatin St NW	9/24/2012	Incomplete Chain of Custody
24	6308 8th St NW	9/24/2012	No Chain of Custody
25	644 Lamont St NW	9/24/2012	No Chain of Custody
26	702 9th St SE	9/24/2012	Stagnation unknown
27	834 Delafield PI NW	9/24/2012	No Chain of Custody
28	1302 Randolph St NW	10/22/2012	Multi-family housing
29	223 14th PI NE	10/22/2012	Stagnation less than 6 hours
30	231 K St NE	10/22/2012	Bottles not marked 1st or 2nd draw
31	302 RITTENHOUSE ST NW	10/22/2012	Incomplete Chain of Custody
32	3809 ALTON PL NW	10/22/2012	Bottles not marked 1st or 2nd draw
33	4327 IOWA AVE NW	10/22/2012	Bottles not full
34	4429 3rd St NW	10/22/2012	No lead; public portion replaced in May 2007 and private portion in Sept 2011 (reported by customer in Oct 2012)
35	502 Oglethorpe St NW	10/22/2012	Ice maker, humidifier, or sprinkler on during stagnation
36	5817 7th St NW	11/26/2012	Stagnation less than 6 hours
37	743 Gresham PI NW	11/26/2012	Stagnation less than 6 hours

Table C.4 Deviations from Sample Order

No	Address	Priority	Scheduled Month	Reason for Deviation
1	1150 Abbey Pl NE	Primary	July	Customer no longer wants to participate in program
2	118 Kentucky Ave SE	Primary	July	Customer no longer wants to participate in program
3	1262 COLUMBIA RD NW	Primary	July	Requested next month
4	1635 WEBSTER ST NW	Primary	July	Rejected first set of samples and customer sampled again
5	2212 38th St NW	Primary	July	Rejected first set of samples and customer sampled again in Sept; mistakenly dropped bottles again in Dec
6	313 Aspen St NW	Primary	July	Customer no longer wants to participate in program
7	322 TENNESSEE AVE NE	Primary	Aug	No response on scheduled month, dropped off bottles again in Dec
8	3601 WARREN ST NW	Primary	Aug	Requested next month
9	4310 37th St NW	Primary	Aug	Requested next month
10	5122 Cathedral Ave NW	Primary	Aug	Customer no longer wants to participate in program
11	7129 Georgia Ave NW	Primary	Sep	Customer no longer wants to participate in program
12	5301 RENO RD NW	Primary	Oct	Requested next month
13	5316 28th St NW	Primary	Oct	No response on scheduled month, dropped off bottles again in Dec
14	1434 Taylor St NW	Secondary	Oct	Rejected first set of samples and customer sampled again in Dec
15	531 Tennessee Ave NE	New	None	New participant
16	1378 Taylor St NW	New	None	New participant
17	1346 F St NE	New	None	New participant
18	2128 O ST NW	New	None	New participant

Notes:

- 1) All “New participant” addresses meet Tier 1 criteria under 40 CFR § 141.86(a)(ii) as single family structures with full lead service lines based on DC Water’s customer information and service line inventory.

**Table C.5 Sites with Compliance Results from July 2011 – June 2012 and
No Results in Jul - Dec 2012**

No.	Address	Reason
1	1014 Douglas St NE	No bottles returned this semester; see Table C.2
2	1106 Allison St NW	Samples rejected; see Table C.3
3	118 Kentucky Ave SE	Requested to be removed from the program this semester; see Table C.4
4	1211 Carrollsburg Pl SW	No bottles returned this semester; see Table C.2
5	1212 E Capitol St NE	No bottles returned this semester; see Table C.2
6	1222 HAMILTON ST NW	Samples rejected; see Table C.3
7	125 Madison St NW	Samples rejected; see Table C.3
8	1262 COLUMBIA RD NW	Samples rejected; see Table C.3
9	1315 FRANKLIN ST NE	Samples rejected; see Table C.3
10	1331 Irving St NE	No bottles returned this semester; see Table C.2
11	1339 U St SE	No bottles returned this semester; see Table C.2
12	1346 Madison St NW	No bottles returned this semester; see Table C.2
13	1424 S ST SE	No bottles returned this semester; see Table C.2
14	1436 S St NW	No bottles returned this semester; see Table C.2
15	1520 Locust Rd NW	No bottles returned this semester; see Table C.2
16	1614 V St SE	No bottles returned this semester; see Table C.2
17	1623 U St SE	No bottles returned this semester; see Table C.2
18	1671 Rosedale St NE	No bottles returned this semester; see Table C.2
19	1705 2nd St NE	No bottles returned this semester; see Table C.2
20	1736 Bay St SE	No bottles returned this semester; see Table C.2
21	1836 L St NE	Samples rejected; see Table C.3
22	1908 Biltmore St NW	No bottles returned this semester; see Table C.2
23	2007 37TH ST NW	Samples rejected; see Table C.3
24	201 13th St NE	No bottles returned this semester; see Table C.2
25	2300 Woodridge St NE	No bottles returned this semester; see Table C.2
26	231 K St NE	Samples rejected; see Table C.3
27	234 Longfellow St NW	No bottles returned this semester; see Table C.2
28	2724 36TH PL NW	Removed prior to the July-Dec 2012 compliance period
29	2830 BRENTWOOD RD NE	Samples rejected; see Table C.3
30	3001 7th St NE	Removed prior to the July-Dec 2012 compliance period
31	3030 44TH ST NW	No bottles returned this semester; see Table C.2
32	307 7th St NE	No bottles returned this semester; see Table C.2
33	3232 Klinge Rd NW	No bottles returned this semester; see Table C.2
34	3361 Stuyvesant Pl NW	No bottles returned this semester; see Table C.2
35	3531 16TH ST NW	No bottles returned this semester; see Table C.2
36	3601 WARREN ST NW	No bottles returned this semester; see Table C.2
37	3612 34th St NW	No bottles returned this semester; see Table C.2
38	3618 PORTER ST NW	Removed prior to the July-Dec 2012 compliance period
39	3809 ALTON PL NW	Samples rejected; see Table C.3
40	3908 13TH ST NW	No bottles returned this semester; see Table C.2

No.	Address	Reason
41	420 Kenyon St NW	No bottles returned this semester; see Table C.2
42	4305 38TH ST NW	Removed prior to the July-Dec 2012 compliance period
43	4429 3rd St NW	Samples rejected; see Table C.3
44	502 Oglethorpe St NW	Samples rejected; see Table C.3
45	5024 7th St NW	No bottles returned this semester; see Table C.2
46	5122 Cathedral Ave NW	Requested to be removed from the program this semester; see Table C.4
47	514 13th St SE	No bottles returned this semester; see Table C.2
48	524 10th St SE	Samples rejected; see Table C.3
49	524 Shepherd St NW	Samples rejected; see Table C.3
50	5404 39TH ST NW	No bottles returned this semester; see Table C.2
51	5517 7th St NW	No bottles returned this semester; see Table C.2
52	5613 30th St NW	No bottles returned this semester; see Table C.2
53	5731 3rd PI NW	No bottles returned this semester; see Table C.2
54	580 49th PI NE	No bottles returned this semester; see Table C.2
55	5907 4th St NW	No bottles returned this semester; see Table C.2
56	6001 33rd St NW	No bottles returned this semester; see Table C.2
57	617 6th St NE	No bottles returned this semester; see Table C.2
58	6308 8th St NW	Samples rejected; see Table C.3
59	702 9th St SE	Samples rejected; see Table C.3
60	7129 Georgia Ave NW	Requested to be removed from the program this semester; see Table C.4
61	720 ALABAMA AVE SE	No bottles returned this semester; see Table C.2
62	817 DECATUR ST NW	No bottles returned this semester; see Table C.2
63	826 Emerson St NW	Removed prior to the July-Dec 2012 compliance period
64	912 Emerson St NW	No bottles returned this semester; see Table C.2

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-001

SAMPLE INFORMATION

Sample Number: 1207260-001 Customer Sample Number: 3002817 Project: LCR
Location: 1st Draw 1318 WALLACH PL NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:42 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.064 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-002

SAMPLE INFORMATION

Sample Number: 1207260-002 Customer Sample Number: 3002817 Project: LCR
Location: 2nd Draw 1318 WALLACH PL NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-003

SAMPLE INFORMATION

Sample Number: 1207260-003 Customer Sample Number: 3026174 Project: LCR
Location: 1st Draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 7/26/2012 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.210 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.063 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-004

SAMPLE INFORMATION

Sample Number: 1207260-004 Customer Sample Number: 3026174 Project: LCR
Location: 2nd draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 7/26/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.224 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-005

SAMPLE INFORMATION

Sample Number: 1207260-005 Customer Sample Number: 3106027 Project: LCR
Location: 1st Draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.068 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0027 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-006

SAMPLE INFORMATION

Sample Number: 1207260-006 Customer Sample Number: 3106027 Project: LCR
Location: 2nd Draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.084 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0053 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-007

SAMPLE INFORMATION

Sample Number: 1207260-007 Customer Sample Number: 3006211 Project: LCR
Location: 1st Draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 7/26/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-008

SAMPLE INFORMATION

Sample Number: 1207260-008 Customer Sample Number: 3006211 Project: LCR
Location: 2nd Draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 7/26/2012 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-009

SAMPLE INFORMATION

Sample Number: 1207260-009 Customer Sample Number: 3099025 Project: LCR
Location: 1st Draw 1010 10TH ST NE Type: Dist.

Collection Date: 7/26/2012 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.062 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-010

SAMPLE INFORMATION

Sample Number: 1207260-010 Customer Sample Number: 3099025 Project: LCR
Location: 2nd Draw 1010 10TH ST NE Type: Dist.

Collection Date: 7/26/2012 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-011

SAMPLE INFORMATION

Sample Number: 1207260-011 Customer Sample Number: 3029191 Project: LCR
Location: 1st Draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.065 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-012

SAMPLE INFORMATION

Sample Number: 1207260-012 Customer Sample Number: 3029191 Project: LCR
Location: 2nd Draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.064 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-013

SAMPLE INFORMATION

Sample Number: 1207260-013 Customer Sample Number: 3000532 Project: LCR
Location: 1st Draw 2128 O ST. NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.077 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-014

SAMPLE INFORMATION

Sample Number: 1207260-014 Customer Sample Number: 3000532 Project: LCR
Location: 2nd Draw 2128 O ST. NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.043 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-015

SAMPLE INFORMATION

Sample Number: 1207260-015 Customer Sample Number: 3100684 Project: LCR
Location: 1st Draw 1346 F ST. NE Type: Dist.

Collection Date: 7/24/2012 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0069 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-016

SAMPLE INFORMATION

Sample Number: 1207260-016 Customer Sample Number: 3100684 Project: LCR
Location: 2nd Draw 1346 F ST. NE Type: Dist.

Collection Date: 7/24/2012 Collection Time: 20:01 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0125 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-017


SAMPLE INFORMATION

Sample Number: 1207260-017 Customer Sample Number: 3111849 Project: LCR
Location: 1st Draw 119 16TH ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.046 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0036 mg/L	9/5/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:  9/6/2012
Michael Chicoine, Laboratory Manager Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-018

SAMPLE INFORMATION

Sample Number: 1207260-018 Customer Sample Number: 3111849 Project: LCR
Location: 2nd Draw 119 16TH ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.050 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-019

SAMPLE INFORMATION

Sample Number: 1207260-019 Customer Sample Number: 3073087 Project: LCR
Location: 1st Draw 317 9TH ST SE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.067 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.067 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1207260-020

SAMPLE INFORMATION

Sample Number: 1207260-020 Customer Sample Number: 3073087 Project: LCR
Location: 2nd Draw 317 9TH ST SE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 5:52 Sampler: HOME OWNER Received Date and Time: 7/30/2012 11:19:02 AM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-001 Customer Sample Number: 3124875 Project: LCR
Location: 1st draw 228 V ST NE Type: Dist.

Collection Date: 7/24/2012 Collection Time: 21:04 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.047 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-002 Customer Sample Number: 3124875 Project: LCR
Location: 2nd draw 228 V ST NE Type: Dist.

Collection Date: 7/24/2012 Collection Time: 21:08 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0171 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-003 Customer Sample Number: 3121925 Project: LCR
Location: 1st draw 144 TENNESSEE AVE NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 5:41 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0131 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-004 Customer Sample Number: 3121925 Project: LCR
Location: 2nd draw 144 TENNESSEE AVE NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0060 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-005 Customer Sample Number: 3100985 Project: LCR
Location: 1st draw 1703 D ST NE Type: Dist.

Collection Date: 7/23/2012 Collection Time: 18:21 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.206 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0045 mg/L	9/5/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-006 Customer Sample Number: 3100985 Project: LCR
Location: 2nd draw 1703 D ST NE Type: Dist.

Collection Date: 7/23/2012 Collection Time: 18:22 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.176 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-007 Customer Sample Number: 3113467 Project: LCR
Location: 1st draw 1011 TAYLOR ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.138 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-008 Customer Sample Number: 3113467 Project: LCR
Location: 2nd draw 1011 TAYLOR ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.226 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	9/5/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-009 Customer Sample Number: 3080372 Project: LCR
Location: 1st draw 2435 33RD ST SE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.447 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0179 mg/L	9/5/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-010 Customer Sample Number: 3080372 Project: LCR
Location: 2nd draw 2435 33RD ST SE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.387 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0158 mg/L	9/5/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-011 Customer Sample Number: 3027905 Project: LCR
Location: 1st draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.051 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	< 0.001 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-012 Customer Sample Number: 3027905 Project: LCR
Location: 2nd draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	< 0.001 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-013 Customer Sample Number: 3111360 Project: LCR
Location: 1st draw 1519 OLIVE ST, NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:44 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.231 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	9/5/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-014 Customer Sample Number: 3111360 Project: LCR
Location: 2nd draw 1519 OLIVE ST, NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.233 mg/L	9/5/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	9/5/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	9/5/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-015 Customer Sample Number: 3002488 Project: LCR
Location: 1st draw 1424 S ST NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.046 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-016 Customer Sample Number: 3002488 Project: LCR
Location: 2nd draw 1424 S ST NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:46 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-017 Customer Sample Number: 3028665 Project: LCR
Location: 1st draw 1378 TAYLOR ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-018 Customer Sample Number: 3028665 Project: LCR
Location: 2nd draw 1378 TAYLOR ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 5:53 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-019 Customer Sample Number: 3109249 Project: LCR
Location: 1st draw 1025 44TH ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.045 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-020 Customer Sample Number: 3109249 Project: LCR
Location: 2nd draw 1025 44TH ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-021

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-021 Customer Sample Number: 3035494 Project: LCR
Location: 1st draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 9:27 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-022 Customer Sample Number: 3035494 Project: LCR
Location: 2nd draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 9:31 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-023 Customer Sample Number: 3017940 Project: LCR
Location: 1st draw 10 S ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-024 Customer Sample Number: 3017940 Project: LCR
Location: 2nd draw 10 S ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-025 Customer Sample Number: 3034000 Project: LCR
Location: 1st draw 1649 HARVARD ST. NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.122 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-026 Customer Sample Number: 3034000 Project: LCR
Location: 2nd draw 1649 HARVARD ST. NW Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.088 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-027 Customer Sample Number: 3109545 Project: LCR
Location: 1st draw 213 49TH ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.102 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 9/6/2012
Report Number: LC-W1207267-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1207267-028 Customer Sample Number: 3109545 Project: LCR
Location: 2nd draw 213 49TH ST NE Type: Dist.

Collection Date: 7/25/2012 Collection Time: 7:46 Sampler: HOME OWNER Received Date and Time: 7/30/2012 9:35:00 AM Received By: tviswanathan

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.101 mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/6/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1208110-001

SAMPLE INFORMATION

Sample Number: 1208110-001 Customer Sample Number: 3122289 Project: LCR
Location: 1st draw 531 TENNESSEE AVE NE Type: Dist.

Collection Date: 8/4/2012 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/6/2012
Report Number: LC-W1208110-002

SAMPLE INFORMATION

Sample Number: 1208110-002 Customer Sample Number: 3122289 Project: LCR
Location: 2nd draw 531 TENNESSEE AVE NE Type: Dist.

Collection Date: 8/4/2012 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/22/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	8/22/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	8/22/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/6/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-001

SAMPLE INFORMATION

Sample Number: 1209034-001 Customer Sample Number: 3021532 Project: LCR
Location: 1st draw 501 WEBSTER ST NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.102 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-002

SAMPLE INFORMATION

Sample Number: 1209034-002 Customer Sample Number: 3122309 Project: LCR
Location: 1st draw 349 TENNESSEE AVE NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-003

SAMPLE INFORMATION

Sample Number: 1209034-003 Customer Sample Number: 3051579 Project: LCR
Location: 1st draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 16:35 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0047 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-004

SAMPLE INFORMATION

Sample Number: 1209034-004 Customer Sample Number: 3051579 Project: LCR
Location: 2nd draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 16:36 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0045 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-005

SAMPLE INFORMATION

Sample Number: 1209034-005 Customer Sample Number: 3104746 Project: LCR
Location: 1st draw 4418 14TH ST NE Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.059 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-006

SAMPLE INFORMATION

Sample Number: 1209034-006 Customer Sample Number: 3104746 Project: LCR
Location: 2nd draw 4418 14TH ST NE Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.153 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0104 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-007

SAMPLE INFORMATION

Sample Number: 1209034-007 Customer Sample Number: 3006813 Project: LCR
Location: 1st draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.204 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-008

SAMPLE INFORMATION

Sample Number: 1209034-008 Customer Sample Number: 3006813 Project: LCR
Location: 2nd draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-009

SAMPLE INFORMATION

Sample Number: 1209034-009 Customer Sample Number: 3045865 Project: LCR
Location: 1st draw 4926 GLENBROOK RD., NW Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-010

SAMPLE INFORMATION

Sample Number: 1209034-010 Customer Sample Number: 3045865 Project: LCR
Location: 2nd draw 4926 GLENBROOK RD., NW Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-011

SAMPLE INFORMATION

Sample Number: 1209034-011 Customer Sample Number: 3070403 Project: LCR
Location: 1st draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.041 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-012

SAMPLE INFORMATION

Sample Number: 1209034-012 Customer Sample Number: 3070403 Project: LCR
Location: 2nd draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 8/28/2012 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-013

SAMPLE INFORMATION

Sample Number: 1209034-013 Customer Sample Number: 3035973 Project: LCR
Location: 1st draw 3218 MACOMB ST NW Type: Dist.

Collection Date: 8/28/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.097 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-014

SAMPLE INFORMATION

Sample Number: 1209034-014 Customer Sample Number: 3035973 Project: LCR
Location: 2nd draw 3218 MACOMB ST NW Type: Dist.

Collection Date: 8/28/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0098 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-015

SAMPLE INFORMATION

Sample Number: 1209034-015 Customer Sample Number: 3023204 Project: LCR
Location: 1st draw 5226 7TH ST. NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.710 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0025 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-016

SAMPLE INFORMATION

Sample Number: 1209034-016 Customer Sample Number: 3023204 Project: LCR
Location: 2nd draw 5226 7TH ST. NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.101 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0069 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-017

SAMPLE INFORMATION

Sample Number: 1209034-017 Customer Sample Number: 3044360 Project: LCR
Location: 1st draw 4409 LOWELL ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.199 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-018

SAMPLE INFORMATION

Sample Number: 1209034-018 Customer Sample Number: 3044360 Project: LCR
Location: 2nd draw 4409 LOWELL ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-019

SAMPLE INFORMATION

Sample Number: 1209034-019 Customer Sample Number: 3010741 Project: LCR
Location: 1st draw 3727 T ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.054 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.116 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-020

SAMPLE INFORMATION

Sample Number: 1209034-020 Customer Sample Number: 3010741 Project: LCR
Location: 2nd draw 3727 T ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.090 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0077 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-021

SAMPLE INFORMATION

Sample Number: 1209034-021 Customer Sample Number: 3042399 Project: LCR
Location: 1st draw 4131 YUMA ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.035 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0025 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-022

SAMPLE INFORMATION

Sample Number: 1209034-022 Customer Sample Number: 3042399 Project: LCR
Location: 2nd draw 4131 YUMA ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-023

SAMPLE INFORMATION

Sample Number: 1209034-023 Customer Sample Number: 3035454 Project: LCR
Location: 1st draw 3216 KLINGLE RD NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-024

SAMPLE INFORMATION

Sample Number: 1209034-024 Customer Sample Number: 3035454 Project: LCR
Location: 2nd draw 3216 KLINGLE RD NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:07 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0064 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-025

SAMPLE INFORMATION

Sample Number: 1209034-025 Customer Sample Number: 3040552 Project: LCR
Location: 1st draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-026

SAMPLE INFORMATION

Sample Number: 1209034-026 Customer Sample Number: 3040552 Project: LCR
Location: 2nd draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-027

SAMPLE INFORMATION

Sample Number: 1209034-027 Customer Sample Number: 3021575 Project: LCR
Location: 1st draw 4401 5TH ST. NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:17 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.062 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-028

SAMPLE INFORMATION

Sample Number: 1209034-028 Customer Sample Number: 3021575 Project: LCR
Location: 2nd draw 4401 5TH ST. NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.031 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0036 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-029

SAMPLE INFORMATION

Sample Number: 1209034-029 Customer Sample Number: 3107442 Project: LCR
Location: 1st draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:17 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.066 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	9/13/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/25/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-030

SAMPLE INFORMATION

Sample Number: 1209034-030 Customer Sample Number: 3107442 Project: LCR
Location: 2nd draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-031

SAMPLE INFORMATION

Sample Number: 1209034-031 Customer Sample Number: 3117544 Project: LCR
Location: 1st draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.125 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-032

SAMPLE INFORMATION

Sample Number: 1209034-032 Customer Sample Number: 3117544 Project: LCR
Location: 2nd draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.111 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-033

SAMPLE INFORMATION

Sample Number: 1209034-033 Customer Sample Number: 3055284 Project: LCR
Location: 1st draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.076 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.215 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0200 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-034

SAMPLE INFORMATION

Sample Number: 1209034-034 Customer Sample Number: 3055284 Project: LCR
Location: 2nd draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:49 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-035

SAMPLE INFORMATION

Sample Number: 1209034-035 Customer Sample Number: 3040315 Project: LCR
Location: 1st draw 3973 HARRISON ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.303 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-036

SAMPLE INFORMATION

Sample Number: 1209034-036 Customer Sample Number: 3040315 Project: LCR
Location: 2nd draw 3973 HARRISON ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:49 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.053 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-037

SAMPLE INFORMATION

Sample Number: 1209034-037 Customer Sample Number: 3058406 Project: LCR
Location: 1st draw 4550 30TH ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0032 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-038

SAMPLE INFORMATION

Sample Number: 1209034-038 Customer Sample Number: 3058406 Project: LCR
Location: 2nd draw 4550 30TH ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0087 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-039

SAMPLE INFORMATION

Sample Number: 1209034-039 Customer Sample Number: 3043615 Project: LCR
Location: 1st draw 4824 46TH ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.221 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-040

SAMPLE INFORMATION

Sample Number: 1209034-040 Customer Sample Number: 3043615 Project: LCR
Location: 2nd draw 4824 46TH ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.117 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	9/13/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/25/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-041

SAMPLE INFORMATION

Sample Number: 1209034-041 Customer Sample Number: 3053584 Project: LCR
Location: 1st draw 3706 35TH ST NW Type: Dist.

Collection Date: 8/30/2012 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0025 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-042

SAMPLE INFORMATION

Sample Number: 1209034-042 Customer Sample Number: 3053584 Project: LCR
Location: 2nd draw 3706 35TH ST NW Type: Dist.

Collection Date: 8/30/2012 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0036 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-043

SAMPLE INFORMATION

Sample Number: 1209034-043 Customer Sample Number: 3042083 Project: LCR
Location: 1st draw 4307 CHESAPEAKE ST. NW Type: Dist.

Collection Date: 8/30/2012 Collection Time: 4:48 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-044

SAMPLE INFORMATION

Sample Number: 1209034-044 Customer Sample Number: 3042083 Project: LCR
Location: 2nd draw 4307 CHESAPEAKE ST. NW Type: Dist.

Collection Date: 8/30/2012 Collection Time: 4:50 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-045

SAMPLE INFORMATION

Sample Number: 1209034-045 Customer Sample Number: 3035196 Project: LCR
Location: 1st draw 3206 38TH ST NW Type: Dist.

Collection Date: 8/30/2012 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.193 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-046

SAMPLE INFORMATION

Sample Number: 1209034-046 Customer Sample Number: 3035196 Project: LCR
Location: 2nd draw 3206 38TH ST NW Type: Dist.

Collection Date: 8/30/2012 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0091 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-047

SAMPLE INFORMATION

Sample Number: 1209034-047 Customer Sample Number: 3043835 Project: LCR
Location: 1st draw 4627 49TH ST NW Type: Dist.

Collection Date: 8/31/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.090 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209034-048

SAMPLE INFORMATION

Sample Number: 1209034-048 Customer Sample Number: 3043835 Project: LCR
Location: 2nd draw 4627 49TH ST NW Type: Dist.

Collection Date: 8/31/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/5/2012 3:51:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.036 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.030 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209072-001

SAMPLE INFORMATION

Sample Number: 1209072-001 Customer Sample Number: 3108722 Project: LCR
Location: 1st draw 4120 GRANT ST NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:31:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209072-002

SAMPLE INFORMATION

Sample Number: 1209072-002 Customer Sample Number: 3108722 Project: LCR
Location: 2nd draw 4120 GRANT ST NE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:31:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209072-003

SAMPLE INFORMATION

Sample Number: 1209072-003 Customer Sample Number: 3056809 Project: LCR
Location: 1st draw 4214 8TH ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:31:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209072-004

SAMPLE INFORMATION

Sample Number: 1209072-004 Customer Sample Number: 3056809 Project: LCR
Location: 2nd draw 4214 8TH ST NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:31:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	9/13/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	9/13/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	9/13/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209083-001

SAMPLE INFORMATION

Sample Number: 1209083-001 Customer Sample Number: 3009852 Project: LCR
Location: 1st draw 3533 W PL NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/11/2012 4:26:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/19/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	9/19/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/19/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: LC-W1209083-002

SAMPLE INFORMATION

Sample Number: 1209083-002 Customer Sample Number: 3009852 Project: LCR
Location: 2nd draw 3533 W PL NW Type: Dist.

Collection Date: 8/29/2012 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 9/11/2012 4:26:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/19/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	9/19/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/19/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-001

SAMPLE INFORMATION

Sample Number: 1210007-001 Customer Sample Number: 3052513 Project: LCR
Location: 1st draw 636 ROCK CRK CHURCH RD, NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-002

SAMPLE INFORMATION

Sample Number: 1210007-002 Customer Sample Number: 3052513 Project: LCR
Location: 2nd draw 636 ROCK CRK CHURCH RD, NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.075 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-003

SAMPLE INFORMATION

Sample Number: 1210007-003 Customer Sample Number: 3087431 Project: LCR
Location: 1st draw 1603 MASSACHUSETTS AVE SE Type: Dist.

Collection Date: 9/25/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-004

SAMPLE INFORMATION

Sample Number: 1210007-004 Customer Sample Number: 3087431 Project: LCR
Location: 2nd draw 1603 MASSACHUSETTS AVE SE Type: Dist.

Collection Date: 9/25/2012 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-005

SAMPLE INFORMATION

Sample Number: 1210007-005 Customer Sample Number: 3049333 Project: LCR
Location: 1st draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-006

SAMPLE INFORMATION

Sample Number: 1210007-006 Customer Sample Number: 3049333 Project: LCR
Location: 2nd draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-007

SAMPLE INFORMATION

Sample Number: 1210007-007 Customer Sample Number: 3029443 Project: LCR
Location: 1st draw 1203 QUINCY ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.549 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-008

SAMPLE INFORMATION

Sample Number: 1210007-008 Customer Sample Number: 3029443 Project: LCR
Location: 2nd draw 1203 QUINCY ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.036 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.053 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-009

SAMPLE INFORMATION

Sample Number: 1210007-009 Customer Sample Number: 3120431 Project: LCR
Location: 1st draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 9/24/2012 Collection Time: 16:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-010

SAMPLE INFORMATION

Sample Number: 1210007-010 Customer Sample Number: 3120431 Project: LCR
Location: 2nd draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 9/24/2012 Collection Time: 16:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.038 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-011

SAMPLE INFORMATION

Sample Number: 1210007-011 Customer Sample Number: 3011592 Project: LCR
Location: 1st draw 75 BATES ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 17:17 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.077 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-012

SAMPLE INFORMATION

Sample Number: 1210007-012 Customer Sample Number: 3011592 Project: LCR
Location: 2nd draw 75 BATES ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 17:19 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-013

SAMPLE INFORMATION

Sample Number: 1210007-013 Customer Sample Number: 3099778 Project: LCR
Location: 1st draw 619 12TH ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-014

SAMPLE INFORMATION

Sample Number: 1210007-014 Customer Sample Number: 3099778 Project: LCR
Location: 2nd draw 619 12TH ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 7:18 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-015

SAMPLE INFORMATION

Sample Number: 1210007-015 Customer Sample Number: 3122831 Project: LCR
Location: 1st draw 905 KENT PL NE Type: Dist.

Collection Date: 9/25/2012 Collection Time: 22:48 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.214 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-016

SAMPLE INFORMATION

Sample Number: 1210007-016 Customer Sample Number: 3122831 Project: LCR
Location: 2nd draw 905 KENT PL NE Type: Dist.

Collection Date: 9/25/2012 Collection Time: 22:51 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.250 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-017

SAMPLE INFORMATION

Sample Number: 1210007-017 Customer Sample Number: 3087203 Project: LCR
Location: 1st draw 1319 POTOMAC AV SE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-018

SAMPLE INFORMATION

Sample Number: 1210007-018 Customer Sample Number: 3087203 Project: LCR
Location: 2nd draw 1319 POTOMAC AV SE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-019

SAMPLE INFORMATION

Sample Number: 1210007-019 Customer Sample Number: 3092217 Project: LCR
Location: 1st draw 8 N ST SW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 18:34 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.124 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-020

SAMPLE INFORMATION

Sample Number: 1210007-020 Customer Sample Number: 3092217 Project: LCR
Location: 2nd draw 8 N ST SW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 18:35 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.095 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0031 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-021

SAMPLE INFORMATION

Sample Number: 1210007-021 Customer Sample Number: 3017981 Project: LCR
Location: 1st draw 87 S ST. NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.043 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-022

SAMPLE INFORMATION

Sample Number: 1210007-022 Customer Sample Number: 3017981 Project: LCR
Location: 2nd draw 87 S ST. NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-023

SAMPLE INFORMATION

Sample Number: 1210007-023 Customer Sample Number: 3022277 Project: LCR
Location: 1st draw 804 DELAFIELD PL. NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 5:42 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-024

SAMPLE INFORMATION

Sample Number: 1210007-024 Customer Sample Number: 3022277 Project: LCR
Location: 2nd draw 804 DELAFIELD PL. NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 5:46 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-025

SAMPLE INFORMATION

Sample Number: 1210007-025 Customer Sample Number: 3104963 Project: LCR
Location: 1st draw 1420 HAMLIN ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 5:49 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-026

SAMPLE INFORMATION

Sample Number: 1210007-026 Customer Sample Number: 3104963 Project: LCR
Location: 2nd draw 1420 HAMLIN ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-027

SAMPLE INFORMATION

Sample Number: 1210007-027 Customer Sample Number: 3022011 Project: LCR
Location: 1st draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.105 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-028

SAMPLE INFORMATION

Sample Number: 1210007-028 Customer Sample Number: 3022011 Project: LCR
Location: 2nd draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.113 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0374 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-029

SAMPLE INFORMATION

Sample Number: 1210007-029 Customer Sample Number: 3127313 Project: LCR
Location: 1st draw 617 M ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.036 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0030 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-030

SAMPLE INFORMATION

Sample Number: 1210007-030 Customer Sample Number: 3127313 Project: LCR
Location: 2nd draw 617 M ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.064 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.072 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-031

SAMPLE INFORMATION

Sample Number: 1210007-031 Customer Sample Number: 3026837 Project: LCR
Location: 1st draw 6210 8TH ST NW Type: Dist.

Collection Date: 9/27/2012 Collection Time: 5:42 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.044 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0044 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-032

SAMPLE INFORMATION

Sample Number: 1210007-032 Customer Sample Number: 3026837 Project: LCR
Location: 2nd draw 6210 8TH ST NW Type: Dist.

Collection Date: 9/27/2012 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-033

SAMPLE INFORMATION

Sample Number: 1210007-033 Customer Sample Number: 3023157 Project: LCR
Location: 1st draw 641 GALLATIN ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:56 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-034

SAMPLE INFORMATION

Sample Number: 1210007-034 Customer Sample Number: 3023157 Project: LCR
Location: 2nd draw 641 GALLATIN ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:57 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0044 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-035

SAMPLE INFORMATION

Sample Number: 1210007-035 Customer Sample Number: 3029182 Project: LCR
Location: 1st draw 1635 WEBSTER ST NW Type: Dist.

Collection Date: 9/27/2012 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-036

SAMPLE INFORMATION

Sample Number: 1210007-036 Customer Sample Number: 3029182 Project: LCR
Location: 2nd draw 1635 WEBSTER ST NW Type: Dist.

Collection Date: 9/27/2012 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-037

SAMPLE INFORMATION

Sample Number: 1210007-037 Customer Sample Number: 3038936 Project: LCR
Location: 1st draw 5923 33RD ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.053 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.131 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-038

SAMPLE INFORMATION

Sample Number: 1210007-038 Customer Sample Number: 3038936 Project: LCR
Location: 2nd draw 5923 33RD ST NW Type: Dist.

Collection Date: 9/26/2012 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.066 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	10/18/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/23/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210007-039

SAMPLE INFORMATION

Sample Number: 1210007-039 Customer Sample Number: 3022794 Project: LCR
Location: 1st draw 926 HAMILTON ST NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/1/2012 10:53:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0062 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210050-001

SAMPLE INFORMATION

Sample Number: 1210050-001 Customer Sample Number: 3010160 Project: LCR
Location: 1st draw 2212 38TH ST NW Type: Dist.

Collection Date: 9/29/2012 Collection Time: 19:33 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:19:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.079 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210050-002

SAMPLE INFORMATION

Sample Number: 1210050-002 Customer Sample Number: 3010160 Project: LCR
Location: 2nd draw 2212 38TH ST NW Type: Dist.

Collection Date: 9/29/2012 Collection Time: 19:35 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:19:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0139 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210050-003

SAMPLE INFORMATION

Sample Number: 1210050-003 Customer Sample Number: 3106057 Project: LCR
Location: 1st draw 1808 KEARNEY ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 5:28 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:19:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.070 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.104 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210050-004

SAMPLE INFORMATION

Sample Number: 1210050-004 Customer Sample Number: 3106057 Project: LCR
Location: 2nd draw 1808 KEARNEY ST NE Type: Dist.

Collection Date: 9/26/2012 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:19:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.035 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.097 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210063-001

SAMPLE INFORMATION

Sample Number: 1210063-001 Customer Sample Number: 3109897 Project: LCR
Location: 1st Draw 6105 DIX ST NE Type: Dist.

Collection Date: 10/2/2012 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 10/4/2012 2:58:06 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/23/2012
Report Number: LC-W1210063-002

SAMPLE INFORMATION

Sample Number: 1210063-002 Customer Sample Number: 3109897 Project: LCR
Location: 2nd Draw 6105 DIX ST NE Type: Dist.

Collection Date: 10/2/2012 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 10/4/2012 2:58:06 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-001

SAMPLE INFORMATION

Sample Number: 1210250-001 Customer Sample Number: 3019336 Project: LCR
Location: 1st Draw 605 COLUMBIA RD NW Type: Dist.

Collection Date: 10/22/2012 Collection Time: 18:12 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.107 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-002

SAMPLE INFORMATION

Sample Number: 1210250-002 Customer Sample Number: 3019336 Project: LCR
Location: 2nd Draw 605 COLUMBIA RD NW Type: Dist.

Collection Date: 10/22/2012 Collection Time: 18:13 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.092 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-003

SAMPLE INFORMATION

Sample Number: 1210250-003 Customer Sample Number: 3029267 Project: LCR
Location: 1st Draw 3907 13TH ST NW Type: Dist.

Collection Date: 10/22/2012 Collection Time: 18:54 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.125 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-004

SAMPLE INFORMATION

Sample Number: 1210250-004 Customer Sample Number: 3029267 Project: LCR
Location: 2nd Draw 3907 13TH ST NW Type: Dist.

Collection Date: 10/22/2012 Collection Time: 18:55 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.085 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-005

SAMPLE INFORMATION

Sample Number: 1210250-005 Customer Sample Number: 3008069 Project: LCR
Location: 1st Draw 3036 P ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-006

SAMPLE INFORMATION

Sample Number: 1210250-006 Customer Sample Number: 3008069 Project: LCR
Location: 2nd Draw 3036 P ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-007

SAMPLE INFORMATION

Sample Number: 1210250-007 Customer Sample Number: 3020687 Project: LCR
Location: 1st Draw 3917 8TH ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.097 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-008

SAMPLE INFORMATION

Sample Number: 1210250-008 Customer Sample Number: 3020687 Project: LCR
Location: 2nd Draw 3917 8TH ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 7:17 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.047 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.077 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-009

SAMPLE INFORMATION

Sample Number: 1210250-009 Customer Sample Number: 3100201 Project: LCR
Location: 1st Draw 1357 C ST NE Type: Dist.

Collection Date: 10/23/2012 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-010

SAMPLE INFORMATION

Sample Number: 1210250-010 Customer Sample Number: 3100201 Project: LCR
Location: 2nd Draw 1357 C ST NE Type: Dist.

Collection Date: 10/23/2012 Collection Time: 8:16 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.044 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0074 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-011

SAMPLE INFORMATION

Sample Number: 1210250-011 Customer Sample Number: 3108541 Project: LCR
Location: 1st Draw 333 34TH ST NE Type: Dist.

Collection Date: 10/23/2012 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.096 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-012

SAMPLE INFORMATION

Sample Number: 1210250-012 Customer Sample Number: 3108541 Project: LCR
Location: 2nd Draw 333 34TH ST NE Type: Dist.

Collection Date: 10/23/2012 Collection Time: 15:05 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.092 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-013

SAMPLE INFORMATION

Sample Number: 1210250-013 Customer Sample Number: 3022580 Project: LCR
Location: 1st Draw 4818 8TH ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 17:07 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.055 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-014

SAMPLE INFORMATION

Sample Number: 1210250-014 Customer Sample Number: 3022580 Project: LCR
Location: 2nd Draw 4818 8TH ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 17:09 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0063 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-015

SAMPLE INFORMATION

Sample Number: 1210250-015 Customer Sample Number: 3032623 Project: LCR
Location: 1st Draw 780 FAIRMONT ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 18:14 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-016

SAMPLE INFORMATION

Sample Number: 1210250-016 Customer Sample Number: 3032623 Project: LCR
Location: 2nd Draw 780 FAIRMONT ST NW Type: Dist.

Collection Date: 10/23/2012 Collection Time: 18:15 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-017

SAMPLE INFORMATION

Sample Number: 1210250-017 Customer Sample Number: 3072261 Project: LCR
Location: 1st Draw 413 4TH ST SE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 5:22 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.041 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-018

SAMPLE INFORMATION

Sample Number: 1210250-018 Customer Sample Number: 3072261 Project: LCR
Location: 2nd Draw 413 4TH ST SE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 5:27 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-019

SAMPLE INFORMATION

Sample Number: 1210250-019 Customer Sample Number: 3026522 Project: LCR
Location: 1st Draw 6213 7TH ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 5:07 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-020

SAMPLE INFORMATION

Sample Number: 1210250-020 Customer Sample Number: 3026522 Project: LCR
Location: 2nd Draw 6213 7TH ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 5:09 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	11/14/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/20/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-021

SAMPLE INFORMATION

Sample Number: 1210250-021 Customer Sample Number: 3042773 Project: LCR
Location: 1st Draw 4332 BRANDYWINE ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-022

SAMPLE INFORMATION

Sample Number: 1210250-022 Customer Sample Number: 3042773 Project: LCR
Location: 2nd Draw 4332 BRANDYWINE ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-023

SAMPLE INFORMATION

Sample Number: 1210250-023 Customer Sample Number: 3097707 Project: LCR
Location: 1st Draw 230 G ST NE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.042 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-024

SAMPLE INFORMATION

Sample Number: 1210250-024 Customer Sample Number: 3097707 Project: LCR
Location: 2nd Draw 230 G ST NE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0087 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-025

SAMPLE INFORMATION

Sample Number: 1210250-025 Customer Sample Number: 3020685 Project: LCR
Location: 1st Draw 3913 8TH ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.064 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-026

SAMPLE INFORMATION

Sample Number: 1210250-026 Customer Sample Number: 3020685 Project: LCR
Location: 2nd Draw 3913 8TH ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-027

SAMPLE INFORMATION

Sample Number: 1210250-027 Customer Sample Number: 3038872 Project: LCR
Location: 1st Draw 3215 MCKINLEY ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.145 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-028

SAMPLE INFORMATION

Sample Number: 1210250-028 Customer Sample Number: 3038872 Project: LCR
Location: 2nd Draw 3215 MCKINLEY ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.084 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-029

SAMPLE INFORMATION

Sample Number: 1210250-029 Customer Sample Number: 3035198 Project: LCR
Location: 1st Draw 3202 38TH ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.019 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.107 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-030

SAMPLE INFORMATION

Sample Number: 1210250-030 Customer Sample Number: 3035198 Project: LCR
Location: 2nd Draw 3202 38TH ST NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 8:21 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-031

SAMPLE INFORMATION

Sample Number: 1210250-031 Customer Sample Number: 3100953 Project: LCR
Location: 1st Draw 335 17TH PL NE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 19:23 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-032

SAMPLE INFORMATION

Sample Number: 1210250-032 Customer Sample Number: 3100953 Project: LCR
Location: 2nd Draw 335 17TH PL NE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 19:23 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-033

SAMPLE INFORMATION

Sample Number: 1210250-033 Customer Sample Number: 3103403 Project: LCR
Location: 1st Draw 3416 9TH ST NE Type: Dist.

Collection Date: 10/25/2012 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210250-034

SAMPLE INFORMATION

Sample Number: 1210250-034 Customer Sample Number: 3103403 Project: LCR
Location: 2nd Draw 3416 9TH ST NE Type: Dist.

Collection Date: 10/25/2012 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 10/31/2012 9:11:55 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	11/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	11/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-001

SAMPLE INFORMATION

Sample Number: 1212033-001 Customer Sample Number: 3040673 Project: LCR
Location: 1st draw 4111 INGOMAR ST NW Type: Dist.

Collection Date: 11/28/2012 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-002

SAMPLE INFORMATION

Sample Number: 1212033-002 Customer Sample Number: 3040673 Project: LCR
Location: 2nd draw 4111 INGOMAR ST NW Type: Dist.

Collection Date: 11/28/2012 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0025 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-003

SAMPLE INFORMATION

Sample Number: 1212033-003 Customer Sample Number: 3037207 Project: LCR
Location: 1st draw 3218 MORRISON ST NW Type: Dist.

Collection Date: 11/28/2012 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-004

SAMPLE INFORMATION

Sample Number: 1212033-004 Customer Sample Number: 3037207 Project: LCR
Location: 2nd draw 3218 MORRISON ST NW Type: Dist.

Collection Date: 11/28/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-005

SAMPLE INFORMATION

Sample Number: 1212033-005 Customer Sample Number: 3113276 Project: LCR
Location: 1st draw 619 GIRARD ST NE Type: Dist.

Collection Date: 11/29/2012 Collection Time: 8:15 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-006

SAMPLE INFORMATION

Sample Number: 1212033-006 Customer Sample Number: 3113276 Project: LCR
Location: 2nd draw 619 GIRARD ST NE Type: Dist.

Collection Date: 11/29/2012 Collection Time: 8:18 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0058 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-007

SAMPLE INFORMATION

Sample Number: 1212033-007 Customer Sample Number: 3032506 Project: LCR
Location: 1st draw 753 GRESHAM PL. NW Type: Dist.

Collection Date: 11/29/2012 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.052 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-008

SAMPLE INFORMATION

Sample Number: 1212033-008 Customer Sample Number: 3032506 Project: LCR
Location: 2nd draw 753 GRESHAM PL. NW Type: Dist.

Collection Date: 11/29/2012 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.082 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-009

SAMPLE INFORMATION

Sample Number: 1212033-009 Customer Sample Number: 3058539 Project: LCR
Location: 1st draw 4818 ILLINOIS AVE NW Type: Dist.

Collection Date: 11/29/2012 Collection Time: 6:48 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.300 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-010

SAMPLE INFORMATION

Sample Number: 1212033-010 Customer Sample Number: 3058539 Project: LCR
Location: 2nd draw 4818 ILLINOIS AVE NW Type: Dist.

Collection Date: 11/29/2012 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.100 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-011

SAMPLE INFORMATION

Sample Number: 1212033-011 Customer Sample Number: 3021922 Project: LCR
Location: 1st draw 4613 9TH ST NW Type: Dist.

Collection Date: 11/29/2012 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.043 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-012

SAMPLE INFORMATION

Sample Number: 1212033-012 Customer Sample Number: 3021922 Project: LCR
Location: 2nd draw 4613 9TH ST NW Type: Dist.

Collection Date: 11/29/2012 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.082 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-013

SAMPLE INFORMATION

Sample Number: 1212033-013 Customer Sample Number: 3028372 Project: LCR
Location: 1st draw 1434 TAYLOR ST NW Type: Dist.

Collection Date: 12/4/2012 Collection Time: 6:42 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212033-014

SAMPLE INFORMATION

Sample Number: 1212033-014 Customer Sample Number: 3028372 Project: LCR
Location: 2nd draw 1434 TAYLOR ST NW Type: Dist.

Collection Date: 12/4/2012 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:34:58 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-001

SAMPLE INFORMATION

Sample Number: 1212049-001 Customer Sample Number: 3019855 Project: LCR
Location: 1st draw 424 LURAY PL NW Type: Dist.

Collection Date: 12/4/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-002

SAMPLE INFORMATION

Sample Number: 1212049-002 Customer Sample Number: 3019855 Project: LCR
Location: 2nd draw 424 LURAY PL NW Type: Dist.

Collection Date: 12/4/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-003

SAMPLE INFORMATION

Sample Number: 1212049-003 Customer Sample Number: 3057118 Project: LCR
Location: 1st draw 5316 28TH ST. NW Type: Dist.

Collection Date: 12/5/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.191 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.290 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-004

SAMPLE INFORMATION

Sample Number: 1212049-004 Customer Sample Number: 3057118 Project: LCR
Location: 2nd draw 5316 28TH ST. NW Type: Dist.

Collection Date: 12/5/2012 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.216 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.131 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-005

SAMPLE INFORMATION

Sample Number: 1212049-005 Customer Sample Number: 3122315 Project: LCR
Location: 1st draw 322 TENNESSEE AVE NE Type: Dist.

Collection Date: 12/5/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.115 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.035 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-006

SAMPLE INFORMATION

Sample Number: 1212049-006 Customer Sample Number: 3122315 Project: LCR
Location: 2nd draw 322 TENNESSEE AVE NE Type: Dist.

Collection Date: 12/5/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.157 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-007

SAMPLE INFORMATION

Sample Number: 1212049-007 Customer Sample Number: 3026517 Project: LCR
Location: 1st draw 611 ROXBORO PL NW Type: Dist.

Collection Date: 12/5/2012 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212049-008

SAMPLE INFORMATION

Sample Number: 1212049-008 Customer Sample Number: 3026517 Project: LCR
Location: 2nd draw 611 ROXBORO PL NW Type: Dist.

Collection Date: 12/5/2012 Collection Time: 6:11 Sampler: HOME OWNER Received Date and Time: 12/6/2012 12:07:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212093-001

SAMPLE INFORMATION

Sample Number: 1212093-001 Customer Sample Number: 3010160 Project: LCR
Location: 1st draw 2212 38TH ST NW Type: Dist.

Collection Date: 12/10/2012 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:36:07 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212093-002

SAMPLE INFORMATION

Sample Number: 1212093-002 Customer Sample Number: 3010160 Project: LCR
Location: 2nd draw 2212 38TH ST NW Type: Dist.

Collection Date: 12/10/2012 Collection Time: 6:56 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:36:07 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/14/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	12/14/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0040 mg/L	12/14/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

Attachment 2

Non-Regulated Lead Samples

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206095-001

SAMPLE INFORMATION

Sample Number: 1206095-001 Customer Sample Number: 3128758 Program: DS
Location: 1st draw 706 E ST NE Type: Dist.

Collection Date: 6/2/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 6/12/2012 3:06:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206095-002

SAMPLE INFORMATION

Sample Number: 1206095-002 Customer Sample Number: 3128758 Program: DS
Location: 2nd draw 706 E ST NE Type: Dist.

Collection Date: 6/2/2012 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 6/12/2012 3:06:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206095-003

SAMPLE INFORMATION

Sample Number: 1206095-003 Customer Sample Number: 3127586 Program: DS
Location: 1st draw 935 5TH ST NE Type: Dist.

Collection Date: 6/5/2012 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 6/12/2012 3:06:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206095-004

SAMPLE INFORMATION

Sample Number: 1206095-004 Customer Sample Number: 3127586 Program: DS
Location: 2nd draw 935 5TH ST NE Type: Dist.

Collection Date: 6/5/2012 Collection Time: 5:51 Sampler: HOME OWNER Received Date and Time: 6/12/2012 3:06:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206095-005

SAMPLE INFORMATION

Sample Number: 1206095-005 Customer Sample Number: 3048260 Program: DS
Location: 1st draw 1901 YORKTOWN RD NW Type: Dist.

Collection Date: 6/6/2012 Collection Time: 9:23 Sampler: HOME OWNER Received Date and Time: 6/12/2012 3:06:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206095-006

SAMPLE INFORMATION

Sample Number: 1206095-006 Customer Sample Number: 3048260 Program: DS
Location: 2nd draw 1901 YORKTOWN RD NW Type: Dist.

Collection Date: 6/6/2012 Collection Time: 9:26 Sampler: HOME OWNER Received Date and Time: 6/12/2012 3:06:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/25/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-003

SAMPLE INFORMATION

Sample Number: 1206118-003 Customer Sample Number: 3019597 Program: DS
Location: 1st draw 539 IRVING ST NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.4 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-004

SAMPLE INFORMATION

Sample Number: 1206118-004 Customer Sample Number: 3019597 Program: DS
Location: 2nd draw 539 IRVING ST NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 6:56 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-007

SAMPLE INFORMATION

Sample Number: 1206118-007 Customer Sample Number: 3012007 Program: DS
Location: 1st draw 2710 OLIVE ST NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 20:40 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-008

SAMPLE INFORMATION

Sample Number: 1206118-008 Customer Sample Number: 3012007 Program: DS
Location: 2nd draw 2710 OLIVE ST NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 20:43 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-009

SAMPLE INFORMATION

Sample Number: 1206118-009 Customer Sample Number: 3100086 Program: DS
Location: 1st draw 1317 CORBIN PL. NE Type: Dist.

Collection Date: 6/12/2012 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-010

SAMPLE INFORMATION

Sample Number: 1206118-010 Customer Sample Number: 3100086 Program: DS
Location: 2nd draw 1317 CORBIN PL. NE Type: Dist.

Collection Date: 6/12/2012 Collection Time: 5:01 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-011

SAMPLE INFORMATION

Sample Number: 1206118-011 Customer Sample Number: 3052345 Program: DS
Location: 1st draw 406 U STREET NW Type: Dist.

Collection Date: 6/12/2012 Collection Time: 7:09 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-012

SAMPLE INFORMATION

Sample Number: 1206118-012 Customer Sample Number: 3052345 Program: DS
Location: 2nd draw 406 U STREET NW Type: Dist.

Collection Date: 6/12/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-013

SAMPLE INFORMATION

Sample Number: 1206118-013 Customer Sample Number: 3039559 Program: DS
Location: 1st draw 3622 PATTERSON ST NW Type: Dist.

Collection Date: 6/13/2012 Collection Time: 5:10 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	6/25/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-014

SAMPLE INFORMATION

Sample Number: 1206118-014 Customer Sample Number: 3039559 Program: DS
Location: 2nd draw 3622 PATTERSON ST NW Type: Dist.

Collection Date: 6/13/2012 Collection Time: 5:14 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206162-001

SAMPLE INFORMATION

Sample Number: 1206162-001 Customer Sample Number: 3092874 Program: DS
Location: 1st draw 1 P ST SW APT1 Type: Dist.

Collection Date: 6/7/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 6/20/2012 12:16:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206162-002

SAMPLE INFORMATION

Sample Number: 1206162-002 Customer Sample Number: 3092874 Program: DS
Location: 2nd draw 1 P ST SW APT1 Type: Dist.

Collection Date: 6/7/2012 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 6/20/2012 12:16:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206162-003

SAMPLE INFORMATION

Sample Number: 1206162-003 Customer Sample Number: 3006806 Program: DS
Location: 1st draw 52 FLORIDA AVE NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 8:35 Sampler: HOME OWNER Received Date and Time: 6/20/2012 12:16:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206162-004

SAMPLE INFORMATION

Sample Number: 1206162-004 Customer Sample Number: 3006806 Program: DS
Location: 2nd draw 52 FLORIDA AVE NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 8:38 Sampler: HOME OWNER Received Date and Time: 6/20/2012 12:16:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206162-005

SAMPLE INFORMATION

Sample Number: 1206162-005 Customer Sample Number: 3090473 Program: DS
Location: 1st draw 5356 BASS PLACE SE Type: Dist.

Collection Date: 6/16/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/20/2012 12:16:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206162-006

SAMPLE INFORMATION

Sample Number: 1206162-006 Customer Sample Number: 3090473 Program: DS
Location: 2nd draw 5356 BASS PLACE SE Type: Dist.

Collection Date: 6/16/2012 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 6/20/2012 12:16:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-001

SAMPLE INFORMATION

Sample Number: 1206241-001 Customer Sample Number: 3099472 Program: DS
Location: 1st draw 110 TENNESSEE AVE NE Type: Dist.

Collection Date: 6/18/2012 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-002

SAMPLE INFORMATION

Sample Number: 1206241-002 Customer Sample Number: 3099472 Program: DS
Location: 2nd draw 110 TENNESSEE AVE NE Type: Dist.

Collection Date: 6/18/2012 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-005

SAMPLE INFORMATION

Sample Number: 1206241-005 Customer Sample Number: 3064897 Program: DS
Location: 1st draw 4449 WESTOVER PLACE NW Type: Dist.

Collection Date: 6/24/2012 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-006

SAMPLE INFORMATION

Sample Number: 1206241-006 Customer Sample Number: 3064897 Program: DS
Location: 2nd draw 4449 WESTOVER PLACE NW Type: Dist.

Collection Date: 6/24/2012 Collection Time: 9:32 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-007

SAMPLE INFORMATION

Sample Number: 1206241-007 Customer Sample Number: 3128571 Program: DS
Location: 1st draw 721 11TH ST NE Type: Dist.

Collection Date: 6/24/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-008

SAMPLE INFORMATION

Sample Number: 1206241-008 Customer Sample Number: 3128571 Program: DS
Location: 2nd draw 721 11TH ST NE Type: Dist.

Collection Date: 6/24/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-009

SAMPLE INFORMATION

Sample Number: 1206241-009 Customer Sample Number: 3074943 Program: DS
Location: 1st draw 1413 IVES PL SE Type: Dist.

Collection Date: 6/24/2012 Collection Time: 17:25 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-010

SAMPLE INFORMATION

Sample Number: 1206241-010 Customer Sample Number: 3074943 Program: DS
Location: 2nd draw 1413 IVES PL SE Type: Dist.

Collection Date: 6/24/2012 Collection Time: 17:26 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-001

SAMPLE INFORMATION

Sample Number: 1207019-001 Customer Sample Number: 3121755 Program: DS
Location: 1st draw 441 11TH ST NE Type: Dist.

Collection Date: 6/25/2012 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-002

SAMPLE INFORMATION

Sample Number: 1207019-002 Customer Sample Number: 3121755 Program: DS
Location: 2nd draw 441 11TH ST NE Type: Dist.

Collection Date: 6/25/2012 Collection Time: 19:10 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	8.2 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-003

SAMPLE INFORMATION

Sample Number: 1207019-003 Customer Sample Number: 3033824 Program: DS
Location: 1st draw 1829 IRVING ST NW Type: Dist.

Collection Date: 6/26/2012 Collection Time: 16:15 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-004

SAMPLE INFORMATION

Sample Number: 1207019-004 Customer Sample Number: 3033824 Program: DS
Location: 2nd draw 1829 IRVING ST NW Type: Dist.

Collection Date: 6/26/2012 Collection Time: 16:20 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-005

SAMPLE INFORMATION

Sample Number: 1207019-005 Customer Sample Number: 3021131 Program: DS
Location: 1st draw 4113 3RD ST NW Type: Dist.

Collection Date: 6/26/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-006

SAMPLE INFORMATION

Sample Number: 1207019-006 Customer Sample Number: 3021131 Program: DS
Location: 2nd draw 4113 3RD ST NW Type: Dist.

Collection Date: 6/26/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-009

SAMPLE INFORMATION

Sample Number: 1207019-009 Customer Sample Number: 3145664 Program: DS
Location: 1st draw 4010 18TH ST NW Type: Dist.

Collection Date: 6/28/2012 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	27.6 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-010

SAMPLE INFORMATION

Sample Number: 1207019-010 Customer Sample Number: 3145664 Program: DS
Location: 2nd draw 4010 18TH ST NW Type: Dist.

Collection Date: 6/28/2012 Collection Time: 15:05 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.2 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-001

SAMPLE INFORMATION

Sample Number: 1207098-001 Customer Sample Number: 3050326 Program: DS
Location: 1st draw 4001 16TH ST NW Type: Dist.

Collection Date: 7/9/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-002

SAMPLE INFORMATION

Sample Number: 1207098-002 Customer Sample Number: 3050326 Program: DS
Location: 2nd draw 4001 16TH ST NW Type: Dist.

Collection Date: 7/9/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-003

SAMPLE INFORMATION

Sample Number: 1207098-003 Customer Sample Number: 3122768 Program: DS
Location: 1st draw 920 9TH ST NE Type: Dist.

Collection Date: 7/9/2012 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-004

SAMPLE INFORMATION

Sample Number: 1207098-004 Customer Sample Number: 3122768 Program: DS
Location: 2nd draw 920 9TH ST NE Type: Dist.

Collection Date: 7/9/2012 Collection Time: 6:57 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-009

SAMPLE INFORMATION

Sample Number: 1207098-009 Customer Sample Number: 3074414 Program: DS
Location: 1st draw 208 KENTUCKY AVE SE Type: Dist.

Collection Date: 7/1/2012 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-010

SAMPLE INFORMATION

Sample Number: 1207098-010 Customer Sample Number: 3074414 Program: DS
Location: 2nd draw 208 KENTUCKY AVE SE Type: Dist.

Collection Date: 7/1/2012 Collection Time: 9:35 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-011

SAMPLE INFORMATION

Sample Number: 1207098-011 Customer Sample Number: 3076218 Program: DS
Location: 1st draw 1837 BAY ST SE Type: Dist.

Collection Date: 7/3/2012 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-012

SAMPLE INFORMATION

Sample Number: 1207098-012 Customer Sample Number: 3076218 Program: DS
Location: 2nd draw 1837 BAY ST SE Type: Dist.

Collection Date: 7/3/2012 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-013

SAMPLE INFORMATION

Sample Number: 1207098-013 Customer Sample Number: 3072267 Program: DS
Location: 1st draw 427 4TH ST SE Type: Dist.

Collection Date: 7/5/2012 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.3 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-014

SAMPLE INFORMATION

Sample Number: 1207098-014 Customer Sample Number: 3072267 Program: DS
Location: 2nd draw 427 4TH ST SE Type: Dist.

Collection Date: 7/5/2012 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.7 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-015

SAMPLE INFORMATION

Sample Number: 1207098-015 Customer Sample Number: 3122488 Program: DS
Location: 1st draw 1353 CONSTITUTION AVE NE Type: Dist.

Collection Date: 7/5/2012 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-016

SAMPLE INFORMATION

Sample Number: 1207098-016 Customer Sample Number: 3122488 Program: DS
Location: 2nd draw 1353 CONSTITUTION AVE NE Type: Dist.

Collection Date: 7/5/2012 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-017

SAMPLE INFORMATION

Sample Number: 1207098-017 Customer Sample Number: 3112761 Program: DS
Location: 1st draw 1225 18TH ST NE Type: Dist.

Collection Date: 6/29/2012 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.8 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-018

SAMPLE INFORMATION

Sample Number: 1207098-018 Customer Sample Number: 3112761 Program: DS
Location: 2nd draw 1225 18TH ST NE Type: Dist.

Collection Date: 6/29/2012 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.1 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207134-001

SAMPLE INFORMATION

Sample Number: 1207134-001 Customer Sample Number: 3057511 Program: DS
Location: 1st draw 3528 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 7/9/2012 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 7/16/2012 4:14:31 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207134-002

SAMPLE INFORMATION

Sample Number: 1207134-002 Customer Sample Number: 3057511 Program: DS
Location: 2nd draw 3528 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 7/9/2012 Collection Time: 5:43 Sampler: HOME OWNER Received Date and Time: 7/16/2012 4:14:31 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207169-001

SAMPLE INFORMATION

Sample Number: 1207169-001 Customer Sample Number: 3099193 Program: DS
Location: 1st draw 129 10TH ST NE Type: Dist.

Collection Date: 7/6/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207169-002

SAMPLE INFORMATION

Sample Number: 1207169-002 Customer Sample Number: 3099193 Program: DS
Location: 2nd draw 129 10TH ST NE Type: Dist.

Collection Date: 7/6/2012 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207169-003

SAMPLE INFORMATION

Sample Number: 1207169-003 Customer Sample Number: 3039728 Program: DS
Location: 1st draw 6019 WESTERN AVE NW Type: Dist.

Collection Date: 7/16/2012 Collection Time: 6:07 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207169-004

SAMPLE INFORMATION

Sample Number: 1207169-004 Customer Sample Number: 3039728 Program: DS
Location: 2nd draw 6019 WESTERN AVE NW Type: Dist.

Collection Date: 7/16/2012 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207169-006

SAMPLE INFORMATION

Sample Number: 1207169-006 Customer Sample Number: 3100083 Program: DS
Location: 2nd draw 1323 CORBIN PLACE NE Type: Dist.

Collection Date: 7/16/2012 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-001

SAMPLE INFORMATION

Sample Number: 1207250-001 Customer Sample Number: 3054078 Program: DS
Location: 1st draw 3619 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 7/14/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-002

SAMPLE INFORMATION

Sample Number: 1207250-002 Customer Sample Number: 3054078 Program: DS
Location: 2nd draw 3619 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 7/14/2012 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-007

SAMPLE INFORMATION

Sample Number: 1207250-007 Customer Sample Number: 3127003 Program: DS
Location: 1st draw 635 L ST NE Type: Dist.

Collection Date: 7/22/2012 Collection Time: 8:40 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-008

SAMPLE INFORMATION

Sample Number: 1207250-008 Customer Sample Number: 3127003 Program: DS
Location: 2nd draw 635 L ST NE Type: Dist.

Collection Date: 7/22/2012 Collection Time: 8:41 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-009

SAMPLE INFORMATION

Sample Number: 1207250-009 Customer Sample Number: 3000216 Program: DS
Location: 1st draw 2425 I ST NW Type: Dist.

Collection Date: 7/23/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-010

SAMPLE INFORMATION

Sample Number: 1207250-010 Customer Sample Number: 3000216 Program: DS
Location: 2nd draw 2425 I ST NW Type: Dist.

Collection Date: 7/23/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-011

SAMPLE INFORMATION

Sample Number: 1207250-011 Customer Sample Number: 3050967 Program: DS
Location: 1st draw 1422 LONGFELLOW ST NW Type: Dist.

Collection Date: 7/23/2012 Collection Time: 6:11 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-012

SAMPLE INFORMATION

Sample Number: 1207250-012 Customer Sample Number: 3050967 Program: DS
Location: 2nd draw 1422 LONGFELLOW ST NW Type: Dist.

Collection Date: 7/23/2012 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207274-001

SAMPLE INFORMATION

Sample Number: 1207274-001 Customer Sample Number: 3010159 Program: DS
Location: 1st Draw 2214 38TH ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 3:47:10 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207274-002

SAMPLE INFORMATION

Sample Number: 1207274-002 Customer Sample Number: 3010159 Program: DS
Location: 2nd Draw 2214 38TH ST NW Type: Dist.

Collection Date: 7/24/2012 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 7/30/2012 3:47:10 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1208020-001

SAMPLE INFORMATION

Sample Number: 1208020-001 Customer Sample Number: 3009752 Program: DS
Location: 1st draw 2231 HALL PL NW Type: Dist.

Collection Date: 7/26/2012 Collection Time: 10:05 Sampler: HOME OWNER Received Date and Time: 8/1/2012 4:13:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1208020-002

SAMPLE INFORMATION

Sample Number: 1208020-002 Customer Sample Number: 3009752 Program: DS
Location: 2nd draw 2231 HALL PL NW Type: Dist.

Collection Date: 7/26/2012 Collection Time: 10:07 Sampler: HOME OWNER Received Date and Time: 8/1/2012 4:13:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.0 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1208020-003

SAMPLE INFORMATION

Sample Number: 1208020-003 Customer Sample Number: 3074709 Program: DS
Location: 1st draw 768 18TH ST SE Type: Dist.

Collection Date: 7/19/2012 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 8/1/2012 4:13:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	9.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1208020-004

SAMPLE INFORMATION

Sample Number: 1208020-004 Customer Sample Number: 3074709 Program: DS
Location: 2nd draw 768 18TH ST SE Type: Dist.

Collection Date: 7/19/2012 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 8/1/2012 4:13:57 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1208039-001

SAMPLE INFORMATION

Sample Number: 1208039-001 Customer Sample Number: 3071527 Program: DS
Location: 1st draw 152 N. CAROLINA AVE SE Type: Dist.

Collection Date: 8/1/2012 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 8/3/2012 1:46:48 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1208039-002

SAMPLE INFORMATION

Sample Number: 1208039-002 Customer Sample Number: 3071527 Program: DS
Location: 2nd draw 152 N. CAROLINA AVE SE Type: Dist.

Collection Date: 8/1/2012 Collection Time: 5:57 Sampler: HOME OWNER Received Date and Time: 8/3/2012 1:46:48 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1207169-005

SAMPLE INFORMATION

Sample Number: 1207169-005 Customer Sample Number: 3100083 Program: DS
Location: 1st draw 1323 CORBIN PLACE NE Type: Dist.

Collection Date: 7/16/2012 Collection Time: 7:52 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	70.9 ug/L	9/4/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1207169-006

SAMPLE INFORMATION

Sample Number: 1207169-006 Customer Sample Number: 3100083 Program: DS
Location: 2nd draw 1323 CORBIN PLACE NE Type: Dist.

Collection Date: 7/16/2012 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 7/18/2012 4:15:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208088-001

SAMPLE INFORMATION

Sample Number: 1208088-001 Customer Sample Number: 3074974 Program: DS
Location: 1st draw 721 15TH ST SE Type: Dist.

Collection Date: 8/2/2012 Collection Time: 17:37 Sampler: HOME OWNER Received Date and Time: 8/8/2012 4:06:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208088-002

SAMPLE INFORMATION

Sample Number: 1208088-002 Customer Sample Number: 3074974 Program: DS
Location: 2nd draw 721 15TH ST SE Type: Dist.

Collection Date: 8/2/2012 Collection Time: 17:39 Sampler: HOME OWNER Received Date and Time: 8/8/2012 4:06:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208088-003

SAMPLE INFORMATION

Sample Number: 1208088-003 Customer Sample Number: 3033209 Program: DS
Location: 1st draw 1337 FAIRMONT ST NW Type: Dist.

Collection Date: 8/3/2012 Collection Time: 14:45 Sampler: HOME OWNER Received Date and Time: 8/8/2012 4:06:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208088-004

SAMPLE INFORMATION

Sample Number: 1208088-004 Customer Sample Number: 3033209 Program: DS
Location: 2nd draw 1337 FAIRMONT ST NW Type: Dist.

Collection Date: 8/3/2012 Collection Time: 14:50 Sampler: HOME OWNER Received Date and Time: 8/8/2012 4:06:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208110-003

SAMPLE INFORMATION

Sample Number: 1208110-003 Customer Sample Number: 3059168 Program: DS
Location: 1st draw 1015 IRVING ST NW Type: Dist.

Collection Date: 8/6/2012 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208110-004

SAMPLE INFORMATION

Sample Number: 1208110-004 Customer Sample Number: 3059168 Program: DS
Location: 2nd draw 1015 IRVING ST NW Type: Dist.

Collection Date: 8/6/2012 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.8 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208110-005

SAMPLE INFORMATION

Sample Number: 1208110-005 Customer Sample Number: 3023462 Program: DS
Location: 1st draw 423 EMERSON ST NW Type: Dist.

Collection Date: 8/7/2012 Collection Time: 15:55 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208110-006

SAMPLE INFORMATION

Sample Number: 1208110-006 Customer Sample Number: 3023462 Program: DS
Location: 2nd draw 423 EMERSON ST NW Type: Dist.

Collection Date: 8/7/2012 Collection Time: 15:58 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208146-001

SAMPLE INFORMATION

Sample Number: 1208146-001 Customer Sample Number: 3020700 Program: DS
Location: 1st Draw 819 RANDOLF ST. NW Type: Dist.

Collection Date: 8/13/2012 Collection Time: 5:34 Sampler: HOME OWNER Received Date and Time: 8/15/2012 10:49:33 AM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208146-002

SAMPLE INFORMATION

Sample Number: 1208146-002 Customer Sample Number: 3020700 Program: DS
Location: 2nd Draw 819 RANDOLF ST. NW Type: Dist.

Collection Date: 8/13/2012 Collection Time: 5:35 Sampler: HOME OWNER Received Date and Time: 8/15/2012 10:49:33 AM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208219-003

SAMPLE INFORMATION

Sample Number: 1208219-003 Customer Sample Number: 3029382 Program: DS
Location: 1st Draw 1026 QUEBEC PL NW Type: Dist.

Collection Date: 8/14/2012 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 8/22/2012 2:57:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208219-004

SAMPLE INFORMATION

Sample Number: 1208219-004 Customer Sample Number: 3029382 Program: DS
Location: 2nd Draw 1026 QUEBEC PL NW Type: Dist.

Collection Date: 8/14/2012 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 8/22/2012 2:57:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208219-005

SAMPLE INFORMATION

Sample Number: 1208219-005 Customer Sample Number: 3058663 Program: DS
Location: 1st Draw 3239 BEECH ST NW Type: Dist.

Collection Date: 8/14/2012 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 8/22/2012 2:57:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208219-006

SAMPLE INFORMATION

Sample Number: 1208219-006 Customer Sample Number: 3058663 Program: DS
Location: 2nd Draw 3239 BEECH ST NW Type: Dist.

Collection Date: 8/14/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 8/22/2012 2:57:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208261-003

SAMPLE INFORMATION

Sample Number: 1208261-003 Customer Sample Number: 3121987 Program: DS
Location: 1st draw 106 13TH ST NE Type: Dist.

Collection Date: 8/22/2012 Collection Time: 7:29 Sampler: HOME OWNER Received Date and Time: 8/27/2012 4:07:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208261-004

SAMPLE INFORMATION

Sample Number: 1208261-004 Customer Sample Number: 3121987 Program: DS
Location: 2nd draw 106 13TH ST NE Type: Dist.

Collection Date: 8/22/2012 Collection Time: 7:34 Sampler: HOME OWNER Received Date and Time: 8/27/2012 4:07:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208276-003

SAMPLE INFORMATION

Sample Number: 1208276-003 Customer Sample Number: 3046858 Program: DS
Location: 1st draw 7413 BLAIR RD NW Type: Dist.

Collection Date: 8/26/2012 Collection Time: 16:40 Sampler: HOME OWNER Received Date and Time: 8/29/2012 12:32:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208276-004

SAMPLE INFORMATION

Sample Number: 1208276-004 Customer Sample Number: 3046858 Program: DS
Location: 2nd draw 7413 BLAIR RD NW Type: Dist.

Collection Date: 8/26/2012 Collection Time: 16:45 Sampler: HOME OWNER Received Date and Time: 8/29/2012 12:32:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208276-005

SAMPLE INFORMATION

Sample Number: 1208276-005 Customer Sample Number: 3027125 Program: DS
Location: 1st draw 729 TUCKERMAN ST NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 8/29/2012 12:32:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208276-006

SAMPLE INFORMATION

Sample Number: 1208276-006 Customer Sample Number: 3027215 Program: DS
Location: 2nd draw 729 TUCKERMAN ST NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 17:48 Sampler: HOME OWNER Received Date and Time: 8/29/2012 12:32:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209073-001

SAMPLE INFORMATION

Sample Number: 1209073-001 Customer Sample Number: 3020865 Program: DS
Location: 1st draw 4011 4TH ST NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:34:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209073-002

SAMPLE INFORMATION

Sample Number: 1209073-002 Customer Sample Number: 3020865 Program: DS
Location: 2nd draw 4011 4TH ST NW Type: Dist.

Collection Date: 8/27/2012 Collection Time: 5:17 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:34:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209073-003

SAMPLE INFORMATION

Sample Number: 1209073-003 Customer Sample Number: 3074695 Program: DS
Location: 1st draw 536 13TH ST SE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:34:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209073-004

SAMPLE INFORMATION

Sample Number: 1209073-004 Customer Sample Number: 3074695 Program: DS
Location: 2nd draw 536 13TH ST SE Type: Dist.

Collection Date: 8/29/2012 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:34:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209073-005

SAMPLE INFORMATION

Sample Number: 1209073-005 Customer Sample Number: 3041258 Program: DS
Location: 1st draw 4232 RENO RD NW Type: Dist.

Collection Date: 9/6/2012 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:34:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209073-006

SAMPLE INFORMATION

Sample Number: 1209073-006 Customer Sample Number: 3041258 Program: DS
Location: 2nd draw 4232 RENO RD NW Type: Dist.

Collection Date: 9/6/2012 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 9/10/2012 4:34:51 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209084-001

SAMPLE INFORMATION

Sample Number: 1209084-001 Customer Sample Number: 3031982 Program: DS
Location: 1st draw 733 PARK RD NW Type: Dist.

Collection Date: 9/6/2012 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 9/11/2012 4:28:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209084-002

SAMPLE INFORMATION

Sample Number: 1209084-002 Customer Sample Number: 3031982 Program: DS
Location: 2nd draw 733 PARK RD NW Type: Dist.

Collection Date: 9/6/2012 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 9/11/2012 4:28:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.4 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209084-003

SAMPLE INFORMATION

Sample Number: 1209084-003 Customer Sample Number: 3033824 Program: DS
Location: 1st draw 1825 IRVING ST NW Type: Dist.

Collection Date: 9/7/2012 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 9/11/2012 4:28:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209084-004

SAMPLE INFORMATION

Sample Number: 1209084-004 Customer Sample Number: 3033824 Program: DS
Location: 2nd draw 1825 IRVING ST NW Type: Dist.

Collection Date: 9/7/2012 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 9/11/2012 4:28:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-001

SAMPLE INFORMATION

Sample Number: 1209112-001 Customer Sample Number: 3085907 Program: DS
Location: 2nd draw 3415 WHEELER RD SE Type: Dist.

Collection Date: 9/9/2012 Collection Time: 13:00 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-002

SAMPLE INFORMATION

Sample Number: 1209112-002 Customer Sample Number: 3044913 Program: DS
Location: 1st draw 1847 47TH PLACE NW Type: Dist.

Collection Date: 9/10/2012 Collection Time: 6:09 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-003

SAMPLE INFORMATION

Sample Number: 1209112-003 Customer Sample Number: 3044913 Program: DS
Location: 2nd draw 1847 47TH PLACE NW Type: Dist.

Collection Date: 9/10/2012 Collection Time: 6:13 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-004

SAMPLE INFORMATION

Sample Number: 1209112-004 Customer Sample Number: 3059498 Program: DS
Location: 1st draw 4020 51 ST. NW Type: Dist.

Collection Date: 9/8/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-005

SAMPLE INFORMATION

Sample Number: 1209112-005 Customer Sample Number: 3059498 Program: DS
Location: 2nd draw 4020 51 ST. NW Type: Dist.

Collection Date: 9/8/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-006

SAMPLE INFORMATION

Sample Number: 1209112-006 Customer Sample Number: 3058651 Program: DS
Location: 1st draw 3201 BEECH ST. NW Type: Dist.

Collection Date: 9/5/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-007

SAMPLE INFORMATION

Sample Number: 1209112-007 Customer Sample Number: 3058651 Program: DS
Location: 2nd draw 3201 BEECH ST. NW Type: Dist.

Collection Date: 9/5/2012 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-008

SAMPLE INFORMATION

Sample Number: 1209112-008 Customer Sample Number: 3036103 Program: DS
Location: 1st draw 3250 HIGHLAND PL NW Type: Dist.

Collection Date: 9/10/2012 Collection Time: 5:17 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209112-009

SAMPLE INFORMATION

Sample Number: 1209112-009 Customer Sample Number: 3036103 Program: DS
Location: 2nd draw 3250 HIGHLAND PL NW Type: Dist.

Collection Date: 9/10/2012 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 9/13/2012 2:39:36 PM Received By: LNeal

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-001

SAMPLE INFORMATION

Sample Number: 1209149-001 Customer Sample Number: 3032429 Program: DS
Location: 1st draw 1004 GIRARD ST NW Type: Dist.

Collection Date: 9/6/2012 Collection Time: 15:32 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.6 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-002

SAMPLE INFORMATION

Sample Number: 1209149-002 Customer Sample Number: 3032429 Program: DS
Location: 2nd draw 1004 GIRARD ST NW Type: Dist.

Collection Date: 9/6/2012 Collection Time: 15:35 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-003

SAMPLE INFORMATION

Sample Number: 1209149-003 Customer Sample Number: 3027683 Program: DS
Location: 1st draw 4517 ARKANSAS AVE NW Type: Dist.

Collection Date: 9/13/2012 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-004

SAMPLE INFORMATION

Sample Number: 1209149-004 Customer Sample Number: 3027683 Program: DS
Location: 2nd draw 4517 ARKANSAS AVE NW Type: Dist.

Collection Date: 9/13/2012 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-005

SAMPLE INFORMATION

Sample Number: 1209149-005 Customer Sample Number: 3044219 Program: DS
Location: 1st draw 4426 LOWELL ST NW Type: Dist.

Collection Date: 9/14/2012 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-006

SAMPLE INFORMATION

Sample Number: 1209149-006 Customer Sample Number: 3044219 Program: DS
Location: 2nd draw 4426 LOWELL ST NW Type: Dist.

Collection Date: 9/14/2012 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-007

SAMPLE INFORMATION

Sample Number: 1209149-007 Customer Sample Number: 3010050 Program: DS
Location: 1st draw 2239 OBSERVATORY PL NW Type: Dist.

Collection Date: 9/17/2012 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209149-008

SAMPLE INFORMATION

Sample Number: 1209149-008 Customer Sample Number: 3010050 Program: DS
Location: 2nd draw 2239 OBSERVATORY PL NW Type: Dist.

Collection Date: 9/17/2012 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 9/18/2012 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-001

SAMPLE INFORMATION

Sample Number: 1209188-001 Customer Sample Number: 3027882 Program: DS
Location: 1st draw 1417 BUCHANAN ST NW Type: Dist.

Collection Date: 9/19/2012 Collection Time: 7:45 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.7 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-002

SAMPLE INFORMATION

Sample Number: 1209188-002 Customer Sample Number: 3027882 Program: DS
Location: 2nd draw 1417 BUCHANAN ST NW Type: Dist.

Collection Date: 9/19/2012 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-003

SAMPLE INFORMATION

Sample Number: 1209188-003 Customer Sample Number: 3027919 Program: DS
Location: 1st draw 4615 16TH ST NW Type: Dist.

Collection Date: 9/17/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-004

SAMPLE INFORMATION

Sample Number: 1209188-004 Customer Sample Number: 3027919 Program: DS
Location: 2nd draw 4615 16TH ST NW Type: Dist.

Collection Date: 9/17/2012 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-005

SAMPLE INFORMATION

Sample Number: 1209188-005 Customer Sample Number: 3053300 Program: DS
Location: 1st draw 2920 RITTENHOUSE ST NW Type: Dist.

Collection Date: 9/17/2012 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-006

SAMPLE INFORMATION

Sample Number: 1209188-006 Customer Sample Number: 3053300 Program: DS
Location: 2nd draw 2920 RITTENHOUSE ST NW Type: Dist.

Collection Date: 9/17/2012 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-007

SAMPLE INFORMATION

Sample Number: 1209188-007 Customer Sample Number: 3127753 Program: DS
Location: 1st draw 625 4TH ST NE Type: Dist.

Collection Date: 9/15/2012 Collection Time: 6:56 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209188-008

SAMPLE INFORMATION

Sample Number: 1209188-008 Customer Sample Number: 3127753 Program: DS
Location: 2nd draw 625 4TH ST NE Type: Dist.

Collection Date: 9/15/2012 Collection Time: 6:59 Sampler: HOME OWNER Received Date and Time: 9/21/2012 3:19:33 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-001

SAMPLE INFORMATION

Sample Number: 1209232-001 Customer Sample Number: 3054974 Program: DS
Location: 1st draw 3708 MASSACHUSETTS AVE NW Type: Dist.

Collection Date: 9/21/2012 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-002

SAMPLE INFORMATION

Sample Number: 1209232-002 Customer Sample Number: 3054974 Program: DS
Location: 2nd draw 3708 MASSACHUSETTS AVE NW Type: Dist.

Collection Date: 9/21/2012 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-003

SAMPLE INFORMATION

Sample Number: 1209232-003 Customer Sample Number: 3057480 Program: DS
Location: 1st draw 3314 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 9/22/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-004

SAMPLE INFORMATION

Sample Number: 1209232-004 Customer Sample Number: 3057480 Program: DS
Location: 2nd draw 3314 NEW HAMPSHIRE AVE NW Type: Dist.

Collection Date: 9/22/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-005

SAMPLE INFORMATION

Sample Number: 1209232-005 Customer Sample Number: 3034760 Program: DS
Location: 1st draw 2319 TRACY PLACE NW Type: Dist.

Collection Date: 9/23/2012 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-006

SAMPLE INFORMATION

Sample Number: 1209232-006 Customer Sample Number: 3034760 Program: DS
Location: 2nd draw 2319 TRACY PLACE NW Type: Dist.

Collection Date: 9/23/2012 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210008-001

SAMPLE INFORMATION

Sample Number: 1210008-001 Customer Sample Number: 3038639 Program: DS
Location: 1st draw 6639 WESTERN AVE NW Type: Dist.

Collection Date: 9/23/2012 Collection Time: 8:18 Sampler: HOME OWNER Received Date and Time: 10/1/2012 11:17:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210008-002

SAMPLE INFORMATION

Sample Number: 1210008-002 Customer Sample Number: 3038639 Program: DS
Location: 2nd draw 6639 WESTERN AVE NW Type: Dist.

Collection Date: 9/23/2012 Collection Time: 8:22 Sampler: HOME OWNER Received Date and Time: 10/1/2012 11:17:44 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210052-001

SAMPLE INFORMATION

Sample Number: 1210052-001 Customer Sample Number: 3113278 Program: DS
Location: 1st draw 613 GIRARD ST NE Type: Dist.

Collection Date: 9/30/2012 Collection Time: 8:36 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:25:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210052-002

SAMPLE INFORMATION

Sample Number: 1210052-002 Customer Sample Number: 3113278 Program: DS
Location: 2nd draw 613 GIRARD ST NE Type: Dist.

Collection Date: 9/30/2012 Collection Time: 8:40 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:25:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210052-003

SAMPLE INFORMATION

Sample Number: 1210052-003 Customer Sample Number: 3040949 Program: DS
Location: 1st draw 4617 42ND ST NW Type: Dist.

Collection Date: 10/2/2012 Collection Time: 8:04 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:25:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210052-004

SAMPLE INFORMATION

Sample Number: 1210052-004 Customer Sample Number: 3040949 Program: DS
Location: 2nd draw 4617 42ND ST NW Type: Dist.

Collection Date: 10/2/2012 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:25:27 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210096-001

SAMPLE INFORMATION

Sample Number: 1210096-001 Customer Sample Number: 3059257 Program: DS
Location: 1st draw 3311 SHERMAN AVE NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 17:05 Sampler: HOME OWNER Received Date and Time: 10/9/2012 4:30:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210096-002

SAMPLE INFORMATION

Sample Number: 1210096-002 Customer Sample Number: 3059257 Program: DS
Location: 2nd draw 3311 SHERMAN AVE NW Type: Dist.

Collection Date: 9/25/2012 Collection Time: 17:15 Sampler: HOME OWNER Received Date and Time: 10/9/2012 4:30:22 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	24.1 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210132-001

SAMPLE INFORMATION

Sample Number: 1210132-001 Customer Sample Number: 3041277 Program: DS
Location: 1st Draw 3729 VEAZY ST., NW Type: Dist.

Collection Date: 10/5/2012 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 10/12/2012 2:32:02 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210132-002

SAMPLE INFORMATION

Sample Number: 1210132-002 Customer Sample Number: 3041277 Program: DS
Location: 2nd Draw 3729 VEAZY ST., NW Type: Dist.

Collection Date: 10/5/2012 Collection Time: 9:10 Sampler: HOME OWNER Received Date and Time: 10/12/2012 2:32:02 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210132-003

SAMPLE INFORMATION

Sample Number: 1210132-003 Customer Sample Number: 3109698 Program: DS
Location: 1st Draw 5739 BLAINE ST NE Type: Dist.

Collection Date: 10/6/2012 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 10/12/2012 2:32:02 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210132-004

SAMPLE INFORMATION

Sample Number: 1210132-004 Customer Sample Number: 3109698 Program: DS
Location: 2nd Draw 5739 BLAINE ST NE Type: Dist.

Collection Date: 10/6/2012 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 10/12/2012 2:32:02 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210149-001

SAMPLE INFORMATION

Sample Number: 1210149-001 Customer Sample Number: 3032341 Program: DS
Location: 1st Draw 741 IRVING ST NW Type: Dist.

Collection Date: 10/11/2012 Collection Time: 7:49 Sampler: HOME OWNER Received Date and Time: 10/15/2012 3:47:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	9.6 ug/L	10/23/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210149-002

SAMPLE INFORMATION

Sample Number: 1210149-002 Customer Sample Number: 3032341 Program: DS
Location: 2nd Draw 741 IRVING ST NW Type: Dist.

Collection Date: 10/11/2012 Collection Time: 7:53 Sampler: HOME OWNER Received Date and Time: 10/15/2012 3:47:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.0 ug/L	10/23/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210149-003

SAMPLE INFORMATION

Sample Number: 1210149-003 Customer Sample Number: 3099327 Program: DS
Location: 1st Draw 1107 MARYLAND AVE NE Type: Dist.

Collection Date: 10/12/2012 Collection Time: 6:53 Sampler: HOME OWNER Received Date and Time: 10/15/2012 3:47:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.1 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210149-004

SAMPLE INFORMATION

Sample Number: 1210149-004 Customer Sample Number: 3099327 Program: DS
Location: 2nd Draw 1107 MARYLAND AVE NE Type: Dist.

Collection Date: 10/12/2012 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 10/15/2012 3:47:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210167-003

SAMPLE INFORMATION

Sample Number: 1210167-003 Customer Sample Number: 3009868 Program: DS
Location: 1st Draw 2016 TUNLAN RD NW Type: Dist.

Collection Date: 10/12/2012 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 10/17/2012 2:26:16 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210167-004

SAMPLE INFORMATION

Sample Number: 1210167-004 Customer Sample Number: 3009868 Program: DS
Location: 2nd Draw 2016 TUNLAN RD NW Type: Dist.

Collection Date: 10/12/2012 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 10/17/2012 2:26:16 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210167-005

SAMPLE INFORMATION

Sample Number: 1210167-005 Customer Sample Number: 3033024 Program: DS
Location: 1st Draw 1226 EUCLID ST NW Type: Dist.

Collection Date: 10/15/2012 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 10/17/2012 2:26:16 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210167-006

SAMPLE INFORMATION

Sample Number: 1210167-006 Customer Sample Number: 3033024 Program: DS
Location: 2nd Draw 1226 EUCLID ST NW Type: Dist.

Collection Date: 10/15/2012 Collection Time: 6:48 Sampler: HOME OWNER Received Date and Time: 10/17/2012 2:26:16 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210191-003

SAMPLE INFORMATION

Sample Number: 1210191-003 Customer Sample Number: 3074142 Program: DS
Location: 1st Draw 1216 C ST. SE Type: Dist.

Collection Date: 10/12/2012 Collection Time: 10:30 Sampler: HOME OWNER Received Date and Time: 10/19/2012 3:28:23 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210191-004

SAMPLE INFORMATION

Sample Number: 1210191-004 Customer Sample Number: 3074142 Program: DS
Location: 2nd Draw 1216 C ST. SE Type: Dist.

Collection Date: 10/12/2012 Collection Time: 10:36 Sampler: HOME OWNER Received Date and Time: 10/19/2012 3:28:23 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: LC-W1210112-001

SAMPLE INFORMATION

Sample Number: 1210112-001 Customer Sample Number: 3036747 Program: DS
Location: 1st Draw 3416 GARRISON ST. NW Type: Dist.

Collection Date: 10/4/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 10/10/2012 3:32:54 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	11.1 ug/L	11/8/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: LC-W1210112-002

SAMPLE INFORMATION

Sample Number: 1210112-002 Customer Sample Number: 3036747 Program: DS
Location: 2nd Draw 3416 GARRISON ST. NW Type: Dist.

Collection Date: 10/4/2012 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 10/10/2012 3:32:54 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210213-001

SAMPLE INFORMATION

Sample Number: 1210213-001 Customer Sample Number: 3102823 Program: DS
Location: 1st draw 2016 SUMMIT PL. NE Type: Dist.

Collection Date: 10/19/2012 Collection Time: 18:16 Sampler: HOME OWNER Received Date and Time: 10/23/2012 3:39:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.8 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210213-002

SAMPLE INFORMATION

Sample Number: 1210213-002 Customer Sample Number: 3102823 Program: DS
Location: 2nd draw 2016 SUMMIT PL. NE Type: Dist.

Collection Date: 10/19/2012 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 10/23/2012 3:39:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.6 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-003 Customer Sample Number: 3116379 Program: DS
Location: 1st Draw 4402 BANKS PL NE Type: Dist.

Collection Date: 10/23/2012 Collection Time: 21:36 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-004 Customer Sample Number: 3116379 Program: DS
Location: 2nd Draw 4402 BANKS PL NE Type: Dist.

Collection Date: 10/23/2012 Collection Time: 21:40 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-005 Customer Sample Number: 3122624 Program: DS
Location: 1st Draw 808 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-006 Customer Sample Number: 3122624 Program: DS
Location: 2nd Draw 808 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 10/24/2012 Collection Time: 5:01 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-007 Customer Sample Number: 3055275 Program: DS
Location: 1st Draw 4420 GREENWICH PKWY NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-008 Customer Sample Number: 3055275 Program: DS
Location: 2nd Draw 4420 GREENWICH PKWY NW Type: Dist.

Collection Date: 10/24/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1211075-001

SAMPLE INFORMATION

Sample Number: 1211075-001 Customer Sample Number: 3053913 Program: DS
Location: 1st draw 2047 ROSEMONT AVE NW Type: Dist.

Collection Date: 11/3/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/8/2012 3:30:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1211075-002

SAMPLE INFORMATION

Sample Number: 1211075-002 Customer Sample Number: 3053913 Program: DS
Location: 2nd draw 2047 ROSEMONT AVE NW Type: Dist.

Collection Date: 11/3/2012 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 11/8/2012 3:30:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1211075-003

SAMPLE INFORMATION

Sample Number: 1211075-003 Customer Sample Number: 3092263 Program: DS
Location: 1st draw 1511 1ST ST SW Type: Dist.

Collection Date: 11/4/2012 Collection Time: 9:08 Sampler: HOME OWNER Received Date and Time: 11/8/2012 3:30:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1211075-004

SAMPLE INFORMATION

Sample Number: 1211075-004 Customer Sample Number: 3092263 Program: DS
Location: 2nd draw 1511 1ST ST SW Type: Dist.

Collection Date: 11/4/2012 Collection Time: 9:12 Sampler: HOME OWNER Received Date and Time: 11/8/2012 3:30:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1211075-005

SAMPLE INFORMATION

Sample Number: 1211075-005 Customer Sample Number: 3040735 Program: DS
Location: 1st draw 3902 HUNTINGTON ST. NW Type: Dist.

Collection Date: 11/5/2012 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 11/8/2012 3:30:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1211075-006

SAMPLE INFORMATION

Sample Number: 1211075-006 Customer Sample Number: 3040735 Program: DS
Location: 2nd draw 3902 HUNTINGTON ST. NW Type: Dist.

Collection Date: 11/5/2012 Collection Time: 6:54 Sampler: HOME OWNER Received Date and Time: 11/8/2012 3:30:55 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211116-001

SAMPLE INFORMATION

Sample Number: 1211116-001 Customer Sample Number: 3044730 Program: DS
Location: 1st draw 1509 44TH ST, NW Type: Dist.

Collection Date: 11/12/2012 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 11/15/2012 12:07:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	11/19/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211116-002

SAMPLE INFORMATION

Sample Number: 1211116-002 Customer Sample Number: 3044730 Program: DS
Location: 2nd draw 1509 44TH ST, NW Type: Dist.

Collection Date: 11/12/2012 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 11/15/2012 12:07:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	11/19/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211132-001

SAMPLE INFORMATION

Sample Number: 1211132-001 Customer Sample Number: 3017898 Program: DS
Location: 1st draw 65 RANDOLPH PL NW Type: Dist.

Collection Date: 11/6/2012 Collection Time: 19:05 Sampler: HOME OWNER Received Date and Time: 11/16/2012 1:02:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.8 ug/L	11/19/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211132-002

SAMPLE INFORMATION

Sample Number: 1211132-002 Customer Sample Number: 3017898 Program: DS
Location: 2nd draw 65 RANDOLPH PL NW Type: Dist.

Collection Date: 11/6/2012 Collection Time: 19:06 Sampler: HOME OWNER Received Date and Time: 11/16/2012 1:02:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	11/19/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211132-003

SAMPLE INFORMATION

Sample Number: 1211132-003 Customer Sample Number: 3033862 Program: DS
Location: 1st draw 1721 HOBART ST NW Type: Dist.

Collection Date: 11/8/2012 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 11/16/2012 1:02:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211132-004

SAMPLE INFORMATION

Sample Number: 1211132-004 Customer Sample Number: 3033862 Program: DS
Location: 2nd draw 1721 HOBART ST NW Type: Dist.

Collection Date: 11/8/2012 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 11/16/2012 1:02:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-001

SAMPLE INFORMATION

Sample Number: 1211183-001 Customer Sample Number: 3057572 Program: DS
Location: 1st Draw 2911 33RD PL NW Type: Dist.

Collection Date: 11/15/2012 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-002

SAMPLE INFORMATION

Sample Number: 1211183-002 Customer Sample Number: 3057572 Program: DS
Location: 2nd Draw 2911 33RD PL NW Type: Dist.

Collection Date: 11/15/2012 Collection Time: 7:29 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-003

SAMPLE INFORMATION

Sample Number: 1211183-003 Customer Sample Number: 3037992 Program: DS
Location: 1st Draw 3005 STEPHENSEN PL NW Type: Dist.

Collection Date: 11/19/2012 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-004

SAMPLE INFORMATION

Sample Number: 1211183-004 Customer Sample Number: 3037992 Program: DS
Location: 2nd Draw 3005 STEPHENSEN PL NW Type: Dist.

Collection Date: 11/19/2012 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-005

SAMPLE INFORMATION

Sample Number: 1211183-005 Customer Sample Number: 3122367 Program: DS
Location: 1st Draw 311 13TH ST NE Type: Dist.

Collection Date: 11/19/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-006

SAMPLE INFORMATION

Sample Number: 1211183-006 Customer Sample Number: 3122367 Program: DS
Location: 2nd Draw 311 13TH ST NE Type: Dist.

Collection Date: 11/19/2012 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-007

SAMPLE INFORMATION

Sample Number: 1211183-007 Customer Sample Number: 3050980 Program: DS
Location: 1st Draw 1350 INGRAHAM ST. NW Type: Dist.

Collection Date: 11/19/2012 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-008

SAMPLE INFORMATION

Sample Number: 1211183-008 Customer Sample Number: 3050980 Program: DS
Location: 2nd Draw 1350 INGRAHAM ST. NW Type: Dist.

Collection Date: 11/19/2012 Collection Time: 9:10 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-009

SAMPLE INFORMATION

Sample Number: 1211183-009 Customer Sample Number: 3040366 Program: DS
Location: 1st Draw 3933 GARRISON ST. NW Type: Dist.

Collection Date: 11/19/2012 Collection Time: 18:40 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1211183-010

SAMPLE INFORMATION

Sample Number: 1211183-010 Customer Sample Number: 3040366 Program: DS
Location: 2nd Draw 3933 GARRISON ST. NW Type: Dist.

Collection Date: 11/19/2012 Collection Time: 18:43 Sampler: HOME OWNER Received Date and Time: 11/26/2012 2:04:28 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-003

SAMPLE INFORMATION

Sample Number: 1212034-003 Customer Sample Number: 3011931 Program: DS
Location: 1st draw 1324 27TH ST NW Type: Dist.

Collection Date: 12/2/2012 Collection Time: 12:35 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-004

SAMPLE INFORMATION

Sample Number: 1212034-004 Customer Sample Number: 3011931 Program: DS
Location: 2nd draw 1324 27TH ST NW Type: Dist.

Collection Date: 12/2/2012 Collection Time: 12:37 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-005

SAMPLE INFORMATION

Sample Number: 1212034-005 Customer Sample Number: 3057740 Program: DS
Location: 1st draw 1680 TAMARACK ST NW Type: Dist.

Collection Date: 12/2/2012 Collection Time: 10:42 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-006

SAMPLE INFORMATION

Sample Number: 1212034-006 Customer Sample Number: 3057740 Program: DS
Location: 2nd draw 1680 TAMARACK ST NW Type: Dist.

Collection Date: 12/2/2012 Collection Time: 10:45 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-009

SAMPLE INFORMATION

Sample Number: 1212034-009 Customer Sample Number: 3074663 Program: DS
Location: 1st draw 707 14TH ST SE Type: Dist.

Collection Date: 12/3/2012 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-010

SAMPLE INFORMATION

Sample Number: 1212034-010 Customer Sample Number: 3074663 Program: DS
Location: 2nd draw 707 14TH ST SE Type: Dist.

Collection Date: 12/3/2012 Collection Time: 5:34 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-011

SAMPLE INFORMATION

Sample Number: 1212034-011 Customer Sample Number: 3057899 Program: DS
Location: 1st draw 2905 34TH ST NW Type: Dist.

Collection Date: 12/3/2012 Collection Time: 5:10 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-012

SAMPLE INFORMATION

Sample Number: 1212034-012 Customer Sample Number: 3057889 Program: DS
Location: 2nd draw 2905 34TH ST NW Type: Dist.

Collection Date: 12/3/2012 Collection Time: 5:14 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212048-001

SAMPLE INFORMATION

Sample Number: 1212048-001 Customer Sample Number: 3121126 Program: DS
Location: 1st draw 635 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 12/5/2012 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 12/6/2012 11:59:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212048-002

SAMPLE INFORMATION

Sample Number: 1212048-002 Customer Sample Number: 3121126 Program: DS
Location: 2nd draw 635 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 12/5/2012 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 12/6/2012 11:59:42 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-003

SAMPLE INFORMATION

Sample Number: 1212094-003 Customer Sample Number: 3108051 Program: DS
Location: 1st draw 3015 CHANNING ST NE Type: Dist.

Collection Date: 12/5/2012 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-004

SAMPLE INFORMATION

Sample Number: 1212094-004 Customer Sample Number: 3108051 Program: DS
Location: 2nd draw 3015 CHANNING ST NE Type: Dist.

Collection Date: 12/5/2012 Collection Time: 7:11 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.0 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-007

SAMPLE INFORMATION

Sample Number: 1212094-007 Customer Sample Number: 3121855 Program: DS
Location: 1st draw 1216 CONSTITUTION AVE NE Type: Dist.

Collection Date: 12/7/2012 Collection Time: 5:53 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-008

SAMPLE INFORMATION

Sample Number: 1212094-008 Customer Sample Number: 3121855 Program: DS
Location: 2nd draw 1216 CONSTITUTION AVE NE Type: Dist.

Collection Date: 12/7/2012 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-001

SAMPLE INFORMATION

Sample Number: 1206118-001 Customer Sample Number: 3033689 Program: Post-LSR
Location: 1st draw 1757 EUCLID ST NW Type: Dist.
Collection Date: 6/11/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-002

SAMPLE INFORMATION

Sample Number: 1206118-002 Customer Sample Number: 3033689 Program: Post-LSR
Location: 2nd draw 1757 EUCLID ST NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-005

SAMPLE INFORMATION

Sample Number: 1206118-005 Customer Sample Number: 3034068 Program: Post-LSR
Location: 1st draw 2729 ONTARIO ROAD, NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206118-006

SAMPLE INFORMATION

Sample Number: 1206118-006 Customer Sample Number: 3034068 Program: Post-LSR
Location: 2nd draw 2729 ONTARIO ROAD, NW Type: Dist.

Collection Date: 6/11/2012 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 6/14/2012 12:25:22 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206128-001

SAMPLE INFORMATION

Sample Number: 1206128-001 Customer Sample Number: 3008381 Program: Post-LSR
Location: 1st draw 3425 O ST. NW Type: Dist.
Collection Date: 6/7/2012 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 6/15/2012 1:05:56 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206128-002

SAMPLE INFORMATION

Sample Number: 1206128-002 Customer Sample Number: 3008381 Program: Post-LSR
Location: 2nd draw 3425 O ST. NW Type: Dist.

Collection Date: 6/7/2012 Collection Time: 22:05 Sampler: HOME OWNER Received Date and Time: 6/15/2012 1:05:56 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/25/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-003

SAMPLE INFORMATION

Sample Number: 1206241-003 Customer Sample Number: 3008371 Program: Post-LSR
Location: 1st draw 3403 O ST NW Type: Dist.

Collection Date: 6/21/2012 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1206241-004

SAMPLE INFORMATION

Sample Number: 1206241-004 Customer Sample Number: 3008371 Program: Post-LSR
Location: 2nd draw 3403 O ST NW Type: Dist.

Collection Date: 6/21/2012 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 6/27/2012 4:19:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-007

SAMPLE INFORMATION

Sample Number: 1207019-007 Customer Sample Number: 3034071 Program: Post-LSR
Location: 1st draw 2735 ONTARIO RD NW Type: Dist.

Collection Date: 6/27/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207019-008

SAMPLE INFORMATION

Sample Number: 1207019-008 Customer Sample Number: 3034071 Program: Post-LSR
Location: 2nd draw 2735 ONTARIO RD NW Type: Dist.

Collection Date: 6/27/2012 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 7/2/2012 4:36:21 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-005

SAMPLE INFORMATION

Sample Number: 1207098-005 Customer Sample Number: 3034062 Program: Post-LSR
Location: 1st draw 2715 ONTARIO RD NW Type: Dist.
Collection Date: 7/9/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-006

SAMPLE INFORMATION

Sample Number: 1207098-006 Customer Sample Number: 3034062 Program: Post-LSR
Location: 2nd draw 2715 ONTARIO RD NW Type: Dist.

Collection Date: 7/9/2012 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-007

SAMPLE INFORMATION

Sample Number: 1207098-007 Customer Sample Number: 3034067 Program: Post-LSR
Location: 1st draw 2727 ONTARIO RD NW Type: Dist.
Collection Date: 7/1/2012 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207098-008

SAMPLE INFORMATION

Sample Number: 1207098-008 Customer Sample Number: 3034067 Program: Post-LSR
Location: 2nd draw 2727 ONTARIO RD NW Type: Dist.

Collection Date: 7/1/2012 Collection Time: 8:12 Sampler: HOME OWNER Received Date and Time: 7/11/2012 3:49:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-003

SAMPLE INFORMATION

Sample Number: 1207250-003 Customer Sample Number: 3124757 Program: Post-LSR
Location: 1st draw 236 R ST NE Type: Dist.

Collection Date: 7/19/2012 Collection Time: 17:42 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	25.8 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-004

SAMPLE INFORMATION

Sample Number: 1207250-004 Customer Sample Number: 3124757 Program: Post-LSR
Location: 2nd draw 236 R ST NE Type: Dist.

Collection Date: 7/19/2012 Collection Time: 17:43 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	69.4 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-005

SAMPLE INFORMATION

Sample Number: 1207250-005 Customer Sample Number: 3008305 Program: Post-LSR
Location: 1st draw 3258 O ST NW Type: Dist.

Collection Date: 7/20/2012 Collection Time: 16:50 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/20/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/23/2012
Report Number: LC-W1207250-006

SAMPLE INFORMATION

Sample Number: 1207250-006 Customer Sample Number: 3008305 Program: Post-LSR
Location: 2nd draw 3258 O ST NW Type: Dist.

Collection Date: 7/20/2012 Collection Time: 16:51 Sampler: HOME OWNER Received Date and Time: 7/26/2012 3:21:19 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/20/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/23/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208088-005

SAMPLE INFORMATION

Sample Number: 1208088-005 Customer Sample Number: 3008655 Program: Post-LSR
Location: 1st draw 3215 O ST NW APT 3 Type: Dist.

Collection Date: 8/3/2012 Collection Time: 19:35 Sampler: HOME OWNER Received Date and Time: 8/8/2012 4:06:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208088-006

SAMPLE INFORMATION

Sample Number: 1208088-006 Customer Sample Number: 3008655 Program: Post-LSR
Location: 2nd draw 3215 O ST NW APT 3 Type: Dist.

Collection Date: 8/3/2012 Collection Time: 19:38 Sampler: HOME OWNER Received Date and Time: 8/8/2012 4:06:59 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208110-007

SAMPLE INFORMATION

Sample Number: 1208110-007 Customer Sample Number: 3008657 Program: Post-LSR
Location: 1st draw 3249 O ST. NW Type: Dist.

Collection Date: 8/8/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208110-008

SAMPLE INFORMATION

Sample Number: 1208110-008 Customer Sample Number: 3008657 Program: Post-LSR
Location: 2nd draw 3249 O ST. NW Type: Dist.

Collection Date: 8/8/2012 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/10/2012 2:44:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208142-001

SAMPLE INFORMATION

Sample Number: 1208142-001 Customer Sample Number: 3008654 Program: Post-LSR
Location: 1st draw 3213 O ST., NW Type: Dist.

Collection Date: 8/7/2012 Collection Time: 9:33 Sampler: HOME OWNER Received Date and Time: 8/14/2012 2:59:16 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.2 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208142-002

SAMPLE INFORMATION

Sample Number: 1208142-002 Customer Sample Number: 3008654 Program: Post-LSR
Location: 2nd draw 3213 O ST., NW Type: Dist.

Collection Date: 8/7/2012 Collection Time: 9:40 Sampler: HOME OWNER Received Date and Time: 8/14/2012 2:59:16 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208142-003

SAMPLE INFORMATION

Sample Number: 1208142-003 Customer Sample Number: 3008694 Program: Post-LSR
Location: 1st draw 1400 WISCONSIN AVE NW Type: Dist.

Collection Date: 8/6/2012 Collection Time: 11:00 Sampler: HOME OWNER Received Date and Time: 8/14/2012 2:59:16 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	8/22/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208142-004

SAMPLE INFORMATION

Sample Number: 1208142-004 Customer Sample Number: 3008694 Program: Post-LSR
Location: 2nd draw 1400 WISCONSIN AVE NW Type: Dist.

Collection Date: 8/6/2012 Collection Time: 11:01 Sampler: HOME OWNER Received Date and Time: 8/14/2012 2:59:16 PM Received By: TPasquale

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.0 ug/L	8/22/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208219-001

SAMPLE INFORMATION

Sample Number: 1208219-001 Customer Sample Number: 3008481 Program: Post-LSR
Location: 1st Draw 3410 P ST NW Type: Dist.

Collection Date: 8/13/2012 Collection Time: 18:17 Sampler: HOME OWNER Received Date and Time: 8/22/2012 2:57:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208219-002

SAMPLE INFORMATION

Sample Number: 1208219-002 Customer Sample Number: 3008481 Program: Post-LSR
Location: 2nd Draw 3410 P ST NW Type: Dist.

Collection Date: 8/13/2012 Collection Time: 18:19 Sampler: HOME OWNER Received Date and Time: 8/22/2012 2:57:55 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208261-001

SAMPLE INFORMATION

Sample Number: 1208261-001 Customer Sample Number: 3041595 Program: Post-LSR
Location: 1st draw 3548 QUEBEC ST NW Type: Dist.

Collection Date: 8/21/2012 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 8/27/2012 4:07:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208261-002

SAMPLE INFORMATION

Sample Number: 1208261-002 Customer Sample Number: 3041595 Program: Post-LSR
Location: 2nd draw 3548 QUEBEC ST NW Type: Dist.

Collection Date: 8/21/2012 Collection Time: 20:00 Sampler: HOME OWNER Received Date and Time: 8/27/2012 4:07:04 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208276-001

SAMPLE INFORMATION

Sample Number: 1208276-001 Customer Sample Number: 3120433 Program: Post-LSR
Location: 1st draw 909 HAMLIN ST., NE Type: Dist.
Collection Date: 8/25/2012 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 8/29/2012 12:32:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1208276-002

SAMPLE INFORMATION

Sample Number: 1208276-002 Customer Sample Number: 3120433 Program: Post-LSR
Location: 2nd draw 909 HAMLIN ST., NE Type: Dist.

Collection Date: 8/25/2012 Collection Time: 9:01 Sampler: HOME OWNER Received Date and Time: 8/29/2012 12:32:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-007

SAMPLE INFORMATION

Sample Number: 1209232-007 Customer Sample Number: 3125709 Program: Post-LSR
Location: 1st draw 2834 6TH ST NE Type: Dist.

Collection Date: 9/24/2012 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1209232-008

SAMPLE INFORMATION

Sample Number: 1209232-008 Customer Sample Number: 3125709 Program: Post-LSR
Location: 2nd draw 2834 6TH ST NE Type: Dist.

Collection Date: 9/24/2012 Collection Time: 7:16 Sampler: HOME OWNER Received Date and Time: 9/26/2012 3:56:43 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210051-001

SAMPLE INFORMATION

Sample Number: 1210051-001 Customer Sample Number: 3008662 Program: Post-LSR
Location: 1st draw 3261 O ST NW Type: Dist.

Collection Date: 9/22/2012 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:22:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210051-002

SAMPLE INFORMATION

Sample Number: 1210051-002 Customer Sample Number: 3008662 Program: Post-LSR
Location: 2nd draw 3261 O ST NW Type: Dist.

Collection Date: 9/22/2012 Collection Time: 7:26 Sampler: HOME OWNER Received Date and Time: 10/3/2012 4:22:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210064-001

SAMPLE INFORMATION

Sample Number: 1210064-001 Customer Sample Number: 3019845 Program: Post-LSR
Location: 1st Draw 453 LAMONT ST NW Type: Dist.

Collection Date: 9/28/2012 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 10/4/2012 3:06:44 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/16/2012
Report Number: LC-W1210064-002

SAMPLE INFORMATION

Sample Number: 1210064-002 Customer Sample Number: 3019845 Program: Post-LSR
Location: 2nd Draw 453 LAMONT ST NW Type: Dist.

Collection Date: 9/28/2012 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 10/4/2012 3:06:44 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/15/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210167-001

SAMPLE INFORMATION

Sample Number: 1210167-001 Customer Sample Number: 3074586 Program: Post-LSR
Location: 1st Draw 419 15TH ST SE Type: Dist.
Collection Date: 10/10/2012 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 10/17/2012 2:26:16 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210167-002

SAMPLE INFORMATION

Sample Number: 1210167-002 Customer Sample Number: 3074586 Program: Post-LSR
Location: 2nd Draw 419 15TH ST SE Type: Dist.

Collection Date: 10/10/2012 Collection Time: 5:51 Sampler: HOME OWNER Received Date and Time: 10/17/2012 2:26:16 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210191-001

SAMPLE INFORMATION

Sample Number: 1210191-001 Customer Sample Number: 3044838 Program: Post-LSR
Location: 1st Draw 1630 44TH ST NW Type: Dist.
Collection Date: 10/11/2012 Collection Time: 19:07 Sampler: HOME OWNER Received Date and Time: 10/19/2012 3:28:23 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210191-002

SAMPLE INFORMATION

Sample Number: 1210191-002 Customer Sample Number: 3044838 Program: Post-LSR
Location: 2nd Draw 1630 44TH ST NW Type: Dist.

Collection Date: 10/11/2012 Collection Time: 19:09 Sampler: HOME OWNER Received Date and Time: 10/19/2012 3:28:23 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-001 Customer Sample Number: 3054822 Program: Post-LSR
Location: 1st Draw 2334 MASS. AVE NW Type: Dist.
Collection Date: 10/22/2012 Collection Time: 3:30 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 11/20/2012
Report Number: LC-W1210228-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1210228-002 Customer Sample Number: 3054822 Program: Post-LSR
Location: 2nd Draw 2334 MASS. AVE NW Type: Dist.
Collection Date: 10/22/2012 Collection Time: 3:33 Sampler: HOME OWNER Received Date and Time: 10/25/2012 12:13:54 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	11/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210252-001

SAMPLE INFORMATION

Sample Number: 1210252-001 Customer Sample Number: 3128152 Program: Post-LSR
Location: 1st Draw 302 E ST NE Type: Dist.

Collection Date: 10/25/2012 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/31/2012 10:36:19 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/20/2012
Report Number: LC-W1210252-002

SAMPLE INFORMATION

Sample Number: 1210252-002 Customer Sample Number: 3128152 Program: Post-LSR
Location: 2nd Draw 302 E ST NE Type: Dist.

Collection Date: 10/25/2012 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 10/31/2012 10:36:19 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/20/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211116-003

SAMPLE INFORMATION

Sample Number: 1211116-003 Customer Sample Number: 3104187 Program: Post-LSR
Location: 1st draw 1204 FRANKLIN ST NE Type: Dist.
Collection Date: 11/13/2012 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 11/15/2012 12:07:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: LC-W1211116-004

SAMPLE INFORMATION

Sample Number: 1211116-004 Customer Sample Number: 3104187 Program: Post-LSR
Location: 2nd draw 1204 FRANKLIN ST NE Type: Dist.

Collection Date: 11/13/2012 Collection Time: 6:34 Sampler: HOME OWNER Received Date and Time: 11/15/2012 12:07:41 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-001

SAMPLE INFORMATION

Sample Number: 1212034-001 Customer Sample Number: 3107675 Program: Post-LSR
Location: 1st draw 3201 WALNUT ST NE Type: Dist.

Collection Date: 11/26/2012 Collection Time: 14:57 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-002

SAMPLE INFORMATION

Sample Number: 1212034-002 Customer Sample Number: 3107675 Program: Post-LSR
Location: 2nd draw 3201 WALNUT ST NE Type: Dist.

Collection Date: 11/26/2012 Collection Time: 14:57 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-007

SAMPLE INFORMATION

Sample Number: 1212034-007 Customer Sample Number: 3121858 Program: Post-LSR
Location: 1st draw 1222 CONSTITUTION AVE NE Type: Dist.
Collection Date: 12/3/2012 Collection Time: 5:49 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212034-008

SAMPLE INFORMATION

Sample Number: 1212034-008 Customer Sample Number: 3121858 Program: Post-LSR
Location: 2nd draw 1222 CONSTITUTION AVE NE Type: Dist.

Collection Date: 12/3/2012 Collection Time: 5:51 Sampler: HOME OWNER Received Date and Time: 12/5/2012 12:43:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-001

SAMPLE INFORMATION

Sample Number: 1212094-001 Customer Sample Number: 3029942 Program: Post-LSR
Location: 1st draw 1316 MONROE ST NW Type: Dist.

Collection Date: 12/1/2012 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-002

SAMPLE INFORMATION

Sample Number: 1212094-002 Customer Sample Number: 3029942 Program: Post-LSR
Location: 2nd draw 1316 MONROE ST NW Type: Dist.

Collection Date: 12/1/2012 Collection Time: 6:14 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-005

SAMPLE INFORMATION

Sample Number: 1212094-005 Customer Sample Number: 3029210 Program: Post-LSR
Location: 1st draw 1717 WEBSTER ST NW Type: Dist.
Collection Date: 12/5/2012 Collection Time: 14:14 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-006

SAMPLE INFORMATION

Sample Number: 1212094-006 Customer Sample Number: 3029210 Program: Post-LSR
Location: 2nd draw 1717 WEBSTER ST NW Type: Dist.
Collection Date: 12/5/2012 Collection Time: 14:17 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	12/14/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-009

SAMPLE INFORMATION

Sample Number: 1212094-009 Customer Sample Number: 3044227 Program: Post-LSR
Location: 1st draw 3100 44TH ST. NW Type: Dist.

Collection Date: 12/9/2012 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2012
Report Number: LC-W1212094-010

SAMPLE INFORMATION

Sample Number: 1212094-010 Customer Sample Number: 3044227 Program: Post-LSR
Location: 2nd draw 3100 44TH ST. NW Type: Dist.

Collection Date: 12/9/2012 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 12/12/2012 8:38:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	12/14/2012	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2012

Date

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-001

SAMPLE INFORMATION

Sample Number: 1206039-001
Location: 01a
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	735 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.6 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	170 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	8.60 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-002

SAMPLE INFORMATION

Sample Number: 1206039-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.3 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	70.5 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-003

SAMPLE INFORMATION

Sample Number: 1206039-003
Location: 01b
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	266 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.3 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	39.1 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.99 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-004

SAMPLE INFORMATION

Sample Number: 1206039-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.5 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.81 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	26.5 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-005

SAMPLE INFORMATION

Sample Number: 1206039-005
Location: 01c
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	16.7 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.4 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.8 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.88 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-006

SAMPLE INFORMATION

Sample Number: 1206039-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.0 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.0 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-007

SAMPLE INFORMATION

Sample Number: 1206039-007
Location: 01d
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	35.1 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	17.5 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	25.6 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.51 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-008

SAMPLE INFORMATION

Sample Number: 1206039-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.0 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	15.9 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-009

SAMPLE INFORMATION

Sample Number: 1206039-009
Location: 02
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	77.5 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	74.5 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	20.0 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	16.9 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-010

SAMPLE INFORMATION

Sample Number: 1206039-010
Location: 02F
LPR 605 TAYLOR ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	41.0 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.9 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-011

SAMPLE INFORMATION

Sample Number: 1206039-011
Location: 03
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	76.7 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	209 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	62.6 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	29.7 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-012

SAMPLE INFORMATION

Sample Number: 1206039-012
Location: 03F
LPR 605 TAYLOR ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	60.8 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	44.0 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.38 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-013

SAMPLE INFORMATION

Sample Number: 1206039-013
Location: 04
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	47.6 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	53.0 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	18.5 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	35.4 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-014

SAMPLE INFORMATION

Sample Number: 1206039-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.7 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.3 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.38 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-015

SAMPLE INFORMATION

Sample Number: 1206039-015
Location: 05
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	48.1 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.6 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	40.2 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-016

SAMPLE INFORMATION

Sample Number: 1206039-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.6 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.67 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-017

SAMPLE INFORMATION

Sample Number: 1206039-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	79.4 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.0 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	35.5 ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-018

SAMPLE INFORMATION

Sample Number: 1206039-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.0 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.76 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-019

SAMPLE INFORMATION

Sample Number: 1206039-019

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

07

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.92 ug/L	8/16/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	97.7 ug/L	8/16/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.8 ug/L	8/16/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.97 ug/L	8/16/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	86.9 ug/L	8/16/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.81 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	55.1 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.7 ug/L	8/16/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-019

SAMPLE INFORMATION

Sample Number: 1206039-019

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

07

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	126 ug/L	8/16/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.6 ug/L	8/16/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	8/16/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	32.7 ug/L	8/16/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	13.1 ug/L	8/16/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-019

SAMPLE INFORMATION

Sample Number: 1206039-019

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

07

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-020

SAMPLE INFORMATION

Sample Number: 1206039-020
Location: 07F
LPR 605 TAYLOR ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.4 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-021

SAMPLE INFORMATION

Sample Number: 1206039-021

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

08

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.06 ug/L	8/16/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	118 ug/L	8/16/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.9 ug/L	8/16/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.63 ug/L	8/16/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	109 ug/L	8/16/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.43 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	77.5 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	18.7 ug/L	8/16/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 8/22/2012
 Report Number: M- W1206039-021

SAMPLE INFORMATION

Sample Number: 1206039-021

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

08

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	128 ug/L	8/16/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.6 ug/L	8/16/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	8/16/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	34.4 ug/L	8/16/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	9.14 ug/L	8/16/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-021

SAMPLE INFORMATION

Sample Number: 1206039-021

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

08

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-022

SAMPLE INFORMATION

Sample Number: 1206039-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.2 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-023

SAMPLE INFORMATION

Sample Number: 1206039-023
Location: 09
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	118 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	102 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.5 ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.17 ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-024

SAMPLE INFORMATION

Sample Number: 1206039-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	45.6 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-025

SAMPLE INFORMATION

Sample Number: 1206039-025
Location: 10
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	98.0 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	86.3 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.87 ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-026

SAMPLE INFORMATION

Sample Number: 1206039-026
Location: 10F
LPR 605 TAYLOR ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	36.8 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	86.3 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.2 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.72 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-027

SAMPLE INFORMATION

Sample Number: 1206039-027
Location: 11
LPR 605 TAYLOR ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	73.1 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	54.4 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.56 ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-028

SAMPLE INFORMATION

Sample Number: 1206039-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.7 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-029

SAMPLE INFORMATION

Sample Number: 1206039-029

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

12

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.06 ug/L	8/16/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	46.1 ug/L	8/16/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	1.02 ug/L	8/16/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.89 ug/L	8/16/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	53.2 ug/L	8/16/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.17 ug/L	8/16/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.6 ug/L	8/16/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/16/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 8/22/2012
 Report Number: M- W1206039-029

SAMPLE INFORMATION

Sample Number: 1206039-029

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

12

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
6/5/2012	8:30	HJ/YT	6/6/2012 12:33:47 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.5 ug/L	8/16/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	120 ug/L	8/16/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.5 ug/L	8/16/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	8/16/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	< 0.5 ug/L	8/16/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	31.3 ug/L	8/16/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.27 ug/L	8/16/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-029

SAMPLE INFORMATION

Sample Number: 1206039-029

Customer Sample Number:

Location: 605 TAYLOR ST NW UNFILTERED

Type: Dist. Project: LPR

12

Collection Date:
6/5/2012

Collection Time:
8:30

Sampler:
HJ/YT

Received Date and Time:
6/6/2012 12:33:47 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	8/16/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-030

SAMPLE INFORMATION

Sample Number: 1206039-030
Location: 12F
LPR 605 TAYLOR ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	14.0 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.5 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.08 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-031

SAMPLE INFORMATION

Sample Number: 1206039-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.60 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-032

SAMPLE INFORMATION

Sample Number: 1206039-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.28 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-033

SAMPLE INFORMATION

Sample Number: 1206039-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.88 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-034

SAMPLE INFORMATION

Sample Number: 1206039-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.78 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-035

SAMPLE INFORMATION

Sample Number: 1206039-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.65 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-036

SAMPLE INFORMATION

Sample Number: 1206039-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.07 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-037

SAMPLE INFORMATION

Sample Number: 1206039-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.58 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-038

SAMPLE INFORMATION

Sample Number: 1206039-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.87 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-039

SAMPLE INFORMATION

Sample Number: 1206039-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.09 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-040

SAMPLE INFORMATION

Sample Number: 1206039-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.84 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-041

SAMPLE INFORMATION

Sample Number: 1206039-041 Customer Sample Number:
Location: X Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.41 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.38 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-042

SAMPLE INFORMATION

Sample Number: 1206039-042
Location: XF
LPR 605 TAYLOR ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/5/2012 Collection Time: 8:30 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.38 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-043

SAMPLE INFORMATION

Sample Number: 1206039-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 605 TAYLOR ST NW UNFILTERED
Collection Date: 6/4/2012 Collection Time: 22:22 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.2 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/22/2012
Report Number: M- W1206039-044

SAMPLE INFORMATION

Sample Number: 1206039-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 605 TAYLOR ST NW FILTERED
Collection Date: 6/4/2012 Collection Time: 22:22 Sampler: HJ/YT Received Date and Time: 6/6/2012 12:33:47 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	6/11/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.3 ug/L	6/11/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	6/11/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	6/11/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

8/22/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-001

SAMPLE INFORMATION

Sample Number: 1206231-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	134 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	161 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	403 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	53.8 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-002

SAMPLE INFORMATION

Sample Number: 1206231-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	48.0 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	119 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	335 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.63 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-003

SAMPLE INFORMATION

Sample Number: 1206231-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	17.1 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	138 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	38.0 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.4 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-004

SAMPLE INFORMATION

Sample Number: 1206231-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	57.4 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	150 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	35.0 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	129 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-005

SAMPLE INFORMATION

Sample Number: 1206231-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	71.6 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	128 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	23.7 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	18.3 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-006

SAMPLE INFORMATION

Sample Number: 1206231-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	16.9 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	128 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	24.4 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.60 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-007

SAMPLE INFORMATION

Sample Number: 1206231-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	82.1 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	124 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	28.7 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.6 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-008

SAMPLE INFORMATION

Sample Number: 1206231-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	106 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	20.1 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.40 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-009

SAMPLE INFORMATION

Sample Number: 1206231-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	85.6 ug/L	8/21/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	115 ug/L	8/21/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	27.7 ug/L	8/21/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	12.3 ug/L	8/21/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-010

SAMPLE INFORMATION

Sample Number: 1206231-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	99.5 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	20.0 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.54 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-011

SAMPLE INFORMATION

Sample Number: 1206231-011
Location: 03
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	93.6 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	88.0 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.4 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	12.1 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-012

SAMPLE INFORMATION

Sample Number: 1206231-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	73.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.4 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.49 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-013

SAMPLE INFORMATION

Sample Number: 1206231-013
Location: 04
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	75.5 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	52.4 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	13.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-014

SAMPLE INFORMATION

Sample Number: 1206231-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.4 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.12 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-015

SAMPLE INFORMATION

Sample Number: 1206231-015
Location: 05
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	57.0 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.2 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	14.1 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-016

SAMPLE INFORMATION

Sample Number: 1206231-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.4 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.58 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-017

SAMPLE INFORMATION

Sample Number: 1206231-017
Location: 06
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	54.4 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	15.2 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-018

SAMPLE INFORMATION

Sample Number: 1206231-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.1 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.49 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-019

SAMPLE INFORMATION

Sample Number: 1206231-019
Location: 07
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	41.4 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.1 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	12.4 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-020

SAMPLE INFORMATION

Sample Number: 1206231-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.4 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.0 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-021

SAMPLE INFORMATION

Sample Number: 1206231-021
Location: 08
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	50.7 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	19.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	42.3 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-022

SAMPLE INFORMATION

Sample Number: 1206231-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	19.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	7.08 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-023

SAMPLE INFORMATION

Sample Number: 1206231-023
Location: 09
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	48.1 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.1 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.85 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-024

SAMPLE INFORMATION

Sample Number: 1206231-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.9 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.76 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-025

SAMPLE INFORMATION

Sample Number: 1206231-025
Location: 10
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	46.2 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.5 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.11 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-026

SAMPLE INFORMATION

Sample Number: 1206231-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.69 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-027

SAMPLE INFORMATION

Sample Number: 1206231-027
Location: 11
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	47.0 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.5 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.25 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-028

SAMPLE INFORMATION

Sample Number: 1206231-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-029

SAMPLE INFORMATION

Sample Number: 1206231-029
Location: 12
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	49.9 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.09 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-030

SAMPLE INFORMATION

Sample Number: 1206231-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.1 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-031

SAMPLE INFORMATION

Sample Number: 1206231-031
Location: H1
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	44.1 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.6 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.01 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-032

SAMPLE INFORMATION

Sample Number: 1206231-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.63 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-033

SAMPLE INFORMATION

Sample Number: 1206231-033
Location: H2
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	45.1 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.62 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-034

SAMPLE INFORMATION

Sample Number: 1206231-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.5 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.65 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-035

SAMPLE INFORMATION

Sample Number: 1206231-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	46.5 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.82 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-036

SAMPLE INFORMATION

Sample Number: 1206231-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.91 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-037

SAMPLE INFORMATION

Sample Number: 1206231-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	58.2 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.2 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.90 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-038

SAMPLE INFORMATION

Sample Number: 1206231-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.95 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-039

SAMPLE INFORMATION

Sample Number: 1206231-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	51.8 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.00 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-040

SAMPLE INFORMATION

Sample Number: 1206231-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-041

SAMPLE INFORMATION

Sample Number: 1206231-041
Location: X
LPR 1505 BUCHANAN ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	47.4 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.8 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.37 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-042

SAMPLE INFORMATION

Sample Number: 1206231-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/26/2012 Collection Time: 8:45 Sampler: HJ/CN Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-043

SAMPLE INFORMATION

Sample Number: 1206231-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1505 BUCHANAN ST NW UNFILTERED
Collection Date: 6/25/2012 Collection Time: 22:28 Sampler: CUSTOMER Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	65.4 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.4 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.22 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/20/2012
Report Number: M- W1206231-044

SAMPLE INFORMATION

Sample Number: 1206231-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 1505 BUCHANAN ST NW FILTERED
Collection Date: 6/25/2012 Collection Time: 22:28 Sampler: CUSTOMER Received Date and Time: 6/27/2012 12:28:40 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.79 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

9/20/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-001

SAMPLE INFORMATION

Sample Number: 1208291-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	120 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	329 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	4240 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	13.6 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-002

SAMPLE INFORMATION

Sample Number: 1208291-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	132 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	449 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-003

SAMPLE INFORMATION

Sample Number: 1208291-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	57.8 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	191 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	638 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.89 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-004

SAMPLE INFORMATION

Sample Number: 1208291-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	140 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	56.7 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-005

SAMPLE INFORMATION

Sample Number: 1208291-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	82.1 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	166 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	248 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.58 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-006

SAMPLE INFORMATION

Sample Number: 1208291-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	126 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	28.7 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-007

SAMPLE INFORMATION

Sample Number: 1208291-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	94.8 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	171 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	132 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.71 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-008

SAMPLE INFORMATION

Sample Number: 1208291-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	143 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	25.0 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-009

SAMPLE INFORMATION

Sample Number: 1208291-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	91.0 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	129 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	61.1 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.77 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-010

SAMPLE INFORMATION

Sample Number: 1208291-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	96.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	18.2 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-011

SAMPLE INFORMATION

Sample Number: 1208291-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	70.2 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	77.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	34.7 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.89 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-012

SAMPLE INFORMATION

Sample Number: 1208291-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	62.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	15.6 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-013

SAMPLE INFORMATION

Sample Number: 1208291-013
Location: 04
LPR 4010 18TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	69.3 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	68.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.7 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.16 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-014

SAMPLE INFORMATION

Sample Number: 1208291-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	59.7 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.6 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-015

SAMPLE INFORMATION

Sample Number: 1208291-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	112 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	63.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.6 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.24 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-016

SAMPLE INFORMATION

Sample Number: 1208291-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	53.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.7 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-017

SAMPLE INFORMATION

Sample Number: 1208291-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	144 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	65.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.30 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-018

SAMPLE INFORMATION

Sample Number: 1208291-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	53.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.6 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-019

SAMPLE INFORMATION

Sample Number: 1208291-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	106 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	72.0 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.0 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.72 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-020

SAMPLE INFORMATION

Sample Number: 1208291-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	56.0 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.8 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-021

SAMPLE INFORMATION

Sample Number: 1208291-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	95.3 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	64.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.38 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-022

SAMPLE INFORMATION

Sample Number: 1208291-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	52.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.7 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-023

SAMPLE INFORMATION

Sample Number: 1208291-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	79.6 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	55.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.8 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.61 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-024

SAMPLE INFORMATION

Sample Number: 1208291-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	44.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-025

SAMPLE INFORMATION

Sample Number: 1208291-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	58.0 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	45.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.81 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-026

SAMPLE INFORMATION

Sample Number: 1208291-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.7 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.1 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-027

SAMPLE INFORMATION

Sample Number: 1208291-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	45.6 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.9 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.76 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-028

SAMPLE INFORMATION

Sample Number: 1208291-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-029

SAMPLE INFORMATION

Sample Number: 1208291-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	38.6 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	15.5 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.13 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-030

SAMPLE INFORMATION

Sample Number: 1208291-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.5 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.9 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-031

SAMPLE INFORMATION

Sample Number: 1208291-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	40.3 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.1 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.53 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-032

SAMPLE INFORMATION

Sample Number: 1208291-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-033

SAMPLE INFORMATION

Sample Number: 1208291-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	41.0 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.3 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.46 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-034

SAMPLE INFORMATION

Sample Number: 1208291-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-035

SAMPLE INFORMATION

Sample Number: 1208291-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	37.2 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.7 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	21.2 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.14 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-036

SAMPLE INFORMATION

Sample Number: 1208291-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-037

SAMPLE INFORMATION

Sample Number: 1208291-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	38.0 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.14 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-038

SAMPLE INFORMATION

Sample Number: 1208291-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.5 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-039

SAMPLE INFORMATION

Sample Number: 1208291-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	35.3 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.0 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.83 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-040

SAMPLE INFORMATION

Sample Number: 1208291-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-041

SAMPLE INFORMATION

Sample Number: 1208291-041 Customer Sample Number:
Location: X Type: Dist.
LPR 4010 18TH ST NW UNFILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	25.6 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.06 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1208291-042

SAMPLE INFORMATION

Sample Number: 1208291-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 4010 18TH ST NW FILTERED
Collection Date: 8/29/2012 Collection Time: 10:15 Sampler: AB/YT Received Date and Time: 8/31/2012 9:12:20 AM Received By: rhoward

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-001

SAMPLE INFORMATION

Sample Number: 1209114-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	14.4 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	143 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-002

SAMPLE INFORMATION

Sample Number: 1209114-002
Location: 01aF
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	141 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-003

SAMPLE INFORMATION

Sample Number: 1209114-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.3 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-004

SAMPLE INFORMATION

Sample Number: 1209114-004
Location: 01bF
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.9 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-005

SAMPLE INFORMATION

Sample Number: 1209114-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.1 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-006

SAMPLE INFORMATION

Sample Number: 1209114-006
Location: 01cF
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-007

SAMPLE INFORMATION

Sample Number: 1209114-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-008

SAMPLE INFORMATION

Sample Number: 1209114-008
Location: 01dF
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-009

SAMPLE INFORMATION

Sample Number: 1209114-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.1 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.5 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-010

SAMPLE INFORMATION

Sample Number: 1209114-010
Location: 02F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-011

SAMPLE INFORMATION

Sample Number: 1209114-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-012

SAMPLE INFORMATION

Sample Number: 1209114-012
Location: 03F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.7 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-013

SAMPLE INFORMATION

Sample Number: 1209114-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-014

SAMPLE INFORMATION

Sample Number: 1209114-014
Location: 04F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-015

SAMPLE INFORMATION

Sample Number: 1209114-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-016

SAMPLE INFORMATION

Sample Number: 1209114-016
Location: 05F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-017

SAMPLE INFORMATION

Sample Number: 1209114-017
Location: 06
LPR 236 R ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/13/2012
Collection Time: 7:35
Sampler: HJ/DVC
Received Date and Time: 9/13/2012 2:45:14 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.2 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.14 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-018

SAMPLE INFORMATION

Sample Number: 1209114-018
Location: 06F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-019

SAMPLE INFORMATION

Sample Number: 1209114-019
Location: 07
LPR 236 R ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/13/2012
Collection Time: 7:35
Sampler: HJ/DVC
Received Date and Time: 9/13/2012 2:45:14 PM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.4 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	50.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.61 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-020

SAMPLE INFORMATION

Sample Number: 1209114-020
Location: 07F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	49.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-021

SAMPLE INFORMATION

Sample Number: 1209114-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.3 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	66.0 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.87 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-022

SAMPLE INFORMATION

Sample Number: 1209114-022
Location: 08F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	61.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-023

SAMPLE INFORMATION

Sample Number: 1209114-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	20.2 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	80.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.33 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-024

SAMPLE INFORMATION

Sample Number: 1209114-024
Location: 09F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	65.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-025

SAMPLE INFORMATION

Sample Number: 1209114-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.5 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	55.7 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.27 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-026

SAMPLE INFORMATION

Sample Number: 1209114-026
Location: 10F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	54.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-027

SAMPLE INFORMATION

Sample Number: 1209114-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	18.4 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-028

SAMPLE INFORMATION

Sample Number: 1209114-028
Location: 11F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-029

SAMPLE INFORMATION

Sample Number: 1209114-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	21.9 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.08 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-030

SAMPLE INFORMATION

Sample Number: 1209114-030
Location: 12F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-031

SAMPLE INFORMATION

Sample Number: 1209114-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	65.7 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.0 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.16 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-032

SAMPLE INFORMATION

Sample Number: 1209114-032
Location: H1F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-033

SAMPLE INFORMATION

Sample Number: 1209114-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	30.6 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	17.5 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.40 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-034

SAMPLE INFORMATION

Sample Number: 1209114-034
Location: H2F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.5 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-035

SAMPLE INFORMATION

Sample Number: 1209114-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	57.9 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.8 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.04 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-036

SAMPLE INFORMATION

Sample Number: 1209114-036
Location: H3F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.3 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-037

SAMPLE INFORMATION

Sample Number: 1209114-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	27.6 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	17.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.26 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-038

SAMPLE INFORMATION

Sample Number: 1209114-038
Location: H4F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.7 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-039

SAMPLE INFORMATION

Sample Number: 1209114-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	24.8 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.01 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-040

SAMPLE INFORMATION

Sample Number: 1209114-040
Location: H5F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.0 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-041

SAMPLE INFORMATION

Sample Number: 1209114-041 Customer Sample Number:
Location: X Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	85.9 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.57 ug/L	9/19/2012	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-042

SAMPLE INFORMATION

Sample Number: 1209114-042
Location: XF
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/13/2012 Collection Time: 7:35 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.4 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-043

SAMPLE INFORMATION

Sample Number: 1209114-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 236 R ST NE UNFILTERED
Collection Date: 9/12/2012 Collection Time: 21:12 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	13.0 ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.9 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/25/2012
Report Number: M- W1209114-044

SAMPLE INFORMATION

Sample Number: 1209114-044
Location: 00F
LPR 236 R ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/12/2012 Collection Time: 21:12 Sampler: HJ/DVC Received Date and Time: 9/13/2012 2:45:14 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.1 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

9/25/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-001

SAMPLE INFORMATION

Sample Number: 1207007-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/29/2012 8:45 AB/DM 7/2/2012 11:33:21 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	18.5 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.6 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	187 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.64 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-002

SAMPLE INFORMATION

Sample Number: 1207007-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.0 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	176 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-003

SAMPLE INFORMATION

Sample Number: 1207007-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/29/2012 8:45 AB/DM 7/2/2012 11:33:21 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	11.2 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	115 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	27.4 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.75 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-004

SAMPLE INFORMATION

Sample Number: 1207007-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	101 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	25.7 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-005

SAMPLE INFORMATION

Sample Number: 1207007-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/29/2012 8:45 AB/DM 7/2/2012 11:33:21 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.9 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	247 ug/L	9/13/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	22.8 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.83 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-006

SAMPLE INFORMATION

Sample Number: 1207007-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	215 ug/L	9/13/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	23.4 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-007

SAMPLE INFORMATION

Sample Number: 1207007-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
6/29/2012 8:45 AB/DM 7/2/2012 11:33:21 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.8 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	205 ug/L	9/13/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	58.5 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.42 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-008

SAMPLE INFORMATION

Sample Number: 1207007-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	184 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	54.6 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-009

SAMPLE INFORMATION

Sample Number: 1207007-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	14.3 ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.0 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.33 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-010

SAMPLE INFORMATION

Sample Number: 1207007-010
Location: 02F
LPR 1432 MADISON ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.6 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.7 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-011

SAMPLE INFORMATION

Sample Number: 1207007-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.1 ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.9 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.37 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-012

SAMPLE INFORMATION

Sample Number: 1207007-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.7 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-013

SAMPLE INFORMATION

Sample Number: 1207007-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.9 ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.74 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-014

SAMPLE INFORMATION

Sample Number: 1207007-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.9 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-015

SAMPLE INFORMATION

Sample Number: 1207007-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	13.3 ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	15.9 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.61 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-016

SAMPLE INFORMATION

Sample Number: 1207007-016 Customer Sample Number:
Location: 05F Type: Dist.
LLP 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.51 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-017

SAMPLE INFORMATION

Sample Number: 1207007-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.4 ug/L	10/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.8 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	9.14 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-018

SAMPLE INFORMATION

Sample Number: 1207007-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.71 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.09 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-019

SAMPLE INFORMATION

Sample Number: 1207007-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.6 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	8.80 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-020

SAMPLE INFORMATION

Sample Number: 1207007-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.2 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.03 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-021

SAMPLE INFORMATION

Sample Number: 1207007-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.98 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-022

SAMPLE INFORMATION

Sample Number: 1207007-022
Location: 08F
LPR 1432 MADISON ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.2 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.4 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.52 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-023

SAMPLE INFORMATION

Sample Number: 1207007-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.7 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.44 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-024

SAMPLE INFORMATION

Sample Number: 1207007-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.0 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-025

SAMPLE INFORMATION

Sample Number: 1207007-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.2 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-026

SAMPLE INFORMATION

Sample Number: 1207007-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.5 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-027

SAMPLE INFORMATION

Sample Number: 1207007-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	73.3 ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-028

SAMPLE INFORMATION

Sample Number: 1207007-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.2 ug/L	9/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-029

SAMPLE INFORMATION

Sample Number: 1207007-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	197 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.4 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.07 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-030

SAMPLE INFORMATION

Sample Number: 1207007-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.39 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-031

SAMPLE INFORMATION

Sample Number: 1207007-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	232 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.8 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.32 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-032

SAMPLE INFORMATION

Sample Number: 1207007-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.86 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-033

SAMPLE INFORMATION

Sample Number: 1207007-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	227 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.6 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.47 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-034

SAMPLE INFORMATION

Sample Number: 1207007-034
Location: H2F
LPR 1432 MADISON ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 6/29/2012
Collection Time: 8:45
Sampler: AB/DM
Received Date and Time: 7/2/2012 11:33:21 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.1 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment: analyzed 10/4/12 ajp 1431 hrs

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-035

SAMPLE INFORMATION

Sample Number: 1207007-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	234 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.6 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.70 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-036

SAMPLE INFORMATION

Sample Number: 1207007-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.76 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-037

SAMPLE INFORMATION

Sample Number: 1207007-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	225 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	15.9 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.38 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-038

SAMPLE INFORMATION

Sample Number: 1207007-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.69 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-039

SAMPLE INFORMATION

Sample Number: 1207007-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	224 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.2 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.37 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-040

SAMPLE INFORMATION

Sample Number: 1207007-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	8/21/2012	NMitchell
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.3 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:



Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-041

SAMPLE INFORMATION

Sample Number: 1207007-041
Customer Sample Number:
Location: X Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	241 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.1 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.63 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-042

SAMPLE INFORMATION

Sample Number: 1207007-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/29/2012 Collection Time: 8:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.72 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-043

SAMPLE INFORMATION

Sample Number: 1207007-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1432 MADISON ST NW UNFILTERED
Collection Date: 6/28/2012 Collection Time: 22:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	19.5 ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.04 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.61 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/10/2012
Report Number: M- W1207007-044

SAMPLE INFORMATION

Sample Number: 1207007-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 1432 MADISON ST NW FILTERED
Collection Date: 6/28/2012 Collection Time: 22:45 Sampler: AB/DM Received Date and Time: 7/2/2012 11:33:21 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/13/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.60 ug/L	8/21/2012	NMitchell
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	8/21/2012	NMitchell
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/21/2012	NMitchell

Reviewed By:

Michael Chicoine, Laboratory Manager

10/10/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-001

SAMPLE INFORMATION

Sample Number: 1209155-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	288 ug/L	11/8/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	140 ug/L	11/8/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	476 ug/L	11/8/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	109 ug/L	11/8/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-002

SAMPLE INFORMATION

Sample Number: 1209155-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	176 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-003

SAMPLE INFORMATION

Sample Number: 1209155-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	84.1 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	49.7 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	45.8 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.05 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-004

SAMPLE INFORMATION

Sample Number: 1209155-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.0 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	38.5 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-005

SAMPLE INFORMATION

Sample Number: 1209155-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	82.6 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	48.0 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	32.7 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.54 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-006

SAMPLE INFORMATION

Sample Number: 1209155-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.4 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	26.3 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-007

SAMPLE INFORMATION

Sample Number: 1209155-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	92.7 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	52.6 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	21.7 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.19 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-008

SAMPLE INFORMATION

Sample Number: 1209155-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.6 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.2 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-009

SAMPLE INFORMATION

Sample Number: 1209155-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	125 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	20.3 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.87 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-010

SAMPLE INFORMATION

Sample Number: 1209155-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.9 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	15.7 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-011

SAMPLE INFORMATION

Sample Number: 1209155-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	105 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.0 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.1 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-012

SAMPLE INFORMATION

Sample Number: 1209155-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.9 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.2 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-013

SAMPLE INFORMATION

Sample Number: 1209155-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	106 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.4 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.97 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-014

SAMPLE INFORMATION

Sample Number: 1209155-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.0 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.2 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-015

SAMPLE INFORMATION

Sample Number: 1209155-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	113 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.7 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.4 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.1 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-016

SAMPLE INFORMATION

Sample Number: 1209155-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.7 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.7 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.34 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-017

SAMPLE INFORMATION

Sample Number: 1209155-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	104 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.3 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	7.07 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-018

SAMPLE INFORMATION

Sample Number: 1209155-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-019

SAMPLE INFORMATION

Sample Number: 1209155-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	118 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	43.7 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.2 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.09 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-020

SAMPLE INFORMATION

Sample Number: 1209155-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.3 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-021

SAMPLE INFORMATION

Sample Number: 1209155-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	107 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	47.6 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.9 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.26 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-022

SAMPLE INFORMATION

Sample Number: 1209155-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.5 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-023

SAMPLE INFORMATION

Sample Number: 1209155-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	114 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.5 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.98 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-024

SAMPLE INFORMATION

Sample Number: 1209155-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-025

SAMPLE INFORMATION

Sample Number: 1209155-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	100 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.6 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.6 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.01 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-026

SAMPLE INFORMATION

Sample Number: 1209155-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.8 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.0 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-027

SAMPLE INFORMATION

Sample Number: 1209155-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	107 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.3 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.3 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.75 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-028

SAMPLE INFORMATION

Sample Number: 1209155-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.4 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.6 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-029

SAMPLE INFORMATION

Sample Number: 1209155-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	109 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.5 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.10 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-030

SAMPLE INFORMATION

Sample Number: 1209155-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.3 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-031

SAMPLE INFORMATION

Sample Number: 1209155-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	157 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	17.9 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.2 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.05 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-032

SAMPLE INFORMATION

Sample Number: 1209155-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-033

SAMPLE INFORMATION

Sample Number: 1209155-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	154 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-034

SAMPLE INFORMATION

Sample Number: 1209155-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.3 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-035

SAMPLE INFORMATION

Sample Number: 1209155-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	161 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.4 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-036

SAMPLE INFORMATION

Sample Number: 1209155-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.7 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-037

SAMPLE INFORMATION

Sample Number: 1209155-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	160 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-038

SAMPLE INFORMATION

Sample Number: 1209155-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.7 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-039

SAMPLE INFORMATION

Sample Number: 1209155-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	160 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	16.3 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-040

SAMPLE INFORMATION

Sample Number: 1209155-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.0 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-041

SAMPLE INFORMATION

Sample Number: 1209155-041 Customer Sample Number:
Location: X Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	165 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.94 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-042

SAMPLE INFORMATION

Sample Number: 1209155-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/18/2012 Collection Time: 8:35 Sampler: HJ/YT Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-043

SAMPLE INFORMATION

Sample Number: 1209155-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1323 CORBIN PL NE UNFILTERED
Collection Date: 9/17/2012 Collection Time: 23:00 Sampler: CUSTOMER Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	123 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	15.1 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/13/2012
Report Number: M- W1209155-044

SAMPLE INFORMATION

Sample Number: 1209155-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 1323 CORBIN PL NE FILTERED
Collection Date: 9/17/2012 Collection Time: 23:00 Sampler: CUSTOMER Received Date and Time: 9/19/2012 12:07:56 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.2 ug/L	10/23/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	10/23/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/23/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/13/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-001

SAMPLE INFORMATION

Sample Number: 1211060-001 Customer Sample Number:
Location: 00 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 8:44 Sampler: CUSTOMER Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	33.0 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.06 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.48 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-002

SAMPLE INFORMATION

Sample Number: 1211060-002 Customer Sample Number:
Location: 00F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 8:44 Sampler: CUSTOMER Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	20.5 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-003

SAMPLE INFORMATION

Sample Number: 1211060-003 Customer Sample Number:
Location: 01a Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	31.5 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	11.5 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	42.5 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.63 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-004

SAMPLE INFORMATION

Sample Number: 1211060-004 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.33 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	35.8 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-005

SAMPLE INFORMATION

Sample Number: 1211060-005 Customer Sample Number:
Location: 01b Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	30.3 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.40 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.16 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-006

SAMPLE INFORMATION

Sample Number: 1211060-006 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.43 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-007

SAMPLE INFORMATION

Sample Number: 1211060-007 Customer Sample Number:
Location: 01c Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	27.6 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.84 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.26 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-008

SAMPLE INFORMATION

Sample Number: 1211060-008 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.4 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.66 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-009

SAMPLE INFORMATION

Sample Number: 1211060-009 Customer Sample Number:
Location: 01d Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	35.4 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.80 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.27 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-010

SAMPLE INFORMATION

Sample Number: 1211060-010 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.24 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-011

SAMPLE INFORMATION

Sample Number: 1211060-011 Customer Sample Number:
Location: 02 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	44.9 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.6 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.94 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-012

SAMPLE INFORMATION

Sample Number: 1211060-012 Customer Sample Number:
Location: 02F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.75 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-013

SAMPLE INFORMATION

Sample Number: 1211060-013 Customer Sample Number:
Location: 03 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	31.6 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.46 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.20 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-014

SAMPLE INFORMATION

Sample Number: 1211060-014 Customer Sample Number:
Location: 03F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.56 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-015

SAMPLE INFORMATION

Sample Number: 1211060-015 Customer Sample Number:
Location: 04 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	29.9 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.89 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.41 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-016

SAMPLE INFORMATION

Sample Number: 1211060-016 Customer Sample Number:
Location: 04F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.25 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.87 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-017

SAMPLE INFORMATION

Sample Number: 1211060-017 Customer Sample Number:
Location: 05 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	22.5 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.96 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	15.3 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-018

SAMPLE INFORMATION

Sample Number: 1211060-018 Customer Sample Number:
Location: 05F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:34 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.90 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	7.68 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-019

SAMPLE INFORMATION

Sample Number: 1211060-019 Customer Sample Number:
Location: 06 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	27.1 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.11 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	20.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-020

SAMPLE INFORMATION

Sample Number: 1211060-020 Customer Sample Number:
Location: 06F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.74 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-021

SAMPLE INFORMATION

Sample Number: 1211060-021 Customer Sample Number:
Location: 07 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	26.5 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.41 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	16.1 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-022

SAMPLE INFORMATION

Sample Number: 1211060-022 Customer Sample Number:
Location: 07F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.96 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	7.91 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-023

SAMPLE INFORMATION

Sample Number: 1211060-023 Customer Sample Number:
Location: 08 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	29.3 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.25 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	7.80 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-024

SAMPLE INFORMATION

Sample Number: 1211060-024 Customer Sample Number:
Location: 08F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.47 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.17 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-025

SAMPLE INFORMATION

Sample Number: 1211060-025 Customer Sample Number:
Location: 09 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	50.3 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.67 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.51 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-026

SAMPLE INFORMATION

Sample Number: 1211060-026 Customer Sample Number:
Location: 09F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.39 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.50 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-027

SAMPLE INFORMATION

Sample Number: 1211060-027 Customer Sample Number:
Location: 10 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	66.2 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.45 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.28 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-028

SAMPLE INFORMATION

Sample Number: 1211060-028 Customer Sample Number:
Location: 10F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	19.6 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.47 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-029

SAMPLE INFORMATION

Sample Number: 1211060-029 Customer Sample Number:
Location: 11 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	66.0 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.06 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.42 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-030

SAMPLE INFORMATION

Sample Number: 1211060-030 Customer Sample Number:
Location: 11F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.6 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.06 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-031

SAMPLE INFORMATION

Sample Number: 1211060-031 Customer Sample Number:
Location: 12 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	60.8 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.84 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.22 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-032

SAMPLE INFORMATION

Sample Number: 1211060-032 Customer Sample Number:
Location: 12F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:35 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.15 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-033

SAMPLE INFORMATION

Sample Number: 1211060-033 Customer Sample Number:
Location: H1 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	72.9 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.50 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.09 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-034

SAMPLE INFORMATION

Sample Number: 1211060-034 Customer Sample Number:
Location: H1F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.37 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:

Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-035

SAMPLE INFORMATION

Sample Number: 1211060-035 Customer Sample Number:
Location: H2 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	76.6 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.56 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.16 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-036

SAMPLE INFORMATION

Sample Number: 1211060-036 Customer Sample Number:
Location: H2F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.8 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.52 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-037

SAMPLE INFORMATION

Sample Number: 1211060-037 Customer Sample Number:
Location: H3 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	64.3 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.34 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-038

SAMPLE INFORMATION

Sample Number: 1211060-038 Customer Sample Number:
Location: H3F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.50 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-039

SAMPLE INFORMATION

Sample Number: 1211060-039 Customer Sample Number:
Location: H4 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	69.9 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.54 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.05 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-040

SAMPLE INFORMATION

Sample Number: 1211060-040 Customer Sample Number:
Location: H4F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.48 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-041

SAMPLE INFORMATION

Sample Number: 1211060-041 Customer Sample Number:
Location: H5 Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	62.6 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.30 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-042

SAMPLE INFORMATION

Sample Number: 1211060-042 Customer Sample Number:
Location: H5F Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.40 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-043

SAMPLE INFORMATION

Sample Number: 1211060-043 Customer Sample Number:
Location: X Type: Dist.
LPR 807 BUCHANAN ST NW UNFILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	65.0 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.41 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/21/2012
Report Number: M- W1211060-044

SAMPLE INFORMATION

Sample Number: 1211060-044 Customer Sample Number:
Location: XF Type: Dist.
LPR 807 BUCHANAN ST NW FILTERED
Collection Date: 11/6/2012 Collection Time: 14:40 Sampler: IC/DM Received Date and Time: 11/7/2012 3:37:26 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.72 ug/L	11/19/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	11/19/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/19/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

11/21/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

Pipe Loop Research

DC Water is participating in the WaterRF Project #4349, "Impact of Galvanic Corrosion on Lead Release Following Partial Lead Service Line Replacement". DC Water collected stagnated samples from pipe loops constructed of lead-copper and copper-pvc connections. The Washington Aqueduct laboratory analyzed samples for metals.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-001

SAMPLE INFORMATION

Sample Number: 1206065-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.8 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-002

SAMPLE INFORMATION

Sample Number: 1206065-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.0 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-003

SAMPLE INFORMATION

Sample Number: 1206065-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-004

SAMPLE INFORMATION

Sample Number: 1206065-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.9 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-005

SAMPLE INFORMATION

Sample Number: 1206065-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	17 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-006

SAMPLE INFORMATION

Sample Number: 1206065-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-007

SAMPLE INFORMATION

Sample Number: 1206065-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.1 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-008

SAMPLE INFORMATION

Sample Number: 1206065-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.8 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-009

SAMPLE INFORMATION

Sample Number: 1206065-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	19 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-010

SAMPLE INFORMATION

Sample Number: 1206065-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-011

SAMPLE INFORMATION

Sample Number: 1206065-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-012

SAMPLE INFORMATION

Sample Number: 1206065-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-013

SAMPLE INFORMATION

Sample Number: 1206065-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.7 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-014

SAMPLE INFORMATION

Sample Number: 1206065-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.4 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-015

SAMPLE INFORMATION

Sample Number: 1206065-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-016

SAMPLE INFORMATION

Sample Number: 1206065-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-017

SAMPLE INFORMATION

Sample Number: 1206065-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.7 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-018

SAMPLE INFORMATION

Sample Number: 1206065-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/5/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.0 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-019

SAMPLE INFORMATION

Sample Number: 1206065-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-020

SAMPLE INFORMATION

Sample Number: 1206065-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.2 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-021

SAMPLE INFORMATION

Sample Number: 1206065-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.3 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-022

SAMPLE INFORMATION

Sample Number: 1206065-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.6 ug/L	6/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-023

SAMPLE INFORMATION

Sample Number: 1206065-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-024

SAMPLE INFORMATION

Sample Number: 1206065-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.4 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-025

SAMPLE INFORMATION

Sample Number: 1206065-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-026

SAMPLE INFORMATION

Sample Number: 1206065-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.6 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-027

SAMPLE INFORMATION

Sample Number: 1206065-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-028

SAMPLE INFORMATION

Sample Number: 1206065-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-029

SAMPLE INFORMATION

Sample Number: 1206065-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	27 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-030

SAMPLE INFORMATION

Sample Number: 1206065-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	19 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-031

SAMPLE INFORMATION

Sample Number: 1206065-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	22 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-032

SAMPLE INFORMATION

Sample Number: 1206065-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.9 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-033

SAMPLE INFORMATION

Sample Number: 1206065-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-034

SAMPLE INFORMATION

Sample Number: 1206065-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.9 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-035

SAMPLE INFORMATION

Sample Number: 1206065-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206065-036

SAMPLE INFORMATION

Sample Number: 1206065-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/8/2012 Collection Time: 8:45 Sampler: HB Received Date and Time: 6/8/2012 11:43:33 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.7 ug/L	6/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-001

SAMPLE INFORMATION

Sample Number: 1206129-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-002

SAMPLE INFORMATION

Sample Number: 1206129-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.5 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-003

SAMPLE INFORMATION

Sample Number: 1206129-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-004

SAMPLE INFORMATION

Sample Number: 1206129-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.6 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-005

SAMPLE INFORMATION

Sample Number: 1206129-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-006

SAMPLE INFORMATION

Sample Number: 1206129-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-007

SAMPLE INFORMATION

Sample Number: 1206129-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-008

SAMPLE INFORMATION

Sample Number: 1206129-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.5 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-009

SAMPLE INFORMATION

Sample Number: 1206129-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	130 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-010

SAMPLE INFORMATION

Sample Number: 1206129-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	33 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-011

SAMPLE INFORMATION

Sample Number: 1206129-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-012

SAMPLE INFORMATION

Sample Number: 1206129-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.7 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-013

SAMPLE INFORMATION

Sample Number: 1206129-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.1 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-014

SAMPLE INFORMATION

Sample Number: 1206129-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.2 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-015

SAMPLE INFORMATION

Sample Number: 1206129-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-016

SAMPLE INFORMATION

Sample Number: 1206129-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.6 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-017

SAMPLE INFORMATION

Sample Number: 1206129-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.6 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-018

SAMPLE INFORMATION

Sample Number: 1206129-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/12/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-019

SAMPLE INFORMATION

Sample Number: 1206129-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	22 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-020

SAMPLE INFORMATION

Sample Number: 1206129-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-021

SAMPLE INFORMATION

Sample Number: 1206129-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	17 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-022

SAMPLE INFORMATION

Sample Number: 1206129-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-023

SAMPLE INFORMATION

Sample Number: 1206129-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	18 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-024

SAMPLE INFORMATION

Sample Number: 1206129-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-025

SAMPLE INFORMATION

Sample Number: 1206129-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-026

SAMPLE INFORMATION

Sample Number: 1206129-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.8 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-027

SAMPLE INFORMATION

Sample Number: 1206129-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-028

SAMPLE INFORMATION

Sample Number: 1206129-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.5 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-029

SAMPLE INFORMATION

Sample Number: 1206129-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-030

SAMPLE INFORMATION

Sample Number: 1206129-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.7 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-031

SAMPLE INFORMATION

Sample Number: 1206129-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-032

SAMPLE INFORMATION

Sample Number: 1206129-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.1 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-033

SAMPLE INFORMATION

Sample Number: 1206129-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.7 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-034

SAMPLE INFORMATION

Sample Number: 1206129-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-035

SAMPLE INFORMATION

Sample Number: 1206129-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.8 ug/L	6/22/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206129-036

SAMPLE INFORMATION

Sample Number: 1206129-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/15/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 6/15/2012 1:25:53 PM Received By: Rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	6/22/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-001

SAMPLE INFORMATION

Sample Number: 1206194-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-002

SAMPLE INFORMATION

Sample Number: 1206194-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.2 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-003

SAMPLE INFORMATION

Sample Number: 1206194-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-004

SAMPLE INFORMATION

Sample Number: 1206194-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-005

SAMPLE INFORMATION

Sample Number: 1206194-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	110 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-006

SAMPLE INFORMATION

Sample Number: 1206194-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.8 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-007

SAMPLE INFORMATION

Sample Number: 1206194-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-008

SAMPLE INFORMATION

Sample Number: 1206194-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.2 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-009

SAMPLE INFORMATION

Sample Number: 1206194-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-010

SAMPLE INFORMATION

Sample Number: 1206194-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.3 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-011

SAMPLE INFORMATION

Sample Number: 1206194-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-012

SAMPLE INFORMATION

Sample Number: 1206194-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-013

SAMPLE INFORMATION

Sample Number: 1206194-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.7 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-014

SAMPLE INFORMATION

Sample Number: 1206194-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.8 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-015

SAMPLE INFORMATION

Sample Number: 1206194-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.1 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-016

SAMPLE INFORMATION

Sample Number: 1206194-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.8 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-017

SAMPLE INFORMATION

Sample Number: 1206194-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-018

SAMPLE INFORMATION

Sample Number: 1206194-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/19/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-019

SAMPLE INFORMATION

Sample Number: 1206194-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-020

SAMPLE INFORMATION

Sample Number: 1206194-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.1 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-021

SAMPLE INFORMATION

Sample Number: 1206194-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1500 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-022

SAMPLE INFORMATION

Sample Number: 1206194-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.4 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-023

SAMPLE INFORMATION

Sample Number: 1206194-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-024

SAMPLE INFORMATION

Sample Number: 1206194-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-025

SAMPLE INFORMATION

Sample Number: 1206194-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-026

SAMPLE INFORMATION

Sample Number: 1206194-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-027

SAMPLE INFORMATION

Sample Number: 1206194-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-028

SAMPLE INFORMATION

Sample Number: 1206194-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.1 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-029

SAMPLE INFORMATION

Sample Number: 1206194-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-030

SAMPLE INFORMATION

Sample Number: 1206194-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.3 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-031

SAMPLE INFORMATION

Sample Number: 1206194-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-032

SAMPLE INFORMATION

Sample Number: 1206194-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.7 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-033

SAMPLE INFORMATION

Sample Number: 1206194-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1.2 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-034

SAMPLE INFORMATION

Sample Number: 1206194-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	< 1 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-035

SAMPLE INFORMATION

Sample Number: 1206194-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.0 ug/L	7/2/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206194-036

SAMPLE INFORMATION

Sample Number: 1206194-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/22/2012 Collection Time: 8:10 Sampler: HB/VI Received Date and Time: 6/22/2012 11:20:52 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	< 1 ug/L	7/2/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-001

SAMPLE INFORMATION

Sample Number: 1206254-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	59 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-002

SAMPLE INFORMATION

Sample Number: 1206254-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-003

SAMPLE INFORMATION

Sample Number: 1206254-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	800 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-004

SAMPLE INFORMATION

Sample Number: 1206254-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.9 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-005

SAMPLE INFORMATION

Sample Number: 1206254-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	21 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-006

SAMPLE INFORMATION

Sample Number: 1206254-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-007

SAMPLE INFORMATION

Sample Number: 1206254-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	20 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-008

SAMPLE INFORMATION

Sample Number: 1206254-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-009

SAMPLE INFORMATION

Sample Number: 1206254-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	17 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-010

SAMPLE INFORMATION

Sample Number: 1206254-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-011

SAMPLE INFORMATION

Sample Number: 1206254-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-012

SAMPLE INFORMATION

Sample Number: 1206254-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-013

SAMPLE INFORMATION

Sample Number: 1206254-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.9 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-014

SAMPLE INFORMATION

Sample Number: 1206254-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.3 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-015

SAMPLE INFORMATION

Sample Number: 1206254-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.2 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-016

SAMPLE INFORMATION

Sample Number: 1206254-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.3 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-017

SAMPLE INFORMATION

Sample Number: 1206254-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.8 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-018

SAMPLE INFORMATION

Sample Number: 1206254-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/26/2012 Collection Time: 8:15 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-019

SAMPLE INFORMATION

Sample Number: 1206254-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.1 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-020

SAMPLE INFORMATION

Sample Number: 1206254-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-021

SAMPLE INFORMATION

Sample Number: 1206254-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	45 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-022

SAMPLE INFORMATION

Sample Number: 1206254-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-023

SAMPLE INFORMATION

Sample Number: 1206254-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	21 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-024

SAMPLE INFORMATION

Sample Number: 1206254-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-025

SAMPLE INFORMATION

Sample Number: 1206254-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-026

SAMPLE INFORMATION

Sample Number: 1206254-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.3 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-027

SAMPLE INFORMATION

Sample Number: 1206254-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-028

SAMPLE INFORMATION

Sample Number: 1206254-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.3 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-029

SAMPLE INFORMATION

Sample Number: 1206254-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-030

SAMPLE INFORMATION

Sample Number: 1206254-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-031

SAMPLE INFORMATION

Sample Number: 1206254-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-032

SAMPLE INFORMATION

Sample Number: 1206254-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.7 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-033

SAMPLE INFORMATION

Sample Number: 1206254-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/5/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-034

SAMPLE INFORMATION

Sample Number: 1206254-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.2 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-035

SAMPLE INFORMATION

Sample Number: 1206254-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.8 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1206254-036

SAMPLE INFORMATION

Sample Number: 1206254-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 6/29/2012 Collection Time: 7:55 Sampler: HB/VI Received Date and Time: 6/29/2012 10:37:22 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.9 ug/L	7/5/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-001

SAMPLE INFORMATION

Sample Number: 1207049-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.6 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-002

SAMPLE INFORMATION

Sample Number: 1207049-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.9 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-003

SAMPLE INFORMATION

Sample Number: 1207049-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-004

SAMPLE INFORMATION

Sample Number: 1207049-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-005

SAMPLE INFORMATION

Sample Number: 1207049-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-006

SAMPLE INFORMATION

Sample Number: 1207049-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.8 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-007

SAMPLE INFORMATION

Sample Number: 1207049-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.8 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-008

SAMPLE INFORMATION

Sample Number: 1207049-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.8 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-009

SAMPLE INFORMATION

Sample Number: 1207049-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.8 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-010

SAMPLE INFORMATION

Sample Number: 1207049-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.1 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-011

SAMPLE INFORMATION

Sample Number: 1207049-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.0 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-012

SAMPLE INFORMATION

Sample Number: 1207049-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.0 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-013

SAMPLE INFORMATION

Sample Number: 1207049-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.7 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-014

SAMPLE INFORMATION

Sample Number: 1207049-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.9 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-015

SAMPLE INFORMATION

Sample Number: 1207049-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-016

SAMPLE INFORMATION

Sample Number: 1207049-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.9 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-017

SAMPLE INFORMATION

Sample Number: 1207049-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.9 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-018

SAMPLE INFORMATION

Sample Number: 1207049-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/3/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.1 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-019

SAMPLE INFORMATION

Sample Number: 1207049-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-020

SAMPLE INFORMATION

Sample Number: 1207049-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.8 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-021

SAMPLE INFORMATION

Sample Number: 1207049-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	87 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-022

SAMPLE INFORMATION

Sample Number: 1207049-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.4 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-023

SAMPLE INFORMATION

Sample Number: 1207049-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-024

SAMPLE INFORMATION

Sample Number: 1207049-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-025

SAMPLE INFORMATION

Sample Number: 1207049-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-026

SAMPLE INFORMATION

Sample Number: 1207049-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.8 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-027

SAMPLE INFORMATION

Sample Number: 1207049-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-028

SAMPLE INFORMATION

Sample Number: 1207049-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.4 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-029

SAMPLE INFORMATION

Sample Number: 1207049-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-030

SAMPLE INFORMATION

Sample Number: 1207049-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-031

SAMPLE INFORMATION

Sample Number: 1207049-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	130 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-032

SAMPLE INFORMATION

Sample Number: 1207049-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.2 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-033

SAMPLE INFORMATION

Sample Number: 1207049-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-034

SAMPLE INFORMATION

Sample Number: 1207049-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	7/12/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-035

SAMPLE INFORMATION

Sample Number: 1207049-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.1 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207049-036

SAMPLE INFORMATION

Sample Number: 1207049-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/6/2012 Collection Time: 7:50 Sampler: HB/VI Received Date and Time: 7/6/2012 2:25:59 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	7/12/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-001

SAMPLE INFORMATION

Sample Number: 1207112-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	21 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-002

SAMPLE INFORMATION

Sample Number: 1207112-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.1 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-003

SAMPLE INFORMATION

Sample Number: 1207112-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	64 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-004

SAMPLE INFORMATION

Sample Number: 1207112-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.6 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-005

SAMPLE INFORMATION

Sample Number: 1207112-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	77 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-006

SAMPLE INFORMATION

Sample Number: 1207112-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-007

SAMPLE INFORMATION

Sample Number: 1207112-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	19 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-008

SAMPLE INFORMATION

Sample Number: 1207112-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-009

SAMPLE INFORMATION

Sample Number: 1207112-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	20 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-010

SAMPLE INFORMATION

Sample Number: 1207112-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-011

SAMPLE INFORMATION

Sample Number: 1207112-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-012

SAMPLE INFORMATION

Sample Number: 1207112-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-013

SAMPLE INFORMATION

Sample Number: 1207112-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.4 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-014

SAMPLE INFORMATION

Sample Number: 1207112-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-015

SAMPLE INFORMATION

Sample Number: 1207112-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-016

SAMPLE INFORMATION

Sample Number: 1207112-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.1 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-017

SAMPLE INFORMATION

Sample Number: 1207112-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-018

SAMPLE INFORMATION

Sample Number: 1207112-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/9/2012 Collection Time: 8:00 Sampler: YT/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-019

SAMPLE INFORMATION

Sample Number: 1207112-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.1 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-020

SAMPLE INFORMATION

Sample Number: 1207112-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.5 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-021

SAMPLE INFORMATION

Sample Number: 1207112-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-022

SAMPLE INFORMATION

Sample Number: 1207112-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.1 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-023

SAMPLE INFORMATION

Sample Number: 1207112-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	120 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-024

SAMPLE INFORMATION

Sample Number: 1207112-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-025

SAMPLE INFORMATION

Sample Number: 1207112-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-026

SAMPLE INFORMATION

Sample Number: 1207112-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-027

SAMPLE INFORMATION

Sample Number: 1207112-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.3 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-028

SAMPLE INFORMATION

Sample Number: 1207112-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.6 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-029

SAMPLE INFORMATION

Sample Number: 1207112-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-030

SAMPLE INFORMATION

Sample Number: 1207112-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.6 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-031

SAMPLE INFORMATION

Sample Number: 1207112-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.1 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-032

SAMPLE INFORMATION

Sample Number: 1207112-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-033

SAMPLE INFORMATION

Sample Number: 1207112-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-034

SAMPLE INFORMATION

Sample Number: 1207112-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.1 ug/L	7/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-035

SAMPLE INFORMATION

Sample Number: 1207112-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/26/2012
Report Number: LC-W1207112-036

SAMPLE INFORMATION

Sample Number: 1207112-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/13/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/13/2012 11:49:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	7/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-001

SAMPLE INFORMATION

Sample Number: 1207189-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.2 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-002

SAMPLE INFORMATION

Sample Number: 1207189-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-003

SAMPLE INFORMATION

Sample Number: 1207189-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-004

SAMPLE INFORMATION

Sample Number: 1207189-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-005

SAMPLE INFORMATION

Sample Number: 1207189-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	21 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-006

SAMPLE INFORMATION

Sample Number: 1207189-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-007

SAMPLE INFORMATION

Sample Number: 1207189-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-008

SAMPLE INFORMATION

Sample Number: 1207189-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.5 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-009

SAMPLE INFORMATION

Sample Number: 1207189-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-010

SAMPLE INFORMATION

Sample Number: 1207189-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-011

SAMPLE INFORMATION

Sample Number: 1207189-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-012

SAMPLE INFORMATION

Sample Number: 1207189-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-013

SAMPLE INFORMATION

Sample Number: 1207189-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.6 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-014

SAMPLE INFORMATION

Sample Number: 1207189-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.0 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-015

SAMPLE INFORMATION

Sample Number: 1207189-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.1 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-016

SAMPLE INFORMATION

Sample Number: 1207189-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.9 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-017

SAMPLE INFORMATION

Sample Number: 1207189-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.3 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-018

SAMPLE INFORMATION

Sample Number: 1207189-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/17/2012 Collection Time: 8:00 Sampler: HB/VI Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.7 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-019

SAMPLE INFORMATION

Sample Number: 1207189-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-020

SAMPLE INFORMATION

Sample Number: 1207189-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.4 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-021

SAMPLE INFORMATION

Sample Number: 1207189-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-022

SAMPLE INFORMATION

Sample Number: 1207189-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-023

SAMPLE INFORMATION

Sample Number: 1207189-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-024

SAMPLE INFORMATION

Sample Number: 1207189-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-025

SAMPLE INFORMATION

Sample Number: 1207189-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-026

SAMPLE INFORMATION

Sample Number: 1207189-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.2 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-027

SAMPLE INFORMATION

Sample Number: 1207189-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-028

SAMPLE INFORMATION

Sample Number: 1207189-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-029

SAMPLE INFORMATION

Sample Number: 1207189-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-030

SAMPLE INFORMATION

Sample Number: 1207189-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-031

SAMPLE INFORMATION

Sample Number: 1207189-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.5 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-032

SAMPLE INFORMATION

Sample Number: 1207189-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.0 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-033

SAMPLE INFORMATION

Sample Number: 1207189-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.8 ug/L	7/26/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-034

SAMPLE INFORMATION

Sample Number: 1207189-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-035

SAMPLE INFORMATION

Sample Number: 1207189-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	32 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207189-036

SAMPLE INFORMATION

Sample Number: 1207189-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/20/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 7/20/2012 2:07:19 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.1 ug/L	7/26/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-001

SAMPLE INFORMATION

Sample Number: 1207257-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.7 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-002

SAMPLE INFORMATION

Sample Number: 1207257-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.5 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-003

SAMPLE INFORMATION

Sample Number: 1207257-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.8 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-004

SAMPLE INFORMATION

Sample Number: 1207257-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.5 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-005

SAMPLE INFORMATION

Sample Number: 1207257-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-006

SAMPLE INFORMATION

Sample Number: 1207257-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-007

SAMPLE INFORMATION

Sample Number: 1207257-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-008

SAMPLE INFORMATION

Sample Number: 1207257-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.6 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-009

SAMPLE INFORMATION

Sample Number: 1207257-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-010

SAMPLE INFORMATION

Sample Number: 1207257-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-011

SAMPLE INFORMATION

Sample Number: 1207257-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	8/1/2012	RHoward
Comment:							
ND=Non-Detect			MDL = Minimum Detection Level			RDL = Reporting Detection Limit	

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-012

SAMPLE INFORMATION

Sample Number: 1207257-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-013

SAMPLE INFORMATION

Sample Number: 1207257-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1100 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-014

SAMPLE INFORMATION

Sample Number: 1207257-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1.4 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-015

SAMPLE INFORMATION

Sample Number: 1207257-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-016

SAMPLE INFORMATION

Sample Number: 1207257-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.3 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-017

SAMPLE INFORMATION

Sample Number: 1207257-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.1 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-018

SAMPLE INFORMATION

Sample Number: 1207257-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/24/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.6 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-019

SAMPLE INFORMATION

Sample Number: 1207257-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-020

SAMPLE INFORMATION

Sample Number: 1207257-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.9 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-021

SAMPLE INFORMATION

Sample Number: 1207257-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-022

SAMPLE INFORMATION

Sample Number: 1207257-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.4 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-023

SAMPLE INFORMATION

Sample Number: 1207257-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-024

SAMPLE INFORMATION

Sample Number: 1207257-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-025

SAMPLE INFORMATION

Sample Number: 1207257-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-026

SAMPLE INFORMATION

Sample Number: 1207257-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.4 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-027

SAMPLE INFORMATION

Sample Number: 1207257-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-028

SAMPLE INFORMATION

Sample Number: 1207257-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-029

SAMPLE INFORMATION

Sample Number: 1207257-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.6 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-030

SAMPLE INFORMATION

Sample Number: 1207257-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.9 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-031

SAMPLE INFORMATION

Sample Number: 1207257-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	8/1/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-032

SAMPLE INFORMATION

Sample Number: 1207257-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-033

SAMPLE INFORMATION

Sample Number: 1207257-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/1/2012	RHoward
Comment: ND=Non-Detect		MDL = Minimum Detection Level		RDL = Reporting Detection Limit			

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-034

SAMPLE INFORMATION

Sample Number: 1207257-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-035

SAMPLE INFORMATION

Sample Number: 1207257-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: HB Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2400 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1207257-036

SAMPLE INFORMATION

Sample Number: 1207257-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/27/2012 Collection Time: 8:20 Sampler: H.B Received Date and Time: 7/27/2012 11:23:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.1 ug/L	8/1/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-001

SAMPLE INFORMATION

Sample Number: 1208037-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-002

SAMPLE INFORMATION

Sample Number: 1208037-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.2 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-003

SAMPLE INFORMATION

Sample Number: 1208037-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-004

SAMPLE INFORMATION

Sample Number: 1208037-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-005

SAMPLE INFORMATION

Sample Number: 1208037-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	18 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-006

SAMPLE INFORMATION

Sample Number: 1208037-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-007

SAMPLE INFORMATION

Sample Number: 1208037-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-008

SAMPLE INFORMATION

Sample Number: 1208037-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-009

SAMPLE INFORMATION

Sample Number: 1208037-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-010

SAMPLE INFORMATION

Sample Number: 1208037-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-011

SAMPLE INFORMATION

Sample Number: 1208037-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	17 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-012

SAMPLE INFORMATION

Sample Number: 1208037-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-013

SAMPLE INFORMATION

Sample Number: 1208037-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.9 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-014

SAMPLE INFORMATION

Sample Number: 1208037-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-015

SAMPLE INFORMATION

Sample Number: 1208037-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.6 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-016

SAMPLE INFORMATION

Sample Number: 1208037-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.6 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-017

SAMPLE INFORMATION

Sample Number: 1208037-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-018

SAMPLE INFORMATION

Sample Number: 1208037-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 7/31/2012 Collection Time: 8:10 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.5 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-019

SAMPLE INFORMATION

Sample Number: 1208037-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	57 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-020

SAMPLE INFORMATION

Sample Number: 1208037-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.3 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-021

SAMPLE INFORMATION

Sample Number: 1208037-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-022

SAMPLE INFORMATION

Sample Number: 1208037-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.4 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-023

SAMPLE INFORMATION

Sample Number: 1208037-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-024

SAMPLE INFORMATION

Sample Number: 1208037-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.4 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-025

SAMPLE INFORMATION

Sample Number: 1208037-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-026

SAMPLE INFORMATION

Sample Number: 1208037-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.7 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-027

SAMPLE INFORMATION

Sample Number: 1208037-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-028

SAMPLE INFORMATION

Sample Number: 1208037-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-029

SAMPLE INFORMATION

Sample Number: 1208037-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-030

SAMPLE INFORMATION

Sample Number: 1208037-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-031

SAMPLE INFORMATION

Sample Number: 1208037-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	80 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-032

SAMPLE INFORMATION

Sample Number: 1208037-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.8 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-033

SAMPLE INFORMATION

Sample Number: 1208037-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	8/8/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-034

SAMPLE INFORMATION

Sample Number: 1208037-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.2 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-035

SAMPLE INFORMATION

Sample Number: 1208037-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.3 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208037-036

SAMPLE INFORMATION

Sample Number: 1208037-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/3/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/3/2012 11:09:03 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.2 ug/L	8/8/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-001

SAMPLE INFORMATION

Sample Number: 1208105-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.0 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-002

SAMPLE INFORMATION

Sample Number: 1208105-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-003

SAMPLE INFORMATION

Sample Number: 1208105-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-004

SAMPLE INFORMATION

Sample Number: 1208105-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.9 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-005

SAMPLE INFORMATION

Sample Number: 1208105-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	19 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-006

SAMPLE INFORMATION

Sample Number: 1208105-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-007

SAMPLE INFORMATION

Sample Number: 1208105-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-008

SAMPLE INFORMATION

Sample Number: 1208105-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.9 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-009

SAMPLE INFORMATION

Sample Number: 1208105-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-010

SAMPLE INFORMATION

Sample Number: 1208105-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-011

SAMPLE INFORMATION

Sample Number: 1208105-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-012

SAMPLE INFORMATION

Sample Number: 1208105-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-013

SAMPLE INFORMATION

Sample Number: 1208105-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-014

SAMPLE INFORMATION

Sample Number: 1208105-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-015

SAMPLE INFORMATION

Sample Number: 1208105-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-016

SAMPLE INFORMATION

Sample Number: 1208105-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.8 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-017

SAMPLE INFORMATION

Sample Number: 1208105-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	23 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-018

SAMPLE INFORMATION

Sample Number: 1208105-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/7/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.1 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-019

SAMPLE INFORMATION

Sample Number: 1208105-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-020

SAMPLE INFORMATION

Sample Number: 1208105-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.4 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-021

SAMPLE INFORMATION

Sample Number: 1208105-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-022

SAMPLE INFORMATION

Sample Number: 1208105-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-023

SAMPLE INFORMATION

Sample Number: 1208105-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	18 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-024

SAMPLE INFORMATION

Sample Number: 1208105-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-025

SAMPLE INFORMATION

Sample Number: 1208105-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-026

SAMPLE INFORMATION

Sample Number: 1208105-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.1 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-027

SAMPLE INFORMATION

Sample Number: 1208105-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-028

SAMPLE INFORMATION

Sample Number: 1208105-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.1 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-029

SAMPLE INFORMATION

Sample Number: 1208105-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-030

SAMPLE INFORMATION

Sample Number: 1208105-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-031

SAMPLE INFORMATION

Sample Number: 1208105-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1.7 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-032

SAMPLE INFORMATION

Sample Number: 1208105-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	< 1 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-033

SAMPLE INFORMATION

Sample Number: 1208105-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.1 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-034

SAMPLE INFORMATION

Sample Number: 1208105-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1.9 ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-035

SAMPLE INFORMATION

Sample Number: 1208105-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	1.1 ug/L	8/14/2012	NMitchell

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/16/2012
Report Number: LC-W1208105-036

SAMPLE INFORMATION

Sample Number: 1208105-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/10/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/10/2012 12:26:05 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	ND ug/L	8/14/2012	NMitchell

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

8/16/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-001

SAMPLE INFORMATION

Sample Number: 1208176-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	42 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-002

SAMPLE INFORMATION

Sample Number: 1208176-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-003

SAMPLE INFORMATION

Sample Number: 1208176-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-004

SAMPLE INFORMATION

Sample Number: 1208176-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.2 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-005

SAMPLE INFORMATION

Sample Number: 1208176-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	18 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-006

SAMPLE INFORMATION

Sample Number: 1208176-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-007

SAMPLE INFORMATION

Sample Number: 1208176-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-008

SAMPLE INFORMATION

Sample Number: 1208176-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.7 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-009

SAMPLE INFORMATION

Sample Number: 1208176-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-010

SAMPLE INFORMATION

Sample Number: 1208176-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-011

SAMPLE INFORMATION

Sample Number: 1208176-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-012

SAMPLE INFORMATION

Sample Number: 1208176-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-013

SAMPLE INFORMATION

Sample Number: 1208176-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.2 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-014

SAMPLE INFORMATION

Sample Number: 1208176-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.0 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-015

SAMPLE INFORMATION

Sample Number: 1208176-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.8 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-016

SAMPLE INFORMATION

Sample Number: 1208176-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.3 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-017

SAMPLE INFORMATION

Sample Number: 1208176-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.5 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-018

SAMPLE INFORMATION

Sample Number: 1208176-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/14/2012 Collection Time: 7:50 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.6 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-019

SAMPLE INFORMATION

Sample Number: 1208176-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.9 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-020

SAMPLE INFORMATION

Sample Number: 1208176-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.4 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-021

SAMPLE INFORMATION

Sample Number: 1208176-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-022

SAMPLE INFORMATION

Sample Number: 1208176-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.3 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-023

SAMPLE INFORMATION

Sample Number: 1208176-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-024

SAMPLE INFORMATION

Sample Number: 1208176-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-025

SAMPLE INFORMATION

Sample Number: 1208176-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-026

SAMPLE INFORMATION

Sample Number: 1208176-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.1 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-027

SAMPLE INFORMATION

Sample Number: 1208176-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.7 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-028

SAMPLE INFORMATION

Sample Number: 1208176-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.6 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-029

SAMPLE INFORMATION

Sample Number: 1208176-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-030

SAMPLE INFORMATION

Sample Number: 1208176-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-031

SAMPLE INFORMATION

Sample Number: 1208176-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-032

SAMPLE INFORMATION

Sample Number: 1208176-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.2 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-033

SAMPLE INFORMATION

Sample Number: 1208176-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.3 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-034

SAMPLE INFORMATION

Sample Number: 1208176-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.1 ug/L	8/29/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-035

SAMPLE INFORMATION

Sample Number: 1208176-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.6 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/5/2012
Report Number: LC-W1208176-036

SAMPLE INFORMATION

Sample Number: 1208176-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/17/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/17/2012 10:24:22 AM Received By: ASanders

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	8/29/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/5/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-001

SAMPLE INFORMATION

Sample Number: 1208245-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.4 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-002

SAMPLE INFORMATION

Sample Number: 1208245-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.0 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-003

SAMPLE INFORMATION

Sample Number: 1208245-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-004

SAMPLE INFORMATION

Sample Number: 1208245-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-005

SAMPLE INFORMATION

Sample Number: 1208245-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	22 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-006

SAMPLE INFORMATION

Sample Number: 1208245-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-007

SAMPLE INFORMATION

Sample Number: 1208245-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-008

SAMPLE INFORMATION

Sample Number: 1208245-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.9 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-009

SAMPLE INFORMATION

Sample Number: 1208245-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-010

SAMPLE INFORMATION

Sample Number: 1208245-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.5 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-011

SAMPLE INFORMATION

Sample Number: 1208245-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-012

SAMPLE INFORMATION

Sample Number: 1208245-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-013

SAMPLE INFORMATION

Sample Number: 1208245-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.0 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-014

SAMPLE INFORMATION

Sample Number: 1208245-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-015

SAMPLE INFORMATION

Sample Number: 1208245-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.3 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-016

SAMPLE INFORMATION

Sample Number: 1208245-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-017

SAMPLE INFORMATION

Sample Number: 1208245-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.6 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-018

SAMPLE INFORMATION

Sample Number: 1208245-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/21/2012 Collection Time: 8:00 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-019

SAMPLE INFORMATION

Sample Number: 1208245-019 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-020

SAMPLE INFORMATION

Sample Number: 1208245-020 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-021

SAMPLE INFORMATION

Sample Number: 1208245-021 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-022

SAMPLE INFORMATION

Sample Number: 1208245-022 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-023

SAMPLE INFORMATION

Sample Number: 1208245-023 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	240 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-024

SAMPLE INFORMATION

Sample Number: 1208245-024 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.3 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-025

SAMPLE INFORMATION

Sample Number: 1208245-025 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-026

SAMPLE INFORMATION

Sample Number: 1208245-026 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-027

SAMPLE INFORMATION

Sample Number: 1208245-027 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-028

SAMPLE INFORMATION

Sample Number: 1208245-028 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-029

SAMPLE INFORMATION

Sample Number: 1208245-029 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-030

SAMPLE INFORMATION

Sample Number: 1208245-030 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-031

SAMPLE INFORMATION

Sample Number: 1208245-031 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.0 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-032

SAMPLE INFORMATION

Sample Number: 1208245-032 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.9 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-033

SAMPLE INFORMATION

Sample Number: 1208245-033 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-034

SAMPLE INFORMATION

Sample Number: 1208245-034 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.9 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-035

SAMPLE INFORMATION

Sample Number: 1208245-035 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.6 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208245-036

SAMPLE INFORMATION

Sample Number: 1208245-036 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/24/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 8/24/2012 2:02:06 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.1 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-001

SAMPLE INFORMATION

Sample Number: 1208295-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-002

SAMPLE INFORMATION

Sample Number: 1208295-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.5 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-003

SAMPLE INFORMATION

Sample Number: 1208295-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-004

SAMPLE INFORMATION

Sample Number: 1208295-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.3 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-005

SAMPLE INFORMATION

Sample Number: 1208295-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	520 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-006

SAMPLE INFORMATION

Sample Number: 1208295-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-007

SAMPLE INFORMATION

Sample Number: 1208295-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-008

SAMPLE INFORMATION

Sample Number: 1208295-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.3 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-009

SAMPLE INFORMATION

Sample Number: 1208295-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-010

SAMPLE INFORMATION

Sample Number: 1208295-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	10 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-011

SAMPLE INFORMATION

Sample Number: 1208295-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-012

SAMPLE INFORMATION

Sample Number: 1208295-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-013

SAMPLE INFORMATION

Sample Number: 1208295-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.4 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-014

SAMPLE INFORMATION

Sample Number: 1208295-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-015

SAMPLE INFORMATION

Sample Number: 1208295-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.3 ug/L	9/6/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-016

SAMPLE INFORMATION

Sample Number: 1208295-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-017

SAMPLE INFORMATION

Sample Number: 1208295-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.9 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/13/2012
Report Number: LC-W1208295-018

SAMPLE INFORMATION

Sample Number: 1208295-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 8/31/2012 Collection Time: 7:55 Sampler: HB Received Date and Time: 8/31/2012 1:00:55 PM Received By: rhoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	9/6/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/13/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-001

SAMPLE INFORMATION

Sample Number: 1209052-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-002

SAMPLE INFORMATION

Sample Number: 1209052-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-003

SAMPLE INFORMATION

Sample Number: 1209052-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-004

SAMPLE INFORMATION

Sample Number: 1209052-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.8 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-005

SAMPLE INFORMATION

Sample Number: 1209052-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	22 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-006

SAMPLE INFORMATION

Sample Number: 1209052-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-007

SAMPLE INFORMATION

Sample Number: 1209052-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-008

SAMPLE INFORMATION

Sample Number: 1209052-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.4 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-009

SAMPLE INFORMATION

Sample Number: 1209052-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.5 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-010

SAMPLE INFORMATION

Sample Number: 1209052-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.7 ug/L	9/11/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-011

SAMPLE INFORMATION

Sample Number: 1209052-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-012

SAMPLE INFORMATION

Sample Number: 1209052-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-013

SAMPLE INFORMATION

Sample Number: 1209052-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.7 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-014

SAMPLE INFORMATION

Sample Number: 1209052-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.8 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-015

SAMPLE INFORMATION

Sample Number: 1209052-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.4 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-016

SAMPLE INFORMATION

Sample Number: 1209052-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	9/11/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-017

SAMPLE INFORMATION

Sample Number: 1209052-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	76 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209052-018

SAMPLE INFORMATION

Sample Number: 1209052-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 9/7/2012 Collection Time: 8:30 Sampler: HB Received Date and Time: 9/7/2012 1:10:03 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.1 ug/L	9/11/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-001

SAMPLE INFORMATION

Sample Number: 1209122-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	40 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-002

SAMPLE INFORMATION

Sample Number: 1209122-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.7 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-003

SAMPLE INFORMATION

Sample Number: 1209122-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-004

SAMPLE INFORMATION

Sample Number: 1209122-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.3 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-005

SAMPLE INFORMATION

Sample Number: 1209122-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	21 ug/L	9/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-006

SAMPLE INFORMATION

Sample Number: 1209122-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-007

SAMPLE INFORMATION

Sample Number: 1209122-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-008

SAMPLE INFORMATION

Sample Number: 1209122-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.5 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-009

SAMPLE INFORMATION

Sample Number: 1209122-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.5 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-010

SAMPLE INFORMATION

Sample Number: 1209122-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.4 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-011

SAMPLE INFORMATION

Sample Number: 1209122-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	16 ug/L	9/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-012

SAMPLE INFORMATION

Sample Number: 1209122-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	12 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-013

SAMPLE INFORMATION

Sample Number: 1209122-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.4 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-014

SAMPLE INFORMATION

Sample Number: 1209122-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	5.4 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-015

SAMPLE INFORMATION

Sample Number: 1209122-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-016

SAMPLE INFORMATION

Sample Number: 1209122-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	2.4 ug/L	9/18/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-017

SAMPLE INFORMATION

Sample Number: 1209122-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.0 ug/L	9/18/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/28/2012
Report Number: LC-W1209122-018

SAMPLE INFORMATION

Sample Number: 1209122-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 9/14/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/14/2012 2:07:43 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.1 ug/L	9/18/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/28/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-001

SAMPLE INFORMATION

Sample Number: 1209187-001 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	600 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-002

SAMPLE INFORMATION

Sample Number: 1209187-002 Customer Sample Number: Program: LLP
Location: PIPELOOP 2A DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.6 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-003

SAMPLE INFORMATION

Sample Number: 1209187-003 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-004

SAMPLE INFORMATION

Sample Number: 1209187-004 Customer Sample Number: Program: LLP
Location: PIPELOOP 2B DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.2 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-005

SAMPLE INFORMATION

Sample Number: 1209187-005 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	15 ug/L	9/25/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-006

SAMPLE INFORMATION

Sample Number: 1209187-006 Customer Sample Number: Program: LLP
Location: PIPELOOP 2C DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.9 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-007

SAMPLE INFORMATION

Sample Number: 1209187-007 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	11 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-008

SAMPLE INFORMATION

Sample Number: 1209187-008 Customer Sample Number: Program: LLP
Location: PIPELOOP 5A DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	7.5 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-009

SAMPLE INFORMATION

Sample Number: 1209187-009 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	13 ug/L	9/25/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-010

SAMPLE INFORMATION

Sample Number: 1209187-010 Customer Sample Number: Program: LLP
Location: PIPELOOP 5B DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	8.8 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-011

SAMPLE INFORMATION

Sample Number: 1209187-011 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	14 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-012

SAMPLE INFORMATION

Sample Number: 1209187-012 Customer Sample Number: Program: LLP
Location: PIPELOOP 5C DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	9.2 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-013

SAMPLE INFORMATION

Sample Number: 1209187-013 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	9/25/2012	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-014

SAMPLE INFORMATION

Sample Number: 1209187-014 Customer Sample Number: Program: LLP
Location: PIPELOOP 6A DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.9 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-015

SAMPLE INFORMATION

Sample Number: 1209187-015 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.3 ug/L	9/25/2012	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-016

SAMPLE INFORMATION

Sample Number: 1209187-016 Customer Sample Number: Program: LLP
Location: PIPELOOP 6B DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	3.9 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-017

SAMPLE INFORMATION

Sample Number: 1209187-017 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C TOTAL Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	6.0 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/1/2012
Report Number: LC-W1209187-018

SAMPLE INFORMATION

Sample Number: 1209187-018 Customer Sample Number: Program: LLP
Location: PIPELOOP 6C DISSOLVED Type: Dist.
Collection Date: 9/21/2012 Collection Time: 9:00 Sampler: HB Received Date and Time: 9/21/2012 3:12:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.9	15 ug/L	0.2 ug/L	1 ug/L	4.1 ug/L	9/25/2012	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/1/2012

Date

DC Water Fountain and Sink Samples

At the request of DC Water's Union, DC Water's water quality staff collected lead samples from all locations that are used by employees for drinking purposes. Sample sites included fountains and sinks at all DC Water owned facilities.

Sampling procedures included flushing lines for several minutes, stagnating for at least 15 hours and collecting samples using 250 mL plastic bottles. All samples were analyzed by the Washington Aqueduct.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-007

SAMPLE INFORMATION

Sample Number: 1209115-007 Customer Sample Number: Project: UNION
Location: BP7 5000 OVERLOOK AVE. CMF Type: Dist.
 MACHINE SHOP #1

Collection Date: 9/13/2012 Collection Time: 12:30 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.096 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-008

SAMPLE INFORMATION

Sample Number: 1209115-008 Customer Sample Number: Project: UNION
Location: BP8 5000 OVERLOOK AVE CMF Type: Dist.
MECHANIC SHOP

Collection Date: 9/13/2012 Collection Time: 12:40 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-009

SAMPLE INFORMATION

Sample Number: 1209115-009 Customer Sample Number: Project: UNION
Location: BP9 5000 OVERLOOK AVE. COF 4TH Type: Dist.
FLOOR (FOUNTAIN #1)

Collection Date: 9/13/2012 Collection Time: 11:25 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-010

SAMPLE INFORMATION

Sample Number: 1209115-010 Customer Sample Number: Project: UNION
Location: BP10 5000 OVERLOOK AVE. COF 4TH Type: Dist.
 FLOOR (FOUNTAIN #2)

Collection Date: 9/13/2012 Collection Time: 11:30 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-011

SAMPLE INFORMATION

Sample Number: 1209115-011 Customer Sample Number: Project: UNION
Location: BP11 5000 OVERLOOK AVE. COF 4TH Type: Dist.
 FLOOR (FOUNTAIN #3)

Collection Date: 9/13/2012 Collection Time: 11:40 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.051 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-014

SAMPLE INFORMATION

Sample Number: 1209115-014 Customer Sample Number: Project: UNION
Location: BP14 5000 OVERLOOK AVE. COF 5TH Type: Dist.
 FLOOR (FOUNTAIN #3)

Collection Date: 9/13/2012 Collection Time: 12:10 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1209115-015

SAMPLE INFORMATION

Sample Number: 1209115-015 Customer Sample Number: Project: UNION
Location: BP100 5000 COF 2ND FLOOR Type: Dist.

Collection Date: 9/13/2012 Collection Time: 12:00 Sampler: HB Received Date and Time: 9/13/2012 2:56:50 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	< 0.001 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210124-001

SAMPLE INFORMATION

Sample Number: 1210124-001 Customer Sample Number: Project: UNION
Location: 4-O O STREET BUILDING F (BREAK ROOM) Type: Dist.

Collection Date: 10/11/2012 Collection Time: 11:00 Sampler: HB Received Date and Time: 10/11/2012 2:56:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.108 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210124-002

SAMPLE INFORMATION

Sample Number: 1210124-002 Customer Sample Number: Project: UNION
Location: 6-O O STREET BUILDING H (1ST FLOOR) (NORTH) Type: Dist.

Collection Date: 10/11/2012 Collection Time: 10:50 Sampler: HB Received Date and Time: 10/11/2012 2:56:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.383 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210124-003

SAMPLE INFORMATION

Sample Number: 1210124-003 Customer Sample Number: Project: UNION
Location: 7-O O STREET BUILDING H (1ST FLOOR) (SOUTH) Type: Dist.

Collection Date: 10/11/2012 Collection Time: 10:45 Sampler: HB Received Date and Time: 10/11/2012 2:56:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.433 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210124-004

SAMPLE INFORMATION

Sample Number: 1210124-004 Customer Sample Number: Project: UNION
Location: 8-O O STREET BUILDING H (2ND FLOOR) (KITCHEN) Type: Dist.

Collection Date: 10/11/2012 Collection Time: 10:35 Sampler: HB Received Date and Time: 10/11/2012 2:56:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.091 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.048 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210124-005

SAMPLE INFORMATION

Sample Number: 1210124-005 Customer Sample Number: Project: UNION
Location: 11-O O STREET BUILDING FLEET SHOP Type: Dist.

Collection Date: 10/11/2012 Collection Time: 10:15 Sampler: HB Received Date and Time: 10/11/2012 2:56:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.222 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210124-006

SAMPLE INFORMATION

Sample Number: 1210124-006 Customer Sample Number: Project: UNION
Location: 12-O O STREET BUILDING FLEET SHOP Type: Dist.
(2ND FLOOR KITCHEN)

Collection Date: 10/11/2012 Collection Time: 10:00 Sampler: HB Received Date and Time: 10/11/2012 2:56:36 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.130 mg/L	10/18/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.053 mg/L	10/18/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	10/18/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-001

SAMPLE INFORMATION

Sample Number: 1210182-001 Customer Sample Number: Project: UNION
Location: 1-B BRYANT ST 1ST FLOOR (NORTH - HIGH) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 10:55 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.054 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.069 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-003

SAMPLE INFORMATION

Sample Number: 1210182-003 Customer Sample Number: Project: UNION
Location: 3-B BRYANT ST 1ST FLOOR (SOUTH) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 11:10 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.104 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.135 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-005

SAMPLE INFORMATION

Sample Number: 1210182-005 Customer Sample Number: Project: UNION
Location: 5-B BRYANT ST 2ND FLOOR (NORTH- Type: Dist.
LOW)

Collection Date: 10/18/2012 Collection Time: 11:25 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-006

SAMPLE INFORMATION

Sample Number: 1210182-006 Customer Sample Number: Project: UNION
Location: 6-B BRYANT ST 2ND FLOOR (SOUTH) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 11:40 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.085 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.115 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/23/2012	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/26/2012
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-008

SAMPLE INFORMATION

Sample Number: 1210182-008 Customer Sample Number: Project: UNION
Location: 8-B BRYANT ST 3RD FLOOR Type: Dist.
(NORTHWEST-LOW)

Collection Date: 10/18/2012 Collection Time: 11:55 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.051 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.076 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-009

SAMPLE INFORMATION

Sample Number: 1210182-009 Customer Sample Number: Project: UNION
Location: 9-B BRYANT ST 3RD FLOOR (SOUTH-HIGH) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 12:05 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.035 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.127 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-010

SAMPLE INFORMATION

Sample Number: 1210182-010 Customer Sample Number: Project: UNION
Location: 10-B BRYANT ST 3RD FLOOR (SOUTH- Type: Dist.
LOW)

Collection Date: 10/18/2012 Collection Time: 12:10 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.112 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-012

SAMPLE INFORMATION

Sample Number: 1210182-012 Customer Sample Number: Project: UNION
Location: 12-B BRYANT ST BASEMENT (NORTH-LOW) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 12:30 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.348 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-013

SAMPLE INFORMATION

Sample Number: 1210182-013 Customer Sample Number: Project: UNION
Location: 13-B BRYANT ST SHOP (HIGH) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 12:45 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.091 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-014

SAMPLE INFORMATION

Sample Number: 1210182-014 Customer Sample Number: Project: UNION
Location: 14-B BRYANT ST SHOP (LOW) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 12:50 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.113 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-015

SAMPLE INFORMATION

Sample Number: 1210182-015 Customer Sample Number: Project: UNION
Location: 15-B BRYANT ST KITCHEN (3RD FLOOR) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 11:05 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.198 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.117 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-016

SAMPLE INFORMATION

Sample Number: 1210182-016 Customer Sample Number: Project: UNION
Location: 16-B BRYANT ST KITCHEN (1ST FLOOR) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 13:00 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.296 mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.071 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/26/2012
Report Number: LC-W1210182-017

SAMPLE INFORMATION

Sample Number: 1210182-017 Customer Sample Number: Project: UNION
Location: 1-R FORT RENO (FOUNTAIN) Type: Dist.

Collection Date: 10/18/2012 Collection Time: 9:30 Sampler: HB Received Date and Time: 10/18/2012 2:22:21 PM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/23/2012	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.057 mg/L	10/23/2012	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/23/2012	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/26/2012

Date

Research – Reservoir Samples

DC Water analyzed samples from the Ft Reno Reservoir for several metals, including lead. All results are included in the report.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-001

SAMPLE INFORMATION

Sample Number: 1211166-001

Customer Sample Number:

Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 TOP

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:00

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.17 ug/L	12/4/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	21.8 ug/L	12/4/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.60 ug/L	12/4/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.67 ug/L	12/4/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.28 ug/L	12/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	0.90 ug/L	12/4/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-001

SAMPLE INFORMATION

Sample Number: 1211166-001

Customer Sample Number:

Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 TOP

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:00

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.61 ug/L	12/4/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	145 ug/L	12/4/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.55 ug/L	12/4/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	35.3 ug/L	12/4/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-001

SAMPLE INFORMATION

Sample Number: 1211166-001

Customer Sample Number:

Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 TOP

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:00

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-002

SAMPLE INFORMATION

Sample Number: 1211166-002

Customer Sample Number:

Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 MIDDLE

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:25

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.19 ug/L	12/4/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	32.9 ug/L	12/4/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.68 ug/L	12/4/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.92 ug/L	12/4/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.37 ug/L	12/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.03 ug/L	12/4/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-002

SAMPLE INFORMATION

Sample Number: 1211166-002

Customer Sample Number:

Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 MIDDLE

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:25

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.58 ug/L	12/4/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	148 ug/L	12/4/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.54 ug/L	12/4/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	35.9 ug/L	12/4/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-002

SAMPLE INFORMATION

Sample Number: 1211166-002

Customer Sample Number:

Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 MIDDLE

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:25

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 12/12/2012
 Report Number:M- W1211166-003

SAMPLE INFORMATION

Sample Number: 1211166-003 Customer Sample Number:
 Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 BOTTOM Type: SP Project: RESPR

Collection Date: 11/21/2012 Collection Time: 9:15 Sampler: AB/DVC Received Date and Time: 11/21/2012 11:35:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.09 ug/L	12/4/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	30.7 ug/L	12/4/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	0.51 ug/L	12/4/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	1.06 ug/L	12/4/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.68 ug/L	12/4/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.48 ug/L	12/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	0.92 ug/L	12/4/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-003

SAMPLE INFORMATION

Sample Number: 1211166-003 Customer Sample Number:
Location: 3900 DONALDSON PL. NW NORTH HATCH - 2 BOTTOM Type: SP Project: RESPR

Collection Date: 11/21/2012 Collection Time: 9:15 Sampler: AB/DVC Received Date and Time: 11/21/2012 11:35:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-004

SAMPLE INFORMATION

Sample Number: 1211166-004

Customer Sample Number:

Location: 3900 DONALDSON PL NW SOUTH HATCH-5 TOP

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:40

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.15 ug/L	12/4/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	58.0 ug/L	12/4/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.86 ug/L	12/4/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.76 ug/L	12/4/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.27 ug/L	12/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.02 ug/L	12/4/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-004

SAMPLE INFORMATION

Sample Number: 1211166-004

Customer Sample Number:

Location: 3900 DONALDSON PL NW SOUTH HATCH-5 TOP

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:40

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.58 ug/L	12/4/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	149 ug/L	12/4/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.53 ug/L	12/4/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	0.73 ug/L	12/4/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	35.8 ug/L	12/4/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-004

SAMPLE INFORMATION

Sample Number: 1211166-004

Customer Sample Number:

Location: 3900 DONALDSON PL NW SOUTH HATCH-5 TOP

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:40

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-005

SAMPLE INFORMATION

Sample Number: 1211166-005

Customer Sample Number:

Location: 3900 DONALDSON PL. NW SOUTH HATCH -5 MIDDLE

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
10:00

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.15 ug/L	12/4/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	50.7 ug/L	12/4/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.95 ug/L	12/4/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.72 ug/L	12/4/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.44 ug/L	12/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	0.92 ug/L	12/4/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-005

SAMPLE INFORMATION

Sample Number: 1211166-005

Customer Sample Number:

Location: 3900 DONALDSON PL. NW SOUTH HATCH -5 MIDDLE

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
10:00

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	153 ug/L	12/4/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.58 ug/L	12/4/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	37.2 ug/L	12/4/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-005

SAMPLE INFORMATION

Sample Number: 1211166-005

Customer Sample Number:

Location: 3900 DONALDSON PL. NW SOUTH HATCH -5 MIDDLE

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
10:00

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2012

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-006

SAMPLE INFORMATION

Sample Number: 1211166-006

Customer Sample Number:

Location: 3900 DONALDSON PL. NW SOUTH HATCH -5 BOTTOM

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:50

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Lithium	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.19 ug/L	12/4/2012	TPasquale
Beryllium	EPA 200.8	4 ug/L	0.13 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Aluminum	EPA 200.8	ug/L	2 ug/L	10 ug/L	23.4 ug/L	12/4/2012	TPasquale
Vanadium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	0.51 ug/L	12/4/2012	TPasquale
Chromium	EPA 200.8	100 ug/L	0.27 ug/L	0.5 ug/L	0.86 ug/L	12/4/2012	TPasquale
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.80 ug/L	12/4/2012	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cobalt	EPA 200.8	ug/L	0.12 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Nickel	EPA 200.8	ug/L	0.11 ug/L	0.5 ug/L	2.56 ug/L	12/4/2012	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.25 ug/L	12/4/2012	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-006

SAMPLE INFORMATION

Sample Number: 1211166-006

Customer Sample Number:

Location: 3900 DONALDSON PL. NW SOUTH HATCH -5 BOTTOM

Type: SP Project: RESPR

Collection Date:
11/21/2012

Collection Time:
9:50

Sampler:
AB/DVC

Received Date and Time:
11/21/2012 11:35:05 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Arsenic	EPA 200.8	10 ug/L	0.17 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Selenium	EPA 200.8	50 ug/L	0.31 ug/L	0.5 ug/L	0.54 ug/L	12/4/2012	TPasquale
Strontium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	158 ug/L	12/4/2012	TPasquale
Molybdenum	EPA 200.8	ug/L	0.22 ug/L	0.5 ug/L	0.58 ug/L	12/4/2012	TPasquale
Silver	EPA 200.8	ug/L	4.5 ug/L	10 ug/L	ND ug/L	12/4/2012	TPasquale
Cadmium	EPA 200.8	5 ug/L	0.21 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Antimony	EPA 200.8	6 ug/L	0.11 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Barium	EPA 200.8	2000 ug/L	0.13 ug/L	0.5 ug/L	38.4 ug/L	12/4/2012	TPasquale
Thallium	EPA 200.8	2 ug/L	0.33 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2012	TPasquale
Thorium	EPA 200.8	ug/L	0.09 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2012
Report Number: M- W1211166-006

SAMPLE INFORMATION

Sample Number: 1211166-006 Customer Sample Number:
Location: 3900 DONALDSON PL. NW SOUTH HATCH -5 BOTTOM Type: SP Project: RESPR

Collection Date: 11/21/2012 Collection Time: 9:50 Sampler: AB/DVC Received Date and Time: 11/21/2012 11:35:05 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Uranium	EPA 200.8	ug/L	0.06 ug/L	0.5 ug/L	ND ug/L	12/4/2012	TPasquale

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2012

Date


5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

Attachment 3

Customer Letter Distribution Certification



January 9, 2013

William Arguto
U.S. Environmental Protection Agency Region III
1650 Arch Street
Philadelphia, PA 19103-2029

Re: Certification of Distribution of Consumer Test Results

Dear Mr. Arguto:

The District of Columbia Water and Sewer Authority (PWSID: DC000002) hereby certifies that for the lead and copper compliance monitoring period ending December 31, 2012, the “consumer notification of test results” have been distributed to the participating Lead and Copper Compliance monitoring customers in a manner consistent with the requirements of 40 CFR § 141.85(d). Pursuant to 40 CFR § 141.90(f)(3), attached are copies of sample consumer notifications.

Sincerely,

Jessica Edwards-Brandt
Manager, Drinking Water Division

cc: Charles Kiely
Gregory Hope
Randy Hayman



January 9, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead and copper levels were below the Environmental Protection Agency (EPA) action levels.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

If you are pregnant or have children under age six, you should consider using cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Some people who drink water containing copper in excess of the action level may, with short term

exposure, experience gastrointestinal distress, and with long-term exposure may experience liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



January 9, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The first draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



January 9, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The second draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager