



Lead and Copper Compliance Report July through December 2013

Table 1 summarizes the District of Columbia Water and Sewer Authority’s (DC Water) Lead and Copper compliance results for the monitoring period July through December 2013.

Table 1. Lead and Copper Summary Data

Number of Samples	
Lead and Copper	113
90th Percentile First Draw Concentrations	
Lead mg/L	0.0055
Copper mg/L	0.101
Service Line Materials	
Full Lead	71%
Partial Lead	29%

The appendices and attachments contain the following information and data:

- Appendix A: Lead and Copper Compliance Data
 - Table A.1 First Draw Lead Results
 - Table A.2 First Draw Copper Results

- Appendix B: Additional Monitoring Data
 - Table B.1 Second Draw Lead Results
 - Table B.2 Second Draw Copper Results

- Appendix C: Additional Sampling Information
 - Table C.1 Sample Kit Distribution
 - Table C.2 Sample Kits Not Returned
 - Table C.3 Samples Returned and Rejected for Compliance Analysis
 - Table C.4 Deviations from Sample Order
 - Table C.5 Sites with Compliance Results from July 2012 – June 2013 and No Results in July – December 2013

- Attachment 1: Washington Aqueduct Test Results for LCR Compliance
- Attachment 2: Other Additional Monitoring Data:
 - Customer requested tests
 - Post-LSR
 - Lead profiles
 - Other Research
- Attachment 3: Certification of Consumer Tap Results for July through December 2013

Appendix A: Lead and Copper Compliance Data

Table A.1 First Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
1	123 TENNESSEE AVE NE	Lead	12/6/2013	0.0000
2	1310 R ST NW	Lead	12/4/2013	0.0000
3	1436 S St NW	Partial Lead	7/25/2013	0.0000
4	15 Milmarson Pl NW	Lead	7/24/2013	0.0000
5	1706 NEW JERSEY AVE NW	Lead	7/23/2013	0.0000
6	2923 Cathedral AVE NW	Lead	7/24/2013	0.0000
7	3036 P St NW	Partial Lead	10/29/2013	0.0000
8	307 7th St NE	Lead	7/23/2013	0.0000
9	317 9th St SE	Partial Lead	7/24/2013	0.0000
10	333 34th St NE	Partial Lead	10/22/2013	0.0000
11	3416 9th St NE	Partial Lead	10/22/2013	0.0000
12	36 Florida Ave NW	Partial Lead	8/20/2013	0.0000
13	3724 CHESAPEAKE ST NW	Lead	12/5/2013	0.0000
14	4332 BRANDYWINE ST NW	Partial Lead	10/23/2013	0.0000
15	4447 HAWTHORNE ST NW	Lead	12/4/2013	0.0000
16	449 S St NW	Lead	8/20/2013	0.0000
17	4926 Glenbrook Rd NW	Lead	8/22/2013	0.0000
18	5003 7TH ST NW	Partial Lead	12/6/2013	0.0000
19	53 P St NW	Partial Lead	10/24/2013	0.0000
20	6105 Dix St NE	Lead	9/26/2013	0.0000
21	619 12th St NE	Lead	9/25/2013	0.0000
22	75 Bates St NW	Lead	9/24/2013	0.0000
23	1375 MONROE ST NW	Lead	12/5/2013	0.0000
24	1420 Hamlin St NE	Partial Lead	9/25/2013	0.0000
25	1850 2ND ST NW	Partial Lead	11/19/2013	0.0000
26	1003 Quebec Pl NW	Lead	7/25/2013	0.0000
27	1319 POTOMAC AVE SE	Partial Lead	9/25/2013	0.0000
28	2007 37TH ST NW	Lead	7/29/2013	0.0000
29	3913 8TH ST NW	Partial Lead	10/22/2013	0.0000
30	621 Upshur St NW	Lead	10/23/2013	0.0000
31	1262 COLUMBIA RD NW	Lead	7/24/2013	0.0000
32	308 9th St SE	Partial Lead	10/21/2013	0.0000
33	331 RALEIGH ST SE	Lead	8/21/2013	0.0000
34	1222 HAMILTON ST NW	Partial Lead	10/22/2013	0.0000
35	2830 BRENTWOOD RD NE	Lead	7/23/2013	0.0000
36	6213 7TH ST NW	Partial Lead	10/23/2013	0.0000
37	3202 38TH ST NW	Partial Lead	10/22/2013	0.0000
38	3722 MCKINLEY ST NW	Partial Lead	12/5/2013	0.0000
39	617 6th St NE	Lead	9/25/2013	0.0000
40	1003 Otis St NE	Lead	7/24/2013	0.0010
41	1620 Webster St NW	Lead	7/24/2013	0.0010

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
42	4214 8th St NW	Lead	8/20/2013	0.0010
43	4806 Kansas Ave NW	Lead	11/19/2013	0.0010
44	4818 8th ST NW	Partial Lead	10/22/2013	0.0010
45	53 V St NW	Partial Lead	10/24/2013	0.0010
46	3710 Huntington St NW	Lead	8/21/2013	0.0011
47	561 23RD PL NE	Lead	12/4/2013	0.0011
48	1424 S ST NW	Lead	8/8/2013	0.0012
49	1529 UPSHUR ST NW	Lead	12/6/2013	0.0012
50	1613 Webster St NW	Lead	7/24/2013	0.0012
51	4215 39th St NW	Partial Lead	10/22/2013	0.0012
52	1011 Taylor St NE	Lead	7/24/2013	0.0013
53	1412 S St NW	Partial Lead	10/1/2013	0.0013
54	1635 WEBSTER ST NW	Lead	7/25/2013	0.0013
55	1671 Rosedale St NE	Partial Lead	11/19/2013	0.0013
56	3636 13TH ST NW	Lead	10/24/2013	0.0013
57	1519 Olive St NE	Lead	7/24/2013	0.0014
58	1331 Irving St NE	Lead	7/24/2013	0.0015
59	2408 2nd St NE	Partial Lead	9/26/2013	0.0015
60	1353 JEFFERSON ST NW	Partial Lead	9/24/2013	0.0016
61	2435 33RD ST SE	Lead	7/24/2013	0.0016
62	3706 35th St NW	Lead	9/10/2013	0.0016
63	6308 8th St NW	Lead	9/25/2013	0.0016
64	1659 NEWTON ST NW	Lead	12/5/2013	0.0017
65	3218 MACOMB ST NW	Lead	8/21/2013	0.0017
66	5404 39TH ST NW	Partial Lead	10/25/2013	0.0017
67	228 V ST NE	Lead	7/23/2013	0.0018
68	910 Farragut St NW	Lead	10/23/2013	0.0018
69	420 Kenyon St NW	Partial Lead	11/20/2013	0.0019
70	2913 Brandywine St NW	Lead	7/23/2013	0.0020
71	531 Tennessee Ave NE	Lead	8/20/2013	0.0020
72	636 ROCK CRK CHURCH RD NW	Lead	9/25/2013	0.0020
73	1738 ALLISON ST NW	Lead	12/4/2013	0.0021
74	3301 BROWN St NW	Partial Lead	11/15/2013	0.0021
75	1428 VARNUM ST NW	Lead	12/3/2013	0.0022
76	1826 Jackson St NE	Lead	7/24/2013	0.0022
77	501 Webster St NW	Lead	8/19/2013	0.0022
78	1305 TAYLOR ST NW	Lead	12/4/2013	0.0023
79	309 11TH ST SE	Lead	7/23/2013	0.0023
80	336 Quackenbos St NE	Lead	8/21/2013	0.0023
81	124 16TH ST NE	Lead	12/5/2013	0.0024
82	1627 Gales St NE	Lead	8/21/2013	0.0026
83	2719 O ST NW	Lead	12/3/2013	0.0026
84	3030 44TH ST NW	Partial Lead	11/19/2013	0.0028
85	6001 33rd St NW	Lead	9/27/2013	0.0028
86	6209 30TH ST NW	Lead	8/20/2013	0.0028
87	3211 Central Ave NE	Lead	8/20/2013	0.0029

No	Address	Pipe Material	Collection Date	Lead 1 st Draw (mg/L)
88	5923 33rd St NW	Lead	9/25/2013	0.0029
89	913 Hamlin St NE	Lead	9/24/2013	0.0029
90	1378 Taylor St NW	Lead	7/23/2013	0.0031
91	1649 HARVARD ST NW	Lead	7/24/2013	0.0032
92	119 16TH ST NE	Lead	7/24/2013	0.0035
93	2832 BRENTWOOD RD NE	Lead	12/5/2013	0.0035
94	450 Newton Pl NW	Lead	7/24/2013	0.0035
95	1211 Carrollsburg Pl SW	Partial Lead	9/25/2013	0.0039
96	10 S St NW	Lead	7/24/2013	0.0041
97	1513 27TH ST NW	Lead	12/5/2013	0.0042
98	1705 D St NE	Lead	11/19/2013	0.0043
99	5234 Illinois Ave NW	Lead	9/11/2013	0.0047
100	3727 T St NW	Lead	8/21/2013	0.0050
101	807 Buchanan St NW	Lead	9/25/2013	0.0054
102	5301 RENO RD NW	Partial Lead	10/22/2013	0.0055
103	1346 F St NE	Lead	7/22/2013	0.0056
104	926 Hamilton St NW	Lead	9/24/2013	0.0059
105	5318 9TH ST NW	Lead	8/22/2013	0.0077
106	125 Madison St NW	Lead	7/23/2013	0.0081
107	4401 5TH ST NW	Lead	8/20/2013	0.0081
108	421 Hamilton St NW	Lead	11/19/2013	0.0102
109	5731 3rd Pl NW	Lead	8/21/2013	0.0127
110	223 14th Pl NE	Partial Lead	9/25/2013	0.0266
111	3907 13th St NW	Partial Lead	10/22/2013	0.0395
112	1505 Buchanan St NW	Lead	7/24/2013	0.0422
113	4703 Macarthur Blvd NW	Lead	8/20/2013	0.1031

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.0000" may have been reported by the laboratory as non-detect, <0.0005 mg/L, or less than 0.001 mg/L.

Table A.2 First Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
1	3706 35th St NW	Lead	9/10/2013	0.002
2	636 ROCK CRK CHURCH RD NW	Lead	9/25/2013	0.003
3	807 Buchanan St NW	Lead	9/25/2013	0.005
4	926 Hamilton St NW	Lead	9/24/2013	0.005
5	1519 Olive St NE	Lead	7/24/2013	0.007
6	4214 8th St NW	Lead	8/20/2013	0.008
7	124 16TH ST NE	Lead	12/5/2013	0.010
8	2913 Brandywine St NW	Lead	7/23/2013	0.010
9	5731 3rd Pl NW	Lead	8/21/2013	0.010
10	6213 7TH ST NW	Partial Lead	10/23/2013	0.010
11	2830 BRENTWOOD RD NE	Lead	7/23/2013	0.012
12	5003 7TH ST NW	Partial Lead	12/6/2013	0.012
13	531 Tennessee Ave NE	Lead	8/20/2013	0.012
14	420 Kenyon St NW	Partial Lead	11/20/2013	0.013
15	1331 Irving St NE	Lead	7/24/2013	0.014
16	3416 9th St NE	Partial Lead	10/22/2013	0.014
17	1378 Taylor St NW	Lead	7/23/2013	0.015
18	308 9th St SE	Partial Lead	10/21/2013	0.015
19	331 RALEIGH ST SE	Lead	8/21/2013	0.016
20	1011 Taylor St NE	Lead	7/24/2013	0.017
21	617 6th St NE	Lead	9/25/2013	0.017
22	1635 WEBSTER ST NW	Lead	7/25/2013	0.018
23	6001 33rd St NW	Lead	9/27/2013	0.018
24	1659 NEWTON ST NW	Lead	12/5/2013	0.019
25	3710 Huntington St NW	Lead	8/21/2013	0.019
26	913 Hamlin St NE	Lead	9/24/2013	0.020
27	6105 Dix St NE	Lead	9/26/2013	0.021
28	910 Farragut St NW	Lead	10/23/2013	0.021
29	1826 Jackson St NE	Lead	7/24/2013	0.022
30	53 P St NW	Partial Lead	10/24/2013	0.022
31	1305 TAYLOR ST NW	Lead	12/4/2013	0.024
32	1319 POTOMAC AVE SE	Partial Lead	9/25/2013	0.024
33	1706 NEW JERSEY AVE NW	Lead	7/23/2013	0.024
34	336 Quackenbos St NE	Lead	8/21/2013	0.024
35	450 Newton Pl NW	Lead	7/24/2013	0.024
36	10 S St NW	Lead	7/24/2013	0.025
37	1222 HAMILTON ST NW	Partial Lead	10/22/2013	0.026
38	1346 F St NE	Lead	7/22/2013	0.026
39	125 Madison St NW	Lead	7/23/2013	0.027
40	5234 Illinois Ave NW	Lead	9/11/2013	0.027
41	1262 COLUMBIA RD NW	Lead	7/24/2013	0.028
42	561 23RD PL NE	Lead	12/4/2013	0.028
43	6209 30TH ST NW	Lead	8/20/2013	0.028
44	2923 Cathedral AVE NW	Lead	7/24/2013	0.029

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
45	307 7th St NE	Lead	7/23/2013	0.030
46	449 S St NW	Lead	8/20/2013	0.031
47	4926 Glenbrook Rd NW	Lead	8/22/2013	0.032
48	5404 39TH ST NW	Partial Lead	10/25/2013	0.033
49	1649 HARVARD ST NW	Lead	7/24/2013	0.034
50	1705 D St NE	Lead	11/19/2013	0.034
51	3030 44TH ST NW	Partial Lead	11/19/2013	0.034
52	309 11TH ST SE	Lead	7/23/2013	0.034
53	333 34th St NE	Partial Lead	10/22/2013	0.036
54	1420 Hamlin St NE	Partial Lead	9/25/2013	0.037
55	4215 39th St NW	Partial Lead	10/22/2013	0.037
56	1353 JEFFERSON ST NW	Partial Lead	9/24/2013	0.038
57	4447 HAWTHORNE ST NW	Lead	12/4/2013	0.038
58	53 V St NW	Partial Lead	10/24/2013	0.039
59	1627 Gales St NE	Lead	8/21/2013	0.040
60	621 Upshur St NW	Lead	10/23/2013	0.040
61	1424 S ST NW	Lead	8/8/2013	0.041
62	2435 33RD ST SE	Lead	7/24/2013	0.041
63	3636 13TH ST NW	Lead	10/24/2013	0.041
64	6308 8th St NW	Lead	9/25/2013	0.041
65	1513 27TH ST NW	Lead	12/5/2013	0.042
66	228 V ST NE	Lead	7/23/2013	0.042
67	4332 BRANDYWINE ST NW	Partial Lead	10/23/2013	0.042
68	1428 VARNUM ST NW	Lead	12/3/2013	0.043
69	1412 S St NW	Partial Lead	10/1/2013	0.047
70	3036 P St NW	Partial Lead	10/29/2013	0.048
71	1375 MONROE ST NW	Lead	12/5/2013	0.049
72	3301 BROWN St NW	Partial Lead	11/15/2013	0.049
73	3913 8TH ST NW	Partial Lead	10/22/2013	0.049
74	1003 Otis St NE	Lead	7/24/2013	0.050
75	4818 8th ST NW	Partial Lead	10/22/2013	0.051
76	1620 Webster St NW	Lead	7/24/2013	0.054
77	1613 Webster St NW	Lead	7/24/2013	0.055
78	1671 Rosedale St NE	Partial Lead	11/19/2013	0.055
79	119 16TH ST NE	Lead	7/24/2013	0.060
80	2408 2nd St NE	Partial Lead	9/26/2013	0.060
81	123 TENNESSEE AVE NE	Lead	12/6/2013	0.063
82	1738 ALLISON ST NW	Lead	12/4/2013	0.063
83	2832 BRENTWOOD RD NE	Lead	12/5/2013	0.063
84	1850 2ND ST NW	Partial Lead	11/19/2013	0.064
85	317 9th St SE	Partial Lead	7/24/2013	0.064
86	5301 RENO RD NW	Partial Lead	10/22/2013	0.064
87	1003 Quebec Pl NW	Lead	7/25/2013	0.065
88	3722 MCKINLEY ST NW	Partial Lead	12/5/2013	0.065
89	75 Bates St NW	Lead	9/24/2013	0.066
90	15 Milmarson Pl NW	Lead	7/24/2013	0.067

No	Address	Pipe Material	Collection Date	Copper 1 st Draw (mg/L)
91	3202 38TH ST NW	Partial Lead	10/22/2013	0.067
92	1310 R ST NW	Lead	12/4/2013	0.068
93	3727 T St NW	Lead	8/21/2013	0.069
94	5318 9TH ST NW	Lead	8/22/2013	0.070
95	223 14th Pl NE	Partial Lead	9/25/2013	0.072
96	3211 Central Ave NE	Lead	8/20/2013	0.074
97	2007 37TH ST NW	Lead	7/29/2013	0.080
98	2719 O ST NW	Lead	12/3/2013	0.082
99	1211 Carrollsburg Pl SW	Partial Lead	9/25/2013	0.089
100	3724 CHESAPEAKE ST NW	Lead	12/5/2013	0.092
101	1505 Buchanan St NW	Lead	7/24/2013	0.100
102	4401 5TH ST NW	Lead	8/20/2013	0.101
103	619 12th St NE	Lead	9/25/2013	0.110
104	3218 MACOMB ST NW	Lead	8/21/2013	0.116
105	3907 13th St NW	Partial Lead	10/22/2013	0.118
106	4806 Kansas Ave NW	Lead	11/19/2013	0.125
107	1436 S St NW	Partial Lead	7/25/2013	0.132
108	421 Hamilton St NW	Lead	11/19/2013	0.137
109	5923 33rd St NW	Lead	9/25/2013	0.144
110	4703 Macarthur Blvd NW	Lead	8/20/2013	0.147
111	501 Webster St NW	Lead	8/19/2013	0.157
112	1529 UPSHUR ST NW	Lead	12/6/2013	0.162
113	36 Florida Ave NW	Partial Lead	8/20/2013	0.205

Notes:

- 1) All addresses meet Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.
- 2) Service line material listings are representative of the pipe material known at the time the sample was collected.
- 3) Results expressed as "0.000" may have been reported by the laboratory as non-detect or < 0.001 mg/L.

Appendix B: Additional Monitoring Data

Tables B.1 and B.2 present results from the second draw samples collected at the time of the Lead and Copper Rule compliance sampling. Additional monitoring data presented in Attachment 2 to this report contains sample data collected from other DC Water programs that focused on lead, copper, or other metals that included lead sample results. A description of the program followed by the data set is included in Attachment 2.

Table B.1 Second Draw Lead Results

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
1	123 TENNESSEE AVE NE	Lead	12/6/2013	0.0000
2	1262 COLUMBIA RD NW	Lead	7/24/2013	0.0000
3	1310 R ST NW	Lead	12/4/2013	0.0000
4	1375 MONROE ST NW	Lead	12/5/2013	0.0000
5	1436 S St NW	Partial Lead	7/25/2013	0.0000
6	15 Milmarson Pl NW	Lead	7/24/2013	0.0000
7	1529 UPSHUR ST NW	Lead	12/6/2013	0.0000
8	1613 Webster St NW	Lead	7/24/2013	0.0000
9	1706 NEW JERSEY AVE NW	Lead	7/23/2013	0.0000
10	2923 Cathedral AVE NW	Lead	7/24/2013	0.0000
11	3036 P St NW	Partial Lead	10/29/2013	0.0000
12	307 7th St NE	Lead	7/23/2013	0.0000
13	309 11TH ST SE	Lead	7/23/2013	0.0000
14	317 9th St SE	Partial Lead	7/24/2013	0.0000
15	333 34th St NE	Partial Lead	10/22/2013	0.0000
16	336 Quackenbos St NE	Lead	8/21/2013	0.0000
17	3416 9th St NE	Partial Lead	10/22/2013	0.0000
18	36 Florida Ave NW	Partial Lead	8/20/2013	0.0000
19	3722 MCKINLEY ST NW	Partial Lead	12/5/2013	0.0000
20	3724 CHESAPEAKE ST NW	Lead	12/5/2013	0.0000
21	4447 HAWTHORNE ST NW	Lead	12/4/2013	0.0000
22	449 S St NW	Lead	8/20/2013	0.0000
23	4926 Glenbrook Rd NW	Lead	8/22/2013	0.0000
24	5003 7TH ST NW	Partial Lead	12/6/2013	0.0000
25	53 P St NW	Partial Lead	10/24/2013	0.0000
26	6105 Dix St NE	Lead	9/26/2013	0.0000
27	619 12th St NE	Lead	9/25/2013	0.0000
28	621 Upshur St NW	Lead	10/23/2013	0.0000
29	75 Bates St NW	Lead	9/24/2013	0.0000
30	1635 WEBSTER ST NW	Lead	7/25/2013	0.0005
31	4332 BRANDYWINE ST NW	Partial Lead	10/23/2013	0.0005
32	1412 S St NW	Partial Lead	10/1/2013	0.0006

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
33	2007 37TH ST NW	Lead	7/29/2013	0.0006
34	2830 BRENTWOOD RD NE	Lead	7/23/2013	0.0006
35	6213 7TH ST NW	Partial Lead	10/23/2013	0.0006
36	1319 POTOMAC AVE SE	Partial Lead	9/25/2013	0.0007
37	1671 Rosedale St NE	Partial Lead	11/19/2013	0.0007
38	2435 33RD ST SE	Lead	7/24/2013	0.0008
39	3202 38TH ST NW	Partial Lead	10/22/2013	0.0008
40	3913 8TH ST NW	Partial Lead	10/22/2013	0.0008
41	5301 RENO RD NW	Partial Lead	10/22/2013	0.0008
42	1003 Otis St NE	Lead	7/24/2013	0.0009
43	2408 2nd St NE	Partial Lead	9/26/2013	0.0009
44	1627 Gales St NE	Lead	8/21/2013	0.0010
45	308 9th St SE	Partial Lead	10/21/2013	0.0010
46	4806 Kansas Ave NW	Lead	11/19/2013	0.0010
47	617 6th St NE	Lead	9/25/2013	0.0010
48	1003 Quebec Pl NW	Lead	7/25/2013	0.0012
49	1222 HAMILTON ST NW	Partial Lead	10/22/2013	0.0012
50	1331 Irving St NE	Lead	7/24/2013	0.0012
51	4818 8th ST NW	Partial Lead	10/22/2013	0.0012
52	4214 8th St NW	Lead	8/20/2013	0.0013
53	1011 Taylor St NE	Lead	7/24/2013	0.0014
54	1738 ALLISON ST NW	Lead	12/4/2013	0.0014
55	2832 BRENTWOOD RD NE	Lead	12/5/2013	0.0014
56	3030 44TH ST NW	Partial Lead	11/19/2013	0.0014
57	420 Kenyon St NW	Partial Lead	11/20/2013	0.0014
58	4215 39th St NW	Partial Lead	10/22/2013	0.0014
59	1420 Hamlin St NE	Partial Lead	9/25/2013	0.0015
60	1519 Olive St NE	Lead	7/24/2013	0.0016
61	3211 Central Ave NE	Lead	8/20/2013	0.0017
62	421 Hamilton St NW	Lead	11/19/2013	0.0017
63	3706 35th St NW	Lead	9/10/2013	0.0018
64	5923 33rd St NW	Lead	9/25/2013	0.0018
65	53 V St NW	Partial Lead	10/24/2013	0.0019
66	531 Tennessee Ave NE	Lead	8/20/2013	0.0020
67	1620 Webster St NW	Lead	7/24/2013	0.0021
68	3218 MACOMB ST NW	Lead	8/21/2013	0.0021
69	1428 VARNUM ST NW	Lead	12/3/2013	0.0022
70	119 16TH ST NE	Lead	7/24/2013	0.0024
71	5404 39TH ST NW	Partial Lead	10/25/2013	0.0024
72	6209 30TH ST NW	Lead	8/20/2013	0.0024
73	636 ROCK CRK CHURCH RD NW	Lead	9/25/2013	0.0025
74	1659 NEWTON ST NW	Lead	12/5/2013	0.0026
75	1353 JEFFERSON ST NW	Partial Lead	9/24/2013	0.0026
76	331 RALEIGH ST SE	Lead	8/21/2013	0.0026
77	2913 Brandywine St NW	Lead	7/23/2013	0.0027
78	1826 Jackson St NE	Lead	7/24/2013	0.0028

No	Address	Pipe Material	Collection Date	Lead 2 nd Draw (mg/L)
79	1850 2ND ST NW	Partial Lead	11/19/2013	0.0028
80	1649 HARVARD ST NW	Lead	7/24/2013	0.0029
81	1424 S ST NW	Lead	8/8/2013	0.0032
82	913 Hamlin St NE	Lead	9/24/2013	0.0032
83	5318 9TH ST NW	Lead	8/22/2013	0.0033
84	1305 TAYLOR ST NW	Lead	12/4/2013	0.0034
85	4401 5TH ST NW	Lead	8/20/2013	0.0034
86	6001 33rd St NW	Lead	9/27/2013	0.0034
87	5234 Illinois Ave NW	Lead	9/11/2013	0.0035
88	910 Farragut St NW	Lead	10/23/2013	0.0037
89	10 S St NW	Lead	7/24/2013	0.0038
90	1513 27TH ST NW	Lead	12/5/2013	0.0046
91	3301 BROWN St NW	Partial Lead	11/15/2013	0.0047
92	4703 Macarthur Blvd NW	Lead	8/20/2013	0.0052
93	3710 Huntington St NW	Lead	8/21/2013	0.0058
94	124 16TH ST NE	Lead	12/5/2013	0.0066
95	450 Newton Pl NW	Lead	7/24/2013	0.0072
96	6308 8th St NW	Lead	9/25/2013	0.0080
97	3727 T St NW	Lead	8/21/2013	0.0088
98	1378 Taylor St NW	Lead	7/23/2013	0.0091
99	3636 13TH ST NW	Lead	10/24/2013	0.0096
100	1705 D St NE	Lead	11/19/2013	0.0103
101	2719 O ST NW	Lead	12/3/2013	0.0103
102	1346 F St NE	Lead	7/22/2013	0.0105
103	223 14th Pl NE	Partial Lead	9/25/2013	0.0115
104	1211 Carrollsburg Pl SW	Partial Lead	9/25/2013	0.0123
105	228 V ST NE	Lead	7/23/2013	0.0138
106	1505 Buchanan St NW	Lead	7/24/2013	0.0140
107	125 Madison St NW	Lead	7/23/2013	0.0160
108	807 Buchanan St NW	Lead	9/25/2013	0.0201
109	5731 3rd Pl NW	Lead	8/21/2013	0.1550
110	3907 13th St NW	Partial Lead	10/22/2013	0.1610

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) Results expressed as “0.0000” may have been reported by the laboratory as non-detect or < 0.0005 mg/L.
- 3) The second draw samples were rejected from 501 Webster NW, 561 23rd Pl NW, and 926 Hamilton St NW because they did not follow the sampling criteria for collecting the second draw sample as described in the instructions.

Table B.2 Second Draw Copper Results

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
1	3706 35th St NW	Lead	9/10/2013	0.002
2	636 ROCK CRK CHURCH RD NW	Lead	9/25/2013	0.003
3	4214 8th St NW	Lead	8/20/2013	0.004
4	6001 33rd St NW	Lead	9/27/2013	0.004
5	2913 Brandywine St NW	Lead	7/23/2013	0.005
6	1378 Taylor St NW	Lead	7/23/2013	0.006
7	2435 33RD ST SE	Lead	7/24/2013	0.006
8	1519 Olive St NE	Lead	7/24/2013	0.007
9	1620 Webster St NW	Lead	7/24/2013	0.007
10	331 RALEIGH ST SE	Lead	8/21/2013	0.007
11	807 Buchanan St NW	Lead	9/25/2013	0.007
12	910 Farragut St NW	Lead	10/23/2013	0.007
13	3710 Huntington St NW	Lead	8/21/2013	0.008
14	1706 NEW JERSEY AVE NW	Lead	7/23/2013	0.008
15	6105 Dix St NE	Lead	9/26/2013	0.008
16	1627 Gales St NE	Lead	8/21/2013	0.009
17	3036 P St NW	Partial Lead	10/29/2013	0.009
18	421 Hamilton St NW	Lead	11/19/2013	0.009
19	6213 7TH ST NW	Partial Lead	10/23/2013	0.009
20	6308 8th St NW	Lead	9/25/2013	0.009
21	119 16TH ST NE	Lead	7/24/2013	0.010
22	124 16TH ST NE	Lead	12/5/2013	0.010
23	3211 Central Ave NE	Lead	8/20/2013	0.010
24	3727 T St NW	Lead	8/21/2013	0.010
25	5003 7TH ST NW	Partial Lead	12/6/2013	0.010
26	6209 30TH ST NW	Lead	8/20/2013	0.010
27	4215 39th St NW	Partial Lead	10/22/2013	0.011
28	1346 F St NE	Lead	7/22/2013	0.012
29	1420 Hamlin St NE	Partial Lead	9/25/2013	0.012
30	336 Quackenbos St NE	Lead	8/21/2013	0.012
31	450 Newton Pl NW	Lead	7/24/2013	0.012
32	5301 RENO RD NW	Partial Lead	10/22/2013	0.012
33	531 Tennessee Ave NE	Lead	8/20/2013	0.012
34	1222 HAMILTON ST NW	Partial Lead	10/22/2013	0.013
35	1659 NEWTON ST NW	Lead	12/5/2013	0.013
36	1826 Jackson St NE	Lead	7/24/2013	0.013
37	2719 O ST NW	Lead	12/3/2013	0.013
38	2832 BRENTWOOD RD NE	Lead	12/5/2013	0.013
39	4332 BRANDYWINE ST NW	Partial Lead	10/23/2013	0.013
40	75 Bates St NW	Lead	9/24/2013	0.013
41	1305 TAYLOR ST NW	Lead	12/4/2013	0.014
42	1319 POTOMAC AVE SE	Partial Lead	9/25/2013	0.014
43	1375 MONROE ST NW	Lead	12/5/2013	0.014
44	1613 Webster St NW	Lead	7/24/2013	0.014

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
45	228 V ST NE	Lead	7/23/2013	0.014
46	617 6th St NE	Lead	9/25/2013	0.014
47	4703 Macarthur Blvd NW	Lead	8/20/2013	0.014
48	125 Madison St NW	Lead	7/23/2013	0.015
49	1424 S ST NW	Lead	8/8/2013	0.015
50	1505 Buchanan St NW	Lead	7/24/2013	0.015
51	1635 WEBSTER ST NW	Lead	7/25/2013	0.015
52	307 7th St NE	Lead	7/23/2013	0.015
53	3416 9th St NE	Partial Lead	10/22/2013	0.015
54	5731 3rd Pl NW	Lead	8/21/2013	0.015
55	2007 37TH ST NW	Lead	7/29/2013	0.016
56	2923 Cathedral AVE NW	Lead	7/24/2013	0.017
57	5318 9TH ST NW	Lead	8/22/2013	0.017
58	621 Upshur St NW	Lead	10/23/2013	0.017
59	2830 BRENTWOOD RD NE	Lead	7/23/2013	0.018
60	308 9th St SE	Partial Lead	10/21/2013	0.018
61	309 11TH ST SE	Lead	7/23/2013	0.018
62	913 Hamlin St NE	Lead	9/24/2013	0.018
63	123 TENNESSEE AVE NE	Lead	12/6/2013	0.019
64	1649 HARVARD ST NW	Lead	7/24/2013	0.019
65	10 S St NW	Lead	7/24/2013	0.020
66	1331 Irving St NE	Lead	7/24/2013	0.020
67	1850 2ND ST NW	Partial Lead	11/19/2013	0.020
68	317 9th St SE	Partial Lead	7/24/2013	0.020
69	3636 13TH ST NW	Lead	10/24/2013	0.020
70	1705 D St NE	Lead	11/19/2013	0.021
71	3301 BROWN St NW	Partial Lead	11/15/2013	0.021
72	5234 Illinois Ave NW	Lead	9/11/2013	0.021
73	53 P St NW	Partial Lead	10/24/2013	0.022
74	619 12th St NE	Lead	9/25/2013	0.022
75	53 V St NW	Partial Lead	10/24/2013	0.023
76	420 Kenyon St NW	Partial Lead	11/20/2013	0.024
77	4818 8th ST NW	Partial Lead	10/22/2013	0.024
78	449 S St NW	Lead	8/20/2013	0.025
79	333 34th St NE	Partial Lead	10/22/2013	0.026
80	1011 Taylor St NE	Lead	7/24/2013	0.027
81	1310 R ST NW	Lead	12/4/2013	0.028
82	1353 JEFFERSON ST NW	Partial Lead	9/24/2013	0.029
83	3722 MCKINLEY ST NW	Partial Lead	12/5/2013	0.029
84	4401 5TH ST NW	Lead	8/20/2013	0.031
85	1262 COLUMBIA RD NW	Lead	7/24/2013	0.032
86	15 Milmarson Pl NW	Lead	7/24/2013	0.032
87	4447 HAWTHORNE ST NW	Lead	12/4/2013	0.033
88	1003 Quebec Pl NW	Lead	7/25/2013	0.036
89	1513 27TH ST NW	Lead	12/5/2013	0.036
90	1671 Rosedale St NE	Partial Lead	11/19/2013	0.038

No	Address	Pipe Material	Collection Date	Copper 2nd Draw (mg/L)
91	3913 8TH ST NW	Partial Lead	10/22/2013	0.038
92	223 14th PI NE	Partial Lead	9/25/2013	0.039
93	4926 Glenbrook Rd NW	Lead	8/22/2013	0.039
94	1003 Otis St NE	Lead	7/24/2013	0.040
95	1738 ALLISON ST NW	Lead	12/4/2013	0.040
96	3202 38TH ST NW	Partial Lead	10/22/2013	0.041
97	36 Florida Ave NW	Partial Lead	8/20/2013	0.041
98	1529 UPSHUR ST NW	Lead	12/6/2013	0.042
99	1428 VARNUM ST NW	Lead	12/3/2013	0.046
100	1436 S St NW	Partial Lead	7/25/2013	0.050
101	5404 39TH ST NW	Partial Lead	10/25/2013	0.050
102	1211 Carrollsburg PI SW	Partial Lead	9/25/2013	0.053
103	3030 44TH ST NW	Partial Lead	11/19/2013	0.054
104	1412 S St NW	Partial Lead	10/1/2013	0.059
105	3724 CHESAPEAKE ST NW	Lead	12/5/2013	0.059
106	3218 MACOMB ST NW	Lead	8/21/2013	0.086
107	3907 13th St NW	Partial Lead	10/22/2013	0.087
108	5923 33rd St NW	Lead	9/25/2013	0.091
109	2408 2nd St NE	Partial Lead	9/26/2013	0.106
110	4806 Kansas Ave NW	Lead	11/19/2013	0.128

Notes:

- 1) Service line material listings are representative of the pipe material at the time the sample was collected.
- 2) The second draw samples were rejected from 501 Webster NW, 561 23rd PI NW, and 926 Hamilton St NW because they did not follow the sampling criteria for collecting the second draw sample as described in the instructions.
- 3) Results expressed as "0.000" may have been reported by the laboratory as non-detect or < 0.001 mg/L.

Appendix C – Additional Sampling Information

Table C.1 Sample Kit Distribution

No	Address	Bottle Drop Date
1	10 S St NW	7/22/2013
2	1003 Otis St NE	7/22/2013
3	1003 Quebec Pl NW	7/22/2013
4	1010 10th St NE	7/22/2013
5	1011 Taylor St NE	7/22/2013
6	1025 44th St NE	7/22/2013
7	108 Varnum St NW	7/22/2013
8	109 19th St SE	7/22/2013
9	1106 Allison St NW	7/22/2013
10	119 16TH ST NE	7/22/2013
11	125 Madison St NW	7/22/2013
12	1262 COLUMBIA RD NW	7/22/2013
13	1315 FRANKLIN ST NE	7/22/2013
14	1318 Wallach Pl NW	7/22/2013
15	1331 Irving St NE	7/22/2013
16	1339 U St SE	7/22/2013
17	1346 F St NE	7/22/2013
18	1357 C St NE	7/22/2013
19	1378 Taylor St NW	7/22/2013
20	1424 S ST NW	7/22/2013
21	1429 Ives Pl SE	7/22/2013
22	1434 Taylor St NW	7/22/2013
23	1436 S St NW	7/22/2013
24	1453 S St NW	7/22/2013
25	15 Milmarson Pl NW	7/22/2013
26	1505 Buchanan St NW	7/22/2013
27	1519 Olive St NE	7/22/2013
28	1520 Locust Rd NW	7/22/2013
29	1613 Webster St NW	7/22/2013
30	1620 Hamlin St NE	7/22/2013
31	1620 Webster St NW	7/22/2013
32	1623 U St SE	7/22/2013
33	1635 WEBSTER ST NW	7/22/2013
34	1649 HARVARD ST NW	7/22/2013
35	1703 D St NE	7/22/2013
36	1706 NEW JERSEY AVE NW	7/22/2013
37	1826 Jackson St NE	7/22/2013
38	2007 37TH ST NW	7/22/2013
39	2107 2nd St NE	7/22/2013
40	213 49th St NE	7/22/2013
41	2212 38th St NW	7/22/2013
42	228 V ST NE	7/22/2013

No	Address	Bottle Drop Date
43	24 Evarts St NE	7/22/2013
44	2435 33RD ST SE	7/22/2013
45	2649 Bowen Rd SE	7/22/2013
46	2830 BRENTWOOD RD NE	7/22/2013
47	2913 Brandywine St NW	7/22/2013
48	2923 Cathedral AVE NW	7/22/2013
49	307 7th St NE	7/22/2013
50	309 11TH ST SE	7/22/2013
51	317 9th St SE	7/22/2013
52	450 Newton Pl NW	7/22/2013
53	1627 Gales St NE	8/19/2013
54	3206 38th St NW	8/19/2013
55	3211 Central Ave NE	8/19/2013
56	3216 Klinge Rd NW	8/19/2013
57	3218 MACOMB ST NW	8/19/2013
58	3218 MORRISON ST NW	8/19/2013
59	322 TENNESSEE AVE NE	8/19/2013
60	331 RALEIGH ST SE	8/19/2013
61	331 Upshur St NW	8/19/2013
62	336 Quackenbos St NE	8/19/2013
63	3361 Stuyvesant Pl NW	8/19/2013
64	3400 Holmead Pl NW	8/19/2013
65	3511 Woodley Rd NW	8/19/2013
66	3533 W Pl NW	8/19/2013
67	36 Florida Ave NW	8/19/2013
68	3601 WARREN ST NW	8/19/2013
69	3625 Albermarle St NW	8/19/2013
70	3706 35th St NW	8/19/2013
71	3710 Huntington St NW	8/19/2013
72	3727 T St NW	8/19/2013
73	3908 13TH ST NW	8/19/2013
74	4111 INGOMAR ST NW	8/19/2013
75	4118 13TH ST NW	8/19/2013
76	4120 Grant St NE	8/19/2013
77	4131 YUMA ST NW	8/19/2013
78	4214 8th St NW	8/19/2013
79	424 Luray Pl NW	8/19/2013
80	4307 CHESAPEAKE ST NW	8/19/2013
81	4310 37th St NW	8/19/2013
82	4401 5TH ST NW	8/19/2013
83	4409 Lowell St NW	8/19/2013
84	4411 15th St NW	8/19/2013
85	4418 14th St NE	8/19/2013
86	449 S St NW	8/19/2013
87	4550 30TH ST NW	8/19/2013
88	4613 9th St NW	8/19/2013

No	Address	Bottle Drop Date
89	4627 49th St NW	8/19/2013
90	4703 Macarthur Blvd NW	8/19/2013
91	4818 ILLINOIS AVE NW	8/19/2013
92	4926 Glenbrook Rd NW	8/19/2013
93	501 Webster St NW	8/19/2013
94	5024 7th St NW	8/19/2013
95	5226 7th St NW	8/19/2013
96	5234 Illinois Ave NW	8/19/2013
97	524 10th St SE	8/19/2013
98	531 Tennessee Ave NE	8/19/2013
99	5318 9TH ST NW	8/19/2013
100	5517 7th St NW	8/19/2013
101	5613 30th St NW	8/19/2013
102	5731 3rd PI NW	8/19/2013
103	6209 30TH ST NW	8/19/2013
104	1203 Quincy St NW	9/23/2013
105	1211 Carrollsburg PI SW	9/23/2013
106	1222 HAMILTON ST NW	9/23/2013
107	1319 POTOMAC AVE SE	9/23/2013
108	1353 JEFFERSON ST NW	9/23/2013
109	1387 N Carolina Ave NE	9/23/2013
110	1412 S St NW	9/23/2013
111	1412 Shepherd St NW	9/23/2013
112	1420 Hamlin St NE	9/23/2013
113	1603 Massachusetts Ave SE	9/23/2013
114	1731 L St NE	9/23/2013
115	1736 Bay St SE	9/23/2013
116	1808 KEARNEY ST NE	9/23/2013
117	1836 L St NE	9/23/2013
118	1843 MONROE ST NW	9/23/2013
119	1908 Biltmore St NW	9/23/2013
120	2118 14th St SE	9/23/2013
121	223 14th PI NE	9/23/2013
122	230 G St NE	9/23/2013
123	231 K St NE	9/23/2013
124	234 Longfellow St NW	9/23/2013
125	2408 2nd St NE	9/23/2013
126	580 49th PI NE	9/23/2013
127	5817 7th St NW	9/23/2013
128	5923 33rd St NW	9/23/2013
129	6001 33rd St NW	9/23/2013
130	608 Gallatin St NW	9/23/2013
131	6105 Dix St NE	9/23/2013
132	611 Roxboro PI NW	9/23/2013
133	617 6th St NE	9/23/2013
134	619 12th St NE	9/23/2013

No	Address	Bottle Drop Date
135	619 Girard St NE	9/23/2013
136	6210 8th St NW	9/23/2013
137	6308 8th St NW	9/23/2013
138	636 ROCK CRK CHURCH RD NW	9/23/2013
139	641 Gallatin St NW	9/23/2013
140	644 Lamont St NW	9/23/2013
141	702 9th St SE	9/23/2013
142	743 Gresham Pl NW	9/23/2013
143	75 Bates St NW	9/23/2013
144	753 Gresham Pl NW	9/23/2013
145	8 N St SW	9/23/2013
146	804 Delafield Pl NW	9/23/2013
147	807 Buchanan St NW	9/23/2013
148	834 Delafield Pl NW	9/23/2013
149	87 S St NW	9/23/2013
150	905 Kent Pl NE	9/23/2013
151	912 Emerson St NW	9/23/2013
152	913 Hamlin St NE	9/23/2013
153	926 Hamilton St NW	9/23/2013
154	1014 Douglas St NE	10/21/2013
155	1207 Trinidad Ave NE	10/21/2013
156	1212 E Capitol St NE	10/21/2013
157	1214 Evarts St NE	10/21/2013
158	1222 HAMILTON ST NW	10/21/2013
159	1238 HALF ST SW	10/21/2013
160	1346 Madison St NW	10/21/2013
161	143 UHLAND TER NE	10/21/2013
162	1705 2nd St NE	10/21/2013
163	302 RITTENHOUSE ST NW	10/21/2013
164	3036 P St NW	10/21/2013
165	308 9th St SE	10/21/2013
166	32 Todd Pl NE	10/21/2013
167	3202 38TH ST NW	10/21/2013
168	3215 Mckinley St NW	10/21/2013
169	3232 Klinge Rd NW	10/21/2013
170	3301 BROWN St NW	10/21/2013
171	333 34th St NE	10/21/2013
172	335 17TH PL NE	10/21/2013
173	3416 9th St NE	10/21/2013
174	3531 16TH ST NW	10/21/2013
175	3612 34th St NW	10/21/2013
176	3636 13TH ST NW	10/21/2013
177	3809 ALTON PL NW	10/21/2013
178	3907 13th St NW	10/21/2013
179	3913 8TH ST NW	10/21/2013
180	3917 8th St NW	10/21/2013

No	Address	Bottle Drop Date
181	413 4th St SE	10/21/2013
182	416 7th St NE	10/21/2013
183	4215 39th St NW	10/21/2013
184	4327 IOWA AVE NW	10/21/2013
185	4332 BRANDYWINE ST NW	10/21/2013
186	4616 HUNT PL NE	10/21/2013
187	4818 8th ST NW	10/21/2013
188	53 P St NW	10/21/2013
189	53 V St NW	10/21/2013
190	5301 RENO RD NW	10/21/2013
191	5316 28th St NW	10/21/2013
192	5404 39TH ST NW	10/21/2013
193	5907 4th St NW	10/21/2013
194	605 Columbia Rd NW	10/21/2013
195	605 ROCK CRK CHURCH RD NW	10/21/2013
196	617 M St NE	10/21/2013
197	621 Upshur St NW	10/21/2013
198	6213 7TH ST NW	10/21/2013
199	720 ALABAMA AVE SE	10/21/2013
200	7721 14th St NW	10/21/2013
201	780 Fairmont St NW	10/21/2013
202	822 K St NE	10/21/2013
203	910 Farragut St NW	10/21/2013
204	915 Farragut St NW	10/21/2013
205	915 Shepherd St NW	10/21/2013
206	1353 Iris St NW	11/18/2013
207	1424 S ST SE	11/18/2013
208	1614 V St SE	11/18/2013
209	1619 G St SE	11/18/2013
210	1671 Rosedale St NE	11/18/2013
211	1705 D St NE	11/18/2013
212	1802 35TH ST NW	11/18/2013
213	1802 Kilbourne Pl NW	11/18/2013
214	1850 2ND ST NW	11/18/2013
215	1931 SUMMIT PL NE	11/18/2013
216	201 13th St NE	11/18/2013
217	205 TAYLOR ST NW	11/18/2013
218	2220 13th St SE	11/18/2013
219	228 Randolph Pl NE	11/18/2013
220	2305 Minnesota Ave SE	11/18/2013
221	2823 28TH ST NW	11/18/2013
222	2928 33rd Pl NW	11/18/2013
223	3030 44TH ST NW	11/18/2013
224	3105 34th St NW	11/18/2013
225	312 14TH ST NE	11/18/2013
226	313 16th St SE	11/18/2013

No	Address	Bottle Drop Date
227	3428 Brown St NW	11/18/2013
228	3721 Windom Pl NW	11/18/2013
229	42 Q St NE	11/18/2013
230	420 Kenyon St NW	11/18/2013
231	421 Hamilton St NW	11/18/2013
232	441 Quincy St NW	11/18/2013
233	4806 Kansas Ave NW	11/18/2013
234	506 Irving St NW	11/18/2013
235	513 Florida Ave NE	11/18/2013
236	514 13th St SE	11/18/2013
237	522 Park Rd NW	11/18/2013
238	5304 Reno Rd NW	11/18/2013
239	617 Kenyon St NW	11/18/2013
240	661 MARYLAND AVE NE	11/18/2013
241	736 Fairmont St NW	11/18/2013
242	75 P St NW	11/18/2013
243	765 GIRARD ST NW	11/18/2013
244	817 DECATUR ST NW	11/18/2013
245	833 DECATUR ST NW	11/18/2013
246	924 Hamilton St NW	11/18/2013
247	1120 ABBEY PL NE	12/3/2013
248	1124 F ST NE	12/3/2013
249	12 14TH ST SE	12/3/2013
250	123 TENNESSEE AVE NE	12/3/2013
251	124 12TH ST NE	12/3/2013
252	124 16TH ST NE	12/3/2013
253	1246 E ST NE	12/3/2013
254	1305 TAYLOR ST NW	12/3/2013
255	1310 R ST NW	12/3/2013
256	1330 VALLEY PL SE	12/3/2013
257	137 TENNESSEE AVE NE	12/3/2013
258	1375 MONROE ST NW	12/3/2013
259	139 11TH ST NE	12/3/2013
260	1428 VARNUM ST NW	12/3/2013
261	1513 27TH ST NW	12/3/2013
262	1529 UPSHUR ST NW	12/3/2013
263	1546 NEW JERSEY AVE NW	12/3/2013
264	1600 GIRARD ST NE	12/3/2013
265	1603 30TH ST NW	12/3/2013
266	1643 KRAMER ST NE	12/3/2013
267	1659 NEWTON ST NW	12/3/2013
268	1710 22ND ST SE	12/3/2013
269	1738 ALLISON ST NW	12/3/2013
270	1804 WYOMING AVE NW	12/3/2013
271	1831 LAMONT ST NW	12/3/2013
272	2719 O ST NW	12/3/2013

No	Address	Bottle Drop Date
273	2832 BRENTWOOD RD NE	12/3/2013
274	2904 P ST SE	12/3/2013
275	309 K ST NE	12/3/2013
276	325 G ST NE	12/3/2013
277	3619 11TH ST NW	12/3/2013
278	3722 MCKINLEY ST NW	12/3/2013
279	3724 CHESAPEAKE ST NW	12/3/2013
280	4114 FESSENDEN ST NW	12/3/2013
281	4447 HAWTHORNE ST NW	12/3/2013
282	4512 13TH ST NW	12/3/2013
283	4719 9TH ST NW	12/3/2013
284	4722 15TH ST NW	12/3/2013
285	5003 7TH ST NW	12/3/2013
286	5312 ILLINOIS AVE NW	12/3/2013
287	561 23RD PL NE	12/3/2013
288	5812 7TH ST NW	12/3/2013
289	609 49TH PL NE	12/3/2013
290	618 4TH ST NE	12/3/2013
291	6501 3RD ST NW	12/3/2013
292	72 S ST NW	12/3/2013
293	764 GRESHAM PL NW	12/3/2013
294	812 44TH ST NE	12/3/2013
295	909 L ST NE	12/3/2013

Table C.2 Sample Kits Not Returned

No	Address	Bottle Drop Date
1	1010 10th St NE	7/22/2013
2	1025 44th St NE	7/22/2013
3	109 19th St SE	7/22/2013
4	1106 Allison St NW	7/22/2013
5	1318 Wallach Pl NW	7/22/2013
6	1339 U St SE	7/22/2013
7	1357 C St NE	7/22/2013
8	1429 Ives Pl SE	7/22/2013
9	1434 Taylor St NW	7/22/2013
10	1453 S St NW	7/22/2013
11	1520 Locust Rd NW	7/22/2013
12	1620 Hamlin St NE	7/22/2013
13	1623 U St SE	7/22/2013
14	1703 D St NE	7/22/2013
15	2107 2nd St NE	7/22/2013
16	2212 38th St NW	7/22/2013
17	24 Evarts St NE	7/22/2013
18	2649 Bowen Rd SE	7/22/2013
19	3216 Klinge Rd NW	8/19/2013
20	3218 MORRISON ST NW	8/19/2013
21	322 TENNESSEE AVE NE	8/19/2013
22	3511 Woodley Rd NW	8/19/2013
23	3533 W Pl NW	8/19/2013
24	3601 WARREN ST NW	8/19/2013
25	3625 Albermarle St NW	8/19/2013
26	3908 13TH ST NW	8/19/2013
27	4111 INGOMAR ST NW	8/19/2013
28	4118 13TH ST NW	8/19/2013
29	4131 YUMA ST NW	8/19/2013
30	424 Luray Pl NW	8/19/2013
31	4409 Lowell St NW	8/19/2013
32	4411 15th St NW	8/19/2013
33	4418 14th St NE	8/19/2013
34	4613 9th St NW	8/19/2013
35	4818 ILLINOIS AVE NW	8/19/2013
36	5024 7th St NW	8/19/2013
37	5226 7th St NW	8/19/2013
38	524 10th St SE	8/19/2013
39	5517 7th St NW	8/19/2013
40	5613 30th St NW	8/19/2013
41	1203 Quincy St NW	9/23/2013
42	1387 N Carolina Ave NE	9/23/2013
43	1412 Shepherd St NW	9/23/2013
44	1603 Massachusetts Ave SE	9/23/2013
45	1731 L St NE	9/23/2013

No	Address	Bottle Drop Date
46	1736 Bay St SE	9/23/2013
47	1808 KEARNEY ST NE	9/23/2013
48	1908 Biltmore St NW	9/23/2013
49	2118 14th St SE	9/23/2013
50	230 G St NE	9/23/2013
51	231 K St NE	9/23/2013
52	234 Longfellow St NW	9/23/2013
53	580 49th Pl NE	9/23/2013
54	5817 7th St NW	9/23/2013
55	608 Gallatin St NW	9/23/2013
56	611 Roxboro Pl NW	9/23/2013
57	619 Girard St NE	9/23/2013
58	6210 8th St NW	9/23/2013
59	641 Gallatin St NW	9/23/2013
60	644 Lamont St NW	9/23/2013
61	702 9th St SE	9/23/2013
62	743 Gresham Pl NW	9/23/2013
63	753 Gresham Pl NW	9/23/2013
64	8 N St SW	9/23/2013
65	804 Delafield Pl NW	9/23/2013
66	834 Delafield Pl NW	9/23/2013
67	87 S St NW	9/23/2013
68	905 Kent Pl NE	9/23/2013
69	912 Emerson St NW	9/23/2013
70	1014 Douglas St NE	10/21/2013
71	1207 Trinidad Ave NE	10/21/2013
72	1214 Evarts St NE	10/21/2013
73	1238 HALF ST SW	10/21/2013
74	1346 Madison St NW	10/21/2013
75	143 UHLAND TER NE	10/21/2013
76	1705 2nd St NE	10/21/2013
77	302 RITTENHOUSE ST NW	10/21/2013
78	32 Todd Pl NE	10/21/2013
79	3215 Mckinley St NW	10/21/2013
80	3232 Klinge Rd NW	10/21/2013
81	335 17TH PL NE	10/21/2013
82	3531 16TH ST NW	10/21/2013
83	3612 34th St NW	10/21/2013
84	413 4th St SE	10/21/2013
85	416 7th St NE	10/21/2013
86	4616 HUNT PL NE	10/21/2013
87	5316 28th St NW	10/21/2013
88	5907 4th St NW	10/21/2013
89	605 ROCK CRK CHURCH RD NW	10/21/2013
90	720 ALABAMA AVE SE	10/21/2013
91	7721 14th St NW	10/21/2013
92	822 K St NE	10/21/2013

No	Address	Bottle Drop Date
93	915 Farragut St NW	10/21/2013
94	915 Shepherd St NW	10/21/2013
95	1424 S ST SE	11/18/2013
96	1614 V St SE	11/18/2013
97	1619 G St SE	11/18/2013
98	1802 35TH ST NW	11/18/2013
99	1802 Kilbourne Pl NW	11/18/2013
100	201 13th St NE	11/18/2013
101	205 TAYLOR ST NW	11/18/2013
102	2220 13th St SE	11/18/2013
103	228 Randolph Pl NE	11/18/2013
104	2305 Minnesota Ave SE	11/18/2013
105	2823 28TH ST NW	11/18/2013
106	2928 33rd Pl NW	11/18/2013
107	3105 34th St NW	11/18/2013
108	312 14TH ST NE	11/18/2013
109	313 16th St SE	11/18/2013
110	3428 Brown St NW	11/18/2013
111	3721 Windom Pl NW	11/18/2013
112	42 Q St NE	11/18/2013
113	441 Quincy St NW	11/18/2013
114	506 Irving St NW	11/18/2013
115	513 Florida Ave NE	11/18/2013
116	514 13th St SE	11/18/2013
117	5304 Reno Rd NW	11/18/2013
118	617 Kenyon St NW	11/18/2013
119	661 MARYLAND AVE NE	11/18/2013
120	736 Fairmont St NW	11/18/2013
121	75 P St NW	11/18/2013
122	817 DECATUR ST NW	11/18/2013
123	833 DECATUR ST NW	11/18/2013
124	924 Hamilton St NW	11/18/2013
125	1124 F ST NE	12/3/2013
126	764 GRESHAM PL NW	12/3/2013
127	1546 NEW JERSEY AVE NW	12/3/2013
128	4114 FESSENDEN ST NW	12/3/2013
129	309 K ST NE	12/3/2013
130	618 4TH ST NE	12/3/2013
131	4722 15TH ST NW	12/3/2013
132	1643 KRAMER ST NE	12/3/2013
133	909 L ST NE	12/3/2013
134	3619 11TH ST NW	12/3/2013
135	1710 22ND ST SE	12/3/2013
136	137 TENNESSEE AVE NE	12/3/2013
137	1246 E ST NE	12/3/2013
138	1603 30TH ST NW	12/3/2013
139	6501 3RD ST NW	12/3/2013

No	Address	Bottle Drop Date
140	1600 GIRARD ST NE	12/3/2013
141	1330 VALLEY PL SE	12/3/2013
142	325 G ST NE	12/3/2013
143	1120 ABBEY PL NE	12/3/2013
144	4512 13TH ST NW	12/3/2013

Table C.3 Samples Returned and Rejected for Compliance Analysis

No	Address	Bottle Drop Date	Reject Reason
1	108 Varnum St NW	7/22/2013	No chain of custody provided
2	213 49th St NE	7/22/2013	Water used during stagnation period
3	1315 FRANKLIN ST NE	7/22/2013	Leak in plumbing
4	331 Upshur St NW	8/19/2013	No chain of custody provided
5	3206 38th St NW	8/19/2013	Ice maker on
6	3361 Stuyvesant Pl NW	8/19/2013	Leak in plumbing
7	3400 Holmead Pl NW	8/19/2013	Incomplete chain of custody
8	4120 Grant St NE	8/19/2013	Stagnation less than 6 hours
9	4307 CHESAPEAKE ST NW	8/19/2013	Stagnation less than 6 hours
10	4310 37th St NW	8/19/2013	Ice maker on
11	4627 49th St NW	8/19/2013	Stagnation period unknown
12	4550 30TH ST NW	8/19/2013	Stagnation period unknown
13	1836 L St NE	9/23/2013	No lead service, private side replaced in 2012
14	1843 MONROE ST NW	9/23/2013	No lead, private side replacement 2013
15	1222 HAMILTON ST NW	9/23/2013	Stagnation less than 6 hours
16	605 Columbia Rd NW	10/21/2013	Stagnation greater than 18 hours
17	617 M St NE	10/21/2013	Water used during stagnation period
18	780 Fairmont St NW	10/21/2013	No lead, private side replacement reported
19	1212 E Capitol St NE	10/21/2013	Multi-family residence
20	3809 ALTON PL NW	10/21/2013	Leak in plumbing
21	3917 8th St NW	10/21/2013	Leak in plumbing
22	4327 IOWA AVE NW	10/21/2013	Ice maker in use; bottles not full
23	522 Park Rd NW	11/18/2013	Incomplete chain of custody
24	765 GIRARD ST NW	11/18/2013	Incomplete chain of custody
25	1353 Iris St NW	11/18/2013	Water used during stagnation period
26	1931 SUMMIT PL NE	11/18/2013	Multi-family residence
27	12 14TH ST SE	12/3/2013	Stagnation greater than 18 hours
28	72 S ST NW	12/3/2013	Multi-family residence
29	124 12TH ST NE	12/3/2013	Multi-family residence
30	139 11TH ST NE	12/3/2013	Multi-family residence
31	609 49TH PL NE	12/3/2013	Incomplete chain of custody
32	812 44TH ST NE	12/3/2013	No lead service, house rebuilt in 2006
33	1804 WYOMING AVE NW	12/3/2013	Multi-family residence
34	1831 LAMONT ST NW	12/3/2013	Multi-family residence
35	2904 P ST SE	12/3/2013	Stagnation greater than 18 hours
36	4719 9TH ST NW	12/3/2013	Filter not bypassed
37	5312 ILLINOIS AVE NW	12/3/2013	Leak in plumbing
38	5812 7TH ST NW	12/3/2013	Stagnation greater than 18 hours

Table C.4 Deviations from Sample Order

No	Address	Priority	Scheduled Month	Deviation Reason
1	4824 46th St NW	Secondary	Aug	Customer requested to not participate
2	1222 HAMILTON ST NW	Primary	Sept	First sample rejected; dropped again
3	309 11th st se	NEW ^[1]	July	Added site this semester
4	450 Newton Pl NW	NEW ^[1]	July	Added site this semester
5	1627 Gales St NE	NEW ^[1]	Aug	Added site this semester
6	6209 30TH ST NW	NEW ^[1]	Aug	Added site this semester
7	3636 13TH ST NW	NEW ^[1]	Oct	Added site this semester
8	421 Hamilton St NW	NEW ^[1]	Nov	Added site this semester
9	1705 D St NE	NEW ^[1]	Nov	Added site this semester
10	4806 Kansas Ave NW	NEW ^[1]	Nov	Added site this semester
11	1124 F ST NE	NEW ^[2]	Dec	Added site this semester
12	561 23RD PL NE	NEW ^[2]	Dec	Added site this semester
13	12 14TH ST SE	NEW ^[2]	Dec	Added site this semester
14	764 GRESHAM PL NW	NEW ^[2]	Dec	Added site this semester
15	1546 NEW JERSEY AVE NW	NEW ^[2]	Dec	Added site this semester
16	2904 P ST SE	NEW ^[2]	Dec	Added site this semester
17	72 S ST NW	NEW ^[2]	Dec	Added site this semester
18	4114 FESSENDEN ST NW	NEW ^[2]	Dec	Added site this semester
19	309 K ST NE	NEW ^[2]	Dec	Added site this semester
20	124 16TH ST NE	NEW ^[2]	Dec	Added site this semester
21	2832 BRENTWOOD RD NE	NEW ^[2]	Dec	Added site this semester
22	618 4TH ST NE	NEW ^[2]	Dec	Added site this semester
23	4722 15TH ST NW	NEW ^[2]	Dec	Added site this semester
24	3722 MCKINLEY ST NW	NEW ^[2]	Dec	Added site this semester
25	1643 KRAMER ST NE	NEW ^[2]	Dec	Added site this semester
26	139 11TH ST NE	NEW ^[2]	Dec	Added site this semester
27	909 L ST NE	NEW ^[2]	Dec	Added site this semester
28	1428 VARNUM ST NW	NEW ^[2]	Dec	Added site this semester
29	3619 11TH ST NW	NEW ^[2]	Dec	Added site this semester
30	1659 NEWTON ST NW	NEW ^[2]	Dec	Added site this semester
31	1710 22ND ST SE	NEW ^[2]	Dec	Added site this semester
32	137 TENNESSEE AVE NE	NEW ^[2]	Dec	Added site this semester
33	5312 ILLINOIS AVE NW	NEW ^[2]	Dec	Added site this semester
34	1738 ALLISON ST NW	NEW ^[2]	Dec	Added site this semester
35	1246 E ST NE	NEW ^[2]	Dec	Added site this semester
36	812 44TH ST NE	NEW ^[2]	Dec	Added site this semester
37	1603 30TH ST NW	NEW ^[2]	Dec	Added site this semester
38	1513 27TH ST NW	NEW ^[2]	Dec	Added site this semester
39	6501 3RD ST NW	NEW ^[2]	Dec	Added site this semester
40	5003 7TH ST NW	NEW ^[2]	Dec	Added site this semester
41	1600 GIRARD ST NE	NEW ^[2]	Dec	Added site this semester
42	3724 CHESAPEAKE ST NW	NEW ^[2]	Dec	Added site this semester
43	1831 LAMONT ST NW	NEW ^[2]	Dec	Added site this semester

No	Address	Priority	Scheduled Month	Deviation Reason
44	1310 R ST NW	NEW ^[2]	Dec	Added site this semester
45	5812 7TH ST NW	NEW ^[2]	Dec	Added site this semester
46	124 12TH ST NE	NEW ^[2]	Dec	Added site this semester
47	1305 TAYLOR ST NW	NEW ^[2]	Dec	Added site this semester
48	1330 VALLEY PL SE	NEW ^[2]	Dec	Added site this semester
49	2719 O ST NW	NEW ^[2]	Dec	Added site this semester
50	325 G ST NE	NEW ^[2]	Dec	Added site this semester
51	1375 MONROE ST NW	NEW ^[2]	Dec	Added site this semester
52	1529 UPSHUR ST NW	NEW ^[2]	Dec	Added site this semester
53	123 TENNESSEE AVE NE	NEW ^[2]	Dec	Added site this semester
54	1120 ABBEY PL NE	NEW ^[2]	Dec	Added site this semester
55	1804 WYOMING AVE NW	NEW ^[2]	Dec	Added site this semester
56	609 49TH PL NE	NEW ^[2]	Dec	Added site this semester
57	4719 9TH ST NW	NEW ^[2]	Dec	Added site this semester
58	4447 HAWTHORNE ST NW	NEW ^[2]	Dec	Added site this semester
59	4512 13TH ST NW	NEW ^[2]	Dec	Added site this semester

Notes:

[1] New participants were customers who contacted DC Water, requested a lead test, and agreed to participate in the Lead and Copper Monitoring Program. DC Water's records for these homes were full lead service and a single family home at the time of sample kit distribution.

[2] New participants in December were customers that were randomly selected, met Tier 1 criteria under 40 CFR 141.86(a)(3)(ii) as single family structures with either full or partial lead service lines based on DC Water's customer information and service line inventory.

Table C.5 Sites with Compliance Results from July 2012 through June 2013 and No Results in July through December 2013

No	Address	Reason
1	1010 10th St NE	Did not return bottles; See Table C.2
2	1025 44th St NE	Did not return bottles; See Table C.2
3	109 19th St SE	Did not return bottles; See Table C.2
4	1203 Quincy St NW	Did not return bottles; See Table C.2
5	1318 Wallach Pl NW	Did not return bottles; See Table C.2
6	1357 C St NE	Did not return bottles; See Table C.2
7	1412 Shepherd St NW	Did not return bottles; See Table C.2
8	1434 Taylor St NW	Did not return bottles; See Table C.2
9	144 Tennessee Ave NE	Removed from Sample Pool prior to this semester
10	1453 S St NW	Did not return bottles; See Table C.2
11	1603 Massachusetts Ave SE	Did not return bottles; See Table C.2
12	1703 D St NE	Did not return bottles; See Table C.2
13	1736 Bay St SE	Did not return bottles; See Table C.2
14	1808 KEARNEY ST NE	Did not return bottles; See Table C.2
15	2107 2nd St NE	Did not return bottles; See Table C.2
16	2128 O ST NW	Removed from Sample Pool prior to this semester
17	213 49th St NE	Sample rejected; See Table C.3
18	2212 38th St NW	Did not return bottles; See Table C.2
19	230 G St NE	Did not return bottles; See Table C.2
20	24 Evarts St NE	Did not return bottles; See Table C.2
21	302 RITTENHOUSE ST NW	Did not return bottles; See Table C.2
22	3206 38th St NW	Sample rejected; See Table C.3
23	3215 Mckinley St NW	Did not return bottles; See Table C.2
24	3216 Klinge Rd NW	Did not return bottles; See Table C.2
25	3218 MORRISON ST NW	Did not return bottles; See Table C.2
26	322 TENNESSEE AVE NE	Did not return bottles; See Table C.2
27	335 17TH PL NE	Did not return bottles; See Table C.2
28	3361 Stuyvesant Pl NW	Sample rejected; See Table C.3
29	349 TENNESSEE AVE NE	Removed from Sample Pool prior to this semester
30	3533 W Pl NW	Did not return bottles; See Table C.2
31	3601 WARREN ST NW	Did not return bottles; See Table C.2
32	3625 Albermarle St NW	Did not return bottles; See Table C.2
33	3809 ALTON PL NW	Sample rejected; See Table C.3
34	3908 13TH ST NW	Did not return bottles; See Table C.2
35	3917 8th St NW	Sample rejected; See Table C.3
37	4111 INGOMAR ST NW	Did not return bottles; See Table C.2
38	4120 Grant St NE	Sample rejected; See Table C.3
39	413 4th St SE	Did not return bottles; See Table C.2
40	4131 YUMA ST NW	Did not return bottles; See Table C.2
41	424 Luray Pl NW	Did not return bottles; See Table C.2
42	4307 CHESAPEAKE ST NW	Sample rejected; See Table C.3
43	4310 37th St NW	Sample rejected; See Table C.3
44	4409 Lowell St NW	Did not return bottles; See Table C.2

No	Address	Reason
45	4418 14th St NE	Did not return bottles; See Table C.2
46	4550 30TH ST NW	Sample rejected; See Table C.3
47	4613 9th St NW	Did not return bottles; See Table C.2
48	4627 49th St NW	Sample rejected; See Table C.3
49	4818 ILLINOIS AVE NW	Did not return bottles; See Table C.2
51	5226 7th St NW	Did not return bottles; See Table C.2
52	5316 28th St NW	Did not return bottles; See Table C.2
53	5517 7th St NW	Did not return bottles; See Table C.2
54	580 49th PI NE	Did not return bottles; See Table C.2
55	605 Columbia Rd NW	Sample rejected; See Table C.3
56	605 ROCK CRK CHURCH RD NW	Did not return bottles; See Table C.2
57	611 Roxboro PI NW	Did not return bottles; See Table C.2
58	617 M St NE	Sample rejected; See Table C.3
59	619 Girard St NE	Did not return bottles; See Table C.2
60	6210 8th St NW	Did not return bottles; See Table C.2
61	641 Gallatin St NW	Did not return bottles; See Table C.2
62	702 9th St SE	Did not return bottles; See Table C.2
63	753 Gresham PI NW	Did not return bottles; See Table C.2
64	780 Fairmont St NW	Sample rejected; See Table C.3
65	8 N St SW	Did not return bottles; See Table C.2
66	804 Delafield PI NW	Did not return bottles; See Table C.2
67	834 Delafield PI NW	Did not return bottles; See Table C.2
68	87 S St NW	Did not return bottles; See Table C.2
69	905 Kent PI NE	Did not return bottles; See Table C.2
70	912 Emerson St NW	Did not return bottles; See Table C.2

Attachment 1

Washington Aqueduct Test Results for LCR Compliance Samples

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-001

SAMPLE INFORMATION

Sample Number: 1307250-001 Customer Sample Number: 3035494 Project: LCR
Location: 1st draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 10:54 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.088 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-002

SAMPLE INFORMATION

Sample Number: 1307250-002 Customer Sample Number: 3035494 Project: LCR
Location: 2nd draw 2923 CATHEDRAL AVE NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 10:56 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-003

SAMPLE INFORMATION

Sample Number: 1307250-003 Customer Sample Number: 3058228 Project: LCR
Location: 1st draw 2913 BRANDYWINE ST NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.060 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-004

SAMPLE INFORMATION

Sample Number: 1307250-004 Customer Sample Number: 3058228 Project: LCR
Location: 2nd draw 2913 BRANDYWINE ST NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.054 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0027 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-005

SAMPLE INFORMATION

Sample Number: 1307250-005 Customer Sample Number: 3029191 Project: LCR
Location: 1st draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:08 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.054 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-006

SAMPLE INFORMATION

Sample Number: 1307250-006 Customer Sample Number: 3029191 Project: LCR
Location: 2nd draw 1620 WEBSTER ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.056 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-007

SAMPLE INFORMATION

Sample Number: 1307250-007 Customer Sample Number: 3052487 Project: LCR
Location: 1st draw 450 NEWTON PL NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-008

SAMPLE INFORMATION

Sample Number: 1307250-008 Customer Sample Number: 3052487 Project: LCR
Location: 2nd draw 450 NEWTON PL NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:17 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.042 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0072 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-009

SAMPLE INFORMATION

Sample Number: 1307250-009 Customer Sample Number: 3027905 Project: LCR
Location: 1st draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.044 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.100 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0422 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-010

SAMPLE INFORMATION

Sample Number: 1307250-010 Customer Sample Number: 3027905 Project: LCR
Location: 2nd draw 1505 BUCHANAN ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0140 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-011

SAMPLE INFORMATION

Sample Number: 1307250-011 Customer Sample Number: 3025494 Project: LCR
Location: 1st draw 125 MADISON ST NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.120 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0081 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-012

SAMPLE INFORMATION

Sample Number: 1307250-012 Customer Sample Number: 3025494 Project: LCR
Location: 2nd draw 125 MADISON ST NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.198 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0160 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-013

SAMPLE INFORMATION

Sample Number: 1307250-013 Customer Sample Number: 3026174 Project: LCR
Location: 1st draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.067 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-014

SAMPLE INFORMATION

Sample Number: 1307250-014 Customer Sample Number: 3026174 Project: LCR
Location: 2nd draw 15 MILMARSON PL NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:07 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-015

SAMPLE INFORMATION

Sample Number: 1307250-015 Customer Sample Number: 3106027 Project: LCR
Location: 1st draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 8:01 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.065 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-016

SAMPLE INFORMATION

Sample Number: 1307250-016 Customer Sample Number: 3106027 Project: LCR
Location: 2nd draw 1826 JACKSON ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 8:02 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.085 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-017

SAMPLE INFORMATION

Sample Number: 1307250-017 Customer Sample Number: 3028665 Project: LCR
Location: 1st draw 1378 TAYLOR ST NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 17:20 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0031 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-018

SAMPLE INFORMATION

Sample Number: 1307250-018 Customer Sample Number: 3028665 Project: LCR
Location: 2nd draw 1378 TAYLOR ST NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 17:23 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0091 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-019

SAMPLE INFORMATION

Sample Number: 1307250-019 Customer Sample Number: 3104275 Project: LCR
Location: 1st draw 1331 IRVING ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 4:10 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-020

SAMPLE INFORMATION

Sample Number: 1307250-020 Customer Sample Number: 3104275 Project: LCR
Location: 2nd draw 1331 IRVING ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 4:12 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-021

SAMPLE INFORMATION

Sample Number: 1307250-021 Customer Sample Number: 3107490 Project: LCR
Location: 1st draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 16:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.167 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-022

SAMPLE INFORMATION

Sample Number: 1307250-022 Customer Sample Number: 3107490 Project: LCR
Location: 2nd draw 2830 BRENTWOOD RD NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 16:05 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.165 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-023

SAMPLE INFORMATION

Sample Number: 1307250-023 Customer Sample Number: 3032866 Project: LCR
Location: 1st draw 1262 COLUMBIA RD. NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-024

SAMPLE INFORMATION

Sample Number: 1307250-024 Customer Sample Number: 3032866 Project: LCR
Location: 2nd draw 1262 COLUMBIA RD. NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.051 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-025

SAMPLE INFORMATION

Sample Number: 1307250-025 Customer Sample Number: 3080372 Project: LCR
Location: 1st draw 2435 33RD ST SE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.075 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-026

SAMPLE INFORMATION

Sample Number: 1307250-026 Customer Sample Number: 3080372 Project: LCR
Location: 2nd draw 2435 33RD ST SE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:11 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.054 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.006 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-027

SAMPLE INFORMATION

Sample Number: 1307250-027 Customer Sample Number: 3017940 Project: LCR
Location: 1st draw 10 S ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 9:11 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0041 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-028

SAMPLE INFORMATION

Sample Number: 1307250-028 Customer Sample Number: 3017940 Project: LCR
Location: 2nd draw 10 S ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 9:12 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0038 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-029

SAMPLE INFORMATION

Sample Number: 1307250-029 Customer Sample Number: 3029182 Project: LCR
Location: 1st draw 1635 WEBSTER ST, NW Type: Dist.

Collection Date: 7/25/2013 Collection Time: 6:59 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.263 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-030

SAMPLE INFORMATION

Sample Number: 1307250-030 Customer Sample Number: 3029182 Project: LCR
Location: 2nd draw 1635 WEBSTER ST, NW Type: Dist.

Collection Date: 7/25/2013 Collection Time: 7:06 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-031

SAMPLE INFORMATION

Sample Number: 1307250-031 Customer Sample Number: 3034000 Project: LCR
Location: 1st draw 1649 HARVARD ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.034 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0032 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-032

SAMPLE INFORMATION

Sample Number: 1307250-032 Customer Sample Number: 3034000 Project: LCR
Location: 2nd draw 1649 HARVARD ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-033

SAMPLE INFORMATION

Sample Number: 1307250-033 Customer Sample Number: 3029396 Project: LCR
Location: 1st draw 1003 QUEBEC PL NW Type: Dist.

Collection Date: 7/25/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.065 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-034

SAMPLE INFORMATION

Sample Number: 1307250-034 Customer Sample Number: 3029396 Project: LCR
Location: 2nd draw 1003 QUEBEC PL NW Type: Dist.

Collection Date: 7/25/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-035

SAMPLE INFORMATION

Sample Number: 1307250-035 Customer Sample Number: 3006211 Project: LCR
Location: 1st draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 18:53 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-036

SAMPLE INFORMATION

Sample Number: 1307250-036 Customer Sample Number: 3006211 Project: LCR
Location: 2nd draw 1706 NEW JERSEY AVE NW Type: Dist.

Collection Date: 7/23/2013 Collection Time: 18:57 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.030 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-037

SAMPLE INFORMATION

Sample Number: 1307250-037 Customer Sample Number: 3002478 Project: LCR
Location: 1st draw 1436 S ST NW Type: Dist.

Collection Date: 7/25/2013 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.132 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-038

SAMPLE INFORMATION

Sample Number: 1307250-038 Customer Sample Number: 3002478 Project: LCR
Location: 2nd draw 1436 S ST NW Type: Dist.

Collection Date: 7/25/2013 Collection Time: 6:23 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-039

SAMPLE INFORMATION

Sample Number: 1307250-039 Customer Sample Number: 3073087 Project: LCR
Location: 1st draw 317 9TH ST SE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 4:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.064 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-040

SAMPLE INFORMATION

Sample Number: 1307250-040 Customer Sample Number: 3073087 Project: LCR
Location: 2nd draw 317 9TH ST SE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 4:05 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.070 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-041

SAMPLE INFORMATION

Sample Number: 1307250-041 Customer Sample Number: 3029171 Project: LCR
Location: 1st draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.030 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.055 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-042

SAMPLE INFORMATION

Sample Number: 1307250-042 Customer Sample Number: 3029171 Project: LCR
Location: 2nd draw 1613 WEBSTER ST. NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.049 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-043

SAMPLE INFORMATION

Sample Number: 1307250-043 Customer Sample Number: 3111360 Project: LCR
Location: 1st draw 1519 OLIVE ST, NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.049 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-044

SAMPLE INFORMATION

Sample Number: 1307250-044 Customer Sample Number: 3111360 Project: LCR
Location: 2nd draw 1519 OLIVE ST, NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 5:31 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.050 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-045

SAMPLE INFORMATION

Sample Number: 1307250-045 Customer Sample Number: 3113467 Project: LCR
Location: 1st draw 1011 TAYLOR ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.145 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-046

SAMPLE INFORMATION

Sample Number: 1307250-046 Customer Sample Number: 3113467 Project: LCR
Location: 2nd draw 1011 TAYLOR ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.188 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-047

SAMPLE INFORMATION

Sample Number: 1307250-047 Customer Sample Number: 3113400 Project: LCR
Location: 1st draw 1003 OTIS ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-048

SAMPLE INFORMATION

Sample Number: 1307250-048 Customer Sample Number: 3113400 Project: LCR
Location: 2nd draw 1003 OTIS ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-049

SAMPLE INFORMATION

Sample Number: 1307250-049 Customer Sample Number: 3124875 Project: LCR
Location: 1st draw 228 V ST NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 20:27 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.045 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.042 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-050

SAMPLE INFORMATION

Sample Number: 1307250-050 Customer Sample Number: 3124875 Project: LCR
Location: 2nd draw 228 V ST NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 20:29 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.041 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0138 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-051

SAMPLE INFORMATION

Sample Number: 1307250-051 Customer Sample Number: 3111849 Project: LCR
Location: 1st draw 119 16TH ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.060 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-052

SAMPLE INFORMATION

Sample Number: 1307250-052 Customer Sample Number: 3111849 Project: LCR
Location: 2nd draw 119 16TH ST NE Type: Dist.

Collection Date: 7/24/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-053

SAMPLE INFORMATION

Sample Number: 1307250-053 Customer Sample Number: 3100684 Project: LCR
Location: 1st draw 1346 F ST. NE Type: Dist.

Collection Date: 7/22/2013 Collection Time: 21:32 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0056 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-054

SAMPLE INFORMATION

Sample Number: 1307250-054 Customer Sample Number: 3100684 Project: LCR
Location: 2nd draw 1346 F ST. NE Type: Dist.

Collection Date: 7/22/2013 Collection Time: 21:35 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0105 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-055

SAMPLE INFORMATION

Sample Number: 1307250-055 Customer Sample Number: 3111675 Project: LCR
Location: 1st draw 307 7TH ST NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.030 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

8/14/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-056

SAMPLE INFORMATION

Sample Number: 1307250-056 Customer Sample Number: 3111675 Project: LCR
Location: 2nd draw 307 7TH ST NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.034 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-057

SAMPLE INFORMATION

Sample Number: 1307250-057 Customer Sample Number: 3073397 Project: LCR
Location: 1st draw 309 11TH ST SE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 8:38 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.100 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.034 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/14/2013
Report Number: LC-W1307250-058

SAMPLE INFORMATION

Sample Number: 1307250-058 Customer Sample Number: 3073397 Project: LCR
Location: 2nd draw 309 11TH ST SE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 8:39 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:34:25 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	8/9/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	8/9/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/9/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

8/14/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308042-001

SAMPLE INFORMATION

Sample Number: 1308042-001 Customer Sample Number: 3009912 Project: LCR
Location: 1st draw 2007 37TH ST NW Type: Dist.

Collection Date: 7/29/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/5/2013 4:08:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.080 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308042-002

SAMPLE INFORMATION

Sample Number: 1308042-002 Customer Sample Number: 3009912 Project: LCR
Location: 2nd draw 2007 37TH ST NW Type: Dist.

Collection Date: 7/29/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 8/5/2013 4:08:48 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308119-001

SAMPLE INFORMATION

Sample Number: 1308119-001 Customer Sample Number: 3002488 Project: LCR
Location: 1st draw 1424 S ST NW Type: Dist.

Collection Date: 8/8/2013 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:05:25 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308119-002

SAMPLE INFORMATION

Sample Number: 1308119-002 Customer Sample Number: 3002488 Project: LCR
Location: 2nd draw 1424 S ST NW Type: Dist.

Collection Date: 8/8/2013 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:05:25 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0032 mg/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-001

SAMPLE INFORMATION

Sample Number: 1308230-001 Customer Sample Number: 3021532 Project: LCR
Location: 1st draw 501 WEBSTER ST NW Type: Dist.

Collection Date: 8/19/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.157 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-002

SAMPLE INFORMATION

Sample Number: 1308230-002 Customer Sample Number: 3005355 Project: LCR
Location: 1st draw 449 S ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.031 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-003

SAMPLE INFORMATION

Sample Number: 1308230-003 Customer Sample Number: 3005355 Project: LCR
Location: 2nd draw 449 S ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.025 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-005

SAMPLE INFORMATION

Sample Number: 1308230-005 Customer Sample Number: 3040552 Project: LCR
Location: 2nd draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0058 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-006

SAMPLE INFORMATION

Sample Number: 1308230-006 Customer Sample Number: 3037853 Project: LCR
Location: 1st draw 6209 30TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.059 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-007

SAMPLE INFORMATION

Sample Number: 1308230-007 Customer Sample Number: 3037853 Project: LCR
Location: 2nd draw 6209 30TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 7:12 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-008

SAMPLE INFORMATION

Sample Number: 1308230-008 Customer Sample Number: 3107442 Project: LCR
Location: 1st draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 8/20/2013 Collection Time: 16:14 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.082 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.074 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-009

SAMPLE INFORMATION

Sample Number: 1308230-009 Customer Sample Number: 3107442 Project: LCR
Location: 2nd draw 3211 CENTRAL AVE NE Type: Dist.

Collection Date: 8/20/2013 Collection Time: 16:19 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.047 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-010

SAMPLE INFORMATION

Sample Number: 1308230-010 Customer Sample Number: 3010741 Project: LCR
Location: 1st draw 3727 T ST NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.096 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.069 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0050 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-011

SAMPLE INFORMATION

Sample Number: 1308230-011 Customer Sample Number: 3010741 Project: LCR
Location: 2nd draw 3727 T ST NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.120 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0088 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-012

SAMPLE INFORMATION

Sample Number: 1308230-012 Customer Sample Number: 3035973 Project: LCR
Location: 1st draw 3218 MACOMB ST NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.116 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-013

SAMPLE INFORMATION

Sample Number: 1308230-013 Customer Sample Number: 3035973 Project: LCR
Location: 2nd draw 3218 MACOMB ST NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.086 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-014

SAMPLE INFORMATION

Sample Number: 1308230-014 Customer Sample Number: 3117544 Project: LCR
Location: 1st draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 8/21/2013 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.268 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-015

SAMPLE INFORMATION

Sample Number: 1308230-015 Customer Sample Number: 3117544 Project: LCR
Location: 2nd draw 336 QUACKENBOS ST. NE Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.227 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-016

SAMPLE INFORMATION

Sample Number: 1308230-016 Customer Sample Number: 3056809 Project: LCR
Location: 1st draw 4214 8TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-017

SAMPLE INFORMATION

Sample Number: 1308230-017 Customer Sample Number: 3056809 Project: LCR
Location: 2nd draw 4214 8TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 7:21 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.012 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-018

SAMPLE INFORMATION

Sample Number: 1308230-018 Customer Sample Number: 3122289 Project: LCR
Location: 1st draw 531 TENNESSEE AVE NE Type: Dist.

Collection Date: 8/20/2013 Collection Time: 20:10 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-019

SAMPLE INFORMATION

Sample Number: 1308230-019 Customer Sample Number: 3122289 Project: LCR
Location: 2nd draw 531 TENNESSEE AVE NE Type: Dist.

Collection Date: 8/20/2013 Collection Time: 20:12 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-020

SAMPLE INFORMATION

Sample Number: 1308230-020 Customer Sample Number: 3006813 Project: LCR
Location: 1st draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.205 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-021

SAMPLE INFORMATION

Sample Number: 1308230-021 Customer Sample Number: 3006813 Project: LCR
Location: 2nd draw 36 FLORIDA AVE NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-022

SAMPLE INFORMATION

Sample Number: 1308230-022 Customer Sample Number: 3021575 Project: LCR
Location: 1st draw 4401 5TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.101 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0081 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-023

SAMPLE INFORMATION

Sample Number: 1308230-023 Customer Sample Number: 3021575 Project: LCR
Location: 2nd draw 4401 5TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.031 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-025

SAMPLE INFORMATION

Sample Number: 1308230-025 Customer Sample Number: 3055284 Project: LCR
Location: 2nd draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0052 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-026

SAMPLE INFORMATION

Sample Number: 1308230-026 Customer Sample Number: 3070403 Project: LCR
Location: 1st draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.016 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-027

SAMPLE INFORMATION

Sample Number: 1308230-027 Customer Sample Number: 3070403 Project: LCR
Location: 2nd draw 331 RALEIGH ST SE Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.081 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-028

SAMPLE INFORMATION

Sample Number: 1308230-028 Customer Sample Number: 3101219 Project: LCR
Location: 1st draw 1627 GALES ST NE Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.035 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-029

SAMPLE INFORMATION

Sample Number: 1308230-029 Customer Sample Number: 3101219 Project: LCR
Location: 2nd draw 1627 GALES ST NE Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-030

SAMPLE INFORMATION

Sample Number: 1308230-030 Customer Sample Number: 3024835 Project: LCR
Location: 1st draw 5731 3RD PL NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 8:22 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.412 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0127 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308255-001

Report revised on 12/30/2013 by MC.
Lab Sample Number 1308255-001, the address was changed from 4929 Glenbrook Rd NW to
4926 Glenbrook Rd NW as reported on the chain of custody.

SAMPLE INFORMATION

Sample Number: 1308255-001 Customer Sample Number: 3045865 Project: LCR
Location: 1st draw 4926 GLENBROOK RD NW Type: Dist.

Collection Date: 8/22/2013 Collection Time: 4:35 Sampler: HOME OWNER Received Date and Time: 8/28/2013 10:00:01 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.032 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308255-002

Report revised on 12/30/2013 by MC.
Lab Sample Number 1308255-002, the address was changed from 4929 Glenbrook Rd NW to 4926
Glenbrook Rd NW as reported on the chain of custody.

SAMPLE INFORMATION

Sample Number: 1308255-002 Customer Sample Number: 3045865 Project: LCR
Location: 2nd draw 4926 GLENBROOK RD NW Type: Dist.

Collection Date: 8/22/2013 Collection Time: 4:40 Sampler: HOME OWNER Received Date and Time: 8/28/2013 10:00:01 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308230-031

SAMPLE INFORMATION

Sample Number: 1308230-031 Customer Sample Number: 3024835 Project: LCR
Location: 2nd draw 5731 3RD PL NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 8:23 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	1.86 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.1550 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308255-003

SAMPLE INFORMATION

Sample Number: 1308255-003 Customer Sample Number: 3023639 Project: LCR
Location: 1st draw 5318 9TH ST. NW Type: Dist.

Collection Date: 8/22/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 8/28/2013 10:00:01 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.089 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.070 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0077 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308255-004

SAMPLE INFORMATION

Sample Number: 1308255-004 Customer Sample Number: 3023639 Project: LCR
Location: 2nd draw 5318 9TH ST. NW Type: Dist.

Collection Date: 8/22/2013 Collection Time: 7:34 Sampler: HOME OWNER Received Date and Time: 8/28/2013 10:00:01 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0033 mg/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/16/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/27/2013
Report Number: LC-W1308230-004

SAMPLE INFORMATION

Sample Number: 1308230-004 Customer Sample Number: 3040552 Project: LCR
Location: 1st draw 3710 HUNTINGTON ST NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/27/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/27/2013
Report Number: LC-W1308230-024

SAMPLE INFORMATION

Sample Number: 1308230-024 Customer Sample Number: 3055284 Project: LCR
Location: 1st draw 4703 MACARTHUR BLVD NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/26/2013 1:56:52 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	9/11/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.147 mg/L	9/11/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.1031 mg/L	9/11/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/27/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/27/2013
Report Number: LC-W1309096-001

SAMPLE INFORMATION

Sample Number: 1309096-001 Customer Sample Number: 3053584 Project: LCR
Location: 1st draw 3706 35TH ST NW Type: Dist.

Collection Date: 9/10/2013 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:40:30 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.036 mg/L	9/19/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	9/19/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	9/19/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/27/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/27/2013
Report Number: LC-W1309096-002

SAMPLE INFORMATION

Sample Number: 1309096-002 Customer Sample Number: 3053584 Project: LCR
Location: 2nd draw 3706 35TH ST NW Type: Dist.

Collection Date: 9/10/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:40:30 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	9/19/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.002 mg/L	9/19/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	9/19/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/27/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309166-001

SAMPLE INFORMATION

Sample Number: 1309166-001 Customer Sample Number: 3051579 Project: LCR
Location: 1st draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 9/11/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:17:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.027 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0047 mg/L	10/17/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309166-002

SAMPLE INFORMATION

Sample Number: 1309166-002 Customer Sample Number: 3051579 Project: LCR
Location: 2nd draw 5234 ILLINOIS AVE NW Type: Dist.

Collection Date: 9/11/2013 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:17:49 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-001 Customer Sample Number: 3120431 Project: LCR
Location: 1st draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 9/24/2013 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-002 Customer Sample Number: 3120431 Project: LCR
Location: 2nd draw 913 HAMLIN ST NE Type: Dist.

Collection Date: 9/24/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0032 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-003 Customer Sample Number: 3022794 Project: LCR
Location: 1st draw 926 HAMILTON ST NW Type: Dist.

Collection Date: 9/24/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0059 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-004 Customer Sample Number: 3011592 Project: LCR
Location: 1st draw 75 BATES ST NW Type: Dist.

Collection Date: 9/24/2013 Collection Time: 17:29 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.066 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-005 Customer Sample Number: 3011592 Project: LCR
Location: 2nd draw 75 BATES ST NW Type: Dist.

Collection Date: 9/24/2013 Collection Time: 17:32 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-006 Customer Sample Number: 3049333 Project: LCR
Location: 1st draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 9/24/2013 Collection Time: 17:50 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.038 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-007 Customer Sample Number: 3049333 Project: LCR
Location: 2nd draw 1353 JEFFERSON ST NW Type: Dist.

Collection Date: 9/24/2013 Collection Time: 17:51 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-008 Customer Sample Number: 3130077 Project: LCR
Location: 1st draw 223 14TH PL NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 0:15 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.072 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0266 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-010 Customer Sample Number: 3087203 Project: LCR
Location: 1st draw 1319 POTOMAC AVE SE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.094 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/17/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-011

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-011 Customer Sample Number: 3087203 Project: LCR
Location: 2nd draw 1319 POTOMAC AV SE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-012

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-012 Customer Sample Number: 3052513 Project: LCR
Location: 1st draw 636 ROCK CRK CHURCH RD, NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:01 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0020 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-013

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-013 Customer Sample Number: 3052513 Project: LCR
Location: 2nd draw 636 ROCK CRK CHURCH RD, NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.003 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0025 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-014

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-014 Customer Sample Number: 3026885 Project: LCR
Location: 1st draw 6308 8TH ST NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.053 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0016 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-015

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-015 Customer Sample Number: 3026885 Project: LCR
Location: 2nd draw 6308 8TH ST NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.054 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0080 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-016

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-016 Customer Sample Number: 3127230 Project: LCR
Location: 1st draw 617 6TH ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.019 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-017

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-017 Customer Sample Number: 3127230 Project: LCR
Location: 2nd draw 617 6TH ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-018

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-018 Customer Sample Number: 3104963 Project: LCR
Location: 1st draw 1420 HAMLIN ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-019

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-019 Customer Sample Number: 3104963 Project: LCR
Location: 2nd draw 1420 HAMLIN ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-020

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-020 Customer Sample Number: 3038936 Project: LCR
Location: 1st draw 5923 33RD ST NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.044 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.144 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0029 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310005-021

SAMPLE INFORMATION

Sample Number: 1310005-021 Customer Sample Number: 3038936 Project: LCR
Location: 2nd draw 5923 33RD ST NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.091 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-022

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-022 Customer Sample Number: 3022011 Project: LCR
Location: 1st draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:28 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.118 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.005 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0054 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-023

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-023 Customer Sample Number: 3022011 Project: LCR
Location: 2nd draw 807 BUCHANAN ST NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:31 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.119 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0201 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-024

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-024 Customer Sample Number: 3099778 Project: LCR
Location: 1st draw 619 12TH ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.110 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-025

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-025 Customer Sample Number: 3099778 Project: LCR
Location: 2nd draw 619 12TH ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.069 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-026

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-026 Customer Sample Number: 3092716 Project: LCR
Location: 1st draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:58 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.088 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.089 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0039 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-027

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-027 Customer Sample Number: 3092716 Project: LCR
Location: 2nd draw 1211 CARROLLSBURG PL SW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:59 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.087 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.053 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0123 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-028

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-028 Customer Sample Number: 3103161 Project: LCR
Location: 1st draw 2408 2ND ST NE Type: Dist.

Collection Date: 9/26/2013 Collection Time: 17:53 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah



Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.060 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0015 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-029

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-029 Customer Sample Number: 3103161 Project: LCR
Location: 2nd draw 2408 2ND ST NE Type: Dist.

Collection Date: 9/26/2013 Collection Time: 17:55 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.106 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-030

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-030 Customer Sample Number: 3038949 Project: LCR
Location: 1st draw 6001 33RD ST NW Type: Dist.

Collection Date: 9/27/2013 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.066 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310005-031

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-031 Customer Sample Number: 3038949 Project: LCR
Location: 2nd draw 6001 33RD ST NW Type: Dist.

Collection Date: 9/27/2013 Collection Time: 6:29 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.111 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.004 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310047-001

SAMPLE INFORMATION

Sample Number: 1310047-001 Customer Sample Number: 3109897 Project: LCR
Location: 1st draw 6105 DIX ST NE Type: Dist.

Collection Date: 9/26/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:55:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/17/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310047-002

SAMPLE INFORMATION

Sample Number: 1310047-002 Customer Sample Number: 3109897 Project: LCR
Location: 2nd draw 6105 DIX ST NE Type: Dist.

Collection Date: 9/26/2013 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:55:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.008 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	10/17/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310047-003

SAMPLE INFORMATION

Sample Number: 1310047-003 Customer Sample Number: 3002494 Project: LCR
Location: 1st draw 1412 S ST., NW Type: Dist.

Collection Date: 10/1/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:55:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.047 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/22/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310047-004

SAMPLE INFORMATION

Sample Number: 1310047-004 Customer Sample Number: 3002494 Project: LCR
Location: 2nd draw 1412 S ST., NW Type: Dist.

Collection Date: 10/1/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:55:14 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.023 mg/L	10/17/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.059 mg/L	10/17/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	10/17/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/29/2013
Report Number: LC-W1310005-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310005-009 Customer Sample Number: 3130077 Project: LCR
Location: 2nd draw 223 14TH PL NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 0:20 Sampler: HOME OWNER Received Date and Time: 10/1/2013 11:38:45 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	10/24/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	10/24/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0115 mg/L	10/24/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

10/29/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-001

SAMPLE INFORMATION

Sample Number: 1310266-001 Customer Sample Number: 3108541 Project: LCR
Location: 1st Draw 333 34TH ST NE Type: Dist.

Collection Date: 10/22/2013 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.086 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-002

SAMPLE INFORMATION

Sample Number: 1310266-002 Customer Sample Number: 3108541 Project: LCR
Location: 2nd Draw 333 34TH ST NE Type: Dist.

Collection Date: 10/22/2013 Collection Time: 6:21 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.057 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-003

SAMPLE INFORMATION

Sample Number: 1310266-003 Customer Sample Number: 3041124 Project: LCR
Location: 1st Draw 4215 39TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 7:44 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.025 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.037 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-004

SAMPLE INFORMATION

Sample Number: 1310266-004 Customer Sample Number: 3041124 Project: LCR
Location: 2nd Draw 4215 39TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 7:46 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.011 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-005

SAMPLE INFORMATION

Sample Number: 1310266-005 Customer Sample Number: 3049889 Project: LCR
Location: 1st Draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.026 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-006

SAMPLE INFORMATION

Sample Number: 1310266-006 Customer Sample Number: 3049889 Project: LCR
Location: 2nd Draw 1222 HAMILTON ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 9:05 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-007

SAMPLE INFORMATION

Sample Number: 1310266-007 Customer Sample Number: 3020685 Project: LCR
Location: 1st Draw 3913 8TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 16:47 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	1.18 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-008

SAMPLE INFORMATION

Sample Number: 1310266-008 Customer Sample Number: 3020685 Project: LCR
Location: 2nd Draw 3913 8TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 16:49 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.128 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.038 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-009

SAMPLE INFORMATION

Sample Number: 1310266-009 Customer Sample Number: 3022580 Project: LCR
Location: 1st Draw 4818 8TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 17:10 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.051 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-010

SAMPLE INFORMATION

Sample Number: 1310266-010 Customer Sample Number: 3022580 Project: LCR
Location: 2nd Draw 4818 8TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 17:12 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-013

SAMPLE INFORMATION

Sample Number: 1310266-013 Customer Sample Number: 3029267 Project: LCR
Location: 1st Draw 3907 13TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 19:20 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.118 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0395 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-014

SAMPLE INFORMATION

Sample Number: 1310266-014 Customer Sample Number: 3029267 Project: LCR
Location: 2nd Draw 3907 13TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 19:23 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.087 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.1610 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-015

SAMPLE INFORMATION

Sample Number: 1310266-015 Customer Sample Number: 3056944 Project: LCR
Location: 1st Draw 621 UPSHUR ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 5:20 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-016

SAMPLE INFORMATION

Sample Number: 1310266-016 Customer Sample Number: 3056944 Project: LCR
Location: 2nd Draw 621 UPSHUR ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 5:22 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.017 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-017

SAMPLE INFORMATION

Sample Number: 1310266-017 Customer Sample Number: 3026522 Project: LCR
Location: 1st Draw 6213 7TH ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.054 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-018

SAMPLE INFORMATION

Sample Number: 1310266-018 Customer Sample Number: 3026522 Project: LCR
Location: 2nd Draw 6213 7TH ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 5:32 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.031 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-019

SAMPLE INFORMATION

Sample Number: 1310266-019 Customer Sample Number: 3022547 Project: LCR
Location: 1st Draw 910 FARRAGUT ST. NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0018 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-020

SAMPLE INFORMATION

Sample Number: 1310266-020 Customer Sample Number: 3022547 Project: LCR
Location: 2nd Draw 910 FARRAGUT ST. NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 8:46 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.007 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0037 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-021

SAMPLE INFORMATION

Sample Number: 1310266-021 Customer Sample Number: 3042773 Project: LCR
Location: 1st Draw 4332 BRANDYWINE ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.042 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-022

SAMPLE INFORMATION

Sample Number: 1310266-022 Customer Sample Number: 3042773 Project: LCR
Location: 2nd Draw 4332 BRANDYWINE ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.022 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-023

SAMPLE INFORMATION

Sample Number: 1310266-023 Customer Sample Number: 3006873 Project: LCR
Location: 1st Draw 53 P ST NW Type: Dist.

Collection Date: 10/24/2013 Collection Time: 8:14 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-024

SAMPLE INFORMATION

Sample Number: 1310266-024 Customer Sample Number: 3006873 Project: LCR
Location: 2nd Draw 53 P ST NW Type: Dist.

Collection Date: 10/24/2013 Collection Time: 8:17 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.022 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-025

SAMPLE INFORMATION

Sample Number: 1310266-025 Customer Sample Number: 3029605 Project: LCR
Location: 1st Draw 3636 13TH ST NW Type: Dist.

Collection Date: 10/24/2013 Collection Time: 18:50 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-026

SAMPLE INFORMATION

Sample Number: 1310266-026 Customer Sample Number: 3029605 Project: LCR
Location: 2nd Draw 3636 13TH ST NW Type: Dist.

Collection Date: 10/24/2013 Collection Time: 18:54 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0096 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-001

SAMPLE INFORMATION

Sample Number: 1310285-001 Customer Sample Number: 3035198 Project: LCR
Location: 1st Draw 3202 38TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.015 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.067 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-002

SAMPLE INFORMATION

Sample Number: 1310285-002 Customer Sample Number: 3035198 Project: LCR
Location: 2nd Draw 3202 38TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.041 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-003

SAMPLE INFORMATION

Sample Number: 1310285-003 Customer Sample Number: 3073211 Project: LCR
Location: 1st Draw 308 9TH ST SE Type: Dist.

Collection Date: 10/21/2013 Collection Time: 17:47 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.043 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-004

SAMPLE INFORMATION

Sample Number: 1310285-004 Customer Sample Number: 3073211 Project: LCR
Location: 2nd Draw 308 9TH ST SE Type: Dist.

Collection Date: 10/21/2013 Collection Time: 17:48 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.018 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-005

SAMPLE INFORMATION

Sample Number: 1310285-005 Customer Sample Number: 3039888 Project: LCR
Location: 1st Draw 5301 RENO RD NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 16:05 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.016 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.064 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0055 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-006

SAMPLE INFORMATION

Sample Number: 1310285-006 Customer Sample Number: 3039888 Project: LCR
Location: 2nd Draw 5301 RENO RD NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 16:10 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.018 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0008 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-011

SAMPLE INFORMATION

Sample Number: 1310285-011 Customer Sample Number: 3039963 Project: LCR
Location: 1st Draw 5404 39TH ST NW Type: Dist.

Collection Date: 10/25/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.058 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-012

SAMPLE INFORMATION

Sample Number: 1310285-012 Customer Sample Number: 3039963 Project: LCR
Location: 2nd Draw 5404 39TH ST NW Type: Dist.

Collection Date: 10/25/2013 Collection Time: 7:08 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.067 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.050 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-025

SAMPLE INFORMATION

Sample Number: 1310285-025 Customer Sample Number: 3008069 Project: LCR
Location: 1st Draw 3036 P ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.021 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.048 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-026

SAMPLE INFORMATION

Sample Number: 1310285-026 Customer Sample Number: 3008069 Project: LCR
Location: 2nd Draw 3036 P ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	11/7/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-001

SAMPLE INFORMATION

Sample Number: 1311001-001 Customer Sample Number: 3103403 Project: LCR
Location: 1st Draw 3416 9TH ST NE Type: Dist.

Collection Date: 10/22/2013 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.080 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-002

SAMPLE INFORMATION

Sample Number: 1311001-002 Customer Sample Number: 3103403 Project: LCR
Location: 2nd Draw 3416 9TH ST NE Type: Dist.

Collection Date: 10/22/2013 Collection Time: 6:24 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.096 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.015 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-003

SAMPLE INFORMATION

Sample Number: 1311001-003 Customer Sample Number: 3052087 Project: LCR
Location: 1st Draw 53 V ST NW Type: Dist.

Collection Date: 10/24/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.039 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-004

SAMPLE INFORMATION

Sample Number: 1311001-004 Customer Sample Number: 3052087 Project: LCR
Location: 2nd Draw 53 V ST NW Type: Dist.

Collection Date: 10/24/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	11/7/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.023 mg/L	11/7/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

11/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-001

SAMPLE INFORMATION

Sample Number: 1311166-001 Customer Sample Number: 3030694 Project: LCR
Location: 1st Draw 3301 BROWN ST NW Type: Dist.

Collection Date: 11/15/2013 Collection Time: 6:04 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-002

SAMPLE INFORMATION

Sample Number: 1311166-002 Customer Sample Number: 3030694 Project: LCR
Location: 2nd Draw 3301 BROWN ST NW Type: Dist.

Collection Date: 11/15/2013 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0047 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-003

SAMPLE INFORMATION

Sample Number: 1311166-003 Customer Sample Number: 3100984 Project: LCR
Location: 1st Draw 1705 D ST NE Type: Dist.

Collection Date: 11/19/2013 Collection Time: 5:26 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.154 mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.034 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0043 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-004

SAMPLE INFORMATION

Sample Number: 1311166-004 Customer Sample Number: 3100984 Project: LCR
Location: 2nd Draw 1705 D ST NE Type: Dist.

Collection Date: 11/19/2013 Collection Time: 5:28 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.117 mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.021 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0103 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-005

SAMPLE INFORMATION

Sample Number: 1311166-005 Customer Sample Number: 3058437 Project: LCR
Location: 1st Draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.125 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-006

SAMPLE INFORMATION

Sample Number: 1311166-006 Customer Sample Number: 3058437 Project: LCR
Location: 2nd Draw 4806 KANSAS AVE NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.128 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0010 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-007

SAMPLE INFORMATION

Sample Number: 1311166-007 Customer Sample Number: 3019513 Project: LCR
Location: 1st Draw 420 KENYON ST. NW Type: Dist.

Collection Date: 11/20/2013 Collection Time: 5:38 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0019 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311166-008

SAMPLE INFORMATION

Sample Number: 1311166-008 Customer Sample Number: 3019513 Project: LCR
Location: 2nd Draw 420 KENYON ST. NW Type: Dist.

Collection Date: 11/20/2013 Collection Time: 5:43 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:41:14 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311195-001

SAMPLE INFORMATION

Sample Number: 1311195-001 Customer Sample Number: 3055102 Project: LCR
Location: 1st draw 3030 44TH ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 6:24 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.034 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311195-002

SAMPLE INFORMATION

Sample Number: 1311195-002 Customer Sample Number: 3055102 Project: LCR
Location: 2nd draw 3030 44TH ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 6:28 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.054 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311195-003

SAMPLE INFORMATION

Sample Number: 1311195-003 Customer Sample Number: 3101136 Project: LCR
Location: 1st draw 1671 ROSEDALE ST NE Type: Dist.

Collection Date: 11/19/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.042 mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.055 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0013 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311195-004

SAMPLE INFORMATION

Sample Number: 1311195-004 Customer Sample Number: 3101136 Project: LCR
Location: 2nd draw 1671 ROSEDALE ST NE Type: Dist.

Collection Date: 11/19/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.052 mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.038 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0007 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311203-001

SAMPLE INFORMATION

Sample Number: 1311203-001 Customer Sample Number: 3018911 Project: LCR
Location: 1st draw 1850 2ND ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 11/27/2013 9:23:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.064 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	12/4/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311203-002

SAMPLE INFORMATION

Sample Number: 1311203-002 Customer Sample Number: 3018911 Project: LCR
Location: 2nd draw 1850 2ND ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 19:00 Sampler: HOME OWNER Received Date and Time: 11/27/2013 9:23:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/4/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.020 mg/L	12/4/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0028 mg/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/12/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1311203-003

SAMPLE INFORMATION

Sample Number: 1311203-003 Customer Sample Number: 3023353 Project: LCR
Location: 1st draw 421 HAMILTON ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 19:59 Sampler: HOME OWNER Received Date and Time: 11/27/2013 9:23:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.957 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.137 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0102 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1311203-004

SAMPLE INFORMATION

Sample Number: 1311203-004 Customer Sample Number: 3023353 Project: LCR
Location: 2nd draw 421 HAMILTON ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 20:01 Sampler: HOME OWNER Received Date and Time: 11/27/2013 9:23:35 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.051 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.009 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-001

SAMPLE INFORMATION

Sample Number: 1312069-001 Customer Sample Number: 3007249 Project: LCR
Location: 1st draw 2719 O ST NW Type: Dist.

Collection Date: 12/3/2013 Collection Time: 18:36 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.011 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.082 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-002

SAMPLE INFORMATION

Sample Number: 1312069-002 Customer Sample Number: 3007249 Project: LCR
Location: 2nd draw 2719 O ST NW Type: Dist.

Collection Date: 12/3/2013 Collection Time: 18:38 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0103 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-003

SAMPLE INFORMATION

Sample Number: 1312069-003 Customer Sample Number: 3029133 Project: LCR
Location: 1st draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 8:05 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.046 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.063 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0021 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-004

SAMPLE INFORMATION

Sample Number: 1312069-004 Customer Sample Number: 3029133 Project: LCR
Location: 2nd draw 1738 ALLISON ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 8:08 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.038 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.040 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-005

SAMPLE INFORMATION

Sample Number: 1312069-005 Customer Sample Number: 3044259 Project: LCR
Location: 1st draw 4447 HAWTHORNE ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.040 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.038 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-006

SAMPLE INFORMATION

Sample Number: 1312069-006 Customer Sample Number: 3044259 Project: LCR
Location: 2nd draw 4447 HAWTHORNE ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 7:01 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.037 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.033 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-007

SAMPLE INFORMATION

Sample Number: 1312069-007 Customer Sample Number: 3107489 Project: LCR
Location: 1st draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 12/5/2013 Collection Time: 5:56 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.179 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.063 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0035 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-008

SAMPLE INFORMATION

Sample Number: 1312069-008 Customer Sample Number: 3107489 Project: LCR
Location: 2nd draw 2832 BRENTWOOD RD NE Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:03 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.237 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0014 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-009

SAMPLE INFORMATION

Sample Number: 1312069-009 Customer Sample Number: 3040894 Project: LCR
Location: 1st draw 3724 CHESAPEAKE ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.092 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-010

SAMPLE INFORMATION

Sample Number: 1312069-010 Customer Sample Number: 3040894 Project: LCR
Location: 2nd draw 3724 CHESAPEAKE ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.028 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.059 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-011

SAMPLE INFORMATION

Sample Number: 1312069-011 Customer Sample Number: 3007205 Project: LCR
Location: 1st draw 1513 27TH ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 9:00 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.042 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0042 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-012

SAMPLE INFORMATION

Sample Number: 1312069-012 Customer Sample Number: 3007205 Project: LCR
Location: 2nd draw 1513 27TH ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 9:03 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.033 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.036 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0046 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-013

SAMPLE INFORMATION

Sample Number: 1312069-013 Customer Sample Number: 3029985 Project: LCR
Location: 1st draw 1375 MONROE ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.049 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0005 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-014

SAMPLE INFORMATION

Sample Number: 1312069-014 Customer Sample Number: 3029985 Project: LCR
Location: 2nd draw 1375 MONROE ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 7:36 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-015

SAMPLE INFORMATION

Sample Number: 1312069-015 Customer Sample Number: 3028265 Project: LCR
Location: 1st draw 1529 UPSHUR ST NW Type: Dist.

Collection Date: 12/6/2013 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.050 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.162 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0012 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-016

SAMPLE INFORMATION

Sample Number: 1312069-016 Customer Sample Number: 3028265 Project: LCR
Location: 2nd draw 1529 UPSHUR ST NW Type: Dist.

Collection Date: 12/6/2013 Collection Time: 5:50 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.065 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.042 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-017

SAMPLE INFORMATION

Sample Number: 1312069-017 Customer Sample Number: 3003009 Project: LCR
Location: 1st draw 1310 R ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.136 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.068 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-018

SAMPLE INFORMATION

Sample Number: 1312069-018 Customer Sample Number: 3003009 Project: LCR
Location: 2nd draw 1310 R ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.093 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-019

SAMPLE INFORMATION

Sample Number: 1312069-019 Customer Sample Number: 3028689 Project: LCR
Location: 1st draw 1305 TAYLOR ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 9:50 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.024 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0023 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-020

SAMPLE INFORMATION

Sample Number: 1312069-020 Customer Sample Number: 3028689 Project: LCR
Location: 2nd draw 1305 TAYLOR ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 9:52 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.048 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.014 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0034 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-021

SAMPLE INFORMATION

Sample Number: 1312069-021 Customer Sample Number: 3030778 Project: LCR
Location: 1st draw 1659 NEWTON ST., NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0017 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-022

SAMPLE INFORMATION

Sample Number: 1312069-022 Customer Sample Number: 3030778 Project: LCR
Location: 2nd draw 1659 NEWTON ST., NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.013 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0026 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312069-023

SAMPLE INFORMATION

Sample Number: 1312069-023 Customer Sample Number: 3101449 Project: LCR
Location: 1st draw 561 23RD PL NE Type: Dist.

Collection Date: 12/4/2013 Collection Time: 0:20 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:59:26 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.029 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.028 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312081-001

SAMPLE INFORMATION

Sample Number: 1312081-001 Customer Sample Number: 3028244 Project: LCR
Location: 1st Draw 1428 VARNUM ST NW Type: Dist.

Collection Date: 12/3/2013 Collection Time: 20:30 Sampler: HOME OWNER Received Date and Time: 10/12/2013 8:24:00 AM Received By: RHoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.017 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.043 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312081-002

SAMPLE INFORMATION

Sample Number: 1312081-002 Customer Sample Number: 3028244 Project: LCR
Location: 2nd Draw 1428 VARNUM ST NW Type: Dist.

Collection Date: 12/3/2013 Collection Time: 20:35 Sampler: HOME OWNER Received Date and Time: 10/12/2013 8:24:00 AM Received By: RHoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.020 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.046 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0022 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312081-003

SAMPLE INFORMATION

Sample Number: 1312081-003 Customer Sample Number: 3039291 Project: LCR
Location: 1st Draw 3722 MCKINLEY ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 10/12/2013 8:24:00 AM Received By: RHoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.065 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0009 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312081-004

SAMPLE INFORMATION

Sample Number: 1312081-004 Customer Sample Number: 3039291 Project: LCR
Location: 2nd Draw 3722 MCKINLEY ST NW Type: Dist.

Collection Date: 12/5/2013 Collection Time: 5:15 Sampler: HOME OWNER Received Date and Time: 10/12/2013 8:24:00 AM Received By: RHoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.010 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.029 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312081-005

SAMPLE INFORMATION

Sample Number: 1312081-005 Customer Sample Number: 3022923 Project: LCR
Location: 1st Draw 5003 7TH ST NW Type: Dist.

Collection Date: 12/6/2013 Collection Time: 4:13 Sampler: HOME OWNER Received Date and Time: 10/12/2013 8:24:00 AM Received By: RHoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.012 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312081-006

SAMPLE INFORMATION

Sample Number: 1312081-006 Customer Sample Number: 3022923 Project: LCR
Location: 2nd Draw 5003 7TH ST NW Type: Dist.

Collection Date: 12/6/2013 Collection Time: 4:16 Sampler: HOME OWNER Received Date and Time: 10/12/2013 8:24:00 AM Received By: RHoward

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.039 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	ND mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312085-001

SAMPLE INFORMATION

Sample Number: 1312085-001 Customer Sample Number: 3100855 Project: LCR
Location: 1st draw 124 16TH ST. NE Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:16:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0024 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312085-002

SAMPLE INFORMATION

Sample Number: 1312085-002 Customer Sample Number: 3100855 Project: LCR
Location: 2nd draw 124 16TH ST. NE Type: Dist.

Collection Date: 12/5/2013 Collection Time: 6:22 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:16:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.010 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0066 mg/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

12/18/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312085-003

SAMPLE INFORMATION

Sample Number: 1312085-003 Customer Sample Number: 3121904 Project: LCR
Location: 1st draw 123 TENNESSEE AVE NE Type: Dist.

Collection Date: 12/6/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:16:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.063 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312085-004

SAMPLE INFORMATION

Sample Number: 1312085-004 Customer Sample Number: 3121904 Project: LCR
Location: 2nd draw 123 TENNESSEE AVE NE Type: Dist.

Collection Date: 12/6/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:16:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.032 mg/L	12/12/2013	RHoward
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.019 mg/L	12/12/2013	RHoward
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	12/12/2013	RHoward

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

Attachment 2

Non-Regulated Lead Samples

Customer Service Samples

DC Water operates a program where customers request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-001

SAMPLE INFORMATION

Sample Number: 1306192-001 Customer Sample Number: 3006288 Program: DS
Location: 1st Draw 415 R ST., NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 21:10 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-002

SAMPLE INFORMATION

Sample Number: 1306192-002 Customer Sample Number: 3006288 Program: DS
Location: 2nd Draw 415 R ST., NW Type: Dist.

Collection Date: 6/12/2013 Collection Time: 21:10 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-003

SAMPLE INFORMATION

Sample Number: 1306192-003 Customer Sample Number: 3128030 Program: DS
Location: 1st Draw 323 K STREET NE Type: Dist.

Collection Date: 6/17/2013 Collection Time: 16:30 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-004

SAMPLE INFORMATION

Sample Number: 1306192-004 Customer Sample Number: 3128030 Program: DS
Location: 2nd Draw 323 K STREET NE Type: Dist.

Collection Date: 6/17/2013 Collection Time: 16:35 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.7 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-005

SAMPLE INFORMATION

Sample Number: 1306192-005 Customer Sample Number: 3027359 Program: DS
Location: 1st Draw 522 UNDERWOOD ST. N.W Type: Dist.

Collection Date: 6/18/2013 Collection Time: 8:06 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/12/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-006

SAMPLE INFORMATION

Sample Number: 1306192-006 Customer Sample Number: 3027359 Program: DS
Location: 2nd Draw 522 UNDERWOOD ST. N.W Type: Dist.

Collection Date: 6/18/2013 Collection Time: 8:10 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/12/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306203-001

SAMPLE INFORMATION

Sample Number: 1306203-001 Customer Sample Number: 3102840 Program: DS
Location: 1st draw 181 UHLAND TER NE Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:48 Sampler: HOME OWNER Received Date and Time: 6/24/2013 10:49:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	7/12/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306203-002

SAMPLE INFORMATION

Sample Number: 1306203-002 Customer Sample Number: 3102840 Program: DS
Location: 2nd draw 181 UHLAND TER NE Type: Dist.

Collection Date: 6/13/2013 Collection Time: 6:51 Sampler: HOME OWNER Received Date and Time: 6/24/2013 10:49:04 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.0 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306220-001

SAMPLE INFORMATION

Sample Number: 1306220-001 Customer Sample Number: 3040113 Program: DS
Location: 1st draw 5318 41ST ST NW Type: Dist.

Collection Date: 6/24/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 6/25/2013 1:48:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306220-002

SAMPLE INFORMATION

Sample Number: 1306220-002 Customer Sample Number: 3040113 Program: DS
Location: 2nd draw 5318 41ST ST NW Type: Dist.

Collection Date: 6/24/2013 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 6/25/2013 1:48:10 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-001

SAMPLE INFORMATION

Sample Number: 1306254-001 Customer Sample Number: 3121411 Program: DS
Location: 1st draw 915 MARYLAND AVE NE Type: Dist.

Collection Date: 6/22/2013 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-002

SAMPLE INFORMATION

Sample Number: 1306254-002 Customer Sample Number: 3121411 Program: DS
Location: 2nd draw 915 MARYLAND AVE NE Type: Dist.

Collection Date: 6/22/2013 Collection Time: 6:02 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-003

SAMPLE INFORMATION

Sample Number: 1306254-003 Customer Sample Number: 3088891 Program: DS
Location: 1st draw 844 51ST ST SE Type: Dist.

Collection Date: 6/22/2013 Collection Time: 22:38 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-004

SAMPLE INFORMATION

Sample Number: 1306254-004 Customer Sample Number: 3088891 Program: DS
Location: 2nd draw 844 51ST ST SE Type: Dist.

Collection Date: 6/22/2013 Collection Time: 22:38 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-005

SAMPLE INFORMATION

Sample Number: 1306254-005 Customer Sample Number: 3100137 Program: DS
Location: 1st draw 1389 D ST NE Type: Dist.

Collection Date: 6/23/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.3 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-006

SAMPLE INFORMATION

Sample Number: 1306254-006 Customer Sample Number: 3100137 Program: DS
Location: 2nd draw 1389 D ST NE Type: Dist.

Collection Date: 6/23/2013 Collection Time: 7:57 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.0 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-007

SAMPLE INFORMATION

Sample Number: 1306254-007 Customer Sample Number: 3127261 Program: DS
Location: 1st draw 646 6TH ST NE Type: Dist.

Collection Date: 6/24/2013 Collection Time: 7:21 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-008

SAMPLE INFORMATION

Sample Number: 1306254-008 Customer Sample Number: 3127261 Program: DS
Location: 2nd draw 646 6TH ST NE Type: Dist.

Collection Date: 6/24/2013 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-013

SAMPLE INFORMATION

Sample Number: 1306254-013 Customer Sample Number: 3034324 Program: DS
Location: 1st draw 1945 BILTMORE ST NW Type: Dist.

Collection Date: 6/27/2013 Collection Time: 19:05 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-014

SAMPLE INFORMATION

Sample Number: 1306254-014 Customer Sample Number: 3034324 Program: DS
Location: 2nd draw 1945 BILTMORE ST NW Type: Dist.

Collection Date: 6/27/2013 Collection Time: 19:07 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307033-001

SAMPLE INFORMATION

Sample Number: 1307033-001 Customer Sample Number: Program: DS
Location: 1st draw 826 CRITTENDEN ST NW Type: Dist.

Collection Date: 6/24/2013 Collection Time: 6:27 Sampler: HOME OWNER Received Date and Time: 7/2/2013 4:08:30 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307033-002

SAMPLE INFORMATION

Sample Number: 1307033-002 Customer Sample Number: Program: DS
Location: 2nd draw 826 CRITTENDEN ST NW Type: Dist.

Collection Date: 6/24/2013 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 7/2/2013 4:08:30 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307033-003

SAMPLE INFORMATION

Sample Number: 1307033-003 Customer Sample Number: 3034638 Program: DS
Location: 1st draw 1616 22ND ST NW Type: Dist.

Collection Date: 6/26/2013 Collection Time: 13:30 Sampler: HOME OWNER Received Date and Time: 7/2/2013 4:08:30 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307033-004

SAMPLE INFORMATION

Sample Number: 1307033-004 Customer Sample Number: 3034638 Program: DS
Location: 2nd draw 1616 22ND ST NW Type: Dist.

Collection Date: 6/26/2013 Collection Time: 13:30 Sampler: HOME OWNER Received Date and Time: 7/2/2013 4:08:30 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-001

SAMPLE INFORMATION

Sample Number: 1307057-001 Customer Sample Number: 3039514 Program: DS
Location: 1st Draw 3511 LEGATION ST NW Type: Dist.

Collection Date: 6/30/2013 Collection Time: 7:41 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.8 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-002

SAMPLE INFORMATION

Sample Number: 1307057-002 Customer Sample Number: 3039514 Program: DS
Location: 2nd Draw 3511 LEGATION ST NW Type: Dist.

Collection Date: 6/30/2013 Collection Time: 7:44 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	23.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-003

SAMPLE INFORMATION

Sample Number: 1307057-003 Customer Sample Number: 3011795 Program: DS
Location: 1st Draw 1640 21ST ST NW APT 1 Type: Dist.

Collection Date: 6/27/2013 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-004

SAMPLE INFORMATION

Sample Number: 1307057-004 Customer Sample Number: 3011795 Program: DS
Location: 2nd Draw 1640 21ST ST NW APT 1 Type: Dist.

Collection Date: 6/27/2013 Collection Time: 17:33 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-005

SAMPLE INFORMATION

Sample Number: 1307057-005 Customer Sample Number: 3060538 Program: DS
Location: 1st Draw 3409 29TH ST NW #4 Type: Dist.

Collection Date: 7/4/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	7/12/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-006

SAMPLE INFORMATION

Sample Number: 1307057-006 Customer Sample Number: 3060538 Program: DS
Location: 2nd Draw 3409 29TH ST NW #4 Type: Dist.

Collection Date: 7/4/2013 Collection Time: 6:31 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-009

SAMPLE INFORMATION

Sample Number: 1307057-009 Customer Sample Number: 3001881 Program: DS
Location: 1st Draw 1616 V ST NW Type: Dist.

Collection Date: 7/4/2013 Collection Time: 7:11 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-010

SAMPLE INFORMATION

Sample Number: 1307057-010 Customer Sample Number: 3001881 Program: DS
Location: 2nd Draw 1616 V ST NW Type: Dist.

Collection Date: 7/4/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.8 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-011

SAMPLE INFORMATION

Sample Number: 1307057-011 Customer Sample Number: 3146701 Program: DS
Location: 1st Draw 808 WHITTIER PL NW Type: Dist.

Collection Date: 7/1/2013 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-012

SAMPLE INFORMATION

Sample Number: 1307057-012 Customer Sample Number: 3146701 Program: DS
Location: 2nd Draw 808 WHITTIER PL NW Type: Dist.

Collection Date: 7/1/2013 Collection Time: 18:23 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307132-001

SAMPLE INFORMATION

Sample Number: 1307132-001 Customer Sample Number: 3040922 Program: DS
Location: 1st draw 3719 CUMBERLAND ST NW Type: Dist.

Collection Date: 7/6/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 7/15/2013 4:04:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.8 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307132-002

SAMPLE INFORMATION

Sample Number: 1307132-002 Customer Sample Number: 3040922 Program: DS
Location: 2nd draw 3719 CUMBERLAND ST NW Type: Dist.

Collection Date: 7/6/2013 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 7/15/2013 4:04:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307132-005

SAMPLE INFORMATION

Sample Number: 1307132-005 Customer Sample Number: 3048212 Program: DS
Location: 1st draw 2001 PLYMOUTH ST NW Type: Dist.

Collection Date: 7/12/2013 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 7/15/2013 4:04:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307132-006

SAMPLE INFORMATION

Sample Number: 1307132-006 Customer Sample Number: 3048212 Program: DS
Location: 2nd draw 2001 PLYMOUTH ST NW Type: Dist.

Collection Date: 7/12/2013 Collection Time: 7:36 Sampler: HOME OWNER Received Date and Time: 7/15/2013 4:04:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307173-001

SAMPLE INFORMATION

Sample Number: 1307173-001 Customer Sample Number: 3101057 Program: DS
Location: 3101057 1716 C ST NE Type: Dist.

Collection Date: 7/12/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 7/19/2013 8:28:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	34.7 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307173-002

SAMPLE INFORMATION

Sample Number: 1307173-002 Customer Sample Number: 3101057 Program: DS
Location: 3101057 1716 C ST NE Type: Dist.

Collection Date: 7/12/2013 Collection Time: 7:13 Sampler: HOME OWNER Received Date and Time: 7/19/2013 8:28:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	12.2 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307173-003

SAMPLE INFORMATION

Sample Number: 1307173-003 Customer Sample Number: 3058591 Program: DS
Location: 3058591 6948 33RD ST NW Type: Dist.

Collection Date: 7/14/2013 Collection Time: 7:40 Sampler: HOME OWNER Received Date and Time: 7/19/2013 8:28:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307173-004

SAMPLE INFORMATION

Sample Number: 1307173-004 Customer Sample Number: 3058591 Program: DS
Location: 3058591 6948 33RD ST NW Type: Dist.

Collection Date: 7/14/2013 Collection Time: 7:43 Sampler: HOME OWNER Received Date and Time: 7/19/2013 8:28:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307173-005

SAMPLE INFORMATION

Sample Number: 1307173-005 Customer Sample Number: 3119843 Program: DS
Location: 3119843 913 HAMILTON ST, NE Type: Dist.

Collection Date: 7/14/2013 Collection Time: 9:41 Sampler: HOME OWNER Received Date and Time: 7/19/2013 8:28:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307173-006

SAMPLE INFORMATION

Sample Number: 1307173-006 Customer Sample Number: 3119843 Program: DS
Location: 3119843 913 HAMILTON ST, NE Type: Dist.

Collection Date: 7/14/2013 Collection Time: 9:43 Sampler: HOME OWNER Received Date and Time: 7/19/2013 8:28:38 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-001

SAMPLE INFORMATION

Sample Number: 1307180-001 Customer Sample Number: 3063063 Program: DS
Location: 1st Draw 117 RHODE ISLAND AVE NE Type: Dist.

Collection Date: 7/17/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-002

SAMPLE INFORMATION

Sample Number: 1307180-002 Customer Sample Number: 3063063 Program: DS
Location: 2nd Draw 117 RHODE ISLAND AVE NE Type: Dist.

Collection Date: 7/17/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-003

SAMPLE INFORMATION

Sample Number: 1307180-003 Customer Sample Number: 3048043 Program: DS
Location: 1st Draw 1311 FERN ST NW Type: Dist.

Collection Date: 7/17/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-004

SAMPLE INFORMATION

Sample Number: 1307180-004 Customer Sample Number: 3048043 Program: DS
Location: 2nd Draw 1311 FERN ST NW Type: Dist.

Collection Date: 7/17/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:00 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-005

SAMPLE INFORMATION

Sample Number: 1307180-005 Customer Sample Number: 3085210 Program: DS
Location: 1st Draw 3008 K ST. SE Type: Dist.

Collection Date: 7/18/2013 Collection Time: 6:33 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-006

SAMPLE INFORMATION

Sample Number: 1307180-006 Customer Sample Number: 3085210 Program: DS
Location: 2nd Draw 3008 K ST. SE Type: Dist.

Collection Date: 7/18/2013 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-007

SAMPLE INFORMATION

Sample Number: 1307180-007 Customer Sample Number: 3098841 Program: DS
Location: 1st Draw 1027 7TH ST NE Type: Dist.

Collection Date: 7/16/2013 Collection Time: 6:12 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307180-008

SAMPLE INFORMATION

Sample Number: 1307180-008 Customer Sample Number: 3098841 Program: DS
Location: 2nd Draw 1027 7TH ST NE Type: Dist.

Collection Date: 7/16/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 7/19/2013 2:51:57 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307213-001

SAMPLE INFORMATION

Sample Number: 1307213-001 Customer Sample Number: 3072266 Program: DS
Location: 1st draw 423 4TH ST SE Type: Dist.

Collection Date: 7/22/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 7/24/2013 12:38:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307213-002

SAMPLE INFORMATION

Sample Number: 1307213-002 Customer Sample Number: 3072266 Program: DS
Location: 2nd draw 423 4TH ST SE Type: Dist.

Collection Date: 7/22/2013 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 7/24/2013 12:38:16 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307249-001

SAMPLE INFORMATION

Sample Number: 1307249-001 Customer Sample Number: 3021620 Program: DS
Location: 1st draw 4409 3RD ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:31:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307249-002

SAMPLE INFORMATION

Sample Number: 1307249-002 Customer Sample Number: 3021620 Program: DS
Location: 2nd draw 4409 3RD ST NW Type: Dist.

Collection Date: 7/24/2013 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 7/29/2013 11:31:45 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308001-001

SAMPLE INFORMATION

Sample Number: 1308001-001 Customer Sample Number: 3111579 Program: DS
Location: 1st Draw 129 RITTENHOUSE ST NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 8/1/2013 8:41:17 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308001-002

SAMPLE INFORMATION

Sample Number: 1308001-002 Customer Sample Number: 3111579 Program: DS
Location: 2nd Draw 129 RITTENHOUSE ST NE Type: Dist.

Collection Date: 7/23/2013 Collection Time: 5:55 Sampler: HOME OWNER Received Date and Time: 8/1/2013 8:41:17 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308001-003

SAMPLE INFORMATION

Sample Number: 1308001-003 Customer Sample Number: 3036898 Program: DS
Location: 1st Draw 3640 FESSENDEN ST NW Type: Dist.

Collection Date: 7/27/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 8/1/2013 8:41:17 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308001-004

SAMPLE INFORMATION

Sample Number: 1308001-004 Customer Sample Number: 3036898 Program: DS
Location: 2nd Draw 3640 FESSENDEN ST NW Type: Dist.

Collection Date: 7/27/2013 Collection Time: 8:04 Sampler: HOME OWNER Received Date and Time: 8/1/2013 8:41:17 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308001-005

SAMPLE INFORMATION

Sample Number: 1308001-005 Customer Sample Number: 3085724 Program: DS
Location: 1st Draw 2317 SAVANNAH ST SE Type: Dist.

Collection Date: 7/27/2013 Collection Time: 15:50 Sampler: HOME OWNER Received Date and Time: 8/1/2013 8:41:17 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308001-006

SAMPLE INFORMATION

Sample Number: 1308001-006 Customer Sample Number: 3085724 Program: DS
Location: 2nd Draw 2317 SAVANNAH ST SE Type: Dist.

Collection Date: 7/27/2013 Collection Time: 15:55 Sampler: HOME OWNER Received Date and Time: 8/1/2013 8:41:17 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308005-001

SAMPLE INFORMATION

Sample Number: 1308005-001 Customer Sample Number: 3032502 Program: DS
Location: 1st draw 745 GRESHAM PL NW Type: Dist.

Collection Date: 7/21/2013 Collection Time: 7:22 Sampler: HOME OWNER Received Date and Time: 8/1/2013 11:23:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308005-002

SAMPLE INFORMATION

Sample Number: 1308005-002 Customer Sample Number: 3032502 Program: DS
Location: 2nd draw 745 GRESHAM PL NW Type: Dist.

Collection Date: 7/21/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 8/1/2013 11:23:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308043-001

SAMPLE INFORMATION

Sample Number: 1308043-001 Customer Sample Number: 3001947 Program: DS
Location: 1st draw 1626 S ST NW Type: Dist.

Collection Date: 7/29/2013 Collection Time: 18:47 Sampler: HOME OWNER Received Date and Time: 8/6/2013 9:35:16 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308043-002

SAMPLE INFORMATION

Sample Number: 1308043-002 Customer Sample Number: 3001947 Program: DS
Location: 2nd draw 1626 S ST NW Type: Dist.

Collection Date: 7/29/2013 Collection Time: 18:48 Sampler: HOME OWNER Received Date and Time: 8/6/2013 9:35:16 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308043-003

SAMPLE INFORMATION

Sample Number: 1308043-003 Customer Sample Number: 3120946 Program: DS
Location: 1st draw 404 M ST NE Type: Dist.

Collection Date: 8/1/2013 Collection Time: 22:46 Sampler: HOME OWNER Received Date and Time: 8/6/2013 9:35:16 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308043-004

SAMPLE INFORMATION

Sample Number: 1308043-004 Customer Sample Number: 3120946 Program: DS
Location: 2nd draw 404 M ST NE Type: Dist.

Collection Date: 8/1/2013 Collection Time: 22:49 Sampler: HOME OWNER Received Date and Time: 8/6/2013 9:35:16 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308043-005

SAMPLE INFORMATION

Sample Number: 1308043-005 Customer Sample Number: 3021387 Program: DS
Location: 1st draw 4311 4TH ST NW Type: Dist.

Collection Date: 8/1/2013 Collection Time: 6:47 Sampler: HOME OWNER Received Date and Time: 8/6/2013 9:35:16 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308043-006

SAMPLE INFORMATION

Sample Number: 1308043-006 Customer Sample Number: 3021387 Program: DS
Location: 2nd draw 4311 4TH ST NW Type: Dist.

Collection Date: 8/1/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 8/6/2013 9:35:16 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-001

SAMPLE INFORMATION

Sample Number: 1308120-001 Customer Sample Number: 3050059 Program: DS
Location: 1st draw 125 RANDOLPH PL NW Type: Dist.

Collection Date: 8/4/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-002

SAMPLE INFORMATION

Sample Number: 1308120-002 Customer Sample Number: 3050059 Program: DS
Location: 2nd draw 125 RANDOLPH PL NW Type: Dist.

Collection Date: 8/4/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.8 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-003

SAMPLE INFORMATION

Sample Number: 1308120-003 Customer Sample Number: 3010174 Program: DS
Location: 1st draw 2209 39TH ST NW Type: Dist.

Collection Date: 8/5/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-004

SAMPLE INFORMATION

Sample Number: 1308120-004 Customer Sample Number: 3010174 Program: DS
Location: 2nd draw 2209 39TH ST NW Type: Dist.

Collection Date: 8/5/2013 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-005

SAMPLE INFORMATION

Sample Number: 1308120-005 Customer Sample Number: 3056957 Program: DS
Location: 1st draw 607 UPSHUR ST NW Type: Dist.

Collection Date: 8/5/2013 Collection Time: 18:19 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-006

SAMPLE INFORMATION

Sample Number: 1308120-006 Customer Sample Number: 3056957 Program: DS
Location: 2nd draw 607 UPSHUR ST NW Type: Dist.

Collection Date: 8/5/2013 Collection Time: 18:20 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-007

SAMPLE INFORMATION

Sample Number: 1308120-007 Customer Sample Number: 3024418 Program: DS
Location: 1st draw 821 MADISON ST NW Type: Dist.

Collection Date: 8/7/2013 Collection Time: 22:00 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.3 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-008

SAMPLE INFORMATION

Sample Number: 1308120-008 Customer Sample Number: 3024418 Program: DS
Location: 2nd draw 821 MADISON ST NW Type: Dist.

Collection Date: 8/7/2013 Collection Time: 22:02 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-009

SAMPLE INFORMATION

Sample Number: 1308120-009 Customer Sample Number: 3111492 Program: DS
Location: 1st draw 5514 BLAIR RD NE Type: Dist.

Collection Date: 8/8/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-010

SAMPLE INFORMATION

Sample Number: 1308120-010 Customer Sample Number: 3111492 Program: DS
Location: 2nd draw 5514 BLAIR RD NE Type: Dist.

Collection Date: 8/8/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-011

SAMPLE INFORMATION

Sample Number: 1308120-011 Customer Sample Number: 3107172 Program: DS
Location: 1st draw 2224 EVARTS ST NE Type: Dist.

Collection Date: 8/9/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308120-012

SAMPLE INFORMATION

Sample Number: 1308120-012 Customer Sample Number: 3107172 Program: DS
Location: 2nd draw 2224 EVARTS ST NE Type: Dist.

Collection Date: 8/9/2013 Collection Time: 7:10 Sampler: HOME OWNER Received Date and Time: 8/13/2013 4:08:15 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308149-001

SAMPLE INFORMATION

Sample Number: 1308149-001 Customer Sample Number: 3080308 Program: DS
Location: 1st draw 3182 WESTOVER DR SE Type: Dist.

Collection Date: 8/11/2013 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 8/15/2013 12:48:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.4 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308149-002

SAMPLE INFORMATION

Sample Number: 1308149-002 Customer Sample Number: 3080308 Program: DS
Location: 2nd draw 3182 WESTOVER DR SE Type: Dist.

Collection Date: 8/11/2013 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 8/15/2013 12:48:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308149-003

SAMPLE INFORMATION

Sample Number: 1308149-003 Customer Sample Number: 3090610 Program: DS
Location: 1st draw 837 HR DRIVE SE Type: Dist.

Collection Date: 8/5/2013 Collection Time: 19:08 Sampler: HOME OWNER Received Date and Time: 8/15/2013 12:48:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308149-004

SAMPLE INFORMATION

Sample Number: 1308149-004 Customer Sample Number: 3090610 Program: DS
Location: 2nd draw 837 HR DRIVE SE Type: Dist.

Collection Date: 8/5/2013 Collection Time: 19:09 Sampler: HOME OWNER Received Date and Time: 8/15/2013 12:48:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308157-001

SAMPLE INFORMATION

Sample Number: 1308157-001 Customer Sample Number: 3021120 Program: DS
Location: 1st Draw 4114 3RD ST NW Type: Dist.

Collection Date: 8/13/2013 Collection Time: 5:44 Sampler: HOME OWNER Received Date and Time: 8/16/2013 9:24:47 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308157-002

SAMPLE INFORMATION

Sample Number: 1308157-002 Customer Sample Number: 3021120 Program: DS
Location: 2nd Draw 4114 3RD ST NW Type: Dist.

Collection Date: 8/13/2013 Collection Time: 5:48 Sampler: HOME OWNER Received Date and Time: 8/16/2013 9:24:47 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308216-001

SAMPLE INFORMATION

Sample Number: 1308216-001 Customer Sample Number: 3107953 Program: DS
Location: 1st draw 3022 CHANNING ST NE Type: Dist.

Collection Date: 8/16/2013 Collection Time: 17:10 Sampler: HOME OWNER Received Date and Time: 8/23/2013 8:48:54 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.6 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308216-002

SAMPLE INFORMATION

Sample Number: 1308216-002 Customer Sample Number: 3107953 Program: DS
Location: 2nd draw 3022 CHANNING ST NE Type: Dist.

Collection Date: 8/16/2013 Collection Time: 17:16 Sampler: HOME OWNER Received Date and Time: 8/23/2013 8:48:54 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308216-003

SAMPLE INFORMATION

Sample Number: 1308216-003 Customer Sample Number: 3000214 Program:
Location: 1st draw 2421 EYE ST NW Type: Dist.

Collection Date: 8/19/2013 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 8/23/2013 8:48:54 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308216-004

SAMPLE INFORMATION

Sample Number: 1308216-004 Customer Sample Number: 3000214 Program:
Location: 2nd draw 2421 EYE ST NW Type: Dist.

Collection Date: 8/19/2013 Collection Time: 6:55 Sampler: HOME OWNER Received Date and Time: 8/23/2013 8:48:54 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/27/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308231-001

SAMPLE INFORMATION

Sample Number: 1308231-001 Customer Sample Number: 3031956 Program: DS
Location: 1st draw 3103 11TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 8/26/2013 2:23:54 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308231-002

SAMPLE INFORMATION

Sample Number: 1308231-002 Customer Sample Number: 3031956 Program: DS
Location: 2nd draw 3103 11TH ST NW Type: Dist.

Collection Date: 8/20/2013 Collection Time: 6:19 Sampler: HOME OWNER Received Date and Time: 8/26/2013 2:23:54 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308276-001

SAMPLE INFORMATION

Sample Number: 1308276-001 Customer Sample Number: 3035576 Program: DS
Location: 1st Draw 2826 27TH STREET NW Type: Dist.

Collection Date: 8/27/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 8/30/2013 10:26:03 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308276-002

SAMPLE INFORMATION

Sample Number: 1308276-002 Customer Sample Number: 3035576 Program: DS
Location: 2nd Draw 2826 27TH STREET NW Type: Dist.

Collection Date: 8/27/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 8/30/2013 10:26:03 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.7 ug/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-001

SAMPLE INFORMATION

Sample Number: 1309041-001 Customer Sample Number: 3124214 Program: DS
Location: 1st draw 402 7TH ST NE Type: Dist.

Collection Date: 8/27/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-002

SAMPLE INFORMATION

Sample Number: 1309041-002 Customer Sample Number: 3124214 Program: DS
Location: 2nd draw 402 7TH ST NE Type: Dist.

Collection Date: 8/27/2013 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-003

SAMPLE INFORMATION

Sample Number: 1309041-003 Customer Sample Number: 3071329 Program: DS
Location: 1st draw 129 E ST SE Type: Dist.

Collection Date: 8/27/2013 Collection Time: 9:54 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-004

SAMPLE INFORMATION

Sample Number: 1309041-004 Customer Sample Number: 3071329 Program: DS
Location: 2nd draw 129 E ST SE Type: Dist.

Collection Date: 8/27/2013 Collection Time: 9:56 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.7 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-007

SAMPLE INFORMATION

Sample Number: 1309041-007 Customer Sample Number: 3028822 Program: DS
Location: 1st draw 1718 UPSHUR ST NW Type: Dist.

Collection Date: 8/28/2013 Collection Time: 6:14 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-008

SAMPLE INFORMATION

Sample Number: 1309041-008 Customer Sample Number: 3028822 Program: DS
Location: 2nd draw 1718 UPSHUR ST NW Type: Dist.

Collection Date: 8/28/2013 Collection Time: 6:16 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-009

SAMPLE INFORMATION

Sample Number: 1309041-009 Customer Sample Number: 3071752 Program: DS
Location: 1st draw 9 5TH ST SE Type: Dist.

Collection Date: 8/31/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-010

SAMPLE INFORMATION

Sample Number: 1309041-010 Customer Sample Number: 3071752 Program: DS
Location: 2nd draw 9 5TH ST SE Type: Dist.

Collection Date: 8/31/2013 Collection Time: 7:50 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309097-001

SAMPLE INFORMATION

Sample Number: 1309097-001 Customer Sample Number: 3021711 Program: DS
Location: 1st draw 827 ALLISON ST NW Type: Dist.

Collection Date: 9/2/2013 Collection Time: 6:50 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:42:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309097-002

SAMPLE INFORMATION

Sample Number: 1309097-002 Customer Sample Number: 3021711 Program: DS
Location: 2nd draw 827 ALLISON ST NW Type: Dist.

Collection Date: 9/2/2013 Collection Time: 6:52 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:42:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309097-003

SAMPLE INFORMATION

Sample Number: 1309097-003 Customer Sample Number: 3010396 Program: DS
Location: 1st draw 2454 39TH PL NW Type: Dist.

Collection Date: 9/4/2013 Collection Time: 7:43 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:42:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309097-004

SAMPLE INFORMATION

Sample Number: 1309097-004 Customer Sample Number: 3010396 Program: DS
Location: 2nd draw 2454 39TH PL NW Type: Dist.

Collection Date: 9/4/2013 Collection Time: 7:49 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:42:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309097-005

SAMPLE INFORMATION

Sample Number: 1309097-005 Customer Sample Number: 3024322 Program: DS
Location: 1st draw 5707 5TH ST NW Type: Dist.

Collection Date: 9/9/2013 Collection Time: 8:33 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:42:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.8 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309097-006

SAMPLE INFORMATION

Sample Number: 1309097-006 Customer Sample Number: 3024322 Program: DS
Location: 2nd draw 5707 5TH ST NW Type: Dist.

Collection Date: 9/9/2013 Collection Time: 8:36 Sampler: HOME OWNER Received Date and Time: 9/11/2013 4:42:49 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	14.2 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-001

SAMPLE INFORMATION

Sample Number: 1309136-001 Customer Sample Number: 3058041 Program: DS
Location: 1st draw 5308 RENO RD NW Type: Dist.

Collection Date: 9/10/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-002

SAMPLE INFORMATION

Sample Number: 1309136-002 Customer Sample Number: 3058041 Program: DS
Location: 2nd draw 5308 RENO RD NW Type: Dist.

Collection Date: 9/10/2013 Collection Time: 6:35 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	9/19/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-003

SAMPLE INFORMATION

Sample Number: 1309136-003 Customer Sample Number: 3059349 Program: DS
Location: 1st draw 1717 POPLAR LN NW Type: Dist.

Collection Date: 9/11/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.0 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-004

SAMPLE INFORMATION

Sample Number: 1309136-004 Customer Sample Number: 3059349 Program: DS
Location: 2nd draw 1717 POPLAR LN NW Type: Dist.

Collection Date: 9/11/2013 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-005

SAMPLE INFORMATION

Sample Number: 1309136-005 Customer Sample Number: 3104935 Program: DS
Location: 1st draw 2901 15TH ST NE Type: Dist.

Collection Date: 9/13/2013 Collection Time: 5:30 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	9.9 ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-006

SAMPLE INFORMATION

Sample Number: 1309136-006 Customer Sample Number: 3104935 Program: DS
Location: 2nd draw 2901 15TH ST NE Type: Dist.

Collection Date: 9/13/2013 Collection Time: 5:38 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	9/19/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309167-001

SAMPLE INFORMATION

Sample Number: 1309167-001 Customer Sample Number: 3113282 Program: DS
Location: 1st draw 605 GIRARD ST NE Type: Dist.

Collection Date: 9/14/2013 Collection Time: 8:08 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:19:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.3 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309167-002

SAMPLE INFORMATION

Sample Number: 1309167-002 Customer Sample Number: 3113282 Program: DS
Location: 2nd draw 605 GIRARD ST NE Type: Dist.

Collection Date: 9/14/2013 Collection Time: 8:11 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:19:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.1 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309167-003

SAMPLE INFORMATION

Sample Number: 1309167-003 Customer Sample Number: 3053448 Program: DS
Location: 1st draw 3337 RUNNYMEDE PL NW Type: Dist.

Collection Date: 9/15/2013 Collection Time: 12:15 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:19:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309167-004

SAMPLE INFORMATION

Sample Number: 1309167-004 Customer Sample Number: 3053448 Program: DS
Location: 2nd draw 3337 RUNNYMEDE PL NW Type: Dist.

Collection Date: 9/15/2013 Collection Time: 12:18 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:19:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309167-005

SAMPLE INFORMATION

Sample Number: 1309167-005 Customer Sample Number: 3042277 Program: DS
Location: 1st draw 4901 43RD ST NW Type: Dist.

Collection Date: 9/17/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:19:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309167-006

SAMPLE INFORMATION

Sample Number: 1309167-006 Customer Sample Number: 3042277 Program: DS
Location: 2nd draw 4901 43RD ST NW Type: Dist.

Collection Date: 9/17/2013 Collection Time: 8:04 Sampler: HOME OWNER Received Date and Time: 9/19/2013 10:19:43 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309181-001

SAMPLE INFORMATION

Sample Number: 1309181-001 Customer Sample Number: 3034143 Program: DS
Location: 1st draw 1847 ONTARIO PL. NW Type: Dist.

Collection Date: 9/17/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 9/20/2013 7:56:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.2 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309181-002

SAMPLE INFORMATION

Sample Number: 1309181-002 Customer Sample Number: 3034143 Program: DS
Location: 2nd draw 1847 ONTARIO PL. NW Type: Dist.

Collection Date: 9/17/2013 Collection Time: 6:20 Sampler: HOME OWNER Received Date and Time: 9/20/2013 7:56:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309232-001

SAMPLE INFORMATION

Sample Number: 1309232-001 Customer Sample Number: 3030097 Program: DS
Location: 1st draw 1354 OTIS PLACE NW Type: Dist.

Collection Date: 9/16/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 9/25/2013 4:08:37 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309232-002

SAMPLE INFORMATION

Sample Number: 1309232-002 Customer Sample Number: 3030097 Program: DS
Location: 2nd draw 1354 OTIS PLACE NW Type: Dist.

Collection Date: 9/16/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 9/25/2013 4:08:37 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.5 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309244-001

SAMPLE INFORMATION

Sample Number: 1309244-001 Customer Sample Number: 3032243 Program: DS
Location: 1st draw 734 COLUMBIA RD NW Type: Dist.

Collection Date: 9/22/2013 Collection Time: 9:48 Sampler: HOME OWNER Received Date and Time: 9/27/2013 8:18:11 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	12.4 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309244-002

SAMPLE INFORMATION

Sample Number: 1309244-002 Customer Sample Number: 3032243 Program: DS
Location: 2nd draw 734 COLUMBIA RD NW Type: Dist.

Collection Date: 9/22/2013 Collection Time: 9:50 Sampler: HOME OWNER Received Date and Time: 9/27/2013 8:18:11 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	11.2 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309244-003

SAMPLE INFORMATION

Sample Number: 1309244-003 Customer Sample Number: 3105306 Program: DS
Location: 1st draw 3308 18TH ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 5:54 Sampler: HOME OWNER Received Date and Time: 9/27/2013 8:18:11 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1309244-004

SAMPLE INFORMATION

Sample Number: 1309244-004 Customer Sample Number: 3105306 Program: DS
Location: 2nd draw 3308 18TH ST NE Type: Dist.

Collection Date: 9/25/2013 Collection Time: 5:57 Sampler: HOME OWNER Received Date and Time: 9/27/2013 8:18:11 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-001

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-001 Customer Sample Number: 3127592 Program: DS
Location: 1st draw 1036 6TH ST NE #102 Type: Dist.
Collection Date: 9/25/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	22.1 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-002

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-002 Customer Sample Number: 3127592 Program: DS
Location: 2nd draw 1036 6TH ST NE #102 Type: Dist.

Collection Date: 9/25/2013 Collection Time: 6:18 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.0 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-003

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-003 Customer Sample Number: 3030875 Program: DS
Location: 1st draw 1318 VERMONT AVE NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-004

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-004 Customer Sample Number: 3030875 Program: DS
Location: 2nd draw 1318 VERMONT AVE NW Type: Dist.

Collection Date: 9/25/2013 Collection Time: 7:28 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-005

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-005 Customer Sample Number: 3023804 Program: DS
Location: 1st draw 440 JEFFERSON ST NW Type: Dist.

Collection Date: 9/26/2013 Collection Time: 5:45 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-006

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-006 Customer Sample Number: 3023804 Program: DS
Location: 2nd draw 440 JEFFERSON ST NW Type: Dist.

Collection Date: 9/26/2013 Collection Time: 5:47 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-007

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-007 Customer Sample Number: 3106881 Program: DS
Location: 1st draw 3028 24TH ST NE Type: Dist.
Collection Date: 9/26/2013 Collection Time: 6:06 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-008

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-008 Customer Sample Number: 3106881 Program: DS
Location: 2nd draw 3028 24TH ST NE Type: Dist.

Collection Date: 9/26/2013 Collection Time: 6:10 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-009

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-009 Customer Sample Number: 3002970 Program: DS
Location: 1st draw 1323 RIGGS ST NW Type: Dist.
Collection Date: 9/27/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority

Report Date: 10/22/2013
Report Number: LC-W1310003-010

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

SAMPLE INFORMATION

Sample Number: 1310003-010 Customer Sample Number: 3002970 Program: DS
Location: 2nd draw 1323 RIGGS ST NW Type: Dist.

Collection Date: 9/27/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/1/2013 10:53:53 AM Received By: DGambrah

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310046-001

SAMPLE INFORMATION

Sample Number: 1310046-001 Customer Sample Number: 3055951 Program: DS
Location: 1st draw 4333 46TH ST NW Type: Dist.

Collection Date: 9/29/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:48:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310046-002

SAMPLE INFORMATION

Sample Number: 1310046-002 Customer Sample Number: 3055951 Program: DS
Location: 2nd draw 4333 46TH ST NW Type: Dist.

Collection Date: 9/29/2013 Collection Time: 7:38 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:48:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310046-003

SAMPLE INFORMATION

Sample Number: 1310046-003 Customer Sample Number: 3098828 Program: DS
Location: 1st draw 1012 8TH ST NE Type: Dist.

Collection Date: 9/30/2013 Collection Time: 19:03 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:48:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310046-004

SAMPLE INFORMATION

Sample Number: 1310046-004 Customer Sample Number: 3098828 Program: DS
Location: 2nd draw 1012 8TH ST NE Type: Dist.

Collection Date: 9/30/2013 Collection Time: 19:08 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:48:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	5.9 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310046-005

SAMPLE INFORMATION

Sample Number: 1310046-005 Customer Sample Number: 3020751 Program: DS
Location: 1st draw 445 RANDOLPH ST NW Type: Dist.

Collection Date: 10/2/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:48:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.8 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310046-006

SAMPLE INFORMATION

Sample Number: 1310046-006 Customer Sample Number: 3020751 Program: DS
Location: 2nd draw 445 RANDOLPH ST NW Type: Dist.

Collection Date: 10/2/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 10/4/2013 12:48:17 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.4 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-001

SAMPLE INFORMATION

Sample Number: 1310106-001 Customer Sample Number: 3100735 Program: DS
Location: 1st draw 1523 ISHERWOOD ST NE Type: Dist.

Collection Date: 10/2/2013 Collection Time: 17:46 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-002

SAMPLE INFORMATION

Sample Number: 1310106-002 Customer Sample Number: 3100735 Program: DS
Location: 2nd draw 1523 ISHERWOOD ST NE Type: Dist.

Collection Date: 10/2/2013 Collection Time: 17:50 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-003

SAMPLE INFORMATION

Sample Number: 1310106-003 Customer Sample Number: 3072089 Program: DS
Location: 1st draw 505 G ST SE Type: Dist.

Collection Date: 10/3/2013 Collection Time: 8:16 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-004

SAMPLE INFORMATION

Sample Number: 1310106-004 Customer Sample Number: 3072089 Program: DS
Location: 2nd draw 505 G ST SE Type: Dist.

Collection Date: 10/3/2013 Collection Time: 8:18 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-005

SAMPLE INFORMATION

Sample Number: 1310106-005 Customer Sample Number: 3075015 Program: DS
Location: 1st draw 1415 S. CAROLINA AVE SE Type: Dist.

Collection Date: 10/3/2013 Collection Time: 17:39 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-006

SAMPLE INFORMATION

Sample Number: 1310106-006 Customer Sample Number: 3075015 Program: DS
Location: 2nd draw 1415 S. CAROLINA AVE SE Type: Dist.

Collection Date: 10/3/2013 Collection Time: 17:40 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.7 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-007

SAMPLE INFORMATION

Sample Number: 1310106-007 Customer Sample Number: 3084157 Program: DS
Location: 1st draw 1527 FORT DUPONT ST SE Type: Dist.

Collection Date: 10/4/2013 Collection Time: 17:30 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-008

SAMPLE INFORMATION

Sample Number: 1310106-008 Customer Sample Number: 3084157 Program: DS
Location: 2nd draw 1527 FORT DUPONT ST SE Type: Dist.

Collection Date: 10/4/2013 Collection Time: 17:36 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-009

SAMPLE INFORMATION

Sample Number: 1310106-009 Customer Sample Number: 3033757 Program: DS
Location: 1st draw 1737 HOBART ST NW Type: Dist.

Collection Date: 10/7/2013 Collection Time: 5:00 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310106-010

SAMPLE INFORMATION

Sample Number: 1310106-010 Customer Sample Number: 3033757 Program: DS
Location: 2nd draw 1737 HOBART ST NW Type: Dist.

Collection Date: 10/7/2013 Collection Time: 5:05 Sampler: HOME OWNER Received Date and Time: 10/9/2013 4:04:53 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	10/17/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310150-001

SAMPLE INFORMATION

Sample Number: 1310150-001 Customer Sample Number: 3074302 Program: DS
Location: 1st draw 125 KENTUCKY AVE SE Type: Dist.

Collection Date: 10/1/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 10/16/2013 8:50:07 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310150-002

SAMPLE INFORMATION

Sample Number: 1310150-002 Customer Sample Number: 3074302 Program: DS
Location: 2nd draw 125 KENTUCKY AVE SE Type: Dist.

Collection Date: 10/1/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 10/16/2013 8:50:07 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310150-003

SAMPLE INFORMATION

Sample Number: 1310150-003 Customer Sample Number: 3032090 Program: DS
Location: 1st draw 720 MORTON ST NW Type: Dist.

Collection Date: 10/4/2013 Collection Time: 10:00 Sampler: HOME OWNER Received Date and Time: 10/16/2013 8:50:07 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310150-004

SAMPLE INFORMATION

Sample Number: 1310150-004 Customer Sample Number: 3032090 Program: DS
Location: 2nd draw 720 MORTON ST NW Type: Dist.

Collection Date: 10/4/2013 Collection Time: 10:03 Sampler: HOME OWNER Received Date and Time: 10/16/2013 8:50:07 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.1 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310150-005

SAMPLE INFORMATION

Sample Number: 1310150-005 Customer Sample Number: 3021367 Program: DS
Location: 1st draw 623 VARNUM ST NW Type: Dist.

Collection Date: 10/7/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/16/2013 8:50:07 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.0 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/22/2013
Report Number: LC-W1310150-006

SAMPLE INFORMATION

Sample Number: 1310150-006 Customer Sample Number: 3021367 Program: DS
Location: 2nd draw 623 VARNUM ST NW Type: Dist.

Collection Date: 10/7/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 10/16/2013 8:50:07 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.9 ug/L	10/17/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

10/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310246-001

SAMPLE INFORMATION

Sample Number: 1310246-001 Customer Sample Number: 3097897 Program: DS
Location: 1st draw 312 3RD ST. NE INSIDE Type: Dist.

Collection Date: 10/18/2013 Collection Time: 8:14 Sampler: HOME OWNER Received Date and Time: 10/25/2013 1:44:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310246-002

SAMPLE INFORMATION

Sample Number: 1310246-002 Customer Sample Number: 3097897 Program: DS
Location: 2nd draw 312 3RD ST. NE INSIDE Type: Dist.

Collection Date: 10/18/2013 Collection Time: 8:20 Sampler: HOME OWNER Received Date and Time: 10/25/2013 1:44:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310246-003

SAMPLE INFORMATION

Sample Number: 1310246-003 Customer Sample Number: 3030427 Program: DS
Location: 1st draw 1435 PARKWOOD PL NW Type: Dist.

Collection Date: 10/16/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 10/25/2013 1:44:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310246-004

SAMPLE INFORMATION

Sample Number: 1310246-004 Customer Sample Number: 3030427 Program: DS
Location: 2nd draw 1435 PARKWOOD PL NW Type: Dist.

Collection Date: 10/16/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 10/25/2013 1:44:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310246-005

SAMPLE INFORMATION

Sample Number: 1310246-005 Customer Sample Number: 3030102 Program: DS
Location: 1st draw 1344 OTIS PLACE NW Type: Dist.

Collection Date: 10/20/2013 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 10/25/2013 1:44:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.0 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310246-006

SAMPLE INFORMATION

Sample Number: 1310246-006 Customer Sample Number: 3030102 Program: DS
Location: 2nd draw 1344 OTIS PLACE NW Type: Dist.

Collection Date: 10/20/2013 Collection Time: 8:47 Sampler: HOME OWNER Received Date and Time: 10/25/2013 1:44:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	11.1 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-011

SAMPLE INFORMATION

Sample Number: 1310266-011 Customer Sample Number: 3028049 Program: DS
Location: 1st Draw 4507 13TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 17:43 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310266-012

SAMPLE INFORMATION

Sample Number: 1310266-012 Customer Sample Number: 3028049 Program: DS
Location: 2nd Draw 4507 13TH ST NW Type: Dist.

Collection Date: 10/22/2013 Collection Time: 17:45 Sampler: HOME OWNER Received Date and Time: 10/29/2013 8:58:24 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-007

SAMPLE INFORMATION

Sample Number: 1310285-007 Customer Sample Number: 3106120 Program: DS
Location: 1st Draw 2031 HAMLIN ST NE Type: Dist.

Collection Date: 10/21/2013 Collection Time: 18:36 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.4 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-008

SAMPLE INFORMATION

Sample Number: 1310285-008 Customer Sample Number: 3106120 Program: DS
Location: 2nd Draw 2031 HAMLIN ST NE Type: Dist.

Collection Date: 10/21/2013 Collection Time: 18:40 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-009

SAMPLE INFORMATION

Sample Number: 1310285-009 Customer Sample Number: 3030875 Program: DS
Location: 1st Draw 3325 18TH ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 6:15 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-010

SAMPLE INFORMATION

Sample Number: 1310285-010 Customer Sample Number: 3030875 Program: DS
Location: 2nd Draw 3325 18TH ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 6:26 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-013

SAMPLE INFORMATION

Sample Number: 1310285-013 Customer Sample Number: 3029587 Program: DS
Location: 1st Draw 938 QUINCY ST NW Type: Dist.

Collection Date: 10/28/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-014

SAMPLE INFORMATION

Sample Number: 1310285-014 Customer Sample Number: 3029587 Program: DS
Location: 2nd Draw 938 QUINCY ST NW Type: Dist.

Collection Date: 10/28/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-015

SAMPLE INFORMATION

Sample Number: 1310285-015 Customer Sample Number: 3053828 Program: DS
Location: 1st Draw 1404 MERIDIAN PL NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-016

SAMPLE INFORMATION

Sample Number: 1310285-016 Customer Sample Number: 3053828 Program: DS
Location: 2nd Draw 1404 MERIDIAN PL NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-017

SAMPLE INFORMATION

Sample Number: 1310285-017 Customer Sample Number: 3018927 Program: DS
Location: 1st Draw 1854 3RD ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 7:02 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.0 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-018

SAMPLE INFORMATION

Sample Number: 1310285-018 Customer Sample Number: 3018927 Program: DS
Location: 2nd Draw 1854 3RD ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 7:04 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-019

SAMPLE INFORMATION

Sample Number: 1310285-019 Customer Sample Number: 3018658 Program: DS
Location: 1st Draw 150 ADAMS ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 18:35 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-020

SAMPLE INFORMATION

Sample Number: 1310285-020 Customer Sample Number: 3018658 Program: DS
Location: 2nd Draw 150 ADAMS ST NW Type: Dist.

Collection Date: 10/23/2013 Collection Time: 18:38 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-021

SAMPLE INFORMATION

Sample Number: 1310285-021 Customer Sample Number: 3030686 Program: DS
Location: 1st Draw 1629 MONROE ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-022

SAMPLE INFORMATION

Sample Number: 1310285-022 Customer Sample Number: 3030686 Program: DS
Location: 2nd Draw 1629 MONROE ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 15:00 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-023

SAMPLE INFORMATION

Sample Number: 1310285-023 Customer Sample Number: 3020060 Program: DS
Location: 1st Draw 3551 6TH ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 14:30 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1310285-024

SAMPLE INFORMATION

Sample Number: 1310285-024 Customer Sample Number: 3020060 Program: DS
Location: 2nd Draw 3551 6TH ST NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 14:30 Sampler: HOME OWNER Received Date and Time: 10/31/2013 9:17:56 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-005

SAMPLE INFORMATION

Sample Number: 1311001-005 Customer Sample Number: 3020527 Program: DS
Location: 1st Draw 506 RANDOLPH ST NW Type: Dist.

Collection Date: 10/27/2013 Collection Time: 7:54 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-006

SAMPLE INFORMATION

Sample Number: 1311001-006 Customer Sample Number: 3020527 Program: DS
Location: 2nd Draw 506 RANDOLPH ST NW Type: Dist.

Collection Date: 10/27/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-007

SAMPLE INFORMATION

Sample Number: 1311001-007 Customer Sample Number: 3050218 Program: DS
Location: 1st Draw 4904 ARKANSAS AVE Type: Dist.

Collection Date: 10/28/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-008

SAMPLE INFORMATION

Sample Number: 1311001-008 Customer Sample Number: 3050218 Program: DS
Location: 2nd Draw 4904 ARKANSAS AVE Type: Dist.

Collection Date: 10/28/2013 Collection Time: 7:55 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.2 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-009

SAMPLE INFORMATION

Sample Number: 1311001-009 Customer Sample Number: 3029531 Program: DS
Location: 1st Draw 914 SPRING RD NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 6:32 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.3 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-010

SAMPLE INFORMATION

Sample Number: 1311001-010 Customer Sample Number: 3029531 Program: DS
Location: 2nd Draw 914 SPRING RD NW Type: Dist.

Collection Date: 10/29/2013 Collection Time: 6:37 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-011

SAMPLE INFORMATION

Sample Number: 1311001-011 Customer Sample Number: 3130927 Program: DS
Location: 1st Draw 1118 CONSTITUTION AVE NE Type: Dist.

Collection Date: 10/29/2013 Collection Time: 17:00 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/12/2013
Report Number: LC-W1311001-012

SAMPLE INFORMATION

Sample Number: 1311001-012 Customer Sample Number: 3130927 Program: DS
Location: 2nd Draw 1118 CONSTITUTION AVE NE Type: Dist.

Collection Date: 10/29/2013 Collection Time: 17:05 Sampler: HOME OWNER Received Date and Time: 11/1/2013 8:26:14 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	11/7/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

11/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-007

SAMPLE INFORMATION

Sample Number: 1311061-007 Customer Sample Number: 3039370 Program: DS
Location: 1st Draw 3712 LIVINGSTON ST NW Type: Dist.

Collection Date: 11/4/2013 Collection Time: 6:36 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-008

SAMPLE INFORMATION

Sample Number: 1311061-008 Customer Sample Number: 3039370 Program: DS
Location: 2nd Draw 3712 LIVINGSTON ST NW Type: Dist.

Collection Date: 11/4/2013 Collection Time: 6:38 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.3 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-009

SAMPLE INFORMATION

Sample Number: 1311061-009 Customer Sample Number: 3040274 Program: DS
Location: 1st Draw 3847 FESSENDEN ST NW Type: Dist.

Collection Date: 11/5/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-010

SAMPLE INFORMATION

Sample Number: 1311061-010 Customer Sample Number: 3040274 Program: DS
Location: 2nd Draw 3847 FESSENDEN ST NW Type: Dist.

Collection Date: 11/5/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311110-001

SAMPLE INFORMATION

Sample Number: 1311110-001 Customer Sample Number: 3028527 Program: DS
Location: 1st draw 1344 RANDOLPH ST NW Type: Dist.

Collection Date: 11/8/2013 Collection Time: 5:54 Sampler: HOME OWNER Received Date and Time: 11/14/2013 3:06:01 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.4 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311110-002

SAMPLE INFORMATION

Sample Number: 1311110-002 Customer Sample Number: 3028527 Program: DS
Location: 2nd draw 1344 RANDOLPH ST NW Type: Dist.

Collection Date: 11/8/2013 Collection Time: 5:58 Sampler: HOME OWNER Received Date and Time: 11/14/2013 3:06:01 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	6.4 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311110-003

SAMPLE INFORMATION

Sample Number: 1311110-003 Customer Sample Number: 3057893 Program: DS
Location: 1st Draw 2929 34TH ST NW Type: Dist.

Collection Date: 11/10/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 11/14/2013 3:06:01 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311110-004

SAMPLE INFORMATION

Sample Number: 1311110-004 Customer Sample Number: 3057893 Program: DS
Location: 2nd draw 2929 34TH ST NW Type: Dist.

Collection Date: 11/10/2013 Collection Time: 7:23 Sampler: HOME OWNER Received Date and Time: 11/14/2013 3:06:01 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	4.7 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311110-005

SAMPLE INFORMATION

Sample Number: 1311110-005 Customer Sample Number: 3012290 Program: DS
Location: 1st draw 3107 N ST NW Type: Dist.

Collection Date: 11/11/2013 Collection Time: 6:41 Sampler: HOME OWNER Received Date and Time: 11/14/2013 3:06:01 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311110-006

SAMPLE INFORMATION

Sample Number: 1311110-006 Customer Sample Number: 3012290 Program: DS
Location: 2nd draw 3107 N ST NW Type: Dist.

Collection Date: 11/11/2013 Collection Time: 6:43 Sampler: HOME OWNER Received Date and Time: 11/14/2013 3:06:01 PM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311155-001

SAMPLE INFORMATION

Sample Number: 1311155-001 Customer Sample Number: 3040191 Program: DS
Location: 1st draw 5330 42ND ST NW Type: Dist.

Collection Date: 11/10/2013 Collection Time: 14:45 Sampler: HOME OWNER Received Date and Time: 11/20/2013 3:01:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311155-002

SAMPLE INFORMATION

Sample Number: 1311155-002 Customer Sample Number: 3040191 Program: DS
Location: 2nd draw 5330 42ND ST NW Type: Dist.

Collection Date: 11/10/2013 Collection Time: 14:49 Sampler: HOME OWNER Received Date and Time: 11/20/2013 3:01:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311155-003

SAMPLE INFORMATION

Sample Number: 1311155-003 Customer Sample Number: 3034715 Program: DS
Location: 1st draw 2202 WYOMING AVE NW Type: Dist.

Collection Date: 11/16/2013 Collection Time: 11:30 Sampler: HOME OWNER Received Date and Time: 11/20/2013 3:01:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	7.7 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311155-004

SAMPLE INFORMATION

Sample Number: 1311155-004 Customer Sample Number: 3034715 Program: DS
Location: 2nd draw 2202 WYOMING AVE NW Type: Dist.

Collection Date: 11/16/2013 Collection Time: 11:30 Sampler: HOME OWNER Received Date and Time: 11/20/2013 3:01:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.1 ug/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311167-001

SAMPLE INFORMATION

Sample Number: 1311167-001 Customer Sample Number: 3061538 Program: DS
Location: 1st Draw 2838 MCGILL TERR. Type: Dist.

Collection Date: 11/17/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:46:00 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311167-002

SAMPLE INFORMATION

Sample Number: 1311167-002 Customer Sample Number: 3061538 Program: DS
Location: 2nd Draw 2838 MCGILL TERR. Type: Dist.

Collection Date: 11/17/2013 Collection Time: 7:05 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:46:00 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311167-003

SAMPLE INFORMATION

Sample Number: 1311167-003 Customer Sample Number: 3029688 Program: DS
Location: 1st Draw 3603 11TH ST NW Type: Dist.

Collection Date: 11/18/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:46:00 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311167-004

SAMPLE INFORMATION

Sample Number: 1311167-004 Customer Sample Number: 3029688 Program: DS
Location: 2nd Draw 3603 11TH ST NW Type: Dist.

Collection Date: 11/18/2013 Collection Time: 18:00 Sampler: HOME OWNER Received Date and Time: 11/22/2013 8:46:00 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311190-001

SAMPLE INFORMATION

Sample Number: 1311190-001 Customer Sample Number: 3125434 Program: DS
Location: 1st draw 175 V ST NE Type: Dist.

Collection Date: 11/18/2013 Collection Time: 13:00 Sampler: HOME OWNER Received Date and Time: 11/25/2013 3:57:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	63.9 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311190-002

SAMPLE INFORMATION

Sample Number: 1311190-002 Customer Sample Number: 3125434 Program: DS
Location: 2nd draw 175 V ST NE Type: Dist.

Collection Date: 11/18/2013 Collection Time: 13:03 Sampler: HOME OWNER Received Date and Time: 11/25/2013 3:57:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	31.1 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311190-003

SAMPLE INFORMATION

Sample Number: 1311190-003 Customer Sample Number: 3037145 Program: DS
Location: 1st draw 3702 LIVINGSTON ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 11/25/2013 3:57:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311190-004

SAMPLE INFORMATION

Sample Number: 1311190-004 Customer Sample Number: 3037145 Program: DS
Location: 2nd draw 3702 LIVINGSTON ST NW Type: Dist.

Collection Date: 11/19/2013 Collection Time: 21:30 Sampler: HOME OWNER Received Date and Time: 11/25/2013 3:57:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311190-005

SAMPLE INFORMATION

Sample Number: 1311190-005 Customer Sample Number: 3091904 Program: DS
Location: 1st draw 3952 1ST ST SW Type: Dist.

Collection Date: 11/21/2013 Collection Time: 6:00 Sampler: HOME OWNER Received Date and Time: 11/25/2013 3:57:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311190-006

SAMPLE INFORMATION

Sample Number: 1311190-006 Customer Sample Number: 3091904 Program: DS
Location: 2nd draw 3952 1ST ST SW Type: Dist.

Collection Date: 11/21/2013 Collection Time: 6:05 Sampler: HOME OWNER Received Date and Time: 11/25/2013 3:57:56 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311194-001

SAMPLE INFORMATION

Sample Number: 1311194-001 Customer Sample Number: 3038089 Program: DS
Location: 1st draw 6340 UTAH AVE NW Type: Dist.

Collection Date: 11/18/2013 Collection Time: 6:40 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:00:20 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311194-002

SAMPLE INFORMATION

Sample Number: 1311194-002 Customer Sample Number: 3038089 Program: DS
Location: 2nd draw 6340 UTAH AVE NW Type: Dist.

Collection Date: 11/18/2013 Collection Time: 6:45 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:00:20 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1311194-003

SAMPLE INFORMATION

Sample Number: 1311194-003 Customer Sample Number: 3021430 Program: DS
Location: 1st draw 4319 3RD ST NW Type: Dist.

Collection Date: 11/24/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:00:20 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1311194-004

SAMPLE INFORMATION

Sample Number: 1311194-004 Customer Sample Number: 3021430 Program: DS
Location: 2nd draw 4319 3RD ST NW Type: Dist.

Collection Date: 11/24/2013 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 11/26/2013 1:00:20 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.6 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312019-001

SAMPLE INFORMATION

Sample Number: 1312019-001 Customer Sample Number: 3125582 Program: DS
Location: 1st draw 37 FRANKLIN ST NE Type: Dist.

Collection Date: 11/21/2013 Collection Time: 16:15 Sampler: HOME OWNER Received Date and Time: 12/3/2013 10:18:57 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312019-002

SAMPLE INFORMATION

Sample Number: 1312019-002 Customer Sample Number: 3125582 Program: DS
Location: 2nd draw 37 FRANKLIN ST NE Type: Dist.

Collection Date: 11/21/2013 Collection Time: 16:15 Sampler: HOME OWNER Received Date and Time: 12/3/2013 10:18:57 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312019-003

SAMPLE INFORMATION

Sample Number: 1312019-003 Customer Sample Number: 3121269 Program: DS
Location: 1st draw 413 1/2 5TH ST NE Type: Dist.

Collection Date: 11/24/2013 Collection Time: 8:25 Sampler: HOME OWNER Received Date and Time: 12/3/2013 10:18:57 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312019-004

SAMPLE INFORMATION

Sample Number: 1312019-004 Customer Sample Number: 3121269 Program: DS
Location: 2nd draw 413 1/2 5TH ST NE Type: Dist.

Collection Date: 11/24/2013 Collection Time: 8:28 Sampler: HOME OWNER Received Date and Time: 12/3/2013 10:18:57 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-001

SAMPLE INFORMATION

Sample Number: 1312055-001 Customer Sample Number: 3045596 Program: DS
Location: 1st Draw 5014 GLENBROOK TER NW Type: Dist.

Collection Date: 11/28/2013 Collection Time: 6:25 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-002

SAMPLE INFORMATION

Sample Number: 1312055-002 Customer Sample Number: 3045596 Program: DS
Location: 2nd Draw 5014 GLENBROOK TER NW Type: Dist.

Collection Date: 11/28/2013 Collection Time: 6:30 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-003

SAMPLE INFORMATION

Sample Number: 1312055-003 Customer Sample Number: 3073072 Program: DS
Location: 1st Draw 812 E ST SE #1 Type: Dist.

Collection Date: 12/1/2013 Collection Time: 10:05 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-004

SAMPLE INFORMATION

Sample Number: 1312055-004 Customer Sample Number: 3073072 Program: DS
Location: 2nd Draw 812 E ST SE #1 Type: Dist.

Collection Date: 12/1/2013 Collection Time: 10:08 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-005

SAMPLE INFORMATION

Sample Number: 1312055-005 Customer Sample Number: 3025286 Program: DS
Location: 1st Draw 206 EMERSON ST NW Type: Dist.

Collection Date: 12/2/2013 Collection Time: 5:18 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-006

SAMPLE INFORMATION

Sample Number: 1312055-006 Customer Sample Number: 3025286 Program: DS
Location: 2nd Draw 206 EMERSON ST NW Type: Dist.

Collection Date: 12/2/2013 Collection Time: 5:21 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-009

SAMPLE INFORMATION

Sample Number: 1312055-009 Customer Sample Number: 3022043 Program: DS
Location: 1st Draw 527 BUCHANAN ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 7:00 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-010

SAMPLE INFORMATION

Sample Number: 1312055-010 Customer Sample Number: 3022043 Program: DS
Location: 2nd Draw 527 BUCHANAN ST NW Type: Dist.

Collection Date: 12/4/2013 Collection Time: 7:03 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312068-001

SAMPLE INFORMATION

Sample Number: 1312068-001 Customer Sample Number: 3121834 Program: DS
Location: 1st draw 124 12TH ST NE Type: Dist.

Collection Date: 12/4/2013 Collection Time: 16:15 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:55:37 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.2 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312068-002

SAMPLE INFORMATION

Sample Number: 1312068-002 Customer Sample Number: 3121834 Program: DS
Location: 2nd draw 124 12TH ST NE Type: Dist.

Collection Date: 12/4/2013 Collection Time: 16:15 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:55:37 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312068-003

SAMPLE INFORMATION

Sample Number: 1312068-003 Customer Sample Number: 3099362 Program: DS
Location: 1st draw 139 11TH ST NE Type: Dist.

Collection Date: 12/5/2013 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:55:37 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312068-004

SAMPLE INFORMATION

Sample Number: 1312068-004 Customer Sample Number: 3099362 Program: DS
Location: 2nd draw 139 11TH ST NE Type: Dist.

Collection Date: 12/5/2013 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 12/9/2013 11:55:37 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312086-003

SAMPLE INFORMATION

Sample Number: 1312086-003 Customer Sample Number: 3128693 Program: DS
Location: 1st draw 910 12TH ST NE Type: Dist.

Collection Date: 12/8/2013 Collection Time: 7:28 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:20:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312086-004

SAMPLE INFORMATION

Sample Number: 1312086-004 Customer Sample Number: 3128693 Program: DS
Location: 2nd draw 910 12TH ST NE Type: Dist.

Collection Date: 12/8/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:20:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312086-005

SAMPLE INFORMATION

Sample Number: 1312086-005 Customer Sample Number: 3097800 Program: DS
Location: 1st draw 914 3RD ST NE Type: Dist.

Collection Date: 12/9/2013 Collection Time: 8:47 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:20:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312086-006

SAMPLE INFORMATION

Sample Number: 1312086-006 Customer Sample Number: 3097800 Program: DS
Location: 2nd draw 914 3RD ST NE Type: Dist.

Collection Date: 12/9/2013 Collection Time: 8:52 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:20:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off 4.5 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-007

SAMPLE INFORMATION

Sample Number: 1306192-007 Customer Sample Number: 3122624 Program: Post-LSR
Location: 1st Draw 808 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 6/19/2013 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306192-008

SAMPLE INFORMATION

Sample Number: 1306192-008 Customer Sample Number: 3122624 Program: Post-LSR
Location: 2nd Draw 808 MASSACHUSETTS AVE NE Type: Dist.

Collection Date: 6/19/2013 Collection Time: 4:45 Sampler: HOME OWNER Received Date and Time: 6/21/2013 8:56:30 AM Received By: LGallimore

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-009

SAMPLE INFORMATION

Sample Number: 1306254-009 Customer Sample Number: 3120944 Program: Post-LSR
Location: 1st draw 400 M ST NE Type: Dist.

Collection Date: 6/24/2013 Collection Time: 20:32 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.4 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-010

SAMPLE INFORMATION

Sample Number: 1306254-010 Customer Sample Number: 3120944 Program: Post-LSR
Location: 2nd draw 400 M ST NE Type: Dist.

Collection Date: 6/24/2013 Collection Time: 20:35 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.8 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-011

SAMPLE INFORMATION

Sample Number: 1306254-011 Customer Sample Number: 3098531 Program: Post-LSR
Location: 1st draw 1139 4TH STREET NE Type: Dist.

Collection Date: 6/25/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	7/12/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1306254-012

SAMPLE INFORMATION

Sample Number: 1306254-012 Customer Sample Number: 3098531 Program: Post-LSR
Location: 2nd draw 1139 4TH STREET NE Type: Dist.

Collection Date: 6/25/2013 Collection Time: 7:37 Sampler: HOME OWNER Received Date and Time: 6/28/2013 2:47:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-007

SAMPLE INFORMATION

Sample Number: 1307057-007 Customer Sample Number: 3110741 Program: Post-LSR
Location: 1st Draw 4515 MEADE ST NE #2 Type: Dist.
Collection Date: 7/1/2013 Collection Time: 7:15 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.9 ug/L	7/12/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/22/2013
Report Number: LC-W1307057-008

SAMPLE INFORMATION

Sample Number: 1307057-008 Customer Sample Number: 3110741 Program: Post-LSR
Location: 2nd Draw 4515 MEADE ST NE #2 Type: Dist.
Collection Date: 7/1/2013 Collection Time: 7:16 Sampler: HOME OWNER Received Date and Time: 7/8/2013 1:53:02 PM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	7/12/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

7/22/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307132-003

SAMPLE INFORMATION

Sample Number: 1307132-003 Customer Sample Number: 3098532 Program: Post-LSR
Location: 1st draw 1137 4TH ST NE Type: Dist.

Collection Date: 7/8/2013 Collection Time: 19:48 Sampler: HOME OWNER Received Date and Time: 7/15/2013 4:04:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307132-004

SAMPLE INFORMATION

Sample Number: 1307132-004 Customer Sample Number: 3098532 Program: Post-LSR
Location: 2nd draw 1137 4TH ST NE Type: Dist.

Collection Date: 7/8/2013 Collection Time: 19:50 Sampler: HOME OWNER Received Date and Time: 7/15/2013 4:04:45 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308005-003

SAMPLE INFORMATION

Sample Number: 1308005-003 Customer Sample Number: 3098540 Program: Post-LSR
Location: 1st draw 1119 4TH STREET NE Type: Dist.

Collection Date: 7/21/2013 Collection Time: 9:30 Sampler: HOME OWNER Received Date and Time: 8/1/2013 11:23:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308005-004

SAMPLE INFORMATION

Sample Number: 1308005-004 Customer Sample Number: 3098540 Program: Post-LSR
Location: 2nd draw 1119 4TH STREET NE Type: Dist.

Collection Date: 7/21/2013 Collection Time: 9:32 Sampler: HOME OWNER Received Date and Time: 8/1/2013 11:23:21 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	8/26/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308231-003

SAMPLE INFORMATION

Sample Number: 1308231-003 Customer Sample Number: 3044485 Program: Post-LSR
Location: 1st draw 1705 HOBAN RD NW Type: Dist.
Collection Date: 8/21/2013 Collection Time: 7:30 Sampler: HOME OWNER Received Date and Time: 8/26/2013 2:23:54 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/11/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1308231-004

SAMPLE INFORMATION

Sample Number: 1308231-004 Customer Sample Number: 3044485 Program: Post-LSR
Location: 2nd draw 1705 HOBAN RD NW Type: Dist.

Collection Date: 8/21/2013 Collection Time: 7:32 Sampler: HOME OWNER Received Date and Time: 8/26/2013 2:23:54 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-005

SAMPLE INFORMATION

Sample Number: 1309041-005 Customer Sample Number: 3031368 Program: Post-LSR
Location: 1st draw 1927 KENYON ST NW Type: Dist.

Collection Date: 8/28/2013 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	3.1 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: LC-W1309041-006

SAMPLE INFORMATION

Sample Number: 1309041-006 Customer Sample Number: 3031368 Program: Post-LSR
Location: 2nd draw 1927 KENYON ST NW Type: Dist.

Collection Date: 8/28/2013 Collection Time: 4:30 Sampler: HOME OWNER Received Date and Time: 9/6/2013 9:22:54 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	2.6 ug/L	9/11/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-007

SAMPLE INFORMATION

Sample Number: 1309136-007 Customer Sample Number: 3041201 Program: Post-LSR
Location: 1st draw 4413 39TH ST NW Type: Dist.
Collection Date: 9/13/2013 Collection Time: 7:33 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/30/2013
Report Number: LC-W1309136-008

SAMPLE INFORMATION

Sample Number: 1309136-008 Customer Sample Number: 3041201 Program: Post-LSR
Location: 2nd draw 4413 39TH ST NW Type: Dist.
Collection Date: 9/13/2013 Collection Time: 7:35 Sampler: HOME OWNER Received Date and Time: 9/17/2013 8:39:44 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

9/30/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-001

SAMPLE INFORMATION

Sample Number: 1311061-001 Customer Sample Number: 3100698 Program: Post-LSR
Location: 1st Draw 1312 F ST. NE Type: Dist.

Collection Date: 10/27/2013 Collection Time: 18:21 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-002

SAMPLE INFORMATION

Sample Number: 1311061-002 Customer Sample Number: 3100698 Program: Post-LSR
Location: 2nd Draw 1312 F ST. NE Type: Dist.

Collection Date: 10/27/2013 Collection Time: 18:23 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-003

SAMPLE INFORMATION

Sample Number: 1311061-003 Customer Sample Number: 3100137 Program: Post-LSR
Location: 1st Draw 1389 D ST NE Type: Dist.

Collection Date: 11/1/2013 Collection Time: 5:40 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-004

SAMPLE INFORMATION

Sample Number: 1311061-004 Customer Sample Number: 3100137 Program: Post-LSR
Location: 2nd Draw 1389 D ST NE Type: Dist.

Collection Date: 11/1/2013 Collection Time: 5:43 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-005

SAMPLE INFORMATION

Sample Number: 1311061-005 Customer Sample Number: 3048211 Program: Post-LSR
Location: 1st Draw 1885 PLYMOUTH ST NW Type: Dist.
Collection Date: 11/2/2013 Collection Time: 7:20 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	12.3 ug/L	12/4/2013	TPasquale

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: LC-W1311061-006

SAMPLE INFORMATION

Sample Number: 1311061-006 Customer Sample Number: 3048211 Program: Post-LSR
Location: 2nd Draw 1885 PLYMOUTH ST NW Type: Dist.

Collection Date: 11/2/2013 Collection Time: 7:25 Sampler: HOME OWNER Received Date and Time: 11/8/2013 8:20:52 AM Received By: HBeiter

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	12/4/2013	TPasquale

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312019-005

SAMPLE INFORMATION

Sample Number: 1312019-005 Customer Sample Number: 3060387 Program: Post-LSR
Location: 1st draw 3225 WOODLEY RD NW Type: Dist.
Collection Date: 11/26/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 12/3/2013 10:18:57 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312019-006

SAMPLE INFORMATION

Sample Number: 1312019-006 Customer Sample Number: 3060387 Program: Post-LSR
Location: 2nd draw 3225 WOODLEY RD NW Type: Dist.

Collection Date: 11/26/2013 Collection Time: 8:00 Sampler: HOME OWNER Received Date and Time: 12/3/2013 10:18:57 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-007

SAMPLE INFORMATION

Sample Number: 1312055-007 Customer Sample Number: 3021386 Program: Post-LSR
Location: 1st Draw 4309 4TH ST NW Type: Dist.
Collection Date: 12/3/2013 Collection Time: 16:43 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312055-008

SAMPLE INFORMATION

Sample Number: 1312055-008 Customer Sample Number: 3021386 Program: Post-LSR
Location: 2nd Draw 4309 4TH ST NW Type: Dist.

Collection Date: 12/3/2013 Collection Time: 16:47 Sampler: HOME OWNER Received Date and Time: 12/6/2013 9:27:16 AM Received By: ECave

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	12/12/2013	RHoward

Comment: ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312086-001

SAMPLE INFORMATION

Sample Number: 1312086-001 Customer Sample Number: 3099998 Program: Post-LSR
Location: 1st draw 1343 EMERALD ST NE Type: Dist.
Collection Date: 12/7/2013 Collection Time: 8:45 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:20:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/18/2013
Report Number: LC-W1312086-002

SAMPLE INFORMATION

Sample Number: 1312086-002 Customer Sample Number: 3099998 Program: Post-LSR
Location: 2nd draw 1343 EMERALD ST NE Type: Dist.
Collection Date: 12/7/2013 Collection Time: 8:47 Sampler: HOME OWNER Received Date and Time: 12/11/2013 9:20:38 AM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Lead	EPA 200.8	15 ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/12/2013	RHoward

Comment:
ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Reviewed By:



Michael Chicoine, Laboratory Manager

12/18/2013

Date

Lead Profile Information

DC Water surveys the plumbing of customers' homes and collects consecutive samples to identify the sources of lead. The homes are those that had elevated lead from previous samples collected for compliance monitoring or from other programs.

This attached sample analysis data contains personal information of DC Water's customers, such as names and home addresses, the disclosure of which would constitute a violation of D.C. Code § 2-534(a)(2) and 5 U.S.C. § 552(b)(6). If EPA is requested to produce the sampling analysis data in whole or in part, in order to maintain confidentiality, the personal information must be redacted from the documents produced.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-001

SAMPLE INFORMATION

Sample Number: 1306007-001	Customer Sample Number:			
Location: 01a LPR 4824 46TH ST NW UNFILTERED	Type: Dist.			
Collection Date: 5/31/2013	Collection Time: 8:30	Sampler: AB/YT	Received Date and Time: 6/3/2013 10:41:15 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.33 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	561 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	156 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	21.0 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-001

SAMPLE INFORMATION

Sample Number: 1306007-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-002

SAMPLE INFORMATION

Sample Number: 1306007-002

Customer Sample Number:

Location: 01aF

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	3.87 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	12.9 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	84.8 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-002

SAMPLE INFORMATION

Sample Number: 1306007-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-003

SAMPLE INFORMATION

Sample Number: 1306007-003 Customer Sample Number:
 Location: 01b Type: Dist.
 LPR 4824 46TH ST NW UNFILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	4.10 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	259 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	13.5 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	88.7 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.33 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-003

SAMPLE INFORMATION

Sample Number: 1306007-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-004

SAMPLE INFORMATION

Sample Number: 1306007-004

Customer Sample Number:

Location: 01bF
LPR 4824 46TH ST NW FILTERED

Type: Dist.

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	3.87 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.53 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	58.0 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-004

SAMPLE INFORMATION

Sample Number: 1306007-004 Customer Sample Number:
Location: 01bF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-005

SAMPLE INFORMATION

Sample Number: 1306007-005
Customer Sample Number:
Location: 01c
Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: 5/31/2013
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 6/3/2013 10:41:15 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.28 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	420 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	185 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-005

SAMPLE INFORMATION

Sample Number: 1306007-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-006

SAMPLE INFORMATION

Sample Number: 1306007-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.56 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.72 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	101 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-006

SAMPLE INFORMATION

Sample Number: 1306007-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number:M- W1306007-007

SAMPLE INFORMATION

Sample Number: 1306007-007

Customer Sample Number:

Location: 01d

Type: Dist.

LPR 4824 46TH ST NW UNFILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.00 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	500 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	207 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-007

SAMPLE INFORMATION

Sample Number: 1306007-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-008

SAMPLE INFORMATION

Sample Number: 1306007-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.36 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	7.93 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	99.4 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-008

SAMPLE INFORMATION

Sample Number: 1306007-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-009

SAMPLE INFORMATION

Sample Number: 1306007-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	3.74 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	158 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	69.4 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.05 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-009

SAMPLE INFORMATION

Sample Number: 1306007-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-010

SAMPLE INFORMATION

Sample Number: 1306007-010

Customer Sample Number:

Location: 02F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	3.43 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	48.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-010

SAMPLE INFORMATION

Sample Number: 1306007-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-011

SAMPLE INFORMATION

Sample Number: 1306007-011

Customer Sample Number:

Location: 03

Type: Dist.

LPR 4824 46TH ST NW UNFILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.76 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	52.0 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	37.1 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.08 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-011

SAMPLE INFORMATION

Sample Number: 1306007-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-012

SAMPLE INFORMATION

Sample Number: 1306007-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.57 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.2 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	33.9 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-012

SAMPLE INFORMATION

Sample Number: 1306007-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-013

SAMPLE INFORMATION

Sample Number: 1306007-013

Customer Sample Number:

Location: 04

Type: Dist.

LPR 4824 46TH ST NW UNFILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.00 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	49.3 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.1 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	20.4 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.14 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-013

SAMPLE INFORMATION

Sample Number: 1306007-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-014

SAMPLE INFORMATION

Sample Number: 1306007-014

Customer Sample Number:

Location: 04F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.80 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	19.5 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-014

SAMPLE INFORMATION

Sample Number: 1306007-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-015

SAMPLE INFORMATION

Sample Number: 1306007-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.66 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	62.0 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	36.8 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.0 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.67 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-015

SAMPLE INFORMATION

Sample Number: 1306007-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-016

SAMPLE INFORMATION

Sample Number: 1306007-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.51 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.8 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	15.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-016

SAMPLE INFORMATION

Sample Number: 1306007-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-017

SAMPLE INFORMATION

Sample Number: 1306007-017

Customer Sample Number:

Location: 06

Type: Dist.

LPR 4824 46TH ST NW UNFILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.30 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	22.5 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.9 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.40 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-017

SAMPLE INFORMATION

Sample Number: 1306007-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-018

SAMPLE INFORMATION

Sample Number: 1306007-018

Customer Sample Number:

Location: 06F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.22 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.9 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.1 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.06 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-018

SAMPLE INFORMATION

Sample Number: 1306007-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-019

SAMPLE INFORMATION

Sample Number: 1306007-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.18 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.5 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.7 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.28 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-019

SAMPLE INFORMATION

Sample Number: 1306007-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-020

SAMPLE INFORMATION

Sample Number: 1306007-020

Customer Sample Number:

Location: 07F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.04 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.40 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-020

SAMPLE INFORMATION

Sample Number: 1306007-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-021

SAMPLE INFORMATION

Sample Number: 1306007-021	Customer Sample Number:			
Location: 08	Type: Dist.			
LPR 4824 46TH ST NW UNFILTERED				
Collection Date: 5/31/2013	Collection Time: 8:30	Sampler: AB/YT	Received Date and Time: 6/3/2013 10:41:15 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.19 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.0 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.3 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.52 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-021

SAMPLE INFORMATION

Sample Number: 1306007-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-022

SAMPLE INFORMATION

Sample Number: 1306007-022

Customer Sample Number:

Location: 08F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.04 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.6 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.7 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.10 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-022

SAMPLE INFORMATION

Sample Number: 1306007-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-023

SAMPLE INFORMATION

Sample Number: 1306007-023
 Location: 09
 LPR 4824 46TH ST NW UNFILTERED

Customer Sample Number:
 Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
5/31/2013	8:30	AB/YT	6/3/2013 10:41:15 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.24 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.7 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.33 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-023

SAMPLE INFORMATION

Sample Number: 1306007-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-024

SAMPLE INFORMATION

Sample Number: 1306007-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4824 46TH ST NW FILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.09 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.2 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.4 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-024

SAMPLE INFORMATION

Sample Number: 1306007-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-025

SAMPLE INFORMATION

Sample Number: 1306007-025
Location: 10
LPR 4824 46TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/31/2013
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 6/3/2013 10:41:15 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.28 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.5 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.0 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-025

SAMPLE INFORMATION

Sample Number: 1306007-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number: M- W1306007-026

SAMPLE INFORMATION

Sample Number: 1306007-026	Customer Sample Number:			
Location: 10F LPR 4824 46TH ST NW FILTERED	Type: Dist.			
Collection Date: 5/31/2013	Collection Time: 8:30	Sampler: AB/YT	Received Date and Time: 6/3/2013 10:41:15 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.11 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.7 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.7 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-026

SAMPLE INFORMATION

Sample Number: 1306007-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-027

SAMPLE INFORMATION

Sample Number: 1306007-027
Location: 11
LPR 4824 46TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.28 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.7 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.7 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-027

SAMPLE INFORMATION

Sample Number: 1306007-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-028

SAMPLE INFORMATION

Sample Number: 1306007-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.11 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	24.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.9 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-028

SAMPLE INFORMATION

Sample Number: 1306007-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-029

SAMPLE INFORMATION

Sample Number: 1306007-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.29 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.7 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.9 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.2 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-029

SAMPLE INFORMATION

Sample Number: 1306007-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-030

SAMPLE INFORMATION

Sample Number: 1306007-030
Location: 12F
LPR 4824 46TH ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/31/2013
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 6/3/2013 10:41:15 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.11 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.1 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-030

SAMPLE INFORMATION

Sample Number: 1306007-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-031

SAMPLE INFORMATION

Sample Number: 1306007-031
Location: H1
LPR 4824 46TH ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.30 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	183 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	42.6 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	11.3 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-031

SAMPLE INFORMATION

Sample Number: 1306007-031 Customer Sample Number:
Location: H1 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-032

SAMPLE INFORMATION

Sample Number: 1306007-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.38 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	10.1 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.7 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-032

SAMPLE INFORMATION

Sample Number: 1306007-032 Customer Sample Number:
Location: H1F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 7/15/2013
 Report Number:M- W1306007-033

SAMPLE INFORMATION

Sample Number: 1306007-033

Customer Sample Number:

Location: H2

Type: Dist.

LPR 4824 46TH ST NW UNFILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.12 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	154 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	34.7 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.1 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-033

SAMPLE INFORMATION

Sample Number: 1306007-033 Customer Sample Number:
Location: H2 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-034

SAMPLE INFORMATION

Sample Number: 1306007-034	Customer Sample Number:			
Location: H2F LPR 4824 46TH ST NW FILTERED	Type: Dist.			
Collection Date: 5/31/2013	Collection Time: 8:30	Sampler: AB/YT	Received Date and Time: 6/3/2013 10:41:15 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.35 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.55 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-034

SAMPLE INFORMATION

Sample Number: 1306007-034 Customer Sample Number:
Location: H2F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-035

SAMPLE INFORMATION

Sample Number: 1306007-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.11 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	150 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	23.4 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	35.2 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	9.73 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-035

SAMPLE INFORMATION

Sample Number: 1306007-035 Customer Sample Number:
Location: H3 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-036

SAMPLE INFORMATION

Sample Number: 1306007-036

Customer Sample Number:

Location: H3F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.36 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.63 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-036

SAMPLE INFORMATION

Sample Number: 1306007-036 Customer Sample Number:
Location: H3F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-037

SAMPLE INFORMATION

Sample Number: 1306007-037

Customer Sample Number:

Location: H4
LPR 4824 46TH ST NW UNFILTERED

Type: Dist.

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.02 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	135 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	30.0 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	8.73 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-037

SAMPLE INFORMATION

Sample Number: 1306007-037 Customer Sample Number:
Location: H4 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-038

SAMPLE INFORMATION

Sample Number: 1306007-038
Customer Sample Number:
Location: H4F
Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 6/3/2013 10:41:15 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.36 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.66 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-038

SAMPLE INFORMATION

Sample Number: 1306007-038 Customer Sample Number:
Location: H4F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-039

SAMPLE INFORMATION

Sample Number: 1306007-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.09 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	145 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.8 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	31.3 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	8.86 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-039

SAMPLE INFORMATION

Sample Number: 1306007-039 Customer Sample Number:
Location: H5 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number:M- W1306007-040

SAMPLE INFORMATION

Sample Number: 1306007-040

Customer Sample Number:

Location: H5F

Type: Dist.

LPR 4824 46TH ST NW FILTERED

Collection Date:
5/31/2013

Collection Time:
8:30

Sampler:
AB/YT

Received Date and Time:
6/3/2013 10:41:15 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.51 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.9 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	9.63 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-040

SAMPLE INFORMATION

Sample Number: 1306007-040 Customer Sample Number:
Location: H5F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-041

SAMPLE INFORMATION

Sample Number: 1306007-041
Location: X
LPR 4824 46TH ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 5/31/2013
Collection Time: 8:30
Sampler: AB/YT
Received Date and Time: 6/3/2013 10:41:15 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.52 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	83.3 ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.0 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	20.1 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.01 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-041

SAMPLE INFORMATION

Sample Number: 1306007-041 Customer Sample Number:
Location: X Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-042

SAMPLE INFORMATION

Sample Number: 1306007-042
Location: XF
LPR 4824 46TH ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 5/31/2013 Collection Time: 8:30 Sampler: AB/YT Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.10 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.30 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.3 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-042

SAMPLE INFORMATION

Sample Number: 1306007-042 Customer Sample Number:
Location: XF Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/31/2013 8:30 AB/YT 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-043

SAMPLE INFORMATION

Sample Number: 1306007-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: 5/30/2013 Collection Time: 21:30 Sampler: CUSTOMER Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	4.52 ug/L	7/1/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	888 ug/L	7/1/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	49.4 ug/L	7/1/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	128 ug/L	7/1/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	52.2 ug/L	7/1/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-043

SAMPLE INFORMATION

Sample Number: 1306007-043 Customer Sample Number:
Location: 00 Type: Dist.
LPR 4824 46TH ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
5/30/2013 21:30 CUSTOMER 6/3/2013 10:41:15 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  7/15/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-044

SAMPLE INFORMATION

Sample Number: 1306007-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/30/2013 Collection Time: 21:30 Sampler: CUSTOMER Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	7/9/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	7/9/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.64 ug/L	7/9/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	19.9 ug/L	7/9/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	7/9/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/15/2013
Report Number: M- W1306007-044

SAMPLE INFORMATION

Sample Number: 1306007-044 Customer Sample Number:
Location: 00F Type: Dist.
LPR 4824 46TH ST NW FILTERED
Collection Date: 5/30/2013 Collection Time: 21:30 Sampler: CUSTOMER Received Date and Time: 6/3/2013 10:41:15 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

7/15/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-001

SAMPLE INFORMATION

Sample Number: 1308083-001

Customer Sample Number:

Location: 01a

Type: Dist.

LPR 3511 LEGATION ST NW UNFILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.97 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	131 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.87 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.77 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-001

SAMPLE INFORMATION

Sample Number: 1308083-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-002

SAMPLE INFORMATION

Sample Number: 1308083-002
Customer Sample Number:
Location: 01aF
Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013
Collection Time: 13:10
Sampler: AB/YT
Received Date and Time: 8/9/2013 9:05:42 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.44 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.00 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-002

SAMPLE INFORMATION

Sample Number: 1308083-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-003

SAMPLE INFORMATION

Sample Number: 1308083-003
Location: 01c
LPR 3511 LEGATION ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.23 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	149 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.57 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.68 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-003

SAMPLE INFORMATION

Sample Number: 1308083-003 Customer Sample Number:
Location: 01c Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-004

SAMPLE INFORMATION

Sample Number: 1308083-004

Customer Sample Number:

Location: 01cF

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.54 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	23.3 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.94 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-004

SAMPLE INFORMATION

Sample Number: 1308083-004 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-005

SAMPLE INFORMATION

Sample Number: 1308083-005 Customer Sample Number:
Location: 01d Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.52 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	133 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.64 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.80 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-005

SAMPLE INFORMATION

Sample Number: 1308083-005 Customer Sample Number:
Location: 01d Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number:M- W1308083-006

SAMPLE INFORMATION

Sample Number: 1308083-006 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.15 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.05 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-006

SAMPLE INFORMATION

Sample Number: 1308083-006 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-007

SAMPLE INFORMATION

Sample Number: 1308083-007 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.90 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	162 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.73 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	9.38 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-007

SAMPLE INFORMATION

Sample Number: 1308083-007 Customer Sample Number:
Location: 02 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-008

SAMPLE INFORMATION

Sample Number: 1308083-008
Location: 02F
LPR 3511 LEGATION ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
8/8/2013	13:10	AB/YT	8/9/2013 9:05:42 AM	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.31 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.80 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-008

SAMPLE INFORMATION

Sample Number: 1308083-008 Customer Sample Number:
Location: 02F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/16/2013
 Report Number:M- W1308083-009

SAMPLE INFORMATION

Sample Number: 1308083-009	Customer Sample Number:			
Location: 03 LPR 3511 LEGATION ST NW UNFILTERED	Type: Dist.			
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/9/2013 9:05:42 AM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.97 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	146 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.30 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	17.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-009

SAMPLE INFORMATION

Sample Number: 1308083-009 Customer Sample Number:
Location: 03 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-010

SAMPLE INFORMATION

Sample Number: 1308083-010
Location: 03F
LPR 3511 LEGATION ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.26 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.41 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.87 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-010

SAMPLE INFORMATION

Sample Number: 1308083-010 Customer Sample Number:
Location: 03F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-011

SAMPLE INFORMATION

Sample Number: 1308083-011

Customer Sample Number:

Location: 04

Type: Dist.

LPR 3511 LEGATION ST NW UNFILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.37 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	136 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.88 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	22.3 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-011

SAMPLE INFORMATION

Sample Number: 1308083-011 Customer Sample Number:
Location: 04 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-012

SAMPLE INFORMATION

Sample Number: 1308083-012

Customer Sample Number:

Location: 04F

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.86 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.40 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.19 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-012

SAMPLE INFORMATION

Sample Number: 1308083-012 Customer Sample Number:
Location: 04F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-013

SAMPLE INFORMATION

Sample Number: 1308083-013
Location: 05
LPR 3511 LEGATION ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/8/2013
Collection Time: 13:10
Sampler: AB/YT
Received Date and Time: 8/9/2013 9:05:42 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.32 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	136 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.66 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	30.3 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-013

SAMPLE INFORMATION

Sample Number: 1308083-013 Customer Sample Number:
Location: 05 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-014

SAMPLE INFORMATION

Sample Number: 1308083-014 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.66 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.04 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.96 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-014

SAMPLE INFORMATION

Sample Number: 1308083-014 Customer Sample Number:
Location: 05F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-015

SAMPLE INFORMATION

Sample Number: 1308083-015 Customer Sample Number:
Location: 06 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.10 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	133 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.53 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	29.4 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-015

SAMPLE INFORMATION

Sample Number: 1308083-015
Location: 06
LPR 3511 LEGATION ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-016

SAMPLE INFORMATION

Sample Number: 1308083-016
Location: 06F
LPR 3511 LEGATION ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/8/2013
Collection Time: 13:10
Sampler: AB/YT
Received Date and Time: 8/9/2013 9:05:42 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.94 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	19.0 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.09 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.11 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-016

SAMPLE INFORMATION

Sample Number: 1308083-016 Customer Sample Number:
Location: 06F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-017

SAMPLE INFORMATION

Sample Number: 1308083-017 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.06 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	133 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.23 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	26.8 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-017

SAMPLE INFORMATION

Sample Number: 1308083-017 Customer Sample Number:
Location: 07 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number:M- W1308083-018

SAMPLE INFORMATION

Sample Number: 1308083-018
Location: 07F
LPR 3511 LEGATION ST NW FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.62 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.63 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.47 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-018

SAMPLE INFORMATION

Sample Number: 1308083-018 Customer Sample Number:
Location: 07F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-019

SAMPLE INFORMATION

Sample Number: 1308083-019 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.59 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	124 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.88 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	19.4 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-019

SAMPLE INFORMATION

Sample Number: 1308083-019 Customer Sample Number:
Location: 08 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-020

SAMPLE INFORMATION

Sample Number: 1308083-020

Customer Sample Number:

Location: 08F

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.20 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.71 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.93 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-020

SAMPLE INFORMATION

Sample Number: 1308083-020 Customer Sample Number:
Location: 08F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-021

SAMPLE INFORMATION

Sample Number: 1308083-021	Customer Sample Number:			
Location: 09	Type: Dist.			
LPR 3511 LEGATION ST NW UNFILTERED				
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/9/2013 9:05:42 AM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.53 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	124 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.93 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	14.9 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-021

SAMPLE INFORMATION

Sample Number: 1308083-021 Customer Sample Number:
Location: 09 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/16/2013
 Report Number: M- W1308083-022

SAMPLE INFORMATION

Sample Number: 1308083-022

Customer Sample Number:

Location: 09F

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.94 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.99 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.97 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-022

SAMPLE INFORMATION

Sample Number: 1308083-022 Customer Sample Number:
Location: 09F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-023

SAMPLE INFORMATION

Sample Number: 1308083-023	Customer Sample Number:			
Location: 10 LPR 3511 LEGATION ST NW UNFILTERED	Type: Dist.			
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/9/2013 9:05:42 AM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.72 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	125 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	8.16 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	17.3 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-023

SAMPLE INFORMATION

Sample Number: 1308083-023 Customer Sample Number:
Location: 10 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-024

SAMPLE INFORMATION

Sample Number: 1308083-024	Customer Sample Number:			
Location: 10F LPR 3511 LEGATION ST NW FILTERED	Type: Dist.			
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/9/2013 9:05:42 AM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.96 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.33 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.38 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-024

SAMPLE INFORMATION

Sample Number: 1308083-024 Customer Sample Number:
Location: 10F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-025

SAMPLE INFORMATION

Sample Number:	1308083-025	Customer Sample Number:							
Location:	11	Type:	Dist.						
LPR	3511 LEGATION ST NW UNFILTERED								
Collection Date:	8/8/2013	Collection Time:	13:10	Sampler:	AB/YT	Received Date and Time:	8/9/2013 9:05:42 AM	Received By:	LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.97 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	126 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	6.21 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	19.9 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-025

SAMPLE INFORMATION

Sample Number: 1308083-025 Customer Sample Number:
Location: 11 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/16/2013
 Report Number: M- W1308083-026

SAMPLE INFORMATION

Sample Number: 1308083-026
 Location: 11F
 LPR 3511 LEGATION ST NW FILTERED
 Customer Sample Number:
 Type: Dist.
 Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.57 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	5.22 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.13 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-026

SAMPLE INFORMATION

Sample Number: 1308083-026 Customer Sample Number:
Location: 11F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-027

SAMPLE INFORMATION

Sample Number: 1308083-027
Location: 12
LPR 3511 LEGATION ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.99 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	124 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	4.84 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	18.0 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-027

SAMPLE INFORMATION

Sample Number: 1308083-027 Customer Sample Number:
Location: 12 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-028

SAMPLE INFORMATION

Sample Number: 1308083-028
Customer Sample Number:
Location: 12F
Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013
Collection Time: 13:10
Sampler: AB/YT
Received Date and Time: 8/9/2013 9:05:42 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-029

SAMPLE INFORMATION

Sample Number: 1308083-029 Customer Sample Number:
Location: H13 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-030

SAMPLE INFORMATION

Sample Number: 1308083-030	Customer Sample Number:			
Location: H13F LPR 3511 LEGATION ST NW FILTERED	Type: Dist.			
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/9/2013 9:05:42 AM	Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.88 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.27 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.54 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-030

SAMPLE INFORMATION

Sample Number: 1308083-030 Customer Sample Number:
Location: H13F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-031

SAMPLE INFORMATION

Sample Number: 1308083-031
Location: H16
LPR 3511 LEGATION ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.75 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	133 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.12 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.47 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-031

SAMPLE INFORMATION

Sample Number: 1308083-031
Location: H16
LPR 3511 LEGATION ST NW UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/8/2013
Collection Time: 13:10
Sampler: AB/YT
Received Date and Time: 8/9/2013 9:05:42 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-032

SAMPLE INFORMATION

Sample Number: 1308083-032

Customer Sample Number:

Location: H16F

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.32 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.97 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-032

SAMPLE INFORMATION

Sample Number: 1308083-032 Customer Sample Number:
Location: H16F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number:M- W1308083-033

SAMPLE INFORMATION

Sample Number: 1308083-033

Customer Sample Number:

Location: H18

Type: Dist.

LPR 3511 LEGATION ST NW UNFILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.52 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	128 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.02 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.42 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-033

SAMPLE INFORMATION

Sample Number: 1308083-033 Customer Sample Number:
Location: H18 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/9/2013 9:05:42 AM LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-034

SAMPLE INFORMATION

Sample Number: 1308083-034

Customer Sample Number:

Location: H19

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.47 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	127 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.84 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.07 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-034

SAMPLE INFORMATION

Sample Number: 1308083-034 Customer Sample Number:
Location: H19 Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/16/2013
 Report Number: M- W1308083-035

SAMPLE INFORMATION

Sample Number: 1308083-035

Customer Sample Number:

Location: H20

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/9/2013 9:05:42 AM

Received By:
LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.53 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	128 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.80 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.96 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-035

SAMPLE INFORMATION

Sample Number: 1308083-035 Customer Sample Number:
Location: H20 Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-036

SAMPLE INFORMATION

Sample Number: 1308083-036
Location: H21
LPR 3511 LEGATION ST NW FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 8/8/2013
Collection Time: 13:10
Sampler: AB/YT
Received Date and Time: 8/9/2013 9:05:42 AM
Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.54 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	130 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.77 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.05 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-036

SAMPLE INFORMATION

Sample Number: 1308083-036 Customer Sample Number:
Location: H21 Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-037

SAMPLE INFORMATION

Sample Number: 1308083-037 Customer Sample Number:
Location: H22 Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.43 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	126 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.68 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.80 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-037

SAMPLE INFORMATION

Sample Number: 1308083-037 Customer Sample Number:
Location: H22 Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-038

SAMPLE INFORMATION

Sample Number: 1308083-038 Customer Sample Number:
Location: 00 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 7:05 Sampler: CUSTOMER Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.98 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	153 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.94 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.14 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-038

SAMPLE INFORMATION

Sample Number: 1308083-038 Customer Sample Number:
Location: 00 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 7:05 Sampler: CUSTOMER Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-039

SAMPLE INFORMATION

Sample Number: 1308083-039 Customer Sample Number:
Location: 00F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 7:05 Sampler: CUSTOMER Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.06 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	1.63 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	ND ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308083-039

SAMPLE INFORMATION

Sample Number: 1308083-039 Customer Sample Number:
Location: 00F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 7:05 Sampler: CUSTOMER Received Date and Time: 8/9/2013 9:05:42 AM Received By: LGallimore

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-001

SAMPLE INFORMATION

Sample Number: 1308148-001 Customer Sample Number:
Location: 01B Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-002

SAMPLE INFORMATION

Sample Number: 1308148-002	Customer Sample Number:			
Location: 01BF LPR 3511 LEGATION ST NW FILTERED	Type: Dist.			
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/15/2013 12:35:50 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.41 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.83 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-002

SAMPLE INFORMATION

Sample Number: 1308148-002 Customer Sample Number:
Location: 01BF Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-003

SAMPLE INFORMATION

Sample Number: 1308148-003
Location: H14
LPR 3511 LEGATION ST NW UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
8/8/2013	13:10	AB/YT	8/15/2013 12:35:50 PM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.85 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	142 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.62 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	10.3 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-003

SAMPLE INFORMATION

Sample Number: 1308148-003 Customer Sample Number:
Location: H14 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-004

SAMPLE INFORMATION

Sample Number: 1308148-004

Customer Sample Number:

Location: H14F

Type: Dist.

LPR 3511 LEGATION ST NW FILTERED

Collection Date:
8/8/2013

Collection Time:
13:10

Sampler:
AB/YT

Received Date and Time:
8/15/2013 12:35:50 PM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.97 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.71 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-004

SAMPLE INFORMATION

Sample Number: 1308148-004 Customer Sample Number:
Location: H14F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-005

SAMPLE INFORMATION

Sample Number: 1308148-005 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED

Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/15/2013 12:35:50 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.83 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	137 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.41 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	7.39 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-005

SAMPLE INFORMATION

Sample Number: 1308148-005 Customer Sample Number:
Location: H15 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-006

SAMPLE INFORMATION

Sample Number: 1308148-006 Customer Sample Number:
Location: H15F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/15/2013 12:35:50 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-007

SAMPLE INFORMATION

Sample Number: 1308148-007 Customer Sample Number:
Location: H17 Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-008

SAMPLE INFORMATION

Sample Number: 1308148-008 Customer Sample Number:
Location: H17F Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/15/2013 12:35:50 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 9/16/2013
 Report Number: M- W1308148-009

SAMPLE INFORMATION

Sample Number: 1308148-009
 Location: X
 LPR 3511 LEGATION ST NW UNFILTERED
 Customer Sample Number:
 Type: Dist.
 Collection Date: 8/8/2013
 Collection Time: 13:10
 Sampler: AB/YT
 Received Date and Time: 8/15/2013 12:35:50 PM
 Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.48 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	127 ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	3.39 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.29 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-009

SAMPLE INFORMATION

Sample Number: 1308148-009
Customer Sample Number:
Location: X Type: Dist.
LPR 3511 LEGATION ST NW UNFILTERED
Collection Date: 8/8/2013 Collection Time: 13:10 Sampler: AB/YT Received Date and Time: 8/15/2013 12:35:50 PM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-010

SAMPLE INFORMATION

Sample Number: 1308148-010	Customer Sample Number:			
Location: XF	Type: Dist.			
LPR 3511 LEGATION ST NW FILTERED				
Collection Date: 8/8/2013	Collection Time: 13:10	Sampler: AB/YT	Received Date and Time: 8/15/2013 12:35:50 PM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.90 ug/L	9/10/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/10/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	2.58 ug/L	9/10/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/10/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/10/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/16/2013
Report Number: M- W1308148-010

SAMPLE INFORMATION

Sample Number: 1308148-010 Customer Sample Number:
Location: XF Type: Dist.
LPR 3511 LEGATION ST NW FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
8/8/2013 13:10 AB/YT 8/15/2013 12:35:50 PM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

9/16/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-001

SAMPLE INFORMATION

Sample Number: 1309100-001
Location: 01a
LPR 1716 C ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013	Collection Time: 8:35	Sampler: IC/ MS	Received Date and Time: 9/12/2013 11:34:09 AM	Received By: JCross
-------------------------------	--------------------------	--------------------	--	------------------------

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	10.1 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	82.4 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	95.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	66.1 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.25 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-001

SAMPLE INFORMATION

Sample Number: 1309100-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-002

SAMPLE INFORMATION

Sample Number: 1309100-002
Location: 01aF
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.21 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	74.5 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	62.5 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.98 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-002

SAMPLE INFORMATION

Sample Number: 1309100-002
Location: 01aF
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-003

SAMPLE INFORMATION

Sample Number: 1309100-003
Location: 01b
LPR 1716 C ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/11/2013
Collection Time: 8:35
Sampler: IC/ MS
Received Date and Time: 9/12/2013 11:34:09 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.95 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	69.1 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	129 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.0 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.27 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-003

SAMPLE INFORMATION

Sample Number: 1309100-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-004

SAMPLE INFORMATION

Sample Number: 1309100-004	Customer Sample Number:			
Location: 01bF LPR 1716 C ST NE FILTERED	Type: Dist.			
Collection Date: 9/11/2013	Collection Time: 8:35	Sampler: IC/ MS	Received Date and Time: 9/12/2013 11:34:09 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.41 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	104 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	24.9 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-004

SAMPLE INFORMATION

Sample Number: 1309100-004
Location: 01bF
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-005

SAMPLE INFORMATION

Sample Number: 1309100-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 1716 C ST NE UNFILTERED

Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/11/2013 8:35 IC/ MS 9/12/2013 11:34:09 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.55 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	76.3 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	114 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.97 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-005

SAMPLE INFORMATION

Sample Number: 1309100-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-006

SAMPLE INFORMATION

Sample Number: 1309100-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1716 C ST NE FILTERED

Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
 9/11/2013 8:35 IC/ MS 9/12/2013 11:34:09 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.35 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	97.7 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	16.3 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	9/19/2013	TPasquale

Comment:
MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect
Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-006

SAMPLE INFORMATION

Sample Number: 1309100-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1716 C ST NE FILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-007

SAMPLE INFORMATION

Sample Number: 1309100-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	11.5 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	88.6 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	89.4 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.2 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.77 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-007

SAMPLE INFORMATION

Sample Number: 1309100-007
Location: 01d
LPR 1716 C ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/11/2013
Collection Time: 8:35
Sampler: IC/ MS
Received Date and Time: 9/12/2013 11:34:09 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-008

SAMPLE INFORMATION

Sample Number: 1309100-008
Location: 01dF
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
9/11/2013	8:35	IC/ MS	9/12/2013 11:34:09 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	10.3 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	69.8 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.1 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.6 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-008

SAMPLE INFORMATION

Sample Number: 1309100-008
Location: 01dF
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-009

SAMPLE INFORMATION

Sample Number: 1309100-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	10.9 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	77.5 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	73.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.5 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.44 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-009

SAMPLE INFORMATION

Sample Number: 1309100-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 10/3/2013
 Report Number: M- W1309100-010

SAMPLE INFORMATION

Sample Number: 1309100-010
 Location: 02F
 LPR 1716 C ST NE FILTERED
 Customer Sample Number:
 Type: Dist.
 Collection Date: 9/11/2013
 Collection Time: 8:35
 Sampler: IC/ MS
 Received Date and Time: 9/12/2013 11:34:09 AM
 Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	10.3 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	62.7 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	13.6 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-010

SAMPLE INFORMATION

Sample Number: 1309100-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 1716 C ST NE FILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-011

SAMPLE INFORMATION

Sample Number: 1309100-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.55 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	63.9 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	49.1 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.61 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-011

SAMPLE INFORMATION

Sample Number: 1309100-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-012

SAMPLE INFORMATION

Sample Number: 1309100-012
Location: 03F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	9.18 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	12.5 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.0 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-012

SAMPLE INFORMATION

Sample Number: 1309100-012
Location: 03F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-013

SAMPLE INFORMATION

Sample Number: 1309100-013
Location: 04
LPR 1716 C ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
9/11/2013	8:35	IC/ MS	9/12/2013 11:34:09 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.60 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	61.1 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.1 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.08 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-013

SAMPLE INFORMATION

Sample Number: 1309100-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number:M- W1309100-014

SAMPLE INFORMATION

Sample Number: 1309100-014
Location: 04F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.25 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.3 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	17.7 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.15 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-014

SAMPLE INFORMATION

Sample Number: 1309100-014
Location: 04F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-015

SAMPLE INFORMATION

Sample Number: 1309100-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1716 C ST NE UNFILTERED

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.58 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	62.2 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.3 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	14.2 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-015

SAMPLE INFORMATION

Sample Number: 1309100-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-016

SAMPLE INFORMATION

Sample Number: 1309100-016
Location: 05F
LPR 1716 C ST NE FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/11/2013
Collection Time: 8:35
Sampler: IC/ MS
Received Date and Time: 9/12/2013 11:34:09 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.10 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.78 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-016

SAMPLE INFORMATION

Sample Number: 1309100-016
Location: 05F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-017

SAMPLE INFORMATION

Sample Number: 1309100-017
Location: 06
LPR 1716 C ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013
Collection Time: 8:35
Sampler: IC/ MS
Received Date and Time: 9/12/2013 11:34:09 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.15 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	59.6 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.4 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.13 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-017

SAMPLE INFORMATION

Sample Number: 1309100-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-018

SAMPLE INFORMATION

Sample Number: 1309100-018
Location: 06F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.75 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.1 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.35 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-018

SAMPLE INFORMATION

Sample Number: 1309100-018
Location: 06F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-019

SAMPLE INFORMATION

Sample Number: 1309100-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1716 C ST NE UNFILTERED

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.52 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	60.7 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	46.8 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.33 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-019

SAMPLE INFORMATION

Sample Number: 1309100-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-020

SAMPLE INFORMATION

Sample Number: 1309100-020
Location: 07F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
9/11/2013	8:35	IC/ MS	9/12/2013 11:34:09 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.35 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	40.6 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-020

SAMPLE INFORMATION

Sample Number: 1309100-020
Location: 07F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-021

SAMPLE INFORMATION

Sample Number: 1309100-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.70 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	61.7 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	49.7 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.69 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-021

SAMPLE INFORMATION

Sample Number: 1309100-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-022

SAMPLE INFORMATION

Sample Number: 1309100-022
Location: 08F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.30 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.4 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-022

SAMPLE INFORMATION

Sample Number: 1309100-022
Location: 08F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-023

SAMPLE INFORMATION

Sample Number: 1309100-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.68 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	70.3 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	51.0 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.51 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-023

SAMPLE INFORMATION

Sample Number: 1309100-023 Customer Sample Number:
Location: 09 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-024

SAMPLE INFORMATION

Sample Number: 1309100-024
Location: 09F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.18 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	42.8 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-024

SAMPLE INFORMATION

Sample Number: 1309100-024
Location: 09F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-025

SAMPLE INFORMATION

Sample Number: 1309100-025
Location: 10
LPR 1716 C ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.03 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	66.9 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	41.0 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.25 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-025

SAMPLE INFORMATION

Sample Number: 1309100-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/11/2013 8:35 IC/ MS 9/12/2013 11:34:09 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-026

SAMPLE INFORMATION

Sample Number: 1309100-026
Location: 10F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.62 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.6 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-026

SAMPLE INFORMATION

Sample Number: 1309100-026
Location: 10F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-027

SAMPLE INFORMATION

Sample Number: 1309100-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.05 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	64.3 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	31.7 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.46 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-027

SAMPLE INFORMATION

Sample Number: 1309100-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-028

SAMPLE INFORMATION

Sample Number: 1309100-028
Location: 11F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.55 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.4 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-028

SAMPLE INFORMATION

Sample Number: 1309100-028
Location: 11F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-029

SAMPLE INFORMATION

Sample Number: 1309100-029	Customer Sample Number:			
Location: 12	Type: Dist.			
LPR 1716 C ST NE UNFILTERED				
Collection Date: 9/11/2013	Collection Time: 8:35	Sampler: IC/ MS	Received Date and Time: 9/12/2013 11:34:09 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.07 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	76.9 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.1 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.86 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-029

SAMPLE INFORMATION

Sample Number: 1309100-029
Location: 12
LPR 1716 C ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-030

SAMPLE INFORMATION

Sample Number: 1309100-030
Location: 12F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-031

SAMPLE INFORMATION

Sample Number: 1309100-031 Customer Sample Number:
Location: H13 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number:M- W1309100-032

SAMPLE INFORMATION

Sample Number: 1309100-032
Location: H13F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date:	Collection Time:	Sampler:	Received Date and Time:	Received By:
9/11/2013	8:35	IC/ MS	9/12/2013 11:34:09 AM	JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.35 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.2 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-032

SAMPLE INFORMATION

Sample Number: 1309100-032
Location: H13F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-033

SAMPLE INFORMATION

Sample Number: 1309100-033

Customer Sample Number:

Location: H14

Type: Dist.

LPR 1716 C ST NE UNFILTERED

Collection Date:
9/11/2013

Collection Time:
8:35

Sampler:
IC/ MS

Received Date and Time:
9/12/2013 11:34:09 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	7.53 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	151 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	54.5 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	66.4 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-033

SAMPLE INFORMATION

Sample Number: 1309100-033 Customer Sample Number:
Location: H14 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number:M- W1309100-034

SAMPLE INFORMATION

Sample Number: 1309100-034

Customer Sample Number:

Location: H14F
LPR 1716 C ST NE FILTERED

Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	6.41 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.7 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-034

SAMPLE INFORMATION

Sample Number: 1309100-034 Customer Sample Number:
Location: H14F Type: Dist.
LPR 1716 C ST NE FILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-035

SAMPLE INFORMATION

Sample Number: 1309100-035 Customer Sample Number:
Location: H15 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.79 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	112 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.2 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	14.3 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-035

SAMPLE INFORMATION

Sample Number: 1309100-035 Customer Sample Number:
Location: H15 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-036

SAMPLE INFORMATION

Sample Number: 1309100-036 Customer Sample Number:
Location: H15F Type: Dist.
LPR 1716 C ST NE FILTERED

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.13 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.2 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-036

SAMPLE INFORMATION

Sample Number: 1309100-036
Location: H15F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-037

SAMPLE INFORMATION

Sample Number: 1309100-037 Customer Sample Number:
Location: H16 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.65 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	125 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.5 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	8.97 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-037

SAMPLE INFORMATION

Sample Number: 1309100-037 Customer Sample Number:
Location: H16 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-038

SAMPLE INFORMATION

Sample Number: 1309100-038

Customer Sample Number:

Location: H16F
LPR 1716 C ST NE FILTERED

Type: Dist.

Collection Date:
9/11/2013

Collection Time:
8:35

Sampler:
IC/ MS

Received Date and Time:
9/12/2013 11:34:09 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	4.89 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-038

SAMPLE INFORMATION

Sample Number: 1309100-038 Customer Sample Number:
Location: H16F Type: Dist.
LPR 1716 C ST NE FILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-039

SAMPLE INFORMATION

Sample Number: 1309100-039

Customer Sample Number:

Location: H17

Type: Dist.

LPR 1716 C ST NE UNFILTERED

Collection Date:
9/11/2013

Collection Time:
8:35

Sampler:
IC/ MS

Received Date and Time:
9/12/2013 11:34:09 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.57 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	104 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.1 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.43 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-039

SAMPLE INFORMATION

Sample Number: 1309100-039 Customer Sample Number:
Location: H17 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-040

SAMPLE INFORMATION

Sample Number: 1309100-040

Customer Sample Number:

Location: H17F

Type: Dist.

LPR 1716 C ST NE FILTERED

Collection Date:
9/11/2013

Collection Time:
8:35

Sampler:
IC/ MS

Received Date and Time:
9/12/2013 11:34:09 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	4.80 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	18.4 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-040

SAMPLE INFORMATION

Sample Number: 1309100-040 Customer Sample Number:
Location: H17F Type: Dist.
LPR 1716 C ST NE FILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-041

SAMPLE INFORMATION

Sample Number: 1309100-041
Location: H18
LPR 1716 C ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/11/2013
Collection Time: 8:35
Sampler: IC/ MS
Received Date and Time: 9/12/2013 11:34:09 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.44 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	106 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.2 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	12.9 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-041

SAMPLE INFORMATION

Sample Number: 1309100-041 Customer Sample Number:
Location: H18 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/11/2013 8:35 IC/ MS 9/12/2013 11:34:09 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-042

SAMPLE INFORMATION

Sample Number: 1309100-042 Customer Sample Number:
Location: H19 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-043

SAMPLE INFORMATION

Sample Number: 1309100-043 Customer Sample Number:
Location: H20 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.65 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	116 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.9 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	11.8 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-043

SAMPLE INFORMATION

Sample Number: 1309100-043 Customer Sample Number:
Location: H20 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 10/3/2013
 Report Number: M- W1309100-044

SAMPLE INFORMATION

Sample Number: 1309100-044 Customer Sample Number:
 Location: H21 Type: Dist.
 LPR 1716 C ST NE UNFILTERED

 Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.57 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	109 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	35.5 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	5.29 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-044

SAMPLE INFORMATION

Sample Number: 1309100-044 Customer Sample Number:
Location: H21 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-045

SAMPLE INFORMATION

Sample Number: 1309100-045
Location: H22
LPR 1716 C ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 9/11/2013
Collection Time: 8:35
Sampler: IC/ MS
Received Date and Time: 9/12/2013 11:34:09 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.41 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	103 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	33.2 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	12.2 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-045

SAMPLE INFORMATION

Sample Number: 1309100-045 Customer Sample Number:
Location: H22 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
9/11/2013 8:35 IC/ MS 9/12/2013 11:34:09 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-046

SAMPLE INFORMATION

Sample Number: 1309100-046 Customer Sample Number:
Location: X Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	5.17 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	74.3 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.4 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	6.26 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-046

SAMPLE INFORMATION

Sample Number: 1309100-046 Customer Sample Number:
Location: X Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
 Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 10/3/2013
 Report Number: M- W1309100-047

SAMPLE INFORMATION

Sample Number: 1309100-047		Customer Sample Number:		
Location: XF	LPR 1716 C ST NE FILTERED		Type: Dist.	
Collection Date: 9/11/2013	Collection Time: 8:35	Sampler: IC/ MS	Received Date and Time: 9/12/2013 11:34:09 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	4.66 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	14.8 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-047

SAMPLE INFORMATION

Sample Number: 1309100-047 Customer Sample Number:
Location: XF Type: Dist.
LPR 1716 C ST NE FILTERED
Collection Date: 9/11/2013 Collection Time: 8:35 Sampler: IC/ MS Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  10/3/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-048

SAMPLE INFORMATION

Sample Number: 1309100-048 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/10/2013 Collection Time: 23:00 Sampler: CUSTOMER Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.72 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	105 ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.5 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.28 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-048

SAMPLE INFORMATION

Sample Number: 1309100-048 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1716 C ST NE UNFILTERED
Collection Date: 9/10/2013 Collection Time: 23:00 Sampler: CUSTOMER Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-049

SAMPLE INFORMATION

Sample Number: 1309100-049
Location: 00F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/10/2013 Collection Time: 23:00 Sampler: CUSTOMER Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	8.30 ug/L	9/19/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	9/19/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.6 ug/L	9/19/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	9/19/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	9/19/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/3/2013
Report Number: M- W1309100-049

SAMPLE INFORMATION

Sample Number: 1309100-049
Location: 00F
LPR 1716 C ST NE FILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 9/10/2013 Collection Time: 23:00 Sampler: CUSTOMER Received Date and Time: 9/12/2013 11:34:09 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

10/3/2013
Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 12/12/2013
 Report Number: M- W1310278-001

SAMPLE INFORMATION

Sample Number: 1310278-001 Customer Sample Number:
 Location: 01a Type: Dist.
 LPR 1036 36TH ST NE UNFILTERED

Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	92.1 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	79.0 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.11 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-001

SAMPLE INFORMATION

Sample Number: 1310278-001 Customer Sample Number:
Location: 01a Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-002

SAMPLE INFORMATION

Sample Number: 1310278-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.31 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	60.2 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	50.9 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-002

SAMPLE INFORMATION

Sample Number: 1310278-002 Customer Sample Number:
Location: 01aF Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-003

SAMPLE INFORMATION

Sample Number: 1310278-003

Customer Sample Number:

Location: 01b

Type: Dist.

LPR 1036 36TH ST NE UNFILTERED

Collection Date:
10/29/2013

Collection Time:
8:30

Sampler:
IC/TY

Received Date and Time:
10/30/2013 10:06:20 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	47.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	10.3 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.13 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-003

SAMPLE INFORMATION

Sample Number: 1310278-003 Customer Sample Number:
Location: 01b Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-004

SAMPLE INFORMATION

Sample Number: 1310278-004
Customer Sample Number:
Location: 01bF
Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	44.8 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	39.5 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.4 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-004

SAMPLE INFORMATION

Sample Number: 1310278-004
Customer Sample Number:
Location: 01bF
Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-005

SAMPLE INFORMATION

Sample Number: 1310278-005

Customer Sample Number:

Location: 01c

Type: Dist.

LPR 1036 36TH ST NE UNFILTERED

Collection Date:
10/29/2013

Collection Time:
8:30

Sampler:
IC/TY

Received Date and Time:
10/30/2013 10:06:20 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.5 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.15 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-005

SAMPLE INFORMATION

Sample Number: 1310278-005 Customer Sample Number:
Location: 01c Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-006

SAMPLE INFORMATION

Sample Number: 1310278-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	17.9 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	14.5 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.34 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-006

SAMPLE INFORMATION

Sample Number: 1310278-006 Customer Sample Number:
Location: 01cF Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-007

SAMPLE INFORMATION

Sample Number: 1310278-007
Location: 01d
LPR 1036 36TH ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	38.3 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.19 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-007

SAMPLE INFORMATION

Sample Number: 1310278-007 Customer Sample Number:
Location: 01d Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-008

SAMPLE INFORMATION

Sample Number: 1310278-008
Location: 01dF
LPR 1036 36TH ST NE FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	39.0 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.1 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	11.6 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.55 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-008

SAMPLE INFORMATION

Sample Number: 1310278-008 Customer Sample Number:
Location: 01dF Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-009

SAMPLE INFORMATION

Sample Number: 1310278-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.8 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.22 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-009

SAMPLE INFORMATION

Sample Number: 1310278-009 Customer Sample Number:
Location: 02 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-010

SAMPLE INFORMATION

Sample Number: 1310278-010 Customer Sample Number:
Location: 02F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-011

SAMPLE INFORMATION

Sample Number: 1310278-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.19 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-011

SAMPLE INFORMATION

Sample Number: 1310278-011 Customer Sample Number:
Location: 03 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-012

SAMPLE INFORMATION

Sample Number: 1310278-012 Customer Sample Number:
Location: 03F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-013

SAMPLE INFORMATION

Sample Number: 1310278-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.7 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.0 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.20 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-013

SAMPLE INFORMATION

Sample Number: 1310278-013 Customer Sample Number:
Location: 04 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-014

SAMPLE INFORMATION

Sample Number: 1310278-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	25.3 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-014

SAMPLE INFORMATION

Sample Number: 1310278-014 Customer Sample Number:
Location: 04F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
 Maureen Schmelling
 Bureau of Water Services
 301 Bryant Street, NW
 Washington, DC 20001

Report Date: 12/12/2013
 Report Number: M- W1310278-015

SAMPLE INFORMATION

Sample Number: 1310278-015 Customer Sample Number:
 Location: 05 Type: Dist.
 LPR 1036 36TH ST NE UNFILTERED

Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.0 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	62.4 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.61 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-015

SAMPLE INFORMATION

Sample Number: 1310278-015 Customer Sample Number:
Location: 05 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-016

SAMPLE INFORMATION

Sample Number: 1310278-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.9 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	21.9 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-016

SAMPLE INFORMATION

Sample Number: 1310278-016 Customer Sample Number:
Location: 05F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-017

SAMPLE INFORMATION

Sample Number: 1310278-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	2.10 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	180 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.3 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.99 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-017

SAMPLE INFORMATION

Sample Number: 1310278-017 Customer Sample Number:
Location: 06 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-018

SAMPLE INFORMATION

Sample Number: 1310278-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.66 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	19.0 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-018

SAMPLE INFORMATION

Sample Number: 1310278-018 Customer Sample Number:
Location: 06F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-019

SAMPLE INFORMATION

Sample Number: 1310278-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.87 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	202 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.1 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	3.01 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-019

SAMPLE INFORMATION

Sample Number: 1310278-019 Customer Sample Number:
Location: 07 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-020

SAMPLE INFORMATION

Sample Number: 1310278-020 Customer Sample Number:
Location: 07F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

**US Army Corps of Engineers
Washington Aqueduct Laboratory**

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-021

SAMPLE INFORMATION

Sample Number: 1310278-021	Customer Sample Number:			
Location: 08	Type: Dist.			
LPR 1036 36TH ST NE UNFILTERED				
Collection Date: 10/29/2013	Collection Time: 8:30	Sampler: IC/TY	Received Date and Time: 10/30/2013 10:06:20 AM	Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.27 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	84.9 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	27.5 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.14 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-021

SAMPLE INFORMATION

Sample Number: 1310278-021 Customer Sample Number:
Location: 08 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-022

SAMPLE INFORMATION

Sample Number: 1310278-022

Customer Sample Number:

Location: 08F

Type: Dist.

LPR 1036 36TH ST NE FILTERED

Collection Date:
10/29/2013

Collection Time:
8:30

Sampler:
IC/TY

Received Date and Time:
10/30/2013 10:06:20 AM

Received By:
JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.20 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	20.9 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-022

SAMPLE INFORMATION

Sample Number: 1310278-022 Customer Sample Number:
Location: 08F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number:M- W1310278-023

SAMPLE INFORMATION

Sample Number: 1310278-023
Location: 09
LPR 1036 36TH ST NE UNFILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	38.8 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.3 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.27 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-023

SAMPLE INFORMATION

Sample Number: 1310278-023
Location: 09
LPR 1036 36TH ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-024

SAMPLE INFORMATION

Sample Number: 1310278-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	22.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-024

SAMPLE INFORMATION

Sample Number: 1310278-024 Customer Sample Number:
Location: 09F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-025

SAMPLE INFORMATION

Sample Number: 1310278-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	23.5 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.0 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.12 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-025

SAMPLE INFORMATION

Sample Number: 1310278-025 Customer Sample Number:
Location: 10 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-026

SAMPLE INFORMATION

Sample Number: 1310278-026 Customer Sample Number:
Location: 10F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-027

SAMPLE INFORMATION

Sample Number: 1310278-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	16.9 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	26.0 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.27 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-027

SAMPLE INFORMATION

Sample Number: 1310278-027 Customer Sample Number:
Location: 11 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-028

SAMPLE INFORMATION

Sample Number: 1310278-028 Customer Sample Number:
Location: 11F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-029

SAMPLE INFORMATION

Sample Number: 1310278-029
Location: 12
LPR 1036 36TH ST NE UNFILTERED

Customer Sample Number:
Type: Dist.

Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	15.2 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	34.8 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.57 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-029

SAMPLE INFORMATION

Sample Number: 1310278-029 Customer Sample Number:
Location: 12 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-030

SAMPLE INFORMATION

Sample Number: 1310278-030 Customer Sample Number:
Location: 12F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	32.0 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.49 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-030

SAMPLE INFORMATION

Sample Number: 1310278-030
Location: 12F
LPR 1036 36TH ST NE FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-031

SAMPLE INFORMATION

Sample Number: 1310278-031 Customer Sample Number:
Location: 13 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	1.03 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	17.2 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	56.4 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	4.16 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-031

SAMPLE INFORMATION

Sample Number: 1310278-031 Customer Sample Number:
Location: 13 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-032

SAMPLE INFORMATION

Sample Number: 1310278-032 Customer Sample Number:
Location: 13F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	47.3 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.18 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-032

SAMPLE INFORMATION

Sample Number: 1310278-032 Customer Sample Number:
Location: 13F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-033

SAMPLE INFORMATION

Sample Number: 1310278-033 Customer Sample Number:
Location: 14 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-034

SAMPLE INFORMATION

Sample Number: 1310278-034 Customer Sample Number:
Location: 14F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	55.7 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-034

SAMPLE INFORMATION

Sample Number: 1310278-034 Customer Sample Number:
Location: 14F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-035

SAMPLE INFORMATION

Sample Number: 1310278-035 Customer Sample Number:
Location: 15 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	65.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	2.23 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-035

SAMPLE INFORMATION

Sample Number: 1310278-035 Customer Sample Number:
Location: 15 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-036

SAMPLE INFORMATION

Sample Number: 1310278-036
Location: 15F
LPR 1036 36TH ST NE FILTERED
Customer Sample Number:
Type: Dist.
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	58.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-036

SAMPLE INFORMATION

Sample Number: 1310278-036 Customer Sample Number:
Location: 15F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-037

SAMPLE INFORMATION

Sample Number: 1310278-037 Customer Sample Number:
Location: 16 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number:M- W1310278-038

SAMPLE INFORMATION

Sample Number: 1310278-038 Customer Sample Number:
Location: 16F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	61.4 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-038

SAMPLE INFORMATION

Sample Number: 1310278-038 Customer Sample Number:
Location: 16F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-039

SAMPLE INFORMATION

Sample Number: 1310278-039 Customer Sample Number:
Location: 17 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	73.2 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.32 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-039

SAMPLE INFORMATION

Sample Number: 1310278-039 Customer Sample Number:
Location: 17 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-040

SAMPLE INFORMATION

Sample Number: 1310278-040 Customer Sample Number:
Location: 17F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-041

SAMPLE INFORMATION

Sample Number: 1310278-041 Customer Sample Number:
Location: 18 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	74.7 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.11 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-041

SAMPLE INFORMATION

Sample Number: 1310278-041 Customer Sample Number:
Location: 18 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-042

SAMPLE INFORMATION

Sample Number: 1310278-042 Customer Sample Number:
Location: 18F Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	65.5 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	< 0.5 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-042

SAMPLE INFORMATION

Sample Number: 1310278-042 Customer Sample Number:
Location: 18F Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-043

SAMPLE INFORMATION

Sample Number: 1310278-043 Customer Sample Number:
Location: H19 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	12.5 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	66.6 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	1.27 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-043

SAMPLE INFORMATION

Sample Number: 1310278-043 Customer Sample Number:
Location: H19 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-044

SAMPLE INFORMATION

Sample Number: 1310278-044 Customer Sample Number:
Location: H20 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-045

SAMPLE INFORMATION

Sample Number: 1310278-045
Customer Sample Number:
Location: H21
Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013
Collection Time: 8:30
Sampler: IC/TY
Received Date and Time: 10/30/2013 10:06:20 AM
Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-046

SAMPLE INFORMATION

Sample Number: 1310278-046 Customer Sample Number:
Location: H22 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED

Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	ND ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	45.5 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-046

SAMPLE INFORMATION

Sample Number: 1310278-046 Customer Sample Number:
Location: H22 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-047

SAMPLE INFORMATION

Sample Number: 1310278-047 Customer Sample Number:
Location: H23 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-048

SAMPLE INFORMATION

Sample Number: 1310278-048 Customer Sample Number:
Location: H24 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-049

SAMPLE INFORMATION

Sample Number: 1310278-049 Customer Sample Number:
Location: H25 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: 10/29/2013 Collection Time: 8:30 Sampler: IC/TY Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	30.7 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.9 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-049

SAMPLE INFORMATION

Sample Number: 1310278-049 Customer Sample Number:
Location: H25 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-050

SAMPLE INFORMATION

Sample Number: 1310278-050 Customer Sample Number:
Location: H26 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.6 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	10.1 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	29.3 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.7 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT


District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-050

SAMPLE INFORMATION

Sample Number: 1310278-050 Customer Sample Number:
Location: H26 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:  12/12/2013
Michael Chicoine, Laboratory Manager Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-051

SAMPLE INFORMATION

Sample Number: 1310278-051 Customer Sample Number:
Location: X Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
Manganese	EPA 200.8	ug/L	0.15 ug/L	0.5 ug/L	0.5 ug/L	12/4/2013	TPasquale
Iron	EPA 200.8	ug/L	5.1 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Copper	EPA 200.8	ug/L	0.17 ug/L	0.5 ug/L	28.8 ug/L	12/4/2013	TPasquale
Zinc	EPA 200.8	ug/L	0.15 ug/L	10 ug/L	< 10 ug/L	12/4/2013	TPasquale
Lead	EPA 200.8	ug/L	0.07 ug/L	0.5 ug/L	0.8 ug/L	12/4/2013	TPasquale

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-051

SAMPLE INFORMATION

Sample Number: 1310278-051 Customer Sample Number:
Location: X Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 8:30 IC/TY 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-052

SAMPLE INFORMATION

Sample Number: 1310278-052 Customer Sample Number:
Location: 00 Type: Dist.
LPR 1036 36TH ST NE UNFILTERED
Collection Date: Collection Time: Sampler: Received Date and Time: Received By:
10/29/2013 0:00 CUSTOMER 10/30/2013 10:06:20 AM JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

METALS REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/12/2013
Report Number: M- W1310278-053

SAMPLE INFORMATION

Sample Number: 1310278-053 Customer Sample Number:
Location: 00F Type: Dist.
LPR 1036 36TH ST NE FILTERED
Collection Date: 10/29/2013 Collection Time: 0:00 Sampler: CUSTOMER Received Date and Time: 10/30/2013 10:06:20 AM Received By: JCross

Parameter	Method	MCL	MDL	RDL	Result	Analysis Date	Analyst
-----------	--------	-----	-----	-----	--------	---------------	---------

Reviewed By:



Michael Chicoine, Laboratory Manager

12/12/2013

Date

5900 MacArthur Blvd. NW, Washington DC 20016 Phone (202) 764-0050 Fax (202) 764-2401

Comment:

MCL = Maximum Contaminant Level MDL = Minimum Detection Level RDL = Reporting Detection Limit ND=Non-Detect

Iron results are for informational purposes only and cannot be used for compliance.

DC Water Fountain and Sink Samples

At the request of DC Water's Union, DC Water's water quality staff collected lead samples from all locations that are used by employees for drinking purposes. Sample sites included fountains and sinks at all DC Water owned facilities.

Sampling procedures included flushing lines for several minutes, stagnating for at least 15 hours and collecting samples using 250 mL plastic bottles. All samples were analyzed by the Washington Aqueduct.

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-002

SAMPLE INFORMATION

Sample Number: 1307163-002 Customer Sample Number: Project: UNION
Location: 2-B BRYANT ST 1ST FLOOR (NORTH- Type: Dist.
LOW)

Collection Date: 7/18/2013 Collection Time: 10:20 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.069 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.072 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-003

SAMPLE INFORMATION

Sample Number: 1307163-003 Customer Sample Number: Project: UNION
Location: 3-B BRYANT ST 1ST FLOOR (SOUTH) Type: Dist.

Collection Date: 7/18/2013 Collection Time: 10:30 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.065 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.071 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-005

SAMPLE INFORMATION

Sample Number: 1307163-005 Customer Sample Number: Project: UNION
Location: 5-B BRYANT ST 2ND FLOOR (NORTH - Type: Dist.
LOW)

Collection Date: 7/18/2013 Collection Time: 10:40 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.049 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.084 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-006

SAMPLE INFORMATION

Sample Number: 1307163-006 Customer Sample Number: Project: UNION
Location: 6-B BRYANT ST 2ND FLOOR (SOUTH) Type: Dist.

Collection Date: 7/18/2013 Collection Time: 10:50 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.063 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.068 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-010

SAMPLE INFORMATION

Sample Number: 1307163-010 Customer Sample Number: Project: UNION
Location: 10-B BRYANT ST 3R FLOOR (SOUTH- Type: Dist.
LOW)

Collection Date: 7/18/2013 Collection Time: 11:10 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.124 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.154 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-011

SAMPLE INFORMATION

Sample Number: 1307163-011 Customer Sample Number: Project: UNION
Location: 11-B BRYANT ST BASEMENT (NORTH-
HIGH) Type: Dist.
Collection Date: 7/18/2013 Collection Time: 11:20 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.057 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.093 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-013

SAMPLE INFORMATION

Sample Number: 1307163-013 Customer Sample Number: Project: UNION
Location: 13-B BRYANT ST 1ST FLOOR SHOP Type: Dist.
(HIGH)

Collection Date: 7/18/2013 Collection Time: 10:00 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.110 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-014

SAMPLE INFORMATION

Sample Number: 1307163-014 Customer Sample Number: Project: UNION
Location: 14-B BRYANT ST 1ST FLOOR SHOP Type: Dist.
(LOW)

Collection Date: 7/18/2013 Collection Time: 10:00 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	< 0.01 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.109 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-015

SAMPLE INFORMATION

Sample Number: 1307163-015 Customer Sample Number: Project: UNION
Location: 15-B BRYANT ST 2ND FLOOR SHOP Type: Dist.
(HIGH)

Collection Date: 7/18/2013 Collection Time: 10:05 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.164 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.095 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0006 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-016

SAMPLE INFORMATION

Sample Number: 1307163-016 Customer Sample Number: Project: UNION
Location: 16-B BRYANT ST 2ND FLOOR SHOP Type: Dist.
(LOW)

Collection Date: 7/18/2013 Collection Time: 10:05 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	1.70 mg/L	7/31/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.672 mg/L	7/31/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0076 mg/L	7/31/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-017

SAMPLE INFORMATION

Sample Number: 1307163-017 Customer Sample Number: Project: UNION
Location: 17-B BRYANT ST KITCHEN (3RD FLOOR) Type: Dist.

Collection Date: 7/18/2013 Collection Time: 11:05 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.070 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.084 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307163-018

SAMPLE INFORMATION

Sample Number: 1307163-018 Customer Sample Number: Project: UNION
Location: 1-R FORT RENO (FOUNTAIN) Type: Dist.

Collection Date: 7/18/2013 Collection Time: 7:30 Sampler: HB/VI Received Date and Time: 7/18/2013 1:01:35 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.067 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-001

SAMPLE INFORMATION

Sample Number: 1307280-001 Customer Sample Number: Project: UNION
Location: BH-1 M STREET BOAT HOUSE Type: Dist.

Collection Date: 7/31/2013 Collection Time: 9:40 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.027 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.177 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-002

SAMPLE INFORMATION

Sample Number: 1307280-002 Customer Sample Number: Project: UNION
Location: 3-O O STREET BUILDING A (KITCHEN) Type: Dist.

Collection Date: 7/31/2013 Collection Time: 10:25 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.147 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.249 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0050 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-003

SAMPLE INFORMATION

Sample Number: 1307280-003 Customer Sample Number: Project: UNION
Location: 4-O O STREET BUILDING F (BREAK Type: Dist.
ROOM)

Collection Date: 7/31/2013 Collection Time: 10:40 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.014 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.078 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-004

SAMPLE INFORMATION

Sample Number: 1307280-004 Customer Sample Number: Project: UNION
Location: 6-O O STREET BUILDING H (1ST FLOOR) (NORTH) Type: Dist.

Collection Date: 7/31/2013 Collection Time: 10:55 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.013 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.277 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-005

SAMPLE INFORMATION

Sample Number: 1307280-005 Customer Sample Number: Project: UNION
Location: 7-O O STREET BUILDING H (1ST FLOOR) (SOUTH) Type: Dist.

Collection Date: 7/31/2013 Collection Time: 11:10 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	ND mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.529 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0011 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-006

SAMPLE INFORMATION

Sample Number: 1307280-006 Customer Sample Number: Project: UNION
Location: 8-O O STREET BUILDING H (2ND FLOOR) (KITCHEN) Type: Dist.

Collection Date: 7/31/2013 Collection Time: 11:20 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.067 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.048 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1307280-007

SAMPLE INFORMATION

Sample Number: 1307280-007 Customer Sample Number: Project: UNION
Location: 11-O O STREET FLEET SHOP Type: Dist.

Collection Date: 7/31/2013 Collection Time: 11:40 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis Date	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.024 mg/L	8/26/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.375 mg/L	8/26/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/26/2013	TPasquale

Comment:
ND=Non-Detect MDL = Minimum Detection Level RDL = Reporting Detection Limit
Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By: 
Michael Chicoine, Laboratory Manager

9/4/2013
Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/4/2013
Report Number: LC-W1308133-001

SAMPLE INFORMATION

Sample Number: 1308133-001 Customer Sample Number: Project: UNION
Location: 13-O O STREET BUILDING H (2ND FLOOR) Type: Dist.

Collection Date: 8/14/2013 Collection Time: 12:45 Sampler: HB Received Date and Time: 8/14/2013 3:45:46 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	0.026 mg/L	8/27/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	0.247 mg/L	8/27/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	< 0.0005 mg/L	8/27/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:



Michael Chicoine, Laboratory Manager

9/4/2013

Date

US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

LEAD AND COPPER REPORT

District of Columbia Water and Sewer
Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/27/2013
Report Number: LC-W1307280-008

SAMPLE INFORMATION

Sample Number: 1307280-008 Customer Sample Number: Project: UNION
Location: 12-O O STREET FLEET SHOP (2ND FLOOR KITCHEN) Type: Dist.

Collection Date: 7/31/2013 Collection Time: 11:45 Sampler: HB Received Date and Time: 7/31/2013 1:46:47 PM Received By: JCross

Parameter	Method	Action Level	MDL	RDL	Result	Analysis	Analyst
Iron	EPA 200.8	mg/L	5.1 ug/L	0.01 mg/L	3.34 mg/L	9/5/2013	TPasquale
Copper	EPA 200.8	1.30 mg/L	0.17 ug/L	0.001 mg/L	1.05 mg/L	9/5/2013	TPasquale
Lead	EPA 200.8	0.015 mg/L	0.07 ug/L	0.0005 mg/L	0.0290 mg/L	9/5/2013	TPasquale

Comment:

ND=Non-Detect

MDL = Minimum Detection Level

RDL = Reporting Detection Limit

Iron results are for informational purposes only and cannot be used for compliance.

Reviewed By:




Michael Chicoine, Laboratory Manager

9/27/2013

Date

Attachment 3

Customer Letter Distribution Certification



DISTRICT OF COLUMBIA WATER AND SEWER AUTHORITY | 3900 DONALDSON PLACE, NW | WASHINGTON, DC 20016

January 9, 2014

William Arguto
U.S. Environmental Protection Agency Region III
1650 Arch Street
Philadelphia, PA 19103-2029

Re: Certification of Distribution of Consumer Test Results

Dear Mr. Arguto:

The District of Columbia Water and Sewer Authority (PWSID: DC000002) hereby certifies that for the lead and copper compliance monitoring period ending December 31, 2013, the “consumer notification of test results” have been distributed to the participating Lead and Copper Compliance monitoring customers in a manner consistent with the requirements of 40 CFR § 141.85(d). Pursuant to 40 CFR § 141.90(f)(3), attached are copies of sample consumer notifications.

Sincerely,

A handwritten signature in black ink, appearing to read "Jessica Edwards-Brandt". The signature is stylized and includes a long horizontal line extending to the right.

Jessica Edwards-Brandt
Manager, Drinking Water Division

cc: Charles Kiely
Gregory Hope
Randy Hayman



December 31, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead and copper levels were below the Environmental Protection Agency (EPA) action levels.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

If you are pregnant or have children under age six, you should consider using cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Some people who drink water containing copper in excess of the action level may, with short term

exposure, experience gastrointestinal distress, and with long-term exposure may experience liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



December 31, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The first draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager



December 31, 2013

«First_name» «Last_Name»
«Address»
Washington, DC «Zip_Code»

Dear «First_name» «Last_Name»,

Thank you for participating in the Lead and Copper Water Monitoring Program administered by the District of Columbia Water and Sewer Authority (DC Water). Your participation helps us monitor the quality of drinking water in the District.

The sample results indicate the lead level was above the Environmental Protection Agency (EPA) action level. DC Water recommends that you take steps to minimize potential lead exposure. You should filter your water until lead levels decline in your drinking water. If you are pregnant or have children under age six, use cold, filtered tap water for drinking and cooking until all sources of lead are removed. This includes water used for making infant formula, beverages and ice.

The potential for lead in drinking water varies among homes in the District. Drinking water is essentially lead-free in the distribution system and prior to entering a water service pipe. Lead can enter water that travels through a lead service pipe or other household lead sources, such as lead solder, lead-based fixtures and galvanized plumbing. A lead service pipe connects the water main in the street to your household plumbing. **According to our records, your home has a full or partial lead service pipe.** (If this information is inaccurate, please contact Customer Service at 202-354-3600.)

Two water samples were collected from your household tap:

- First draw: Measures lead release from household plumbing and fixtures, especially potential lead sources near the tap where the sample is collected. (Required by EPA)
- Second draw: Measures lead release from the lead service pipe and household plumbing.

The second draw water sample was above the lead action level. The EPA action levels for lead and copper are 15 parts per billion (ppb) and 1,300 ppb, respectively. An action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. The Maximum Contaminant Level Goals (MCLG) for lead and copper are zero and 1,300 ppb, respectively. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Sample	Lead Level (ppb)	Copper Level (ppb)
First	«Lead_mgL_1st_Draw»	«Copper_mgL_1st_Draw»
Second	«Lead_mgL_2nd_Draw»	«Copper_mgL_2nd_Draw»
EPA Action Level	15 ppb	1300 ppb

Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk of lead exposure is to infants, young children and pregnant women. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of the body. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

Short-term exposure to copper levels above the action level may cause gastrointestinal distress, and long-term exposure may contribute to liver or kidney damage.

The District Department of the Environment (DDOE) provides information on blood lead testing for young children, pregnant women and nursing mothers. To learn more about protecting yourself and your family from lead exposure, contact DDOE at 202-654-6036 or visit www.ddoe.dc.gov.

Minimizing lead exposure involves the shared responsibility of DC Water and individual residents. DC Water encourages you to take the following steps:

Remove lead sources

- Replace your lead service pipe with copper. DC Water will replace your lead service pipe in public space if you choose to replace the private portion. For more information about lead service pipe replacement, contact Customer Service at 202-354-3600.
- Replace household galvanized plumbing. When lead is released from a lead service pipe and passes through galvanized plumbing (particularly over decades of use), lead can accumulate on the inside, corroded walls of this plumbing. Lead release from galvanized pipes can continue to occur even after a lead service pipe is replaced.
- Install lead-free plumbing fixtures certified to meet NSF Standard 61 Annex G (NSF 61-G). It is important to know that other fixtures may be labeled "lead-free" and still contain up to eight percent lead.
- Flush cold water taps after installing new household pipes or fixtures. New plumbing can release metals after installation. Flush for five minutes at a high flow rate once a day for three days.

Use filtered tap water

- Be sure to select a filter certified to meet NSF Standard 53 for lead removal. The filter package should specifically list the device as certified for removing the contaminant "lead."
- We recommend devices that are installed at your faucet tap (also known as point-of-use) or pitcher-style filters. You can search the NSF International website for certified drinking water filters at www.nsf.org/Certified/DWTU or call 1-800-673-8010.
- Be sure to routinely replace filter cartridges according to the manufacturer's instructions.

Do not use your hot water tap for drinking and cooking

- Always use cold tap water, then heat water if necessary. Boiling water does not reduce lead levels.
- Hot tap water can cause a greater amount of lead to release from plumbing. Always use cold tap water, including water used for making ice, beverages and infant formula.

Run the cold water tap when water is not used for several hours

- Run your cold water tap for two minutes before using it for drinking or cooking.
- Lead and other metals can dissolve in water when it sits in pipes for a few hours.

Remove and clean faucet aerators

- Lead particles and sediment can collect in the aerator screen located at the tip of your faucet.

We appreciate your participation in the Lead and Copper Water Monitoring Program. If you have additional questions, please contact the Drinking Water Division at 202-612-3440 or visit www.dcwater.com/lead.

Sincerely,



George S. Hawkins, General Manager