

Attachment 2

Other Samples Analyzed for Lead

Customer Service Samples

DC Water operates a program where customers can request a lead sampling kit on an annual basis. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to collect samples. DC Water reviews the sampling information to ensure samples were collected correctly. DC Water delivers the samples to the Washington Aqueduct and sends the results to customers.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-017

Sample Location: 1st Draw 1225 Randolph St NE

Customer Sample Number:

Date / Time Collected: 6/19/2021 2:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2106245-017

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1225 Randolph St NE

Customer Sample Number:

Date / Time Collected: 6/19/2021 2:32 PM

Customer Program Code: DS

Laboratory Sample Number: 2106245-018

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107048-001

Sample Location: 1st Draw 1320 L St. SE
Customer Sample Number:
Date / Time Collected: 6/22/2021 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2107048-001
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1320 L St. SE
Customer Sample Number:
Date / Time Collected: 6/22/2021 7:32 AM

Customer Program Code: DS
Laboratory Sample Number: 2107048-002
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107076-019

Sample Location: 1st Draw 1342 Irving St. NW

Customer Sample Number:

Date / Time Collected: 7/6/2021 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-019

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1342 Irving St. NW

Customer Sample Number:

Date / Time Collected: 7/6/2021 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-020

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-009

Sample Location: 1st Draw 1435 Kennedy St. NW

Customer Sample Number:

Date / Time Collected: 6/17/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-009

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1435 Kennedy St. NW

Customer Sample Number:

Date / Time Collected: 6/17/2021 6:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-010

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-015

Sample Location: 1st Draw 1438 Monroe St NW

Customer Sample Number:

Date / Time Collected: 6/28/2021 12:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-015

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	74.0	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1438 Monroe St NW

Customer Sample Number:

Date / Time Collected: 6/28/2021 12:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-016

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	16.5	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106194-001

Sample Location: 1st Draw 1505 Church St NW

Customer Sample Number:

Date / Time Collected: 6/11/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-001

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1505 Church St NW

Customer Sample Number:

Date / Time Collected: 6/11/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-002

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107076-005

Sample Location: 1st Draw 1615 21st St NW

Customer Sample Number:

Date / Time Collected: 7/1/2021 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-005

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1615 21st St NW

Customer Sample Number:

Date / Time Collected: 7/1/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-006

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-003

Sample Location: 1st Draw 1665 32nd St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2021 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-003

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1665 32nd St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2021 7:46 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-004

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-021

Sample Location: 1st Draw 1709 Kenyon St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-021

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1709 Kenyon St. NW

Customer Sample Number:

Date / Time Collected: 6/20/2021 6:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-022

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106220-001

Sample Location: 1st Draw 1712 Crestwood Dr. NW
Customer Sample Number:
Date / Time Collected: 6/12/2021 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2106220-001
Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1712 Crestwood Dr. NW
Customer Sample Number:
Date / Time Collected: 6/12/2021 7:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2106220-002
Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106194-003

Sample Location: 1st Draw 1819 Irving St NW

Customer Sample Number:

Date / Time Collected: 6/8/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-003

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1819 Irving St NW

Customer Sample Number:

Date / Time Collected: 6/8/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-004

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106256-005

Sample Location: 1st Draw 1821 Redwood Terr NW
Customer Sample Number:
Date / Time Collected: 6/21/2021 9:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2106256-005
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1821 Redwood Terr NW
Customer Sample Number:
Date / Time Collected: 6/21/2021 9:22 AM

Customer Program Code: DS
Laboratory Sample Number: 2106256-006
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-001

Sample Location: 1st Draw 1867 Monroe St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2021 6:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-001

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1867 Monroe St. NW

Customer Sample Number:

Date / Time Collected: 6/13/2021 6:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-002

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106194-009

Sample Location: 1st Draw 2127 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 6/16/2021 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-009

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2127 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 6/16/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-010

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-009

Sample Location: 1st Draw 213 Anacostia Ave NE

Customer Sample Number:

Date / Time Collected: 6/29/2021 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-009

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 213 Anacostia Ave NE

Customer Sample Number:

Date / Time Collected: 6/29/2021 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-010

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106220-005

Sample Location: 1st Draw 253 12 ST SE
Customer Sample Number:
Date / Time Collected: 6/14/2021 6:53 AM

Customer Program Code: DS
Laboratory Sample Number: 2106220-005
Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 253 12 ST SE
Customer Sample Number:
Date / Time Collected: 6/14/2021 6:56 AM

Customer Program Code: DS
Laboratory Sample Number: 2106220-006
Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107076-015

Sample Location: 1st Draw 2905 Woodland Dr NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-015

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2905 Woodland Dr NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 9:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-016

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-013

Sample Location: 1st Draw 3025 Porter St NW Apt 22

Customer Sample Number:

Date / Time Collected: 6/24/2021 7:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-013

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3025 Porter St NW Apt 22

Customer Sample Number:

Date / Time Collected: 6/24/2021 7:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-014

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106256-007

Sample Location: 1st Draw 325 10th St NE

Customer Sample Number:

Date / Time Collected: 6/10/2021 8:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2106256-007

Date / Time Received: 6/30/2021 8:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	7/14/2021	SBrooks

Sample Location: 2nd Draw 325 10th St NE

Customer Sample Number:

Date / Time Collected: 6/10/2021 8:23 AM

Customer Program Code: DS

Laboratory Sample Number: 2106256-008

Date / Time Received: 6/30/2021 8:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-041

Sample Location: 1st Draw 328 34th PL NE
Customer Sample Number:
Date / Time Collected: 6/23/2021 5:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2106245-041
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 328 34th PL NE
Customer Sample Number:
Date / Time Collected: 6/23/2021 5:18 AM

Customer Program Code: DS
Laboratory Sample Number: 2106245-042
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-007

Sample Location: 1st Draw 3365 Stuyvesant PL NW
Customer Sample Number:
Date / Time Collected: 6/16/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2106245-007
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3365 Stuyvesant PL NW
Customer Sample Number:
Date / Time Collected: 6/16/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2106245-008
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	27.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106220-007

Sample Location: 1st Draw 3419 30th St. NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106220-007

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3419 30th St. NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2106220-008

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106234-011

Sample Location: 1st Draw 3740 Appleton St NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2106234-011

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3740 Appleton St NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2106234-012

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106194-005

Sample Location: 1st Draw 3801 10th St NW

Customer Sample Number:

Date / Time Collected: 6/15/2021 5:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-005

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3801 10th St NW

Customer Sample Number:

Date / Time Collected: 6/15/2021 5:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2106194-006

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106220-011

Sample Location: 1st Draw 3807 Van Ness St. NW

Customer Sample Number:

Date / Time Collected: 6/16/2021 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2106220-011

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3807 Van Ness St. NW

Customer Sample Number:

Date / Time Collected: 6/16/2021 6:54 AM

Customer Program Code: DS

Laboratory Sample Number: 2106220-012

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107076-001

Sample Location: 1st Draw 3812 47th St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-001

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3812 47th St. NW

Customer Sample Number:

Date / Time Collected: 6/26/2021 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-002

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106256-003

Sample Location: 1st Draw 3823 T St NW
Customer Sample Number:
Date / Time Collected: 6/18/2021 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2106256-003
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3823 T St NW
Customer Sample Number:
Date / Time Collected: 6/18/2021 6:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2106256-004
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-005

Sample Location: 1st Draw 4215 3rd St NW

Customer Sample Number:

Date / Time Collected: 6/25/2021 7:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2107022-005

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4215 3rd St NW

Customer Sample Number:

Date / Time Collected: 6/25/2021 7:04 PM

Customer Program Code: DS

Laboratory Sample Number: 2107022-006

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-001

Sample Location: 1st Draw 4218 3rd St NW

Customer Sample Number:

Date / Time Collected: 6/29/2021 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-001

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4218 3rd St NW

Customer Sample Number:

Date / Time Collected: 6/29/2021 5:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-002

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-005

Sample Location: 1st Draw 4310 3rd St. NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-005

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4310 3rd St. NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 5:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-006

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-003

Sample Location: 1st Draw 4410 35th St NW

Customer Sample Number:

Date / Time Collected: 6/28/2021 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-003

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4410 35th St NW

Customer Sample Number:

Date / Time Collected: 6/28/2021 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-004

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106220-009

Sample Location: 1st Draw 4535 43rd Pl. NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106220-009

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4535 43rd Pl. NW

Customer Sample Number:

Date / Time Collected: 6/14/2021 9:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2106220-010

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-007

Sample Location: 1st Draw 5015 46th St NW

Customer Sample Number:

Date / Time Collected: 6/29/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-007

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 5015 46th St NW

Customer Sample Number:

Date / Time Collected: 6/29/2021 6:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-008

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106220-003

Sample Location: 1st Draw 5110 Jay St. NE
Customer Sample Number:
Date / Time Collected: 6/13/2021 10:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2106220-003
Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 5110 Jay St. NE
Customer Sample Number:
Date / Time Collected: 6/13/2021 10:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2106220-004
Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107022-011

Sample Location: 1st Draw 5327 42nd PI NW

Customer Sample Number:

Date / Time Collected: 6/26/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-011

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 5327 42nd PI NW

Customer Sample Number:

Date / Time Collected: 6/26/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2107022-012

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106194-007

Sample Location: 1st Draw 602 Keefer PI NW

Customer Sample Number:

Date / Time Collected: 6/1/2021 1:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2106194-007

Date / Time Received: 6/22/2021 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	7/14/2021	SBrooks

Sample Location: 2nd Draw 602 Keefer PI NW

Customer Sample Number:

Date / Time Collected: 6/1/2021 1:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2106194-008

Date / Time Received: 6/22/2021 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107076-017

Sample Location: 1st Draw 6408 7th St. NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 2:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2107076-017

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 6408 7th St. NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 2:41 PM

Customer Program Code: DS

Laboratory Sample Number: 2107076-018

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107076-003

Sample Location: 1st Draw 6605 Piney Branch Rd NW

Customer Sample Number:

Date / Time Collected: 6/29/2021 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-003

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 6605 Piney Branch Rd NW

Customer Sample Number:

Date / Time Collected: 6/29/2021 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2107076-004

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106256-001

Sample Location: 1st Draw 6705 13th PI NW

Customer Sample Number:

Date / Time Collected: 6/24/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2106256-001

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 6705 13th PI NW

Customer Sample Number:

Date / Time Collected: 6/24/2021 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2106256-002

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2106245-013

Sample Location: 1st Draw 715 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 6/18/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-013

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 715 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 6/18/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2106245-014

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107133-001

Sample Location: 1st Draw 1010 N Carolina Ave SE
Customer Sample Number:
Date / Time Collected: 7/14/2021 8:12 AM

Customer Program Code: DS
Laboratory Sample Number: 2107133-001
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1010 N Carolina Ave SE
Customer Sample Number:
Date / Time Collected: 7/14/2021 8:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2107133-002
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-013

Sample Location: 1st Draw 117 10TH ST NE

Customer Sample Number:

Date / Time Collected: 7/15/2021 8:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-013

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 117 10TH ST NE

Customer Sample Number:

Date / Time Collected: 7/15/2021 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-014

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107096-017

Sample Location: 1st Draw 1328 Quincy St NW

Customer Sample Number:

Date / Time Collected: 7/7/2021 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107096-017

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1328 Quincy St NW

Customer Sample Number:

Date / Time Collected: 7/7/2021 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107096-018

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107122-005

Sample Location: 1st Draw 1335 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 3:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2107122-005

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1335 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 3:32 PM

Customer Program Code: DS

Laboratory Sample Number: 2107122-006

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107122-007

Sample Location: 1st Draw 139 11th St NE

Customer Sample Number:

Date / Time Collected: 7/12/2021 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2107122-007

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 139 11th St NE

Customer Sample Number:

Date / Time Collected: 7/12/2021 6:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2107122-008

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107175-015

Sample Location: 1st Draw 1513 FOXHALL RD NW

Customer Sample Number:

Date / Time Collected: 7/20/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107175-015

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1513 FOXHALL RD NW

Customer Sample Number:

Date / Time Collected: 7/20/2021 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2107175-016

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107222-015

Sample Location: 1st Draw 1525 KEARNY ST NE

Customer Sample Number:

Date / Time Collected: 7/25/2021 7:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2107222-015

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1525 KEARNY ST NE

Customer Sample Number:

Date / Time Collected: 7/25/2021 7:26 PM

Customer Program Code: DS

Laboratory Sample Number: 2107222-016

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107222-001

Sample Location: 1st Draw 1655 NEWTON ST NW

Customer Sample Number:

Date / Time Collected: 7/22/2021 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-001

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1655 NEWTON ST NW

Customer Sample Number:

Date / Time Collected: 7/22/2021 6:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-002

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-023

Sample Location: 1st Draw 1752 Kilbourne Pl. NW

Customer Sample Number:

Date / Time Collected: 7/18/2021 6:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-023

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1752 Kilbourne Pl. NW

Customer Sample Number:

Date / Time Collected: 7/18/2021 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-024

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-001

Sample Location: 1st Draw 201 6TH STREET NE

Customer Sample Number:

Date / Time Collected: 7/5/2021 9:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-001

Date / Time Received: 7/22/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/4/2021	Sbrooks

Sample Location: 2nd Draw 201 6TH STREET NE

Customer Sample Number:

Date / Time Collected: 7/5/2021 9:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-002

Date / Time Received: 7/22/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-017

Sample Location: 1st Draw 212 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 7/16/2021 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-017

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 212 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 7/16/2021 10:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-018

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108016-011

Sample Location: 1st Draw 215 UNDERWOOD ST NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 5:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-011

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 215 UNDERWOOD ST NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-012

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108016-003

Sample Location: 1st Draw 2208 WYOMING AVE NW

Customer Sample Number:

Date / Time Collected: 7/16/2021 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-003

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 2208 WYOMING AVE NW

Customer Sample Number:

Date / Time Collected: 7/16/2021 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-004

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-011

Sample Location: 1st Draw 225 E Street SE

Customer Sample Number:

Date / Time Collected: 7/15/2021 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-011

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 225 E Street SE

Customer Sample Number:

Date / Time Collected: 7/15/2021 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-012

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108016-013

Sample Location: 1st Draw 232 10TH ST SE

Customer Sample Number:

Date / Time Collected: 7/28/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-013

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 232 10TH ST SE

Customer Sample Number:

Date / Time Collected: 7/28/2021 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-014

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-015

Sample Location: 1st Draw 2348 HUNTER PLACE SE

Customer Sample Number:

Date / Time Collected: 7/15/2021 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-015

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 2348 HUNTER PLACE SE

Customer Sample Number:

Date / Time Collected: 7/15/2021 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-016

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-009

Sample Location: 1st Draw 2901 RITTENHOUSE ST NW

Customer Sample Number:

Date / Time Collected: 7/15/2021 5:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-009

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 2901 RITTENHOUSE ST NW

Customer Sample Number:

Date / Time Collected: 7/15/2021 5:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-010

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107222-009

Sample Location: 1st Draw 301 C ST SE
Customer Sample Number:
Date / Time Collected: 7/25/2021 8:37 AM

Customer Program Code: DS
Laboratory Sample Number: 2107222-009
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 301 C ST SE
Customer Sample Number:
Date / Time Collected: 7/25/2021 8:41 AM

Customer Program Code: DS
Laboratory Sample Number: 2107222-010
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107222-003

Sample Location: 1st Draw 328 36TH ST NE

Customer Sample Number:

Date / Time Collected: 7/22/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-003

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 328 36TH ST NE

Customer Sample Number:

Date / Time Collected: 7/22/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-004

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107222-007

Sample Location: 1st Draw 3331 5TH ST SE

Customer Sample Number:

Date / Time Collected: 7/24/2021 8:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-007

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3331 5TH ST SE

Customer Sample Number:

Date / Time Collected: 7/24/2021 8:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-008

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107096-023

Sample Location: 1st Draw 3334 17TH ST NW

Customer Sample Number:

Date / Time Collected: 7/10/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2107096-023

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3334 17TH ST NW

Customer Sample Number:

Date / Time Collected: 7/10/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107096-024

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	SBrooks

Sample Location: 1st Draw 3334 17TH ST NW

Customer Sample Number:

Date / Time Collected: 7/25/2021 9:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-013

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 2nd Draw 3334 17TH ST NW

Customer Sample Number:

Date / Time Collected: 7/25/2021 9:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2107222-014

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107222-017

Sample Location: 1st Draw 3552 WINFIELD LN NW
Customer Sample Number:
Date / Time Collected: 7/26/2021 5:15 AM

Customer Program Code: DS
Laboratory Sample Number: 2107222-017
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3552 WINFIELD LN NW
Customer Sample Number:
Date / Time Collected: 7/26/2021 5:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2107222-018
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107096-021

Sample Location: 1st Draw 3606 35th St NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 9:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2107096-021

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3606 35th St NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 9:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2107096-022

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-027

Sample Location: 1st Draw 3949 GARRISON ST NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-027

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3949 GARRISON ST NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-028

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107096-019

Sample Location: 1st Draw 40 Q St NE
Customer Sample Number:
Date / Time Collected: 7/8/2021 7:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2107096-019
Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 40 Q St NE
Customer Sample Number:
Date / Time Collected: 7/8/2021 7:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2107096-020
Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107122-001

Sample Location: 1st Draw 4319 F St SE
Customer Sample Number:
Date / Time Collected: 7/12/2021 4:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2107122-001
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 4319 F St SE
Customer Sample Number:
Date / Time Collected: 7/12/2021 4:06 PM

Customer Program Code: DS
Laboratory Sample Number: 2107122-002
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107175-005

Sample Location: 1st Draw 4456 FARADAY PL NW
Customer Sample Number:
Date / Time Collected: 7/18/2021 7:45 PM

Customer Program Code: DS
Laboratory Sample Number: 2107175-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 4456 FARADAY PL NW
Customer Sample Number:
Date / Time Collected: 7/18/2021 7:46 PM

Customer Program Code: DS
Laboratory Sample Number: 2107175-006
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107096-015

Sample Location: 1st Draw 4615 43rd St NW

Customer Sample Number:

Date / Time Collected: 7/10/2021 4:20 PM

Customer Program Code: DS

Laboratory Sample Number: 2107096-015

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 4615 43rd St NW

Customer Sample Number:

Date / Time Collected: 7/10/2021 4:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2107096-016

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-021

Sample Location: 1st Draw 516 E ST SE
Customer Sample Number:
Date / Time Collected: 7/18/2021 6:20 AM

Customer Program Code: DS
Laboratory Sample Number: 2107161-021
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 516 E ST SE
Customer Sample Number:
Date / Time Collected: 7/18/2021 6:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2107161-022
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107175-025

Sample Location: 1st Draw 5420 27TH ST NW

Customer Sample Number:

Date / Time Collected: 7/21/2021 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107175-025

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 5420 27TH ST NW

Customer Sample Number:

Date / Time Collected: 7/21/2021 8:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2107175-026

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-003

Sample Location: 1st Draw 5439 31ST STREET NW

Customer Sample Number:

Date / Time Collected: 7/7/2021 9:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-003

Date / Time Received: 7/22/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/4/2021	Sbrooks

Sample Location: 2nd Draw 5439 31ST STREET NW

Customer Sample Number:

Date / Time Collected: 7/7/2021 9:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-004

Date / Time Received: 7/22/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107122-003

Sample Location: 1st Draw 5728 Eastern Ave NE

Customer Sample Number:

Date / Time Collected: 7/11/2021 11:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2107122-003

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 5728 Eastern Ave NE

Customer Sample Number:

Date / Time Collected: 7/11/2021 11:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2107122-004

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108016-001

Sample Location: 1st Draw 6209 WESTERN AVE NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-001

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 6209 WESTERN AVE NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2108016-002

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107175-021

Sample Location: 1st Draw 638 L ST NE
Customer Sample Number:
Date / Time Collected: 7/20/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2107175-021
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 638 L ST NE
Customer Sample Number:
Date / Time Collected: 7/20/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2107175-022
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107161-007

Sample Location: 1st Draw 700 EAST CAPITOL ST NE

Customer Sample Number:

Date / Time Collected: 7/14/2021 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-007

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 700 EAST CAPITOL ST NE

Customer Sample Number:

Date / Time Collected: 7/14/2021 6:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2107161-008

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107122-009

Sample Location: 1st Draw 7333 8th St NW
Customer Sample Number:
Date / Time Collected: 7/11/2021 4:23 PM

Customer Program Code: DS
Laboratory Sample Number: 2107122-009
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 7333 8th St NW
Customer Sample Number:
Date / Time Collected: 7/11/2021 4:25 PM

Customer Program Code: DS
Laboratory Sample Number: 2107122-010
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108115-019

Sample Location: 1st Draw 1014 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 8/5/2021 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-019

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1014 Spring Rd NW

Customer Sample Number:

Date / Time Collected: 8/5/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-020

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108167-003

Sample Location: 1st Draw 132 U St. NW
Customer Sample Number:
Date / Time Collected: 8/7/2021 6:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2108167-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 132 U St. NW
Customer Sample Number:
Date / Time Collected: 8/7/2021 6:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2108167-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108190-001

Sample Location: 1st Draw 1410 Juniper St NW

Customer Sample Number:

Date / Time Collected: 8/16/2021 6:14 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-001

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1410 Juniper St NW

Customer Sample Number:

Date / Time Collected: 8/16/2021 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-002

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108095-003

Sample Location: 1st Draw 1427 Parkwood PI NW

Customer Sample Number:

Date / Time Collected: 7/29/2021 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-003

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1427 Parkwood PI NW

Customer Sample Number:

Date / Time Collected: 7/29/2021 9:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-004

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108212-007

Sample Location: 1st Draw 1439 Pennsylvania Ave. SE

Customer Sample Number:

Date / Time Collected: 8/17/2021 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2108212-007

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1439 Pennsylvania Ave. SE

Customer Sample Number:

Date / Time Collected: 8/17/2021 8:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2108212-008

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108167-001

Sample Location: 1st Draw 1569 41st St. SE

Customer Sample Number:

Date / Time Collected: 7/18/2021 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-001

Date / Time Received: 8/16/2021 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/19/2021	Rhoffa

Sample Location: 2nd Draw 1569 41st St. SE

Customer Sample Number:

Date / Time Collected: 7/18/2021 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-002

Date / Time Received: 8/16/2021 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108190-007

Sample Location: 1st Draw 1626 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 8/15/2021 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-007

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1626 Argonne PI NW

Customer Sample Number:

Date / Time Collected: 8/15/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-008

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108095-009

Sample Location: 1st Draw 220 8TH ST SE

Customer Sample Number:

Date / Time Collected: 7/30/2021 6:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2108095-009

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 220 8TH ST SE

Customer Sample Number:

Date / Time Collected: 7/30/2021 6:17 PM

Customer Program Code: DS

Laboratory Sample Number: 2108095-010

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108115-009

Sample Location: 1st Draw 220 F St. NE
Customer Sample Number:
Date / Time Collected: 8/1/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2108115-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 220 F St. NE
Customer Sample Number:
Date / Time Collected: 8/1/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2108115-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108095-001

Sample Location: 1st Draw 244 Walnut St NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-001

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 244 Walnut St NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-002

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108095-007

Sample Location: 1st Draw 2537 Queen Annes Ln NW

Customer Sample Number:

Date / Time Collected: 7/30/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-007

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 2537 Queen Annes Ln NW

Customer Sample Number:

Date / Time Collected: 7/30/2021 9:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-008

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108115-015

Sample Location: 1st Draw 2950 NORTHAMPTON ST NW

Customer Sample Number:

Date / Time Collected: 8/4/2021 7:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-015

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 2950 NORTHAMPTON ST NW

Customer Sample Number:

Date / Time Collected: 8/4/2021 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-016

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108115-001

Sample Location: 1st Draw 3053 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 7/18/2021 12:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2108115-001

Date / Time Received: 8/10/2021 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/25/2021	Rhoffa

Sample Location: 2nd Draw 3053 Ordway St. NW

Customer Sample Number:

Date / Time Collected: 7/18/2021 12:29 PM

Customer Program Code: DS

Laboratory Sample Number: 2108115-002

Date / Time Received: 8/10/2021 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108167-007

Sample Location: 1st Draw 3140 17th St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2021 5:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-007

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 3140 17th St. NW

Customer Sample Number:

Date / Time Collected: 8/8/2021 5:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-008

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108095-011

Sample Location: 1st Draw 3151 Monroe St NE

Customer Sample Number:

Date / Time Collected: 7/30/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-011

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 3151 Monroe St NE

Customer Sample Number:

Date / Time Collected: 7/30/2021 9:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-012

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108095-005

Sample Location: 1st Draw 3310 19th St NW

Customer Sample Number:

Date / Time Collected: 7/25/2021 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-005

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 3310 19th St NW

Customer Sample Number:

Date / Time Collected: 7/25/2021 8:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2108095-006

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108212-003

Sample Location: 1st Draw 4115 10th St. NE

Customer Sample Number:

Date / Time Collected: 8/15/2021 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2108212-003

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 4115 10th St. NE

Customer Sample Number:

Date / Time Collected: 8/15/2021 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2108212-004

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108167-013

Sample Location: 1st Draw 4247 Colorado Ave. NW
Customer Sample Number:
Date / Time Collected: 8/9/2021 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2108167-013
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 4247 Colorado Ave. NW
Customer Sample Number:
Date / Time Collected: 8/9/2021 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2108167-014
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108167-009

Sample Location: 1st Draw 4324 46th St NW

Customer Sample Number:

Date / Time Collected: 8/8/2021 6:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-009

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 4324 46th St NW

Customer Sample Number:

Date / Time Collected: 8/8/2021 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-010

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108115-013

Sample Location: 1st Draw 4819 41st St NW

Customer Sample Number:

Date / Time Collected: 8/3/2021 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-013

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 4819 41st St NW

Customer Sample Number:

Date / Time Collected: 8/3/2021 4:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-014

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108190-005

Sample Location: 1st Draw 4921 30th PI NW

Customer Sample Number:

Date / Time Collected: 8/17/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-005

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 4921 30th PI NW

Customer Sample Number:

Date / Time Collected: 8/17/2021 7:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-006

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108115-021

Sample Location: 1st Draw 5012 V St. NW

Customer Sample Number:

Date / Time Collected: 8/6/2021 8:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-021

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 5012 V St. NW

Customer Sample Number:

Date / Time Collected: 8/6/2021 8:58 AM

Customer Program Code: DS

Laboratory Sample Number: 2108115-022

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108212-005

Sample Location: 1st Draw 512 Edgewood St. NE

Customer Sample Number:

Date / Time Collected: 8/16/2021 7:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2108212-005

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 512 Edgewood St. NE

Customer Sample Number:

Date / Time Collected: 8/16/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2108212-006

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108190-003

Sample Location: 1st Draw 518 G St SE
Customer Sample Number:
Date / Time Collected: 8/15/2021 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2108190-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 518 G St SE
Customer Sample Number:
Date / Time Collected: 8/15/2021 5:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2108190-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108190-011

Sample Location: 1st Draw 518 Taylor St NW

Customer Sample Number:

Date / Time Collected: 8/16/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-011

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 518 Taylor St NW

Customer Sample Number:

Date / Time Collected: 8/16/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-012

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108190-009

Sample Location: 1st Draw 5318 Manning PI NW

Customer Sample Number:

Date / Time Collected: 8/12/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-009

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 5318 Manning PI NW

Customer Sample Number:

Date / Time Collected: 8/12/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2108190-010

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108167-015

Sample Location: 1st Draw 5911 2nd PL NW

Customer Sample Number:

Date / Time Collected: 8/9/2021 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-015

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 5911 2nd PL NW

Customer Sample Number:

Date / Time Collected: 8/9/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2108167-016

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108212-001

Sample Location: 1st Draw 7401 Blair Rd NW

Customer Sample Number:

Date / Time Collected: 8/13/2021 1:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2108212-001

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 7401 Blair Rd NW

Customer Sample Number:

Date / Time Collected: 8/13/2021 1:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2108212-002

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.8	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-011

Sample Location: 1st Draw 1125 PARK ST NE

Customer Sample Number:

Date / Time Collected: 8/27/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-011

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1125 PARK ST NE

Customer Sample Number:

Date / Time Collected: 8/27/2021 6:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-012

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-001

Sample Location: 1st Draw 1209 Kennedy St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2021 8:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-001

Date / Time Received: 9/3/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/9/2021	RHoffa

Sample Location: 2nd Draw 1209 Kennedy St. NW

Customer Sample Number:

Date / Time Collected: 8/15/2021 8:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-002

Date / Time Received: 9/3/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-019

Sample Location: 1st Draw 1232 U ST SE
Customer Sample Number:
Date / Time Collected: 8/29/2021 2:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2109013-019
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1232 U ST SE
Customer Sample Number:
Date / Time Collected: 8/29/2021 2:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2109013-020
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2107175-001

Sample Location: 1st Draw 1608 V ST. SE
Customer Sample Number:
Date / Time Collected: 7/13/2021 8:09 PM

Customer Program Code: DS
Laboratory Sample Number: 2107175-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/2/2021	RHoffa

Sample Location: 2nd Draw 1608 V ST. SE
Customer Sample Number:
Date / Time Collected: 7/13/2021 8:11 PM

Customer Program Code: DS
Laboratory Sample Number: 2107175-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108237-005

Sample Location: 1st Draw 1651 Primrose Rd NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 1:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2108237-005

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1651 Primrose Rd NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 1:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2108237-006

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108237-009

Sample Location: 1st Draw 1707 Upshur St NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108237-009

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1707 Upshur St NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2108237-010

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/23/2021

Report revised on 9/23/21 by MC.
Lab Sample Numbers 2109013-013 &
2109013-014, the sample location was changed
from 2032 PIERCE NULL RD NW to 2032 PIERCE
MILL RD NW as recorded on the chain of custody.

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-013

Sample Location: 1st Draw 2032 PIERCE MILL RD NW

Customer Sample Number:

Date / Time Collected: 8/28/2021 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-013

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2032 PIERCE MILL RD NW

Customer Sample Number:

Date / Time Collected: 8/28/2021 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-014

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-017

Sample Location: 1st Draw 2046 34TH ST SE

Customer Sample Number:

Date / Time Collected: 8/23/2021 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-017

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2046 34TH ST SE

Customer Sample Number:

Date / Time Collected: 8/23/2021 8:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-018

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108237-007

Sample Location: 1st Draw 218 Q St NW
Customer Sample Number:
Date / Time Collected: 8/19/2021 6:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2108237-007
Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 218 Q St NW
Customer Sample Number:
Date / Time Collected: 8/19/2021 6:58 AM

Customer Program Code: DS
Laboratory Sample Number: 2108237-008
Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108225-001

Sample Location: 1st Draw 2211 T PI SE
Customer Sample Number:
Date / Time Collected: 8/18/2021 10:43 AM

Customer Program Code: DS
Laboratory Sample Number: 2108225-001
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2211 T PI SE
Customer Sample Number:
Date / Time Collected: 8/18/2021 10:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2108225-002
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108237-003

Sample Location: 1st Draw 2233 39th PI NW

Customer Sample Number:

Date / Time Collected: 8/18/2021 7:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2108237-003

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2233 39th PI NW

Customer Sample Number:

Date / Time Collected: 8/18/2021 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2108237-004

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-001

Sample Location: 1st Draw 2409 HILLSDALE PL SE

Customer Sample Number:

Date / Time Collected: 7/19/2021 7:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-001

Date / Time Received: 9/2/2021 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	9/9/2021	RHoffa

Sample Location: 2nd Draw 2409 HILLSDALE PL SE

Customer Sample Number:

Date / Time Collected: 7/19/2021 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-002

Date / Time Received: 9/2/2021 8:50:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-013

Sample Location: 1st Draw 2425 TUNLAW RD NW

Customer Sample Number:

Date / Time Collected: 8/23/2021 1:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-013

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2425 TUNLAW RD NW

Customer Sample Number:

Date / Time Collected: 8/23/2021 1:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-014

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-003

Sample Location: 1st Draw 248 VAN BUREN ST NW

Customer Sample Number:

Date / Time Collected: 8/25/2021 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-003

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 248 VAN BUREN ST NW

Customer Sample Number:

Date / Time Collected: 8/25/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-004

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-011

Sample Location: 1st Draw 2726 P STREET NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-011

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2726 P STREET NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 10:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-012

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-005

Sample Location: 1st Draw 3326 19TH STREET NW

Customer Sample Number:

Date / Time Collected: 8/27/2021 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-005

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3326 19TH STREET NW

Customer Sample Number:

Date / Time Collected: 8/27/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-006

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-009

Sample Location: 1st Draw 3404 Rodman St NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 10:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-009

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3404 Rodman St NW

Customer Sample Number:

Date / Time Collected: 8/22/2021 10:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-010

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-015

Sample Location: 1st Draw 3406 WARDER ST NW

Customer Sample Number:

Date / Time Collected: 8/23/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-015

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3406 WARDER ST NW

Customer Sample Number:

Date / Time Collected: 8/23/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-016

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-017

Sample Location: 1st Draw 3540 TEXAS AVE SE

Customer Sample Number:

Date / Time Collected: 8/29/2021 5:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2109013-017

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3540 TEXAS AVE SE

Customer Sample Number:

Date / Time Collected: 8/29/2021 5:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2109013-018

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-019

Sample Location: 1st Draw 3723 14TH ST NE

Customer Sample Number:

Date / Time Collected: 8/24/2021 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-019

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3723 14TH ST NE

Customer Sample Number:

Date / Time Collected: 8/24/2021 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-020

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-015

Sample Location: 1st Draw 3919 AMES ST NE

Customer Sample Number:

Date / Time Collected: 8/29/2021 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-015

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3919 AMES ST NE

Customer Sample Number:

Date / Time Collected: 8/29/2021 10:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-016

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-003

Sample Location: 1st Draw 404 CONSTITUTION AVE NE

Customer Sample Number:

Date / Time Collected: 8/17/2021 9:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-003

Date / Time Received: 9/3/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	9/9/2021	RHoffa

Sample Location: 2nd Draw 404 CONSTITUTION AVE NE

Customer Sample Number:

Date / Time Collected: 8/17/2021 9:49 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-004

Date / Time Received: 9/3/2021 8:30:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L	H	9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-021

Sample Location: 1st Draw 4406 VOLTA PL NW

Customer Sample Number:

Date / Time Collected: 8/26/2021 9:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-021

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 4406 VOLTA PL NW

Customer Sample Number:

Date / Time Collected: 8/26/2021 9:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-022

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109013-009

Sample Location: 1st Draw 4615 47TH STREET

Customer Sample Number:

Date / Time Collected: 8/27/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-009

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 4615 47TH STREET

Customer Sample Number:

Date / Time Collected: 8/27/2021 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2109013-010

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2108237-011

Sample Location: 1st Draw 514 Buchanan St NW

Customer Sample Number:

Date / Time Collected: 8/21/2021 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2108237-011

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 514 Buchanan St NW

Customer Sample Number:

Date / Time Collected: 8/21/2021 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2108237-012

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-005

Sample Location: 1st Draw 5704 COLORADO AVE NW
Customer Sample Number:
Date / Time Collected: 8/20/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2109025-005
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 5704 COLORADO AVE NW
Customer Sample Number:
Date / Time Collected: 8/20/2021 8:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2109025-006
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-007

Sample Location: 1st Draw 6110 Broad Branch Rd

Customer Sample Number:

Date / Time Collected: 8/22/2021 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-007

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 6110 Broad Branch Rd

Customer Sample Number:

Date / Time Collected: 8/22/2021 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-008

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-027

Sample Location: 1st Draw 723 NICHOLSON ST NW

Customer Sample Number:

Date / Time Collected: 8/29/2021 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2109025-027

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 723 NICHOLSON ST NW

Customer Sample Number:

Date / Time Collected: 8/29/2021 4:01 PM

Customer Program Code: DS

Laboratory Sample Number: 2109025-028

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109025-025

Sample Location: 1st Draw 800 Quintana PI NW

Customer Sample Number:

Date / Time Collected: 8/28/2021 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-025

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 800 Quintana PI NW

Customer Sample Number:

Date / Time Collected: 8/28/2021 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2109025-026

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109235-009

Sample Location: 1st Draw 112 15th St SE, Apt B

Customer Sample Number:

Date / Time Collected: 9/19/2021 11:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-009

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 112 15th St SE, Apt B

Customer Sample Number:

Date / Time Collected: 9/19/2021 11:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-010

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-007

Sample Location: 1st Draw 1411 Crittenden St NW

Customer Sample Number:

Date / Time Collected: 9/13/2021 9:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-007

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1411 Crittenden St NW

Customer Sample Number:

Date / Time Collected: 9/13/2021 9:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-008

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109063-005

Sample Location: 1st Draw 1431 MERIDIAN PL NW
Customer Sample Number:
Date / Time Collected: 9/2/2021 6:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2109063-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1431 MERIDIAN PL NW
Customer Sample Number:
Date / Time Collected: 9/2/2021 6:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2109063-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109235-015

Sample Location: 1st Draw 1509 Van Buren St. NW

Customer Sample Number:

Date / Time Collected: 9/20/2021 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-015

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1509 Van Buren St. NW

Customer Sample Number:

Date / Time Collected: 9/20/2021 8:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-016

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-005

Sample Location: 1st Draw 1602 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/11/2021 9:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-005

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1602 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/11/2021 9:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-006

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-011

Sample Location: 1st Draw 1606 Belmont St NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/15/2021 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-011

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1606 Belmont St NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/15/2021 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-012

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-031

Sample Location: 1st Draw 1608 Belmont Rd NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/14/2021 5:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2109229-031

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1608 Belmont Rd NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/14/2021 5:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2109229-032

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-017

Sample Location: 1st Draw 1608 Belmont St NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/16/2021 8:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-017

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1608 Belmont St NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/16/2021 8:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-018

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-001

Sample Location: 1st Draw 1610 Belmont St NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/11/2021 11:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2109197-001

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1610 Belmont St NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/11/2021 11:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2109197-002

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-027

Sample Location: 1st Draw 1616 Beekman PI NW, Unit B
Customer Sample Number:
Date / Time Collected: 9/14/2021 8:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2109229-027
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1616 Beekman PI NW, Unit B
Customer Sample Number:
Date / Time Collected: 9/14/2021 8:55 AM

Customer Program Code: DS
Laboratory Sample Number: 2109229-028
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-029

Sample Location: 1st Draw 1616 Belmont St NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/14/2021 11:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-029

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1616 Belmont St NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/14/2021 11:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-030

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-019

Sample Location: 1st Draw 1620 Belmont St NW, Apt B
Customer Sample Number:
Date / Time Collected: 9/13/2021 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2109229-019
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1620 Belmont St NW, Apt B
Customer Sample Number:
Date / Time Collected: 9/13/2021 7:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2109229-020
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-015

Sample Location: 1st Draw 1622 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-015

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1622 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-016

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-013

Sample Location: 1st Draw 1622 Belmont St NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/14/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-013

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1622 Belmont St NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/14/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-014

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-023

Sample Location: 1st Draw 1622 Belmont St NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2109229-023

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1622 Belmont St NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2109229-024

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109093-007

Sample Location: 1st Draw 1625 Newton St NW

Customer Sample Number:

Date / Time Collected: 9/5/2021 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2109093-007

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1625 Newton St NW

Customer Sample Number:

Date / Time Collected: 9/5/2021 6:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2109093-008

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-003

Sample Location: 1st Draw 1626 Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/11/2021 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-003

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1626 Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/11/2021 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-004

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-041

Sample Location: 1st Draw 1628 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/16/2021 6:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-041

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1628 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/16/2021 6:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-042

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-009

Sample Location: 1st Draw 1634 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/14/2021 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-009

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1634 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/14/2021 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-010

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-007

Sample Location: 1st Draw 1644 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/12/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-007

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1644 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/12/2021 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-008

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-021

Sample Location: 1st Draw 1646 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/13/2021 8:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-021

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1646 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/13/2021 8:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-022

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-037

Sample Location: 1st Draw 1646 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/15/2021 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-037

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1646 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/15/2021 7:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-038

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-013

Sample Location: 1st Draw 1654 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/15/2021 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-013

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1654 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/15/2021 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-014

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-015

Sample Location: 1st Draw 1660 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/14/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-015

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1660 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/14/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-016

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-011

Sample Location: 1st Draw 1666 Beekman PI NW, Unit E

Customer Sample Number:

Date / Time Collected: 9/14/2021 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-011

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1666 Beekman PI NW, Unit E

Customer Sample Number:

Date / Time Collected: 9/14/2021 6:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-012

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-039

Sample Location: 1st Draw 1674 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/15/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-039

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1674 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/15/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-040

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-025

Sample Location: 1st Draw 1733 Massachusetts Ave SE

Customer Sample Number:

Date / Time Collected: 9/14/2021 6:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-025

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1733 Massachusetts Ave SE

Customer Sample Number:

Date / Time Collected: 9/14/2021 6:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-026

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-021

Sample Location: 1st Draw 1912 37th St NW

Customer Sample Number:

Date / Time Collected: 9/16/2021 8:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-021

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1912 37th St NW

Customer Sample Number:

Date / Time Collected: 9/16/2021 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2109213-022

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-009

Sample Location: 1st Draw 314 14th PI NE
Customer Sample Number:
Date / Time Collected: 9/13/2021 9:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2109213-009
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 314 14th PI NE
Customer Sample Number:
Date / Time Collected: 9/13/2021 9:00 PM

Customer Program Code: DS
Laboratory Sample Number: 2109213-010
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109235-001

Sample Location: 1st Draw 3206 19th St NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-001

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 3206 19th St NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-002

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109093-001

Sample Location: 1st Draw 3501 NEWARK ST NW

Customer Sample Number:

Date / Time Collected: 9/3/2021 6:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2109093-001

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 3501 NEWARK ST NW

Customer Sample Number:

Date / Time Collected: 9/3/2021 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2109093-002

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109121-007

Sample Location: 1st Draw 3563 Appleton St. NW

Customer Sample Number:

Date / Time Collected: 9/6/2021 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-007

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 3563 Appleton St. NW

Customer Sample Number:

Date / Time Collected: 9/6/2021 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-008

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109063-001

Sample Location: 1st Draw 3636 BRANDYWINE ST NW

Customer Sample Number:

Date / Time Collected: 8/29/2021 9:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2109063-001

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 3636 BRANDYWINE ST NW

Customer Sample Number:

Date / Time Collected: 8/29/2021 9:39 AM

Customer Program Code: DS

Laboratory Sample Number: 2109063-002

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109121-003

Sample Location: 1st Draw 404 49th St. NE

Customer Sample Number:

Date / Time Collected: 9/4/2021 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-003

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 404 49th St. NE

Customer Sample Number:

Date / Time Collected: 9/4/2021 6:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-004

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109152-001

Sample Location: 1st Draw 42 Bates St NW

Customer Sample Number:

Date / Time Collected: 9/8/2021 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2109152-001

Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 42 Bates St NW

Customer Sample Number:

Date / Time Collected: 9/8/2021 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2109152-002

Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-009

Sample Location: 1st Draw 4241 Fort Dupont Ter SE

Customer Sample Number:

Date / Time Collected: 9/13/2021 5:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-009

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 4241 Fort Dupont Ter SE

Customer Sample Number:

Date / Time Collected: 9/13/2021 5:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-010

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-001

Sample Location: 1st Draw 4326 Chesapeake St NW

Customer Sample Number:

Date / Time Collected: 9/9/2021 5:27 PM

Customer Program Code: DS

Laboratory Sample Number: 2109229-001

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 4326 Chesapeake St NW

Customer Sample Number:

Date / Time Collected: 9/9/2021 5:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2109229-002

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109152-003

Sample Location: 1st Draw 4339 Alton PL NW

Customer Sample Number:

Date / Time Collected: 9/10/2021 7:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2109152-003

Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 4339 Alton PL NW

Customer Sample Number:

Date / Time Collected: 9/10/2021 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2109152-004

Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109235-013

Sample Location: 1st Draw 4343 Davenport St NW

Customer Sample Number:

Date / Time Collected: 9/20/2021 6:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-013

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109121-001

Sample Location: 1st Draw 4415 38TH ST NW

Customer Sample Number:

Date / Time Collected: 8/30/2021 8:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-001

Date / Time Received: 9/14/2021 8:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/24/2021	SBrooks

Sample Location: 2nd Draw 4415 38TH ST NW

Customer Sample Number:

Date / Time Collected: 8/30/2021 8:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-002

Date / Time Received: 9/14/2021 8:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109121-011

Sample Location: 1st Draw 4521 Clay St. NE

Customer Sample Number:

Date / Time Collected: 9/6/2021 1:30 PM

Customer Program Code: DS

Laboratory Sample Number: 2109121-011

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 4521 Clay St. NE

Customer Sample Number:

Date / Time Collected: 9/6/2021 1:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2109121-012

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109121-015

Sample Location: 1st Draw 4713 6th St. NE

Customer Sample Number:

Date / Time Collected: 9/7/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-015

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 4713 6th St. NE

Customer Sample Number:

Date / Time Collected: 9/7/2021 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-016

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109229-035

Sample Location: 1st Draw 501 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 9/15/2021 6:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-035

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 501 Kentucky Ave SE

Customer Sample Number:

Date / Time Collected: 9/15/2021 6:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2109229-036

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109235-017

Sample Location: 1st Draw 5100 Fulton St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-017

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 5100 Fulton St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2109235-018

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109213-023

Sample Location: 1st Draw 522 G St SE
Customer Sample Number:
Date / Time Collected: 9/18/2021 2:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2109213-023
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 522 G St SE
Customer Sample Number:
Date / Time Collected: 9/18/2021 2:30 PM

Customer Program Code: DS
Laboratory Sample Number: 2109213-024
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109063-003

Sample Location: 1st Draw 6207 BROAD BRANCH RD NW

Customer Sample Number:

Date / Time Collected: 8/31/2021 8:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2109063-003

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 6207 BROAD BRANCH RD NW

Customer Sample Number:

Date / Time Collected: 8/31/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109063-004

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109121-021

Sample Location: 1st Draw 641 Morton St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-021

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 641 Morton St. NW

Customer Sample Number:

Date / Time Collected: 9/9/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2109121-022

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-005

Sample Location: 1st Draw 813 Ingraham St NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-005

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 813 Ingraham St NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-006

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109093-003

Sample Location: 1st Draw 920 QUINCY ST NW

Customer Sample Number:

Date / Time Collected: 9/3/2021 7:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2109093-003

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 920 QUINCY ST NW

Customer Sample Number:

Date / Time Collected: 9/3/2021 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2109093-004

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-029

Sample Location: 1st Draw 1119 Montello Ave NE

Customer Sample Number:

Date / Time Collected: 9/28/2021 4:05 PM

Customer Program Code: DS

Laboratory Sample Number: 2110044-029

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1119 Montello Ave NE

Customer Sample Number:

Date / Time Collected: 9/28/2021 4:10 PM

Customer Program Code: DS

Laboratory Sample Number: 2110044-030

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110108-001

Sample Location: 1st Draw 1342 S. CAROLINA AVE SE

Customer Sample Number:

Date / Time Collected: 9/13/2021 2:45 PM

Customer Program Code: DS

Laboratory Sample Number: 2110108-001

Date / Time Received: 10/14/2021 8:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks

Sample Location: 2nd Draw 1342 S. CAROLINA AVE SE

Customer Sample Number:

Date / Time Collected: 9/13/2021 2:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2110108-002

Date / Time Received: 10/14/2021 8:25:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report revised on 10/28/21 by mc.
Lab Sample Numbers 2110044-017 & 2110044-018, the address
was changed from 1576 Hamilton St. NW to 1516 Hamilton St. NW
as recorded on the chain-of-custody form.

Report Number: L-DC-DS-2110044-017

Sample Location: 1st Draw 1516 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2021 6:49 PM

Customer Program Code: DS

Laboratory Sample Number: 2110044-017

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1516 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 9/26/2021 6:52 PM

Customer Program Code: DS

Laboratory Sample Number: 2110044-018

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110057-005

Sample Location: 1st Draw 165 Todd Place NE

Customer Sample Number:

Date / Time Collected: 10/2/2021 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2110057-005

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 165 Todd Place NE

Customer Sample Number:

Date / Time Collected: 10/2/2021 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2110057-006

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110057-003

Sample Location: 1st Draw 1704 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 10/1/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2110057-003

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1704 Constitution Ave NE

Customer Sample Number:

Date / Time Collected: 10/1/2021 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2110057-004

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-021

Sample Location: 1st Draw 1814 N. Capitol St. NW, Unit 204

Customer Sample Number:

Date / Time Collected: 9/28/2021 5:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-021

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1814 N. Capitol St. NW, Unit 204

Customer Sample Number:

Date / Time Collected: 9/28/2021 5:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-022

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110108-003

Sample Location: 1st Draw 1854 INGLESIDE TERRACE NW

Customer Sample Number:

Date / Time Collected: 10/1/2021 7:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2110108-003

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1854 INGLESIDE TERRACE NW

Customer Sample Number:

Date / Time Collected: 10/1/2021 7:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2110108-004

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-023

Sample Location: 1st Draw 1918 Park Rd NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-023

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1918 Park Rd NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-024

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-011

Sample Location: 1st Draw 2821 Rittenhouse St NW

Customer Sample Number:

Date / Time Collected: 9/22/2021 6:03 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-011

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 2821 Rittenhouse St NW

Customer Sample Number:

Date / Time Collected: 9/22/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-012

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-033

Sample Location: 1st Draw 32 Underwood St. NW

Customer Sample Number:

Date / Time Collected: 9/30/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-033

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 32 Underwood St. NW

Customer Sample Number:

Date / Time Collected: 9/30/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-034

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-003

Sample Location: 1st Draw 3426 9th St NE

Customer Sample Number:

Date / Time Collected: 9/3/2021 10:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-003

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks

Sample Location: 2nd Draw 3426 9th St NE

Customer Sample Number:

Date / Time Collected: 9/3/2021 10:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-004

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-001

Sample Location: 1st Draw 3732 JOCELYN ST NW

Customer Sample Number:

Date / Time Collected: 8/24/2021 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2110044-001

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L	H	10/20/2021	Sbrooks

Sample Location: 2nd Draw 3732 JOCELYN ST NW

Customer Sample Number:

Date / Time Collected: 8/24/2021 4:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2110044-002

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110057-007

Sample Location: 1st Draw 3916 Benton St NW

Customer Sample Number:

Date / Time Collected: 10/2/2021 8:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2110057-007

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 3916 Benton St NW

Customer Sample Number:

Date / Time Collected: 10/2/2021 8:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2110057-008

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-009

Sample Location: 1st Draw 4519 5th St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-009

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 4519 5th St. NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-010

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110108-005

Sample Location: 1st Draw 4950 CHESAPEAKE ST NW

Customer Sample Number:

Date / Time Collected: 10/5/2021 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2110108-005

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 4950 CHESAPEAKE ST NW

Customer Sample Number:

Date / Time Collected: 10/5/2021 6:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2110108-006

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-005

Sample Location: 1st Draw 4955 11th St NE

Customer Sample Number:

Date / Time Collected: 9/10/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-005

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks

Sample Location: 2nd Draw 4955 11th St NE

Customer Sample Number:

Date / Time Collected: 9/10/2021 9:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-006

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110057-001

Sample Location: 1st Draw 5180 Fulton St NW

Customer Sample Number:

Date / Time Collected: 10/1/2021 7:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2110057-001

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 5180 Fulton St NW

Customer Sample Number:

Date / Time Collected: 10/1/2021 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2110057-002

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-025

Sample Location: 1st Draw 545 Brummel Ct. NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-025

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 545 Brummel Ct. NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-026

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-027

Sample Location: 1st Draw 621 A St SE
Customer Sample Number:
Date / Time Collected: 9/28/2021 7:05 AM

Customer Program Code: DS
Laboratory Sample Number: 2110044-027
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 621 A St SE
Customer Sample Number:
Date / Time Collected: 9/28/2021 7:09 AM

Customer Program Code: DS
Laboratory Sample Number: 2110044-028
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110044-007

Sample Location: 1st Draw 639 5th St. NE

Customer Sample Number:

Date / Time Collected: 9/10/2021 6:25 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-007

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks

Sample Location: 2nd Draw 639 5th St. NE

Customer Sample Number:

Date / Time Collected: 9/10/2021 6:27 AM

Customer Program Code: DS

Laboratory Sample Number: 2110044-008

Date / Time Received: 10/5/2021 11:45:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/10/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2109197-015

Sample Location: 1st Draw 1618 Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/15/2021 7:56 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-015

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/2/2021	SBrooks

Sample Location: 2nd Draw 1618 Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/15/2021 7:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2109197-016

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-003

Sample Location: 1st Draw 1210 Staples St. NE

Customer Sample Number:

Date / Time Collected: 10/10/2021 8:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-003

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1210 Staples St. NE

Customer Sample Number:

Date / Time Collected: 10/10/2021 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-004

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-001

Sample Location: 1st Draw 129 Duddington PL SE

Customer Sample Number:

Date / Time Collected: 10/10/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-001

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 129 Duddington PL SE

Customer Sample Number:

Date / Time Collected: 10/10/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-002

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110254-025

Sample Location: 1st Draw 1313 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 10/21/2021 7:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2110254-025

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1313 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 10/21/2021 7:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2110254-026

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-015

Sample Location: 1st Draw 1316 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 8:53 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-015

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1316 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 8:55 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-016

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110161-005

Sample Location: 1st Draw 1639 Harvard St NW

Customer Sample Number:

Date / Time Collected: 10/15/2021 6:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-005

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1639 Harvard St NW

Customer Sample Number:

Date / Time Collected: 10/15/2021 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-006

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-021

Sample Location: 1st Draw 1768 Hobart St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 6:47 PM

Customer Program Code: DS

Laboratory Sample Number: 2110197-021

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1768 Hobart St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 6:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2110197-022

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110175-001

Sample Location: 1st Draw 1858 PARK RD NW

Customer Sample Number:

Date / Time Collected: 10/15/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110175-001

Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1858 PARK RD NW

Customer Sample Number:

Date / Time Collected: 10/15/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2110175-002

Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110205-005

Sample Location: 1st Draw 1866 Alabama Ave SE

Customer Sample Number:

Date / Time Collected: 10/17/2021 6:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2110205-005

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1866 Alabama Ave SE

Customer Sample Number:

Date / Time Collected: 10/17/2021 6:58 PM

Customer Program Code: DS

Laboratory Sample Number: 2110205-006

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110267-003

Sample Location: 1st Draw 2004 15th St NW

Customer Sample Number:

Date / Time Collected: 10/23/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110267-003

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2004 15th St NW

Customer Sample Number:

Date / Time Collected: 10/23/2021 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2110267-004

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110161-007

Sample Location: 1st Draw 2234 HALL PLACE NW

Customer Sample Number:

Date / Time Collected: 10/14/2021 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-007

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2234 HALL PLACE NW

Customer Sample Number:

Date / Time Collected: 10/14/2021 7:43 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-008

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-027

Sample Location: 1st Draw 3009 S. Dakota Ave NE

Customer Sample Number:

Date / Time Collected: 10/13/2021 5:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-027

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3009 S. Dakota Ave NE

Customer Sample Number:

Date / Time Collected: 10/13/2021 5:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-028

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110205-011

Sample Location: 1st Draw 3148 19th St NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110205-011

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3148 19th St NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2110205-012

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-023

Sample Location: 1st Draw 326 14TH ST NE

Customer Sample Number:

Date / Time Collected: 10/12/2021 8:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-023

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 326 14TH ST NE

Customer Sample Number:

Date / Time Collected: 10/12/2021 8:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-024

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110161-009

Sample Location: 1st Draw 3465 HOLMEAD PL NW

Customer Sample Number:

Date / Time Collected: 10/12/2021 5:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-009

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3465 HOLMEAD PL NW

Customer Sample Number:

Date / Time Collected: 10/12/2021 5:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-010

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110254-023

Sample Location: 1st Draw 3626 13th St NW

Customer Sample Number:

Date / Time Collected: 10/21/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2110254-023

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3626 13th St NW

Customer Sample Number:

Date / Time Collected: 10/21/2021 7:33 AM

Customer Program Code: DS

Laboratory Sample Number: 2110254-024

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110259-001

Sample Location: 1st Draw 3913 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2110259-001

Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3913 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2110259-002

Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-011

Sample Location: 1st Draw 405 Aspen St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-011

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 405 Aspen St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 7:31 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-012

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110161-001

Sample Location: 1st Draw 4211 12th PI NE

Customer Sample Number:

Date / Time Collected: 10/15/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-001

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 4211 12th PI NE

Customer Sample Number:

Date / Time Collected: 10/15/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-002

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110254-017

Sample Location: 1st Draw 4216 4th St NW
Customer Sample Number:
Date / Time Collected: 10/20/2021 7:34 AM

Customer Program Code: DS
Laboratory Sample Number: 2110254-017
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 4216 4th St NW
Customer Sample Number:
Date / Time Collected: 10/20/2021 7:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2110254-018
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-013

Sample Location: 1st Draw 423 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-013

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 423 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 7:52 AM

Customer Program Code: DS

Laboratory Sample Number: 2110197-014

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110161-003

Sample Location: 1st Draw 4351 G Street SE

Customer Sample Number:

Date / Time Collected: 10/15/2021 6:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-003

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 4351 G Street SE

Customer Sample Number:

Date / Time Collected: 10/15/2021 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2110161-004

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-005

Sample Location: 1st Draw 443 2nd St SE
Customer Sample Number:
Date / Time Collected: 10/10/2021 9:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2110197-005
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 443 2nd St SE
Customer Sample Number:
Date / Time Collected: 10/10/2021 9:35 AM

Customer Program Code: DS
Laboratory Sample Number: 2110197-006
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-007

Sample Location: 1st Draw 4434 Hunt PI NE
Customer Sample Number:
Date / Time Collected: 10/10/2021 10:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2110197-007
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 4434 Hunt PI NE
Customer Sample Number:
Date / Time Collected: 10/10/2021 10:45 AM

Customer Program Code: DS
Laboratory Sample Number: 2110197-008
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-009

Sample Location: 1st Draw 5024 Nebraska Ave

Customer Sample Number:

Date / Time Collected: 10/10/2021 7:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2110197-009

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 5024 Nebraska Ave

Customer Sample Number:

Date / Time Collected: 10/10/2021 7:26 PM

Customer Program Code: DS

Laboratory Sample Number: 2110197-010

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-025

Sample Location: 1st Draw 5030 10th St. NE

Customer Sample Number:

Date / Time Collected: 10/12/2021 4:34 PM

Customer Program Code: DS

Laboratory Sample Number: 2110197-025

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 5030 10th St. NE

Customer Sample Number:

Date / Time Collected: 10/12/2021 4:35 PM

Customer Program Code: DS

Laboratory Sample Number: 2110197-026

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110205-021

Sample Location: 1st Draw 5332 5th St NW
Customer Sample Number:
Date / Time Collected: 10/19/2021 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2110205-021
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 5332 5th St NW
Customer Sample Number:
Date / Time Collected: 10/19/2021 8:30 AM

Customer Program Code: DS
Laboratory Sample Number: 2110205-022
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110254-007

Sample Location: 1st Draw 56 Underwood PI NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 4:56 PM

Customer Program Code: DS

Laboratory Sample Number: 2110254-007

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 56 Underwood PI NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 4:57 PM

Customer Program Code: DS

Laboratory Sample Number: 2110254-008

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110197-019

Sample Location: 1st Draw 608 Tewkesbury PL NW
Customer Sample Number:
Date / Time Collected: 10/11/2021 11:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2110197-019
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 608 Tewkesbury PL NW
Customer Sample Number:
Date / Time Collected: 10/11/2021 11:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2110197-020
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110267-001

Sample Location: 1st Draw 640 North Carolina Ave SE

Customer Sample Number:

Date / Time Collected: 10/20/2021 10:22 PM

Customer Program Code: DS

Laboratory Sample Number: 2110267-001

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 640 North Carolina Ave SE

Customer Sample Number:

Date / Time Collected: 10/20/2021 10:25 PM

Customer Program Code: DS

Laboratory Sample Number: 2110267-002

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/9/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110073-009

Sample Location: 1st Draw 1267 Morse St. NE Unit A

Customer Sample Number:

Date / Time Collected: 10/6/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-009

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1267 Morse St. NE Unit A

Customer Sample Number:

Date / Time Collected: 10/6/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-010

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/9/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110073-001

Sample Location: 1st Draw 1532 33rd St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2021 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-001

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	20.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1532 33rd St. NW

Customer Sample Number:

Date / Time Collected: 10/2/2021 11:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-002

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	17.1	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/9/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110073-007

Sample Location: 1st Draw 2241 39th PL NW

Customer Sample Number:

Date / Time Collected: 10/5/2021 7:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-007

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2241 39th PL NW

Customer Sample Number:

Date / Time Collected: 10/5/2021 7:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-008

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/9/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2110073-003

Sample Location: 1st Draw 3298 Arcadia PL NW

Customer Sample Number:

Date / Time Collected: 10/3/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-003

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3298 Arcadia PL NW

Customer Sample Number:

Date / Time Collected: 10/3/2021 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2110073-004

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111176-001

Sample Location: 1st Draw 1315 Linden Ct NE

Customer Sample Number:

Date / Time Collected: 11/8/2021 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2111176-001

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1315 Linden Ct NE

Customer Sample Number:

Date / Time Collected: 11/8/2021 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2111176-002

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-019

Sample Location: 1st Draw 1420 Crittenden St. NW

Customer Sample Number:

Date / Time Collected: 11/8/2021 7:18 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-019

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	23.7	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1420 Crittenden St. NW

Customer Sample Number:

Date / Time Collected: 11/8/2021 7:21 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-020

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-011

Sample Location: 1st Draw 149 U St NE
Customer Sample Number:
Date / Time Collected: 11/4/2021 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2111080-011
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 149 U St NE
Customer Sample Number:
Date / Time Collected: 11/4/2021 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2111080-012
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111054-001

Sample Location: 1st Draw 1515 Varnum St. NW

Customer Sample Number: 3028108

Date / Time Collected: 9/24/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-001

Date / Time Received: 11/4/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1515 Varnum St. NW

Customer Sample Number: 3028108

Date / Time Collected: 9/24/2021 6:51 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-002

Date / Time Received: 11/4/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-009

Sample Location: 1st Draw 1600 E Beekman PI NW

Customer Sample Number:

Date / Time Collected: 9/22/2021 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-009

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1600 E Beekman PI NW

Customer Sample Number:

Date / Time Collected: 9/22/2021 2:00 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-010

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-043

Sample Location: 1st Draw 1602 A Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/26/2021 8:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-043

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1602 A Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/26/2021 8:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-044

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-033

Sample Location: 1st Draw 1604 Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 10/27/2021 7:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-033

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1604 Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 10/27/2021 7:06 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-034

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-001

Sample Location: 1st Draw 1608 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/23/2021 8:11 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-001

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1608 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/23/2021 8:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-002

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-015

Sample Location: 1st Draw 1608 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 10/2/2021 9:02 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-015

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1608 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 10/2/2021 9:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-016

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-001

Sample Location: 1st Draw 1608 Belmont Rd NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/22/2021 7:42 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-001

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1608 Belmont Rd NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/22/2021 7:44 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-002

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-023

Sample Location: 1st Draw 1608 Belmont Rd NW, Unit D

Customer Sample Number:

Date / Time Collected: 10/5/2021 9:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-023

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1608 Belmont Rd NW, Unit D

Customer Sample Number:

Date / Time Collected: 10/5/2021 9:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-024

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-005

Sample Location: 1st Draw 1610 C Belmont St NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/20/2021 6:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-005

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1610 C Belmont St NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/20/2021 6:36 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-006

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-007

Sample Location: 1st Draw 1612 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/19/2021 5:55 PM

Customer Program Code: DS

Laboratory Sample Number: 2111159-007

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1612 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/19/2021 5:58 PM

Customer Program Code: DS

Laboratory Sample Number: 2111159-008

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-035

Sample Location: 1st Draw 1612 Belmont St NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/6/2021 7:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-035

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1612 Belmont St NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/6/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-036

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-005

Sample Location: 1st Draw 1614 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/23/2021 7:40 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-005

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1614 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/23/2021 7:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-006

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-027

Sample Location: 1st Draw 1616 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/20/2021 7:12 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-027

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1616 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/20/2021 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-028

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-021

Sample Location: 1st Draw 1616 Belmont St NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/20/2021 8:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-021

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1616 Belmont St NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/20/2021 8:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-022

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-037

Sample Location: 1st Draw 1616 C Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 10/13/2021 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-037

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1616 C Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 10/13/2021 10:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-038

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-017

Sample Location: 1st Draw 1620 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/21/2021 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-017

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1620 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/21/2021 6:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-018

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-053

Sample Location: 1st Draw 1620 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/20/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-053

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1620 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/20/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-054

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-011

Sample Location: 1st Draw 1622 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/25/2021 6:45 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-011

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1622 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/25/2021 6:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-012

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-017

Sample Location: 1st Draw 1623 Montague NW

Customer Sample Number:

Date / Time Collected: 11/6/2021 3:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-017

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1623 Montague NW

Customer Sample Number:

Date / Time Collected: 11/6/2021 3:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-018

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-019

Sample Location: 1st Draw 1624 Belmont St NW, Unit C

Customer Sample Number:

Date / Time Collected: 11/1/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-019

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1624 Belmont St NW, Unit C

Customer Sample Number:

Date / Time Collected: 11/1/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-020

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-045

Sample Location: 1st Draw 1628 B Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/26/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-045

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1628 B Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/26/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-046

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-051

Sample Location: 1st Draw 1628 D Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/17/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-051

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1628 D Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/17/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-052

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-025

Sample Location: 1st Draw 1630 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/16/2021 11:50 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-025

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1630 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/16/2021 11:53 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-026

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-029

Sample Location: 1st Draw 1638 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/23/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-029

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1638 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 10/23/2021 7:50 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-030

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-055

Sample Location: 1st Draw 1640 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 10/6/2021 5:39 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-055

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1640 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 10/6/2021 5:40 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-056

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-007

Sample Location: 1st Draw 1640 C Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/23/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-007

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1640 C Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/23/2021 9:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-008

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-049

Sample Location: 1st Draw 1644 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/24/2021 7:28 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-049

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1644 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 9/24/2021 7:29 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-050

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-003

Sample Location: 1st Draw 1648 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/26/2021 9:11 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-003

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1648 Beekman PI NW, Unit A

Customer Sample Number:

Date / Time Collected: 9/26/2021 9:15 PM

Customer Program Code: DS

Laboratory Sample Number: 2111080-004

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-013

Sample Location: 1st Draw 1658 D Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/24/2021 6:38 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-013

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1658 D Beekman PI NW, Unit D

Customer Sample Number:

Date / Time Collected: 9/24/2021 6:41 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-014

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-047

Sample Location: 1st Draw 1664 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/22/2021 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-047

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1664 Beekman PI NW, Unit C

Customer Sample Number:

Date / Time Collected: 9/22/2021 7:35 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-048

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-031

Sample Location: 1st Draw 1670 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 10/6/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-031

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1670 Beekman PI NW, Unit B

Customer Sample Number:

Date / Time Collected: 10/6/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-032

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-039

Sample Location: 1st Draw 1672 D Beekman PI NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-039

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 1672 D Beekman PI NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 6:01 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-040

Date / Time Received: 11/8/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111054-019

Sample Location: 1st Draw 1736 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 10/27/2021 5:09 PM

Customer Program Code: DS

Laboratory Sample Number: 2111054-019

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1736 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 10/27/2021 5:12 PM

Customer Program Code: DS

Laboratory Sample Number: 2111054-020

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-009

Sample Location: 1st Draw 1738 R Street NW

Customer Sample Number:

Date / Time Collected: 11/4/2021 4:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-009

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1738 R Street NW

Customer Sample Number:

Date / Time Collected: 11/4/2021 4:19 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-010

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111054-013

Sample Location: 1st Draw 1839 Swann St NW

Customer Sample Number:

Date / Time Collected: 10/27/2021 7:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-013

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1839 Swann St NW

Customer Sample Number:

Date / Time Collected: 10/27/2021 7:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-014

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111054-011

Sample Location: 1st Draw 3825 Huntington St NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-011

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 3825 Huntington St NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 7:32 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-012

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111113-005

Sample Location: 1st Draw 4006 7th St NW
Customer Sample Number:
Date / Time Collected: 11/7/2021 8:13 AM

Customer Program Code: DS
Laboratory Sample Number: 2111113-005
Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 4006 7th St NW
Customer Sample Number:
Date / Time Collected: 11/7/2021 8:17 AM

Customer Program Code: DS
Laboratory Sample Number: 2111113-006
Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111080-041

Sample Location: 1st Draw 4347 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 10/30/2021 7:34 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-041

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 4347 Brandywine St NW

Customer Sample Number:

Date / Time Collected: 10/30/2021 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2111080-042

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-015

Sample Location: 1st Draw 4914 Arkansas Ave NW

Customer Sample Number:

Date / Time Collected: 11/1/2021 7:47 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-015

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 4914 Arkansas Ave NW

Customer Sample Number:

Date / Time Collected: 11/1/2021 7:48 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-016

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111113-009

Sample Location: 1st Draw 4925 Loughboro Rd.

Customer Sample Number:

Date / Time Collected: 11/9/2021 6:10 AM

Customer Program Code: DS

Laboratory Sample Number: 2111113-009

Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 4925 Loughboro Rd.

Customer Sample Number:

Date / Time Collected: 11/9/2021 6:16 AM

Customer Program Code: DS

Laboratory Sample Number: 2111113-010

Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111113-007

Sample Location: 1st Draw 5218 5th St NW
Customer Sample Number:
Date / Time Collected: 11/8/2021 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2111113-007
Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 5218 5th St NW
Customer Sample Number:
Date / Time Collected: 11/8/2021 7:00 AM

Customer Program Code: DS
Laboratory Sample Number: 2111113-008
Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111054-005

Sample Location: 1st Draw 5321 2nd St NW

Customer Sample Number:

Date / Time Collected: 10/20/2021 6:05 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-005

Date / Time Received: 11/4/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 5321 2nd St NW

Customer Sample Number:

Date / Time Collected: 10/20/2021 6:08 AM

Customer Program Code: DS

Laboratory Sample Number: 2111054-006

Date / Time Received: 11/4/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-013

Sample Location: 1st Draw 634 D Street SE #1

Customer Sample Number:

Date / Time Collected: 11/4/2021 6:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-013

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 634 D Street SE #1

Customer Sample Number:

Date / Time Collected: 11/4/2021 6:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-014

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111159-003

Sample Location: 1st Draw 717 G St SW

Customer Sample Number:

Date / Time Collected: 11/2/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-003

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 717 G St SW

Customer Sample Number:

Date / Time Collected: 11/2/2021 9:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111159-004

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111232-001

Sample Location: 1st Draw 1111 44th PI SE

Customer Sample Number:

Date / Time Collected: 11/18/2021 7:30 AM

Customer Program Code: DS

Laboratory Sample Number: 2111232-001

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1111 44th PI SE

Customer Sample Number:

Date / Time Collected: 11/18/2021 7:37 AM

Customer Program Code: DS

Laboratory Sample Number: 2111232-002

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-013

Sample Location: 1st Draw 1147 3rd St NE
Customer Sample Number:
Date / Time Collected: 11/15/2021 7:22 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-013
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1147 3rd St NE
Customer Sample Number:
Date / Time Collected: 11/15/2021 7:25 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-014
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-027

Sample Location: 1st Draw 1306 44th Place SE

Customer Sample Number:

Date / Time Collected: 11/17/2021 6:59 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-027

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1306 44th Place SE

Customer Sample Number:

Date / Time Collected: 11/17/2021 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-028

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-019

Sample Location: 1st Draw 1509 D Street SE
Customer Sample Number:
Date / Time Collected: 11/16/2021 6:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-019
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1509 D Street SE
Customer Sample Number:
Date / Time Collected: 11/16/2021 6:52 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-020
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111252-001

Sample Location: 1st Draw 1729 Newton St. NW, Unit A

Customer Sample Number:

Date / Time Collected: 11/21/2021 7:04 AM

Customer Program Code: DS

Laboratory Sample Number: 2111252-001

Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/3/2021	SBrooks

Sample Location: 2nd Draw 1729 Newton St. NW, Unit A

Customer Sample Number:

Date / Time Collected: 11/21/2021 7:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2111252-002

Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111232-003

Sample Location: 1st Draw 230 9th St. NE
Customer Sample Number:
Date / Time Collected: 11/18/2021 3:35 PM

Customer Program Code: DS
Laboratory Sample Number: 2111232-003
Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 230 9th St. NE
Customer Sample Number:
Date / Time Collected: 11/18/2021 3:40 PM

Customer Program Code: DS
Laboratory Sample Number: 2111232-004
Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-023

Sample Location: 1st Draw 2819 28th St NW

Customer Sample Number:

Date / Time Collected: 11/17/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-023

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 2819 28th St NW

Customer Sample Number:

Date / Time Collected: 11/17/2021 6:00 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-024

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-009

Sample Location: 1st Draw 3416 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 11/15/2021 6:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-009

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 3416 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 11/15/2021 6:24 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-010

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-021

Sample Location: 1st Draw 415 5th St SE
Customer Sample Number:
Date / Time Collected: 11/16/2021 7:36 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-021
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 415 5th St SE
Customer Sample Number:
Date / Time Collected: 11/16/2021 7:38 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-022
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111232-005

Sample Location: 1st Draw 452 Newcomb St. SE

Customer Sample Number:

Date / Time Collected: 11/22/2021 8:20 AM

Customer Program Code: DS

Laboratory Sample Number: 2111232-005

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 452 Newcomb St. SE

Customer Sample Number:

Date / Time Collected: 11/22/2021 8:22 AM

Customer Program Code: DS

Laboratory Sample Number: 2111232-006

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-011

Sample Location: 1st Draw 4559 MacArthur Blvd NW #204

Customer Sample Number:

Date / Time Collected: 11/15/2021 7:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-011

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 4559 MacArthur Blvd NW #204

Customer Sample Number:

Date / Time Collected: 11/15/2021 7:17 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-012

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-029

Sample Location: 1st Draw 518 15th St SE
Customer Sample Number:
Date / Time Collected: 11/17/2021 8:50 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-029
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 518 15th St SE
Customer Sample Number:
Date / Time Collected: 11/17/2021 8:51 AM

Customer Program Code: DS
Laboratory Sample Number: 2111223-030
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-015

Sample Location: 1st Draw 540 Hobart PI NW

Customer Sample Number:

Date / Time Collected: 11/15/2021 8:07 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-015

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 540 Hobart PI NW

Customer Sample Number:

Date / Time Collected: 11/15/2021 8:09 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-016

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS-2111223-017

Sample Location: 1st Draw 725 Kenyon St NW, Unit B

Customer Sample Number:

Date / Time Collected: 11/15/2021 9:13 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-017

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 725 Kenyon St NW, Unit B

Customer Sample Number:

Date / Time Collected: 11/15/2021 9:15 AM

Customer Program Code: DS

Laboratory Sample Number: 2111223-018

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2106088-001

Sample Location: 1st Draw 2501 Q St NW #203

Customer Sample Number:

Date / Time Collected: 6/2/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106088-001

Date / Time Received: 6/9/2021 8:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		6/22/2021	SBrooks

Sample Location: 2nd Draw 2501 Q St NW #203

Customer Sample Number:

Date / Time Collected: 6/2/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106088-002

Date / Time Received: 6/9/2021 8:26:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		6/22/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2106243-001

Sample Location: 1st Draw 1099 22nd St. NW #606

Customer Sample Number:

Date / Time Collected: 6/18/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106243-001

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1099 22nd St. NW #606

Customer Sample Number:

Date / Time Collected: 6/18/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106243-002

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2106219-001

Sample Location: 1st Draw 1772 Church St NW, 409

Customer Sample Number:

Date / Time Collected: 6/13/2021 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106219-001

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1772 Church St NW, 409

Customer Sample Number:

Date / Time Collected: 6/13/2021 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106219-002

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2106193-003

Sample Location: 1st Draw 2824 12th St NE #207

Customer Sample Number:

Date / Time Collected: 6/9/2021 7:44 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106193-003

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2824 12th St NE #207

Customer Sample Number:

Date / Time Collected: 6/9/2021 7:44 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106193-004

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107073-001

Sample Location: 1st Draw 301 G. St. SW #630

Customer Sample Number:

Date / Time Collected: 7/6/2021 10:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107073-001

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 301 G. St. SW #630

Customer Sample Number:

Date / Time Collected: 7/6/2021 10:02 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107073-002

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107017-003

Sample Location: 1st Draw 3023 15th St NW unit A

Customer Sample Number:

Date / Time Collected: 6/30/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107017-003

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3023 15th St NW unit A

Customer Sample Number:

Date / Time Collected: 6/30/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107017-004

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2106255-001

Sample Location: 1st Draw 3024 Tilden St NW #303

Customer Sample Number:

Date / Time Collected: 6/25/2021 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106255-001

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3024 Tilden St NW #303

Customer Sample Number:

Date / Time Collected: 6/25/2021 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106255-002

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107017-001

Sample Location: 1st Draw 3130 Wisconsin Ave NW, Apt. 301

Customer Sample Number:

Date / Time Collected: 6/27/2021 3:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107017-001

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3130 Wisconsin Ave NW, Apt. 301

Customer Sample Number:

Date / Time Collected: 6/27/2021 3:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107017-002

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2106193-001

Sample Location: 1st Draw 3606 Rock Creek Church Rd NW 102

Customer Sample Number:

Date / Time Collected: 6/14/2021 1:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106193-001

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3606 Rock Creek Church Rd NW 102

Customer Sample Number:

Date / Time Collected: 6/14/2021 1:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2106193-002

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107017-005

Sample Location: 1st Draw 400 8th St. NW #401

Customer Sample Number:

Date / Time Collected: 6/29/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107017-005

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 400 8th St. NW #401

Customer Sample Number:

Date / Time Collected: 6/29/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107017-006

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107046-001

Sample Location: 1st Draw 923 B 6th St. NE

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107046-001

Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 923 B 6th St. NE

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:04 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107046-002

Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107121-001

Sample Location: 1st Draw 1324 Euclid St NW Apt 204

Customer Sample Number:

Date / Time Collected: 7/11/2021 9:40 PM

Customer Program Code: DS250

Laboratory Sample Number: 2107121-001

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1324 Euclid St NW Apt 204

Customer Sample Number:

Date / Time Collected: 7/11/2021 9:40 PM

Customer Program Code: DS250

Laboratory Sample Number: 2107121-002

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107162-001

Sample Location: 1st Draw 1427 S ST. NW, APT. B
Customer Sample Number:
Date / Time Collected: 7/13/2021 6:55 AM

Customer Program Code: DS250
Laboratory Sample Number: 2107162-001
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1427 S ST. NW, APT. B
Customer Sample Number:
Date / Time Collected: 7/13/2021 6:55 AM

Customer Program Code: DS250
Laboratory Sample Number: 2107162-002
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107162-011

Sample Location: 1st Draw 1661 PARK RD NW # 103

Customer Sample Number:

Date / Time Collected: 7/16/2021 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-011

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1661 PARK RD NW # 103

Customer Sample Number:

Date / Time Collected: 7/16/2021 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-012

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2108015-001

Sample Location: 1st Draw 2032 16th St NW apt 8

Customer Sample Number:

Date / Time Collected: 7/28/2021 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108015-001

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 2032 16th St NW apt 8

Customer Sample Number:

Date / Time Collected: 7/28/2021 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108015-002

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107162-003

Sample Location: 1st Draw 2610 TUNLAW RD NW APT. 203

Customer Sample Number:

Date / Time Collected: 7/14/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-003

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 2610 TUNLAW RD NW APT. 203

Customer Sample Number:

Date / Time Collected: 7/14/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-004

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107096-025

Sample Location: 1st Draw 3053 Chancellors Way NE

Customer Sample Number:

Date / Time Collected: 7/9/2021 8:33 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107096-025

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3053 Chancellors Way NE

Customer Sample Number:

Date / Time Collected: 7/9/2021 8:33 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107096-026

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107162-009

Sample Location: 1st Draw 3670 38TH ST NW F252

Customer Sample Number:

Date / Time Collected: 7/15/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-009

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3670 38TH ST NW F252

Customer Sample Number:

Date / Time Collected: 7/15/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-010

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107223-001

Sample Location: 1st Draw 3910 8TH ST NW #2

Customer Sample Number:

Date / Time Collected: 7/26/2021 6:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107223-001

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3910 8TH ST NW #2

Customer Sample Number:

Date / Time Collected: 7/26/2021 6:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107223-002

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107131-001

Sample Location: 1st Draw 400 Seward Sqr SE, 31

Customer Sample Number:

Date / Time Collected: 7/14/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107131-001

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 400 Seward Sqr SE, 31

Customer Sample Number:

Date / Time Collected: 7/14/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107131-002

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107162-005

Sample Location: 1st Draw 565 PENNSYLVANIA AVE NW # 1212

Customer Sample Number:

Date / Time Collected: 7/15/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-005

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 565 PENNSYLVANIA AVE NW # 1212

Customer Sample Number:

Date / Time Collected: 7/15/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-006

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2107162-007

Sample Location: 1st Draw 719 HAMLIN ST NE # 4
Customer Sample Number:
Date / Time Collected: 7/15/2021 5:50 AM

Customer Program Code: DS250
Laboratory Sample Number: 2107162-007
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 719 HAMLIN ST NE # 4
Customer Sample Number:
Date / Time Collected: 7/15/2021 5:50 AM

Customer Program Code: DS250
Laboratory Sample Number: 2107162-008
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2107162-013

Sample Location: 1st Draw 909 NEW JERSEY AVE SE 502

Customer Sample Number:

Date / Time Collected: 7/19/2021 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-013

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 909 NEW JERSEY AVE SE 502

Customer Sample Number:

Date / Time Collected: 7/19/2021 9:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2107162-014

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2108206-003

Sample Location: 1st Draw (519) 2727 29th St. NW

Customer Sample Number:

Date / Time Collected: 8/17/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108206-003

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw (519) 2727 29th St. NW

Customer Sample Number:

Date / Time Collected: 8/17/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108206-004

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2108191-001

Sample Location: 1st Draw 1441 Euclid St NW #305

Customer Sample Number:

Date / Time Collected: 8/15/2021 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108191-001

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1441 Euclid St NW #305

Customer Sample Number:

Date / Time Collected: 8/15/2021 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108191-002

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2108113-007

Sample Location: 1st Draw 1527 Park Rd NW, 201

Customer Sample Number:

Date / Time Collected: 8/4/2021 8:06 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108113-007

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/19/2021	RHoffa

Sample Location: 2nd Draw 1527 Park Rd NW, 201

Customer Sample Number:

Date / Time Collected: 8/4/2021 8:06 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108113-008

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2108094-001

Sample Location: 1st Draw 1900 15th St. NW #7

Customer Sample Number:

Date / Time Collected: 7/30/2021 10:53 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108094-001

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1900 15th St. NW #7

Customer Sample Number:

Date / Time Collected: 7/30/2021 10:53 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108094-002

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2108165-001

Sample Location: 1st Draw 1909 19th St. NW

Customer Sample Number:

Date / Time Collected: 7/30/2021 8:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108165-001

Date / Time Received: 8/16/2021 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	8/19/2021	RHoffa

Sample Location: 2nd Draw 1909 19th St. NW

Customer Sample Number:

Date / Time Collected: 7/30/2021 8:30 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108165-002

Date / Time Received: 8/16/2021 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: L-DC-DS250- 2108165-003

Sample Location: 1st Draw 2 M St. NE

Customer Sample Number:

Date / Time Collected: 8/1/2021 9:44 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108165-003

Date / Time Received: 8/16/2021 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/19/2021	RHoffa

Sample Location: 2nd Draw 2 M St. NE

Customer Sample Number:

Date / Time Collected: 8/1/2021 9:44 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108165-004

Date / Time Received: 8/16/2021 9:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2108043-001

Sample Location: 1st Draw 2201 42ND ST NW #4

Customer Sample Number:

Date / Time Collected: 7/27/2021 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108043-001

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 2201 42ND ST NW #4

Customer Sample Number:

Date / Time Collected: 7/27/2021 11:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108043-002

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: L-DC-DS250- 2108113-005

Sample Location: 1st Draw 2314 19th St. NW Apt 6
Customer Sample Number:
Date / Time Collected: 8/3/2021 9:59 AM
Customer Program Code: DS250
Laboratory Sample Number: 2108113-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa

Sample Location: 2nd Draw 2314 19th St. NW Apt 6
Customer Sample Number:
Date / Time Collected: 8/3/2021 9:59 AM
Customer Program Code: DS250
Laboratory Sample Number: 2108113-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: L-DC-DS250- 2108113-001

Sample Location: 1st Draw 2400 41st St. NW #203
Customer Sample Number:
Date / Time Collected: 8/2/2021 7:00 AM
Customer Program Code: DS250
Laboratory Sample Number: 2108113-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/19/2021	RHoffa

Sample Location: 2nd Draw 2400 41st St. NW #203
Customer Sample Number:
Date / Time Collected: 8/2/2021 7:00 AM
Customer Program Code: DS250
Laboratory Sample Number: 2108113-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: L-DC-DS250-2108113-003

Sample Location: 1st Draw 2611 Adams Mill Rd NW #407

Customer Sample Number:

Date / Time Collected: 8/3/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108113-003

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2nd Draw 2611 Adams Mill Rd NW #407

Customer Sample Number:

Date / Time Collected: 8/3/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108113-004

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2108191-005

Sample Location: 1st Draw 426 6th St NE Apt 7

Customer Sample Number:

Date / Time Collected: 8/16/2021 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108191-005

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 426 6th St NE Apt 7

Customer Sample Number:

Date / Time Collected: 8/16/2021 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2108191-006

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2108191-003

Sample Location: 1st Draw 555 Mass Ave NW Apt 605

Customer Sample Number:

Date / Time Collected: 8/16/2021 7:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108191-003

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 555 Mass Ave NW Apt 605

Customer Sample Number:

Date / Time Collected: 8/16/2021 7:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108191-004

Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: L-DC-DS250- 2108206-001

Sample Location: 1st Draw 939 25th St. NW Apt B

Customer Sample Number:

Date / Time Collected: 8/17/2021 5:16 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108206-001

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 939 25th St. NW Apt B

Customer Sample Number:

Date / Time Collected: 8/17/2021 5:16 AM

Customer Program Code: DS250

Laboratory Sample Number: 2108206-002

Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2109014-001

Sample Location: 1st Draw 1331 VERMONT AVE NW APT B

Customer Sample Number:

Date / Time Collected: 8/22/2021 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109014-001

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1331 VERMONT AVE NW APT B

Customer Sample Number:

Date / Time Collected: 8/22/2021 11:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109014-002

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2109014-005

Sample Location: 1st Draw 1731 T ST NW # 5

Customer Sample Number:

Date / Time Collected: 8/31/2021 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109014-005

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1731 T ST NW # 5

Customer Sample Number:

Date / Time Collected: 8/31/2021 6:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109014-006

Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/15/2021

Report Number: L-DC-DS250- 2109014-003

Sample Location: 1st Draw 1939 17TH ST NW APT A
Customer Sample Number:
Date / Time Collected: 8/31/2021 7:35 AM

Customer Program Code: DS250
Laboratory Sample Number: 2109014-003
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1939 17TH ST NW APT A
Customer Sample Number:
Date / Time Collected: 8/31/2021 7:35 AM

Customer Program Code: DS250
Laboratory Sample Number: 2109014-004
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2109026-003

Sample Location: 1st Draw 4007 CONNECTICUT AVE NW APT 512	Customer Program Code: DS250
Customer Sample Number:	Laboratory Sample Number: 2109026-003
Date / Time Collected: 8/24/2021 10:23 AM	Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 4007 CONNECTICUT AVE NW APT 512	Customer Program Code: DS250
Customer Sample Number:	Laboratory Sample Number: 2109026-004
Date / Time Collected: 8/24/2021 10:23 AM	Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2109026-001

Sample Location: 1st Draw 4031 DAVIS PL. NW #3

Customer Sample Number:

Date / Time Collected: 8/22/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109026-001

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 4031 DAVIS PL. NW #3

Customer Sample Number:

Date / Time Collected: 8/22/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109026-002

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2109141-001

Sample Location: 1st Draw 1650 Foxhall Rd NW

Customer Sample Number:

Date / Time Collected: 9/4/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109141-001

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1650 Foxhall Rd NW

Customer Sample Number:

Date / Time Collected: 9/4/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109141-002

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2109151-001

Sample Location: 1st Draw 2320 Wisconsin Ave NW #316

Customer Sample Number:

Date / Time Collected: 9/7/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109151-001

Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 2320 Wisconsin Ave NW #316

Customer Sample Number:

Date / Time Collected: 9/7/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109151-002

Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250-2109230-001

Sample Location: 1st Draw 2400 Virginia Ave NW, Apt 6424

Customer Sample Number:

Date / Time Collected: 9/20/2021 5:58 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109230-001

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 2400 Virginia Ave NW, Apt 6424

Customer Sample Number:

Date / Time Collected: 9/20/2021 5:58 AM

Customer Program Code: DS250

Laboratory Sample Number: 2109230-002

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: L-DC-DS250-2109109-001

Sample Location: 1st Draw 2926 Porter St. NW #102

Customer Sample Number:

Date / Time Collected: 9/4/2021 3:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2109109-001

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 2926 Porter St. NW #102

Customer Sample Number:

Date / Time Collected: 9/4/2021 3:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2109109-002

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-011

Sample Location: 1st Draw 1010 Mass. Ave NW #207

Customer Sample Number:

Date / Time Collected: 9/27/2021 7:09 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-011

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 1010 Mass. Ave NW #207

Customer Sample Number:

Date / Time Collected: 9/27/2021 7:09 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-012

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-015

Sample Location: 1st Draw 1401 16th St NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-015

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 1401 16th St NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:00 PM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-016

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-013

Sample Location: 1st Draw 1414 17th St NW Apt 104

Customer Sample Number:

Date / Time Collected: 9/27/2021 8:28 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-013

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 1414 17th St NW Apt 104

Customer Sample Number:

Date / Time Collected: 9/27/2021 8:28 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-014

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-001

Sample Location: 1st Draw 1529 O Street NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:35 PM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-001

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 1529 O Street NW

Customer Sample Number:

Date / Time Collected: 9/28/2021 6:35 PM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-002

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-003

Sample Location: 1st Draw 1603 A SE #3
Customer Sample Number:
Date / Time Collected: 9/26/2021 10:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2110024-003
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 1603 A SE #3
Customer Sample Number:
Date / Time Collected: 9/26/2021 10:00 AM

Customer Program Code: DS250
Laboratory Sample Number: 2110024-004
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110072-001

Sample Location: 1st Draw 1750 16th St NW, Apt 33

Customer Sample Number:

Date / Time Collected: 10/5/2021 6:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110072-001

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1750 16th St NW, Apt 33

Customer Sample Number:

Date / Time Collected: 10/5/2021 6:55 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110072-002

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-007

Sample Location: 1st Draw 1827 Summit PI NW Apt G3

Customer Sample Number:

Date / Time Collected: 9/27/2021 4:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-007

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 1827 Summit PI NW Apt G3

Customer Sample Number:

Date / Time Collected: 9/27/2021 4:20 PM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-008

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-009

Sample Location: 1st Draw 2700 Woodley Rd NW

Customer Sample Number:

Date / Time Collected: 9/22/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-009

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 2700 Woodley Rd NW

Customer Sample Number:

Date / Time Collected: 9/22/2021 8:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-010

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110024-005

Sample Location: 1st Draw 4850 Connecticut Ave., NW Apt 818

Customer Sample Number:

Date / Time Collected: 9/27/2021 8:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-005

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Sample Location: 2nd Draw 4850 Connecticut Ave., NW Apt 818

Customer Sample Number:

Date / Time Collected: 9/27/2021 8:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110024-006

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110275-001

Sample Location: 1st Draw 1012 Harvard St. NW

Customer Sample Number:

Date / Time Collected: 10/22/2021 9:53 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110275-001

Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1012 Harvard St. NW

Customer Sample Number:

Date / Time Collected: 10/22/2021 9:53 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110275-002

Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110253-003

Sample Location: 1st Draw 1207 GIRAD ST NW Apt. 2

Customer Sample Number:

Date / Time Collected: 10/21/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110253-003

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1207 GIRAD ST NW Apt. 2

Customer Sample Number:

Date / Time Collected: 10/21/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110253-004

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110253-001

Sample Location: 1st Draw 147 R St. NE Apt 11

Customer Sample Number:

Date / Time Collected: 10/20/2021 6:13 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110253-001

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 147 R St. NE Apt 11

Customer Sample Number:

Date / Time Collected: 10/20/2021 6:13 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110253-002

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110156-001

Sample Location: 1st Draw 1819 Q St NW Apt 2

Customer Sample Number:

Date / Time Collected: 10/11/2021 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110156-001

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1819 Q St NW Apt 2

Customer Sample Number:

Date / Time Collected: 10/11/2021 7:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110156-002

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110191-001

Sample Location: 1st Draw 2100 Connecticut Ave NW, 801

Customer Sample Number:

Date / Time Collected: 10/11/2021 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110191-001

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2100 Connecticut Ave NW, 801

Customer Sample Number:

Date / Time Collected: 10/11/2021 5:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110191-002

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110260-003

Sample Location: 1st Draw 2101 16th St NW Apt 223

Customer Sample Number:

Date / Time Collected: 10/24/2021 6:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110260-003

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2101 16th St NW Apt 223

Customer Sample Number:

Date / Time Collected: 10/24/2021 6:29 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110260-004

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110275-003

Sample Location: 1st Draw 2236 13th St. NW Apt 2

Customer Sample Number:

Date / Time Collected: 10/24/2021 7:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110275-003

Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2236 13th St. NW Apt 2

Customer Sample Number:

Date / Time Collected: 10/24/2021 7:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110275-004

Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110260-001

Sample Location: 1st Draw 2339 Ashmead PI NW Apt 4

Customer Sample Number:

Date / Time Collected: 10/23/2021 10:14 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110260-001

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2339 Ashmead PI NW Apt 4

Customer Sample Number:

Date / Time Collected: 10/23/2021 10:14 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110260-002

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2110191-003

Sample Location: 1st Draw 2501 Calvert St NW, Apt 310

Customer Sample Number:

Date / Time Collected: 10/11/2021 10:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110191-003

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2501 Calvert St NW, Apt 310

Customer Sample Number:

Date / Time Collected: 10/11/2021 10:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2110191-004

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111047-001

Sample Location: 1st Draw 2707 Adams Mill Rd NW #407

Customer Sample Number:

Date / Time Collected: 10/26/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111047-001

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2707 Adams Mill Rd NW #407

Customer Sample Number:

Date / Time Collected: 10/26/2021 7:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111047-002

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111078-001

Sample Location: 1st Draw 2707 Adams Mill Rd NW Unit 206

Customer Sample Number:

Date / Time Collected: 10/26/2021 6:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2111078-001

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2707 Adams Mill Rd NW Unit 206

Customer Sample Number:

Date / Time Collected: 10/26/2021 6:15 PM

Customer Program Code: DS250

Laboratory Sample Number: 2111078-002

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

**Washington Aqueduct
Laboratory**

**5900 MacArthur Blvd, NW
Washington, DC 20016**

**Phone (202) 345-5928
Fax (202) 587-9446**



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111160-001

Sample Location: 1st Draw 400 Seward Sqr SE #31

Customer Sample Number:

Date / Time Collected: 11/5/2021 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111160-001

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 400 Seward Sqr SE #31

Customer Sample Number:

Date / Time Collected: 11/5/2021 6:30 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111160-002

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111210-009

Sample Location: 1st Draw 1109 O St NW, #402

Customer Sample Number:

Date / Time Collected: 11/15/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-009

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1109 O St NW, #402

Customer Sample Number:

Date / Time Collected: 11/15/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-010

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111210-001

Sample Location: 1st Draw 1421 Massachusetts Ave NW, Apt 705

Customer Sample Number:

Date / Time Collected: 11/11/2021 10:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-001

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1421 Massachusetts Ave NW, Apt 705

Customer Sample Number:

Date / Time Collected: 11/11/2021 10:45 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-002

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: L-DC-DS250- 2111231-009

Sample Location: 1st Draw 1727 Massachusetts Ave NW

Customer Sample Number:

Date / Time Collected: 11/19/2021 12:26 PM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-009

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1727 Massachusetts Ave NW

Customer Sample Number:

Date / Time Collected: 11/19/2021 12:26 PM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-010

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111231-007

Sample Location: 1st Draw 1775 Church St. #8

Customer Sample Number:

Date / Time Collected: 11/17/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-007

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1775 Church St. #8

Customer Sample Number:

Date / Time Collected: 11/17/2021 8:00 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-008

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111231-001

Sample Location: 1st Draw 1954 Columbia Rd NW, Apt 206

Customer Sample Number:

Date / Time Collected: 11/15/2021 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-001

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1954 Columbia Rd NW, Apt 206

Customer Sample Number:

Date / Time Collected: 11/15/2021 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-002

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: L-DC-DS250- 2111210-003

Sample Location: 1st Draw 2301 Champlain St NW, Apt 302

Customer Sample Number:

Date / Time Collected: 11/14/2021 9:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-003

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 2301 Champlain St NW, Apt 302

Customer Sample Number:

Date / Time Collected: 11/14/2021 9:15 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-004

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111231-005

Sample Location: 1st Draw 3003 Van Ness St NW, Apt w120

Customer Sample Number:

Date / Time Collected: 11/16/2021 7:34 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-005

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 3003 Van Ness St NW, Apt w120

Customer Sample Number:

Date / Time Collected: 11/16/2021 7:34 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-006

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: L-DC-DS250- 2111231-011

Sample Location: 1st Draw 3422 Brown St NW, Unit 202

Customer Sample Number:

Date / Time Collected: 11/20/2021 9:17 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-011

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 3422 Brown St NW, Unit 202

Customer Sample Number:

Date / Time Collected: 11/20/2021 9:17 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-012

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111210-005

Sample Location: 1st Draw 3815 14th St NW, Unit #3

Customer Sample Number:

Date / Time Collected: 11/15/2021 6:56 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-005

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 3815 14th St NW, Unit #3

Customer Sample Number:

Date / Time Collected: 11/15/2021 6:56 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-006

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111210-007

Sample Location: 1st Draw 4559 MacArthur Blvd NW #203

Customer Sample Number:

Date / Time Collected: 11/15/2021 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-007

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 4559 MacArthur Blvd NW #203

Customer Sample Number:

Date / Time Collected: 11/15/2021 7:20 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111210-008

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers

Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-DS250- 2111231-003

Sample Location: 1st Draw 504 L St NE, Apt B

Customer Sample Number:

Date / Time Collected: 11/16/2021 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-003

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 504 L St NE, Apt B

Customer Sample Number:

Date / Time Collected: 11/16/2021 6:50 AM

Customer Program Code: DS250

Laboratory Sample Number: 2111231-004

Date / Time Received: 11/24/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Customer Collected Filtered Samples

DC Water operates a program where customers request a lead sampling kit to test their in-line point-of-use filtered water. The test kit comes with a 1-L bottle and instructions on how to take a sample. Customers collect their own sample and contact DC Water to deliver the bottle to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2106192-001

Sample Location: 3333 RESERVOIR RD NW

Customer Sample Number:

Date / Time Collected: 6/15/2021 6:30 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2106192-001

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2107096-027

Sample Location: 148 Tennessee Ave NW
Customer Sample Number:
Date / Time Collected: 7/8/2021 8:20 PM

Customer Program Code: CUSTFILT
Laboratory Sample Number: 2107096-027
Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2107096-028

Sample Location: 4615 43rd St NW

Customer Sample Number:

Date / Time Collected: 7/10/2021 4:28 PM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2107096-028

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2108044-001

Sample Location: 451 Luray PL NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 11:00 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2108044-001

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	13.0	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2111206-001

Sample Location: 3416 McKinley St. NW

Customer Sample Number:

Date / Time Collected: 11/15/2021 6:30 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2111206-001

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-CUSTFILT- 2111046-001

Sample Location: 3800 Alton PI NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 7:30 AM

Customer Program Code: CUSTFILT

Laboratory Sample Number: 2111046-001

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Customer Collected Lead Profiles

DC Water operates a program where customers who do not have pipe material information about their service line can request a lead sampling kit designed to indicate if the service line has lead pipe. The sample kit has ten 1-liter bottles and instructions. Customers collect their own samples in sequential order following stagnation. DC Water reviews the sampling information to ensure samples were collected correctly. DC Water delivers the samples to the Washington Aqueduct and sends the results to customers.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2106189

Sample Location: 1 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-001
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.0	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-002
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.0	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-003
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.7	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-004
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.0	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-005
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.4	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-006
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.0	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-007
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.5	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-008
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.0	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-009
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.4	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 1425 Crittenden St NW
Date Collected: 6/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106189-010
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.5	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2106190

Sample Location: 1 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-001
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-002
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-003
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-004
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.0	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-005
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-006
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-007
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-008
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.6	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-009
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 1601 Brentwood Rd NE
Date Collected: 6/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106190-010
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2106236

Sample Location: 1 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-001
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-002
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-003
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-004
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-005
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-006
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-007
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-008
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-009
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 445 4th St NE
Date Collected: 6/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106236-010
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2106237

Sample Location: 1 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-001
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	436	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	13.2	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	4.4	ug/L		7/8/2021	SBrooks

Sample Location: 2 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-002
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	327	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.0	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	10.1	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	3.7	ug/L		7/8/2021	SBrooks

Sample Location: 3 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-003
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	446	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	5.1	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	13.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	5.2	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-004
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	302	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	9.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	1.8	ug/L		7/8/2021	SBrooks

Sample Location: 5 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-005
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	229	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	6.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	1.8	ug/L		7/8/2021	SBrooks

Sample Location: 6 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-006
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	140	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	1.2	ug/L		7/8/2021	SBrooks

Sample Location: 7 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-007
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	94.0	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	3.1	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks

Sample Location: 8 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-008
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.4	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	0.6	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-009
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 1738 Gales St NE
Date Collected: 6/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106237-010
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2106253

Sample Location: 1 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-001
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-002
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-003
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-004
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-005
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-006
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-007
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-008
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-009
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.8	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 3100 10th St NE
Date Collected: 6/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106253-010
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2106254

Sample Location: 1 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-001
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-002
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-003
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-004
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-005
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-006
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-007
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-008
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-009
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 704 Malcolm X Ave SE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106254-010
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2107019

Sample Location: 1 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-001
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2		ug/L		7/8/2021	SBrooks

Sample Location: 2 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-002
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-003
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-004
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-005
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	81.5	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-006
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.7	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-007
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-008
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-009
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 3700 13th St NE
Date Collected: 6/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107019-010
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2107020

Sample Location: 1 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-001
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-002
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-003
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-004
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-005
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-006
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-007
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-008
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-009
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 1212 C St NE
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107020-010
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: LT-DC-CCPF-2107021

Sample Location: 1 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-001
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 2 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-002
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 3 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-003
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-004
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 5 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-005
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-006
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-007
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-008
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-009
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 2012 13th St NW
Date Collected: 6/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107021-010
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2106235

Sample Location: 1 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-001
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		500	7570	ug/L		8/6/2021	SBrooks
Lead	EPA 200.8	15	0.2	197	ug/L		8/6/2021	SBrooks
Manganese	EPA 200.8		0.2	35.6	ug/L		8/6/2021	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		8/6/2021	SBrooks

Sample Location: 2 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-002
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	2000	ug/L		8/6/2021	SBrooks
Lead	EPA 200.8	15	0.2	51.8	ug/L		8/6/2021	SBrooks
Manganese	EPA 200.8		0.2	8.5	ug/L		8/6/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2021	SBrooks

Sample Location: 3 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-003
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	1210	ug/L		8/6/2021	SBrooks
Lead	EPA 200.8	15	0.2	31.4	ug/L		8/6/2021	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		8/6/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-004
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	900	ug/L		8/6/2021	SBrooks
Lead	EPA 200.8	15	0.2	25.1	ug/L		8/6/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		8/6/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/6/2021	SBrooks

Sample Location: 5 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-005
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	506	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	15.0	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 6 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-006
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	424	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	14.7	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	3.1	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 7 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-007
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	422	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	13.5	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 8 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-008
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	344	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	9.3	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-009
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	346	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	8.6	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Sample Location: 10 1026 Newton St NE
Date Collected: 6/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2106235-010
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	655	ug/L		7/8/2021	SBrooks
Lead	EPA 200.8	15	0.2	12.3	ug/L		7/8/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		7/8/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/8/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107016

Sample Location: 1 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-001
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-002
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.8	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-003
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-004
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.4	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-005
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-006
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-007
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-008
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.8	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-009
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 1217 Upshur St NE
Date Collected: 6/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107016-010
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	84.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107047

Sample Location: 1 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-001
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.8	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-002
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-003
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-004
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-005
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-006
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-007
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-008
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-009
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 1057 5th St. SE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107047-010
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107093

Sample Location: 1 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-001
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-002
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-003
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-004
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-005
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-006
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-007
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-008
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-009
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 443 Oakwood St. SE
Date Collected: 7/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107093-010
Date / Time Received: 7/13/2021 8:42:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107094

Sample Location: 1 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-001
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.9	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-002
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	1.4	ug/L		7/26/2021	SBrooks

Sample Location: 3 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-003
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.3	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	1.3	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-004
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		7/26/2021	SBrooks

Sample Location: 5 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-005
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	76.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-006
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	1.1	ug/L		7/26/2021	SBrooks

Sample Location: 7 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-007
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-008
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.4	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-009
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 1319 Allison St NE
Date Collected: 6/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107094-010
Date / Time Received: 7/13/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107095

Sample Location: 1 35 V St NE
Date Collected: 7/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107095-001
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		7/26/2021	SBrooks

Sample Location: 2 35 V St NE
Date Collected: 7/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107095-002
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 35 V St NE
Date Collected: 7/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107095-003
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.6	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 35 V St NE **Customer Program Code:** CCPF
Date Collected: 7/2/2021 **Laboratory Sample Number:** 2107095-004
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.9	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 35 V St NE **Customer Program Code:** CCPF
Date Collected: 7/2/2021 **Laboratory Sample Number:** 2107095-005
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 35 V St NE **Customer Program Code:** CCPF
Date Collected: 7/2/2021 **Laboratory Sample Number:** 2107095-006
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 35 V St NE **Customer Program Code:** CCPF
Date Collected: 7/2/2021 **Laboratory Sample Number:** 2107095-007
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 35 V St NE **Customer Program Code:** CCPF
Date Collected: 7/2/2021 **Laboratory Sample Number:** 2107095-008
Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 35 V St NE

Date Collected: 7/2/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2107095-009

Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 35 V St NE

Date Collected: 7/2/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2107095-010

Date / Time Received: 7/13/2021 8:59:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107118

Sample Location: 1 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-001
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-002
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.2	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-003
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-004
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-005
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.6	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-006
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.8	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-007
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.4	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-008
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.6	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-009
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 1229 S St NW
Date Collected: 7/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107118-010
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.3	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107119

Sample Location: 1 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-001
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.6	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-002
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.3	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	3.4	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-003
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.6	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-004
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.8	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-005
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.4	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.5	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-006
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.7	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-007
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-008
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	45.1	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-009
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.5	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 1704 Lawrence St NE
Date Collected: 7/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107119-010
Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.9	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: LT-DC-CCPF-2107127

Sample Location: 1 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-001
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 2 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-002
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 3 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-003
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-004
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 5 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-005
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 6 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-006
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 7 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-007
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 8 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-008
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-009
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Sample Location: 10 1214 T St NW
Date Collected: 7/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107127-010
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		7/26/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		7/26/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		7/26/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		7/26/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107177

Sample Location: 1 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-006
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-007
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-009
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1361 C ST NE
Date Collected: 7/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107177-010
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107178

Sample Location: 1 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	8.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-006
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-007
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.1	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-009
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1838 Capitol Ave NE
Date Collected: 7/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107178-010
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107180

Sample Location: 1 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	70.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	70.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-006
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	70.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-007
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	70.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	73.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-009
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	73.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 4509 SARGENT RD NE
Date Collected: 7/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107180-010
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	74.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107181

Sample Location: 1 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	50.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	141	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.1	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-006
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		8/5/2021	SBrooks

Sample Location: 7 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-007
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-009
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 3531 HOLMEAD PL NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107181-010
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107225

Sample Location: 1 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-001
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-002
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-003
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-004
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-005
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-006
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-007
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-008
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-009
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1508 1ST ST NW
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107225-010
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	87.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107226

Sample Location: 1 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-001
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-002
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-003
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-004
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-005
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	5.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-006
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-007
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-008
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.1	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-009
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 3019 26TH ST NE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107226-010
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107227

Sample Location: 1 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-001
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-002
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-003
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-004
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-005
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-006
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-007
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-008
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-009
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 765 WHEELER HILL DR SE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107227-010
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2107228

Sample Location: 1 3357 STUYVESANT PL NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107228-001
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	0.4	ug/L		8/5/2021	SBrooks

Sample Location: 2 3357 STUYVESANT PL NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107228-002
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 3357 STUYVESANT PL NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107228-003
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	0.5	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3357 STUYVESANT PL NW **Customer Program Code:** CCPF
Date Collected: 7/23/2021 **Laboratory Sample Number:** 2107228-004
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 3357 STUYVESANT PL NW **Customer Program Code:** CCPF
Date Collected: 7/23/2021 **Laboratory Sample Number:** 2107228-005
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 3357 STUYVESANT PL NW **Customer Program Code:** CCPF
Date Collected: 7/23/2021 **Laboratory Sample Number:** 2107228-006
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 3357 STUYVESANT PL NW **Customer Program Code:** CCPF
Date Collected: 7/23/2021 **Laboratory Sample Number:** 2107228-007
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 3357 STUYVESANT PL NW **Customer Program Code:** CCPF
Date Collected: 7/23/2021 **Laboratory Sample Number:** 2107228-008
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 3357 STUYVESANT PL NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107228-009
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 3357 STUYVESANT PL NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107228-010
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.0	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108004

Sample Location: 1 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 220 34th St SE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108004-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108005

Sample Location: 1 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.1	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 194 Chesapeake St SW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108005-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108006

Sample Location: 1 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1106 5th St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108006-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108007

Sample Location: 1 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks

Sample Location: 2 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	176	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	13.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	0.6	ug/L		8/5/2021	SBrooks

Sample Location: 3 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1252 10th St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108007-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108008

Sample Location: 1 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 442 Emerson St NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108008-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108009

Sample Location: 1 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1355 C St NE
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108009-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108012

Sample Location: 1 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.0	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.7	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 1705 Fort Davis St SE
Date Collected: 7/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108012-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108013

Sample Location: 1 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	140	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.4	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.1	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.6	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 541 42nd St NE
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108013-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/16/2021

Report Number: LT-DC-CCPF-2108014

Sample Location: 1 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-001
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-002
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-003
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-004
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-005
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-006
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-007
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-008
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-009
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 40 Bates St NW
Date Collected: 7/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108014-010
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108036

Sample Location: 1 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-001
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 2 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-002
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-003
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-004
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-005
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 6 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-006
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 7 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-007
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.1	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 8 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-008
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-009
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 10 1240 C ST NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108036-010
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108037

Sample Location: 1 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-001
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	0.2	ug/L		8/17/2021	RHoffa

Sample Location: 2 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-002
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-003
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-004
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-005
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 6 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-006
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 7 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-007
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 8 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-008
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-009
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 10 534 23RD PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108037-010
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108038

Sample Location: 1 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-001
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.2	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 2 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-002
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.7	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-003
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.1	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-004
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.5	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-005
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.1	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 6 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-006
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.7	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 7 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-007
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.5	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 8 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-008
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.9	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-009
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.4	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 10 858 51ST PL NE
Date Collected: 7/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108038-010
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108069

Sample Location: 1 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	0.6	ug/L		8/17/2021	RHoffa

Sample Location: 2 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-002
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 7 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 8 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-009
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 10 432 Oakdale PI NW
Date Collected: 7/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108069-010
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108070

Sample Location: 1 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 2 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-002
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 6 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 7 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 8 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-009
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 10 31 Anacostia Rd NE
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108070-010
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108071

Sample Location: 1 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 2 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-002
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 6 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-009
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.0	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 216 Elm St NW
Date Collected: 7/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108071-010
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108072

Sample Location: 1 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-002
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.9	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.5	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.6	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-009
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.5	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 2003 Ridge PI SE
Date Collected: 7/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108072-010
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108073

Sample Location: 1 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-002
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-009
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 3111 10th St NE
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108073-010
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108108

Sample Location: 1 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.6	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.4	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	6.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 3 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-003
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	121	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-004
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	65.9	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.4	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 5 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.6	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.5	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 6 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.5	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.6	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 7 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-007
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.7	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.6	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 8 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-008
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.1	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.9	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 10 1010 D St SE
Date Collected: 7/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108108-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.4	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108109

Sample Location: 1 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	335	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.5	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	271	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.2	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 3 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-003
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	264	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.4	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-004
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	226	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 5 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	277	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 6 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	255	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.4	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 7 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-007
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	262	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 8 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-008
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	245	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.2	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	279	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.7	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 10 3323 Stuyvesant pl NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108109-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	250	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	12.4	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108110

Sample Location: 1 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 3 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-003
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-004
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 5 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 6 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 7 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-007
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 8 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-008
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 10 1256 10th St NW
Date Collected: 8/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108110-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108111

Sample Location: 1 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.8	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.7	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 3 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-003
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.3	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-004
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.3	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 5 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.3	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 6 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.7	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 7 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-007
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.2	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 8 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-008
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.6	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.0	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 10 4613 Sargent Rd NE
Date Collected: 8/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108111-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.6	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108112

Sample Location: 1 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	49.1	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	12.4	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	17.0	ug/L		8/19/2021	Rhoffa

Sample Location: 2 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.8	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	1.4	ug/L		8/19/2021	Rhoffa

Sample Location: 3 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-003
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	0.4	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-004
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.9	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 5 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	0.2	ug/L		8/19/2021	Rhoffa

Sample Location: 6 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	4.5	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 7 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-007
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	8.9	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 8 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-008
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	5.2	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	11.6	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 10 4218 3rd St NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108112-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	3.1	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108157

Sample Location: 1 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	49.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.1	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.7	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.6	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.7	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.8	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.4	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.0	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.0	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 408 Emerson St., NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108157-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.8	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	3.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108158

Sample Location: 1 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	4.2	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.7	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 4626 4th St. NW
Date Collected: 8/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108158-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108159

Sample Location: 1 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	6.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.6	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.1	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	21.8	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	5.6	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.9	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	127	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 4232 3rd St. NW
Date Collected: 8/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108159-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.6	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108160

Sample Location: 1 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.7	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.9	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 412 Buchanan St NW
Date Collected: 8/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108160-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.1	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108161

Sample Location: 1 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	135	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	7.7	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 2 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	143	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	8.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 3 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	142	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	8.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	126	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	8.7	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 5 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	130	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	8.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 6 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	145	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	8.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 7 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	162	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	13.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	7.1	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 8 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	174	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	15.7	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	7.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	192	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	9.0	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	7.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 4611 9th St NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108161-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	123	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	5.3	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.9	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108162

Sample Location: 1 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.8	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	5.5	ug/L		8/19/2021	RHoffa

Sample Location: 2 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	1.1	ug/L		8/19/2021	RHoffa

Sample Location: 3 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.4	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.4	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.4	ug/L		8/19/2021	RHoffa

Sample Location: 5 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		8/19/2021	RHoffa

Sample Location: 6 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.7	ug/L		8/19/2021	RHoffa

Sample Location: 7 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		8/19/2021	RHoffa

Sample Location: 8 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.7	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.9	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.9	ug/L		8/19/2021	RHoffa

Sample Location: 10 41 Bates St. NW
Date Collected: 8/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108162-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.3	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.5	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108163

Sample Location: 1 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	80.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	5.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.7	ug/L		8/19/2021	RHoffa

Sample Location: 2 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.2	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		8/19/2021	RHoffa

Sample Location: 3 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.0	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.4	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.8	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		8/19/2021	RHoffa

Sample Location: 5 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.0	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.2	ug/L		8/19/2021	RHoffa

Sample Location: 6 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.0	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.5	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.2	ug/L		8/19/2021	RHoffa

Sample Location: 7 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.1	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.4	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	0.2	ug/L		8/19/2021	RHoffa

Sample Location: 8 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.6	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.7	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.3	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Sample Location: 10 416 Emerson St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108163-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.0	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	4.6	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: LT-DC-CCPF-2108164

Sample Location: 1 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	8.3	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	212	ug/L		8/19/2021	Rhoffa

Sample Location: 2 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	4.5	ug/L		8/19/2021	Rhoffa

Sample Location: 3 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	1.7	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	2.8	ug/L		8/19/2021	Rhoffa

Sample Location: 5 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.5	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	6.6	ug/L		8/19/2021	Rhoffa

Sample Location: 6 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-006
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	9.9	ug/L		8/19/2021	Rhoffa

Sample Location: 7 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-007
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	9.0	ug/L		8/19/2021	Rhoffa

Sample Location: 8 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-008
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	3.2	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-009
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	1.4	ug/L		8/19/2021	Rhoffa

Sample Location: 10 1665 32nd St. NW
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108164-010
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/19/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/19/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		8/19/2021	Rhoffa
Tin	EPA 200.8		0.2	2.1	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2107179

Sample Location: 1 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 2 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.3	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 3 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.5	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 5 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.8	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 6 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-006
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.2	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 7 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-007
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 8 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.4	ug/L		9/2/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/2/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/2/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		9/2/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-009
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.9	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Sample Location: 10 707 ADRIAN ST SE
Date Collected: 7/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2107179-010
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/5/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/5/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		8/5/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/5/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108035

Sample Location: 1 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-001
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.6	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 2 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-002
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.7	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 3 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-003
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.4	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-004
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.5	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 5 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-005
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.6	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 6 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-006
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.2	ug/L		9/2/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/2/2021	RHoffa
Manganese	EPA 200.8		0.2	33.7	ug/L		9/2/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/2/2021	RHoffa

Sample Location: 7 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-007
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.2	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 8 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-008
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.3	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-009
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.5	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Sample Location: 10 4218 12TH PL NE
Date Collected: 7/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108035-010
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.1	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	2.1	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108068

Sample Location: 1 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	1550	ug/L		9/2/2021	RHoffa
Lead	EPA 200.8	15	0.2	29.3	ug/L		9/2/2021	RHoffa
Manganese	EPA 200.8		0.2	13.7	ug/L		9/2/2021	RHoffa
Tin	EPA 200.8		0.2	38.7	ug/L		9/2/2021	RHoffa

Sample Location: 2 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-002
Date / Time Received: 8/4/2021 10:10:00 AM

E = Analyte concentration exceeded the upper limit of calibration. Result should be considered an estimated value.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	658	ug/L	E	8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	24.0	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	10.8	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	11.6	ug/L		8/17/2021	RHoffa

Sample Location: 3 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	325	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	11.8	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	8.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	6.4	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	195	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	7.9	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	8.0	ug/L		8/17/2021	RHoffa

Sample Location: 5 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	158	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	7.2	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	2.8	ug/L		8/17/2021	RHoffa

Sample Location: 6 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	139	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	7.5	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	2.6	ug/L		8/17/2021	RHoffa

Sample Location: 7 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	127	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	7.2	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	4.8	ug/L		8/17/2021	RHoffa

Sample Location: 8 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	103	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	6.5	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	14.6	ug/L		8/17/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-009
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	122	ug/L		8/17/2021	RHoffa
Lead	EPA 200.8	15	0.2	8.1	ug/L		8/17/2021	RHoffa
Manganese	EPA 200.8		0.2	7.6	ug/L		8/17/2021	RHoffa
Tin	EPA 200.8		0.2	3.6	ug/L		8/17/2021	RHoffa

Sample Location: 10 1406 Franklin St NE
Date Collected: 7/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108068-010
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	123	ug/L		8/19/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.5	ug/L		8/19/2021	RHoffa
Manganese	EPA 200.8		0.2	6.2	ug/L		8/19/2021	RHoffa
Tin	EPA 200.8		0.2	1.6	ug/L		8/19/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108192

Sample Location: 1 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-001
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-002
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-005
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-006
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-007
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-008
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-009
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 2204 Kalorama Rd NW
Date Collected: 8/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108192-010
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108193

Sample Location: 1 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-001
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	119	ug/L		9/2/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/2/2021	RHoffa
Manganese	EPA 200.8		0.2	6.6	ug/L		9/2/2021	RHoffa
Tin	EPA 200.8		0.2	157	ug/L		9/2/2021	RHoffa

Sample Location: 2 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-002
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	55.4	ug/L		8/31/2021	SBrooks

Sample Location: 3 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	26.3	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	33.2	ug/L		8/31/2021	SBrooks

Sample Location: 5 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-005
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.5	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	17.4	ug/L		8/31/2021	SBrooks

Sample Location: 6 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-006
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	11.2	ug/L		8/31/2021	SBrooks

Sample Location: 7 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-007
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	7.8	ug/L		8/31/2021	SBrooks

Sample Location: 8 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-008
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	8.4	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-009
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	8.5	ug/L		8/31/2021	SBrooks

Sample Location: 10 5610 Nebraska Ave NW
Date Collected: 8/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108193-010
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	8.0	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108194

Sample Location: 1 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-001
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	49.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-002
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	51.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-005
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-006
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-007
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-008
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.5	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-009
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 418 Emerson St NW
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108194-010
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.1	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108195

Sample Location: 1 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-001
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.3	ug/L		9/2/2021	RHoffa
Lead	EPA 200.8	15	0.2	5.7	ug/L		9/2/2021	RHoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		9/2/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/2/2021	RHoffa

Sample Location: 2 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-002
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-005
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-006
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-007
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-008
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-009
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 1316 45th PI SE
Date Collected: 8/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108195-010
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108196

Sample Location: 1 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-001
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	86.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-002
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.5	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-005
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	5.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-006
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.5	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-007
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-008
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-009
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 838 Delafield PI NW
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108196-010
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108197

Sample Location: 1 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-001
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-002
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-003
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-004
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-005
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-006
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-007
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.5	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-008
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-009
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 2026 Savannah PI SE
Date Collected: 8/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108197-010
Date / Time Received: 8/19/2021 8:43:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108207

Sample Location: 1 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-001
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-002
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-003
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.1	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-004
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.4	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-005
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-006
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.2	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-007
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-008
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-009
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 1409 Kearny St NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108207-010
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108208

Sample Location: 1 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-001
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	10.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-002
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-003
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.4	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	15.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-004
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-005
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-006
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.4	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	15.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-007
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-008
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-009
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 819 Farragut St. NW
Date Collected: 8/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108208-010
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	14.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108209

Sample Location: 1 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-001
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.9	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	6.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-002
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.4	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-003
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-004
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	51.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-005
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-006
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.8	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-007
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.1	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-008
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.5	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-009
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.3	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.9	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	6.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 3212 17th St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108209-010
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108210

Sample Location: 1 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-001
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-002
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-003
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-004
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-005
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-006
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	87.5	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-007
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-008
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-009
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 3916 Blaine St. NE
Date Collected: 8/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108210-010
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108211

Sample Location: 1 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-001
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-002
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-003
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-004
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-005
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-006
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-007
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-008
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-009
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 112 4th St. NE
Date Collected: 8/15/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108211-010
Date / Time Received: 8/20/2021 12:40:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108223

Sample Location: 1 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-001
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 2 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-002
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 3 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-003
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.8	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-004
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.9	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 5 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-005
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	5.1	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 6 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-006
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.6	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 7 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-007
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.7	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.5	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 8 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-008
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-009
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.0	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Sample Location: 10 1606 G St SE
Date Collected: 8/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108223-010
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.1	ug/L		8/31/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/31/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		8/31/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		8/31/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108282

Sample Location: 1 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-001
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	140	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	8.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-002
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	137	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-003
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	132	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-004
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	130	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-005
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	105	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-006
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	130	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-007
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	130	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-008
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	120	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-009
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	129	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 5020 Sherriff Rd NE
Date Collected: 8/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108282-010
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	120	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	7.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108283

Sample Location: 1 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-001
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-002
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-003
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-004
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-005
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-006
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-007
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-008
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-009
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 1363 C ST NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108283-010
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108284

Sample Location: 1 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-001
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-002
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-003
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.3	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-004
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.5	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-005
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-006
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-007
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.3	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-008
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.6	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-009
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 158 Uhland Ter NE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108284-010
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108286

Sample Location: 1 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-001
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-002
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	45.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-003
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	77.8	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-004
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.8	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-005
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-006
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-007
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-008
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-009
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 1528 5TH ST NW
Date Collected: 8/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108286-010
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2108287

Sample Location: 1 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-001
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-002
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-003
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-004
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-005
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 6 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-006
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 7 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-007
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-008
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.5	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.7	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-009
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 17 6TH ST SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108287-010
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2109015

Sample Location: 1 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-001
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	2.5	ug/L		9/9/2021	RHoffa

Sample Location: 2 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-002
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-003
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-004
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-005
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.8	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-006
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.4	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-007
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.7	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-008
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.4	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-009
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 768 Upsal St SE
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109015-010
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2109016

Sample Location: 1 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-001
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-002
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-003
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-004
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-005
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-006
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-007
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-008
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-009
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 1644 4th St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109016-010
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2109027

Sample Location: 1 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-001
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.0	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	4.5	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-002
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	4.9	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-003
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	4.9	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-004
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-005
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-006
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-007
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.4	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-008
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-009
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.6	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 2716 P ST NW
Date Collected: 8/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109027-010
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2109028

Sample Location: 1 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-001
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-002
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-003
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.3	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-004
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.3	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-005
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.6	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-006
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-007
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.4	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-008
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-009
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.3	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 5808 16TH ST NW
Date Collected: 8/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109028-010
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2109029

Sample Location: 1 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-001
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-002
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-003
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.8	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-004
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.7	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-005
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.6	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	3.0	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-006
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-007
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-008
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.1	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-009
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 4106 Jenifer St NW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109029-010
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/16/2021

Report Number: LT-DC-CCPF-2109030

Sample Location: 1 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-001
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	157	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	4.1	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-002
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.0	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-003
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-004
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-005
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.9	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-006
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-007
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-008
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-009
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 4000 1ST PL SW
Date Collected: 8/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109030-010
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	0.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2108285

Sample Location: 1 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-001
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.7	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-002
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 3 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-003
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.1	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-004
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.3	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 5 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-005
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.4	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 6 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-006
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.0	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 7 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-007
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.2	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 8 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-008
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.6	ug/L		9/29/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/29/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		9/29/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-009
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.8	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 10 613 A ST SE
Date Collected: 8/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2108285-010
Date / Time Received: 8/31/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.7	ug/L		9/9/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/9/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		9/9/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109066

Sample Location: 1 1422 E ST NE

Date Collected: 8/24/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109066-001

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.7	ug/L	H	9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.6	ug/L	H	9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	RHoffa

Sample Location: 2 1422 E ST NE

Date Collected: 8/24/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109066-002

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.5	ug/L	H	9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	3.7	ug/L	H	9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L	H	9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa

Sample Location: 3 1422 E ST NE

Date Collected: 8/24/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109066-003

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.5	ug/L	H	9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L	H	9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1422 E ST NE						Customer Program Code: CCPF			
Date Collected: 8/24/2021						Laboratory Sample Number: 2109066-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/9/2021 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	12.2	ug/L	H	9/16/2021	Rhoffa	
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	9/16/2021	Rhoffa	
Manganese	EPA 200.8		0.2	1.3	ug/L	H	9/16/2021	Rhoffa	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa	

Sample Location: 5 1422 E ST NE						Customer Program Code: CCPF			
Date Collected: 8/24/2021						Laboratory Sample Number: 2109066-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/9/2021 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	11.4	ug/L	H	9/16/2021	Rhoffa	
Lead	EPA 200.8	15	0.2	7.5	ug/L	H	9/16/2021	Rhoffa	
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/16/2021	Rhoffa	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa	

Sample Location: 6 1422 E ST NE						Customer Program Code: CCPF			
Date Collected: 8/24/2021						Laboratory Sample Number: 2109066-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/9/2021 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	13.1	ug/L	H	9/16/2021	Rhoffa	
Lead	EPA 200.8	15	0.2	6.8	ug/L	H	9/16/2021	Rhoffa	
Manganese	EPA 200.8		0.2	1.0	ug/L	H	9/16/2021	Rhoffa	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa	

Sample Location: 7 1422 E ST NE						Customer Program Code: CCPF			
Date Collected: 8/24/2021						Laboratory Sample Number: 2109066-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/9/2021 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	11.8	ug/L	H	9/16/2021	Rhoffa	
Lead	EPA 200.8	15	0.2	3.3	ug/L	H	9/16/2021	Rhoffa	
Manganese	EPA 200.8		0.2	1.4	ug/L	H	9/16/2021	Rhoffa	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa	

Sample Location: 8 1422 E ST NE						Customer Program Code: CCPF			
Date Collected: 8/24/2021						Laboratory Sample Number: 2109066-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/9/2021 8:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	14.7	ug/L	H	9/16/2021	Rhoffa	
Lead	EPA 200.8	15	0.2	3.4	ug/L	H	9/16/2021	Rhoffa	
Manganese	EPA 200.8		0.2	1.5	ug/L	H	9/16/2021	Rhoffa	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa	

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1422 E ST NE

Date Collected: 8/24/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109066-009

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.9	ug/L	H	9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.6	ug/L	H	9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa

Sample Location: 10 1422 E ST NE

Date Collected: 8/24/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109066-010

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L	H	9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.5	ug/L	H	9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L	H	9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109067

Sample Location: 1 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 2 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.6	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	2.0	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 3 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.2	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.3	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 5 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.8	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.7	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 6 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.9	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 7 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.7	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 8 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.8	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.5	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 10 1609 A ST NE
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109067-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109068

Sample Location: 1 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.6	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.7	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 2 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 3 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.3	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.7	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.8	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 6 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	3.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.2	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.4	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.8	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.1	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.1	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.1	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.2	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 902 EMERSON ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109068-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109069

Sample Location: 1 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.2	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.7	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 2 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.2	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 3 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.3	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.8	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.7	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 6 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.2	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.1	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.4	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 1531 1ST ST NW
Date Collected: 8/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109069-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.4	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109070

Sample Location: 1 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	9.7	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 2 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.3	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	10.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 3 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	11.0	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	10.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	10.0	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 6 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	9.7	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.6	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	9.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.4	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	9.1	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	9.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 1017 C ST SE
Date Collected: 8/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109070-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	9.0	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109071

Sample Location: 1 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	12.9	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 2 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 3 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.4	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.2	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.5	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.4	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 6 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.5	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 125 11th St. SE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109071-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.0	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	47.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	1.8	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109073

Sample Location: 1 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	0.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	0.5	ug/L		9/16/2021	Rhoffa

Sample Location: 2 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 3 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.1	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.2	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	50.5	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	50.3	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	5.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 6 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	49.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	4.9	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.0	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	3.5	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	50.8	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	2.0	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 181 Uhland Ter NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109073-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.5	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109074

Sample Location: 1 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.0	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 2 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.0	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 3 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.6	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.8	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 6 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.9	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.1	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.1	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.4	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 3920 HARRISON ST NW
Date Collected: 9/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109074-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.2	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.6	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3920 HARRISON ST NW

Date Collected: 9/3/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109074-009

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 3920 HARRISON ST NW

Date Collected: 9/3/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109074-010

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.1	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	4.0	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109075

Sample Location: 1 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.9	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	ND	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	1.8	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	RHoffa

Sample Location: 2 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.1	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 3 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.1	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 5 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 6 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.5	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 7 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.9	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 8 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.2	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 10 2825 39th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109075-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.7	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109112

Sample Location: 1 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 2 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 3 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.9	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 5 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.9	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 6 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.5	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 7 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 8 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.5	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.1	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 10 18 Bates St. NW
Date Collected: 9/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109112-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.6	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109113

Sample Location: 1 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	77.1	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.5	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 2 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	74.5	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 3 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.4	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.5	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 5 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.6	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 6 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.2	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 7 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.7	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 8 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.4	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.3	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.1	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 10 2916 Fessenden St. NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109113-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	80.2	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109114

Sample Location: 1 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.6	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 2 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 3 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 5 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 6 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 7 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 8 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 10 5468 31st ST NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109114-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109115

Sample Location: 1 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 2 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.7	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 3 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.4	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.3	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 5 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	3930	ug/L		9/23/2021	Sbrooks
Lead	EPA 200.8	15	2.0	27.0	ug/L		9/23/2021	Sbrooks
Manganese	EPA 200.8		0.2	87.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	2.6	ug/L		9/22/2021	Sbrooks

Sample Location: 6 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	3940	ug/L		9/23/2021	Sbrooks
Lead	EPA 200.8	15	10	174	ug/L		9/23/2021	Sbrooks
Manganese	EPA 200.8		0.2	70.7	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	8.7	ug/L		9/22/2021	Sbrooks

Sample Location: 7 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	98.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	0.3	ug/L		9/22/2021	Sbrooks

Sample Location: 8 1314 13th St. NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109115-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1314 13th St. NW

Date Collected: 9/6/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109115-009

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 10 1314 13th St. NW

Date Collected: 9/6/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109115-010

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109116

Sample Location: 1 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 2 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 3 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 5 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 6 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 7 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 8 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 10 1524 Gales St. NE
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109116-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109117

Sample Location: 1 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.1	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.8	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 2 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.8	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	0.3	ug/L		9/22/2021	Sbrooks

Sample Location: 3 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.4	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.0	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 5 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.1	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 6 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.5	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 7 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.3	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 8 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.7	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.2	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.6	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Sample Location: 10 2813 38th St. NW
Date Collected: 9/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109117-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.8	ug/L		9/22/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/22/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/22/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109118

Sample Location: 1 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	96.7	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.1	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 2 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	93.5	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.2	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 3 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	88.1	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	97.0	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.9	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 5 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	98.0	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	7.0	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 6 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	117	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	7.0	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 7 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	103	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.2	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.4	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 8 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	99.1	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.3	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	178	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.8	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.5	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Sample Location: 10 1021 Newton St. NE
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109118-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	157	ug/L		9/22/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/22/2021	SBrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		9/22/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/22/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109119

Sample Location: 1 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 2 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.3	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 3 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.6	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.0	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 6 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 7 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 8 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.4	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 1703 21st St. NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109119-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.0	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109143

Sample Location: 1 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-001
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	75.0	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 2 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-002
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.5	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 3 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-003
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	87.9	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-004
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	232	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-005
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	83.2	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 6 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-006
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.3	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 7 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-007
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.2	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 8 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-008
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	94.6	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-009
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	71.3	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 5310 Illinois Ave NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109143-010
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.5	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109144

Sample Location: 1 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-001
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	75.3	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	25.3	ug/L		9/23/2021	SBrooks

Sample Location: 2 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-002
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.8	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks

Sample Location: 3 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-003
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.3	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	2.1	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-004
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-005
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.5	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L		9/23/2021	SBrooks

Sample Location: 6 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-006
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	315	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 7 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-007
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	161	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 8 5811 32nd St NW
Date Collected: 9/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109144-008
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.1	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5811 32nd St NW

Date Collected: 9/4/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109144-009

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.8	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 5811 32nd St NW

Date Collected: 9/4/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109144-010

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.7	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	5.2	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109145

Sample Location: 1 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-001
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 2 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-002
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 3 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-003
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-004
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-005
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 6 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-006
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 7 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-007
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 8 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-008
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-009
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 2329 20th St NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109145-010
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109146

Sample Location: 1 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-001
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 2 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-002
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 3 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-003
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-004
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-005
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 6 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-006
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 7 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-007
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 8 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-008
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-009
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 2005 Massachusetts Ave NW
Date Collected: 9/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109146-010
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109148

Sample Location: 1 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-001
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 2 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-002
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 3 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-003
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-004
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-005
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 6 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-006
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 7 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-007
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 8 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-008
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-009
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 318 14th PI NE
Date Collected: 9/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109148-010
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109149

Sample Location: 1 1032 Newton St NE

Date Collected: 5/29/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109149-001

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.5	ug/L	H	9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L	H	9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks

Sample Location: 2 1032 Newton St NE

Date Collected: 5/29/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109149-002

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.7	ug/L	H	9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.8	ug/L	H	9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks

Sample Location: 3 1032 Newton St NE

Date Collected: 5/29/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109149-003

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.5	ug/L	H	9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L	H	9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1032 Newton St NE						Customer Program Code: CCPF			
Date Collected: 5/29/2021						Laboratory Sample Number: 2109149-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/15/2021 9:00:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	22.0	ug/L	H	9/23/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/23/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.7	ug/L	H	9/23/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks	

Sample Location: 5 1032 Newton St NE						Customer Program Code: CCPF			
Date Collected: 5/29/2021						Laboratory Sample Number: 2109149-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/15/2021 9:00:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	20.9	ug/L	H	9/23/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/23/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.7	ug/L	H	9/23/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks	

Sample Location: 6 1032 Newton St NE						Customer Program Code: CCPF			
Date Collected: 5/29/2021						Laboratory Sample Number: 2109149-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/15/2021 9:00:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	20.3	ug/L	H	9/23/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/23/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.5	ug/L	H	9/23/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks	

Sample Location: 7 1032 Newton St NE						Customer Program Code: CCPF			
Date Collected: 5/29/2021						Laboratory Sample Number: 2109149-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/15/2021 9:00:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	20.3	ug/L	H	9/23/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/23/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.5	ug/L	H	9/23/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks	

Sample Location: 8 1032 Newton St NE						Customer Program Code: CCPF			
Date Collected: 5/29/2021						Laboratory Sample Number: 2109149-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/15/2021 9:00:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	19.9	ug/L	H	9/23/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/23/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.5	ug/L	H	9/23/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 1032 Newton St NE **Customer Program Code:** CCPF
Date Collected: 5/29/2021 **Laboratory Sample Number:** 2109149-009
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.3	ug/L	H	9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L	H	9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks

Sample Location: 10 1032 Newton St NE **Customer Program Code:** CCPF
Date Collected: 5/29/2021 **Laboratory Sample Number:** 2109149-010
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.0	ug/L	H	9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L	H	9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/23/2021	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: LT-DC-CCPF-2109150

Sample Location: 1 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-001
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.3	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	20.2	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	16.5	ug/L		9/23/2021	SBrooks

Sample Location: 2 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-002
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.2	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	0.5	ug/L		9/23/2021	SBrooks

Sample Location: 3 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-003
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.6	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-004
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.4	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 5 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-005
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 6 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-006
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.8	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	8.1	ug/L		9/23/2021	SBrooks

Sample Location: 7 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-007
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	6.4	ug/L		9/23/2021	SBrooks

Sample Location: 8 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-008
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-009
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.2	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Sample Location: 10 1667 32nd St. NW
Date Collected: 9/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109150-010
Date / Time Received: 9/16/2021 11:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.0	ug/L		9/23/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/23/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/23/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/23/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109072

Sample Location: 1 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	1090	ug/L		9/29/2021	SBrooks
Lead	EPA 200.8	15	0.2	11.7	ug/L		9/29/2021	SBrooks
Manganese	EPA 200.8		0.2	15.4	ug/L		9/29/2021	SBrooks
Tin	EPA 200.8		0.2	1.1	ug/L		9/29/2021	SBrooks

Sample Location: 2 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		50	727	ug/L		9/16/2021	RHoffa
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/16/2021	RHoffa
Manganese	EPA 200.8		0.2	10.7	ug/L		9/16/2021	RHoffa
Tin	EPA 200.8		0.2	3.4	ug/L		9/16/2021	RHoffa

Sample Location: 3 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	302	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	5.5	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	0.2	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	183	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 5 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	203	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	0.3	ug/L		9/16/2021	Rhoffa

Sample Location: 6 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-006
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	166	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.2	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 7 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-007
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	135	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.9	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 8 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-008
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	126	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	3.0	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-009
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.7	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.3	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Sample Location: 10 429 19TH ST NE
Date Collected: 9/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109072-010
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.8	ug/L		9/16/2021	Rhoffa
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/16/2021	Rhoffa
Manganese	EPA 200.8		0.2	2.2	ug/L		9/16/2021	Rhoffa
Tin	EPA 200.8		0.2	ND	ug/L		9/16/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109183

Sample Location: 1 2802 13th St NE

Date Collected: 8/31/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109183-001

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	0.2	ug/L	H	9/30/2021	Sbrooks

Sample Location: 2 2802 13th St NE

Date Collected: 8/31/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109183-002

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.3	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 3 2802 13th St NE

Date Collected: 8/31/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109183-003

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.2	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.4	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2802 13th St NE						Customer Program Code: CCPF			
Date Collected: 8/31/2021						Laboratory Sample Number: 2109183-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 5 2802 13th St NE						Customer Program Code: CCPF			
Date Collected: 8/31/2021						Laboratory Sample Number: 2109183-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 6 2802 13th St NE						Customer Program Code: CCPF			
Date Collected: 8/31/2021						Laboratory Sample Number: 2109183-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	2.6	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	0.3	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 7 2802 13th St NE						Customer Program Code: CCPF			
Date Collected: 8/31/2021						Laboratory Sample Number: 2109183-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	3.8	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	0.9	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	0.3	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 8 2802 13th St NE						Customer Program Code: CCPF			
Date Collected: 8/31/2021						Laboratory Sample Number: 2109183-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	9.1	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks	

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2802 13th St NE

Date Collected: 8/31/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109183-009

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.7	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	9.0	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 10 2802 13th St NE

Date Collected: 8/31/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109183-010

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	8.0	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109184

Sample Location: 1 3661 Alabama Ave SE

Date Collected: 9/5/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109184-001

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.0	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.5	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 2 3661 Alabama Ave SE

Date Collected: 9/5/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109184-002

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.9	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.2	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 3 3661 Alabama Ave SE

Date Collected: 9/5/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109184-003

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.2	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.1	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 3661 Alabama Ave SE						Customer Program Code: CCPF			
Date Collected: 9/5/2021						Laboratory Sample Number: 2109184-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	40.7	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	2.3	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 5 3661 Alabama Ave SE						Customer Program Code: CCPF			
Date Collected: 9/5/2021						Laboratory Sample Number: 2109184-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	45.0	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	2.4	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 6 3661 Alabama Ave SE						Customer Program Code: CCPF			
Date Collected: 9/5/2021						Laboratory Sample Number: 2109184-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	48.9	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	2.9	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 7 3661 Alabama Ave SE						Customer Program Code: CCPF			
Date Collected: 9/5/2021						Laboratory Sample Number: 2109184-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	51.5	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	2.9	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 8 3661 Alabama Ave SE						Customer Program Code: CCPF			
Date Collected: 9/5/2021						Laboratory Sample Number: 2109184-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/21/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	49.4	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	2.8	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 3661 Alabama Ave SE **Customer Program Code:** CCPF
Date Collected: 9/5/2021 **Laboratory Sample Number:** 2109184-009
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.1	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.9	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 10 3661 Alabama Ave SE **Customer Program Code:** CCPF
Date Collected: 9/5/2021 **Laboratory Sample Number:** 2109184-010
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.3	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.9	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109185

Sample Location: 1 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	182	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.0	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	4.1	ug/L		9/30/2021	Sbrooks

Sample Location: 2 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	76.7	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	4.4	ug/L		9/30/2021	Sbrooks

Sample Location: 3 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.7	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	0.5	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 5 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 6 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 7 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 8 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.3	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	2.9	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	0.9	ug/L		9/30/2021	Sbrooks

Sample Location: 10 2911 M St NW
Date Collected: 9/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109185-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.3	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	2.3	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109186

Sample Location: 1 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	98.5	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 2 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	83.3	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 3 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	93.6	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	97.3	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 5 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.2	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 6 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	92.3	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 7 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.1	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 8 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	82.9	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.0	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 10 4114 Ingomar St. NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109186-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.2	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109187

Sample Location: 1 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.8	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.2	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.2	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.5	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.6	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.4	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 3642 Park PL NW
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109187-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.2	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109188

Sample Location: 1 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 1834 Capitol Ave NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109188-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.7	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109189

Sample Location: 1 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.6	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	1.9	ug/L		9/30/2021	SBrooks

Sample Location: 2 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.8	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.0	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	3.4	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.7	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.3	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	6.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	58.4	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.3	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	6.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 5025 Glenbrook Ter NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109189-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.3	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5025 Glenbrook Ter NW

Date Collected: 9/16/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109189-009

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	54.2	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 5025 Glenbrook Ter NW

Date Collected: 9/16/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109189-010

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.8	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109190

Sample Location: 1 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.6	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.7	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	72.1	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.5	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.2	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.8	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	5.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	74.2	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	72.7	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	7.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	89.7	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	7.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 4901 43rd PI NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109190-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	227	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	7.4	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109191

Sample Location: 1 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 712 Upshur St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109191-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109196

Sample Location: 1 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-001
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.8	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	17.6	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 2 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-002
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	96.0	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	18.5	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 3 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-003
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	136	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	19.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-004
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	273	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	20.3	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 5 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-005
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	257	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	20.4	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 6 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-006
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	343	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	20.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 7 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-007
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	236	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	21.0	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 8 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-008
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	207	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	20.6	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-009
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	205	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	20.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 10 4615 43rd St NW
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109196-010
Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	272	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	19.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109206

Sample Location: 1 1008 W St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109206-001

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 2 1008 W St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109206-002

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 3 1008 W St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109206-003

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1008 W St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2109206-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 5 1008 W St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2109206-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 6 1008 W St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2109206-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 7 1008 W St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2109206-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 8 1008 W St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2109206-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 1008 W St NW **Customer Program Code:** CCPF
Date Collected: 9/3/2021 **Laboratory Sample Number:** 2109206-009
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 10 1008 W St NW **Customer Program Code:** CCPF
Date Collected: 9/3/2021 **Laboratory Sample Number:** 2109206-010
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109207

Sample Location: 1 1729 Upshur St NW

Date Collected: 9/7/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109207-001

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks

Sample Location: 2 1729 Upshur St NW

Date Collected: 9/7/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109207-002

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.4	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	2.5	ug/L	H	9/30/2021	Sbrooks

Sample Location: 3 1729 Upshur St NW

Date Collected: 9/7/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109207-003

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	27.0	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1729 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109207-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 5 1729 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109207-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	0.9	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 6 1729 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109207-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	35.3	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.3	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	0.7	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 7 1729 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109207-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	1.6	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 8 1729 Upshur St NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109207-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	1.0	ug/L	H	9/30/2021	Sbrooks	

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1729 Upshur St NW **Customer Program Code:** CCPF
Date Collected: 9/7/2021 **Laboratory Sample Number:** 2109207-009
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	1.2	ug/L	H	9/30/2021	Sbrooks

Sample Location: 10 1729 Upshur St NW **Customer Program Code:** CCPF
Date Collected: 9/7/2021 **Laboratory Sample Number:** 2109207-010
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	0.4	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109208

Sample Location: 1 1360 Madison St. NW

Date Collected: 9/7/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109208-001

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.9	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.7	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 2 1360 Madison St. NW

Date Collected: 9/7/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109208-002

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	72.8	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	7.2	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 3 1360 Madison St. NW

Date Collected: 9/7/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2109208-003

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.2	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	7.0	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1360 Madison St. NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109208-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	67.6	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	6.8	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 5 1360 Madison St. NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109208-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	65.9	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	6.9	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 6 1360 Madison St. NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109208-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	66.5	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.8	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	7.0	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 7 1360 Madison St. NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109208-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	53.3	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	14.6	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Sample Location: 8 1360 Madison St. NW						Customer Program Code: CCPF			
Date Collected: 9/7/2021						Laboratory Sample Number: 2109208-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 9/22/2021 8:50:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	64.0	ug/L	H	9/30/2021	Sbrooks	
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	9/30/2021	Sbrooks	
Manganese	EPA 200.8		0.2	6.8	ug/L	H	9/30/2021	Sbrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks	

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 1360 Madison St. NW **Customer Program Code:** CCPF
Date Collected: 9/7/2021 **Laboratory Sample Number:** 2109208-009
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.5	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	7.3	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Sample Location: 10 1360 Madison St. NW **Customer Program Code:** CCPF
Date Collected: 9/7/2021 **Laboratory Sample Number:** 2109208-010
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.9	ug/L	H	9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	7.1	ug/L	H	9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	9/30/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109209

Sample Location: 1 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-001
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 2 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-002
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 3 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-003
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-004
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 5 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-005
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 6 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-006
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 7 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-007
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 8 5206 14th St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109209-008
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5206 14th St NW

Date Collected: 9/11/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109209-009

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 10 5206 14th St NW

Date Collected: 9/11/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109209-010

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109210

Sample Location: 1 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-001
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 2 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-002
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 3 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-003
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-004
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 5 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-005
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 6 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-006
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 7 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-007
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 8 75 R St NW
Date Collected: 9/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109210-008
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 75 R St NW

Date Collected: 9/11/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109210-009

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Sample Location: 10 75 R St NW

Date Collected: 9/11/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109210-010

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/30/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109211

Sample Location: 1 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-001
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-002
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-003
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-004
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-005
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-006
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-007
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 141 Kentucky Ave SE
Date Collected: 9/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109211-008
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 141 Kentucky Ave SE

Date Collected: 9/14/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109211-009

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 141 Kentucky Ave SE

Date Collected: 9/14/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2109211-010

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109212

Sample Location: 1 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-001
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	1.5	ug/L		9/30/2021	SBrooks

Sample Location: 2 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-002
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-003
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-004
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-005
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-006
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-007
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-008
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-009
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 12 3rd St NE
Date Collected: 9/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109212-010
Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109231

Sample Location: 1 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-001
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-002
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-003
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-004
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-007
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-008
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-009
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 13 4th St. NE
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109231-010
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	82.7	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109232

Sample Location: 1 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-001
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-002
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-003
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-004
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-007
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-008
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-009
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 2232 Observatory PL NW
Date Collected: 9/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109232-010
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	2.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109233

Sample Location: 1 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-001
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-002
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-003
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-004
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-007
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-008
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-009
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 1685 32ND ST NW
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109233-010
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109234

Sample Location: 1 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-001
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	75.4	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-002
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.3	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-003
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.0	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-004
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	100	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	93.3	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.9	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-007
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.9	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-008
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.6	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-009
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.0	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 2211 Branch Ave SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109234-010
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.8	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109246

Sample Location: 1 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-001
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-002
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-003
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-004
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-007
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-008
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-009
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 225 5th St. SE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109246-010
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/21/2021

Report Number: LT-DC-CCPF-2109247

Sample Location: 1 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-001
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 2 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-002
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 3 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-003
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-004
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 5 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 6 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 7 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-007
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 8 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-008
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-009
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Sample Location: 10 1610 Otis St. NE
Date Collected: 9/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2109247-010
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		9/30/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		9/30/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		9/30/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		9/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110036

Sample Location: 1 5040 12th St NE

Date Collected: 9/18/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110036-001

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.1	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	0.3	ug/L	H	10/19/2021	SBrooks

Sample Location: 2 5040 12th St NE

Date Collected: 9/18/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110036-002

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.8	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 3 5040 12th St NE

Date Collected: 9/18/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110036-003

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.7	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 5040 12th St NE						Customer Program Code: CCPF			
Date Collected: 9/18/2021						Laboratory Sample Number: 2110036-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	40.8	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	2.1	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 5 5040 12th St NE						Customer Program Code: CCPF			
Date Collected: 9/18/2021						Laboratory Sample Number: 2110036-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	41.6	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.9	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 6 5040 12th St NE						Customer Program Code: CCPF			
Date Collected: 9/18/2021						Laboratory Sample Number: 2110036-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	39.5	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 7 5040 12th St NE						Customer Program Code: CCPF			
Date Collected: 9/18/2021						Laboratory Sample Number: 2110036-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	36.4	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 8 5040 12th St NE						Customer Program Code: CCPF			
Date Collected: 9/18/2021						Laboratory Sample Number: 2110036-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	38.2	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 5040 12th St NE

Date Collected: 9/18/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110036-009

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.5	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 10 5040 12th St NE

Date Collected: 9/18/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110036-010

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.1	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110037

Sample Location: 1 3312 22nd St NE

Date Collected: 9/19/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110037-001

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	165	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	5.2	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 2 3312 22nd St NE

Date Collected: 9/19/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110037-002

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	165	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	5.2	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 3 3312 22nd St NE

Date Collected: 9/19/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110037-003

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	181	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 3312 22nd St NE						Customer Program Code: CCPF			
Date Collected: 9/19/2021						Laboratory Sample Number: 2110037-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	247	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	4.3	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 5 3312 22nd St NE						Customer Program Code: CCPF			
Date Collected: 9/19/2021						Laboratory Sample Number: 2110037-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	229	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	3.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 6 3312 22nd St NE						Customer Program Code: CCPF			
Date Collected: 9/19/2021						Laboratory Sample Number: 2110037-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	165	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	5.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 7 3312 22nd St NE						Customer Program Code: CCPF			
Date Collected: 9/19/2021						Laboratory Sample Number: 2110037-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	166	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	5.3	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 8 3312 22nd St NE						Customer Program Code: CCPF			
Date Collected: 9/19/2021						Laboratory Sample Number: 2110037-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/5/2021 11:45:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	165	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	5.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3312 22nd St NE

Date Collected: 9/19/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110037-009

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	160	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	5.2	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 10 3312 22nd St NE

Date Collected: 9/19/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110037-010

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	156	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110038

Sample Location: 1 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-001
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-002
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.7	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-003
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-004
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.9	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks

Sample Location: 5 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-005
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.7	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-006
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.9	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-007
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.7	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 117 5th St. SE
Date Collected: 9/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110038-008
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 117 5th St. SE

Date Collected: 9/21/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2110038-009

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 117 5th St. SE

Date Collected: 9/21/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2110038-010

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110039

Sample Location: 1 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-001
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-002
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-003
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-004
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-005
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-006
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-007
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-008
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-009
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 3648 13th St NW
Date Collected: 9/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110039-010
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110040

Sample Location: 1 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-001
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-002
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-003
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-004
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-005
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-006
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-007
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-008
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-009
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 23 6th St. NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110040-010
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110041

Sample Location: 1 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-001
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		10/19/2021	SBrooks

Sample Location: 2 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-002
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-003
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-004
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-005
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-006
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-007
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-008
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-009
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.0	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 117 4th St NE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110041-010
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.0	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110042

Sample Location: 1 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-001
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-002
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.0	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-003
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-004
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.6	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-005
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.8	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-006
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.1	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-007
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.6	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-008
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.3	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-009
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.0	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 3424 17th St. NW
Date Collected: 9/27/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110042-010
Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.9	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110050

Sample Location: 1 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-001
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-002
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-003
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.8	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-004
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-005
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.3	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-006
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.0	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-007
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-008
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-009
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 1334 13th St NW
Date Collected: 10/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110050-010
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.8	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110051

Sample Location: 1 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-001
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	220	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	12.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-002
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	174	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	11.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-003
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	169	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	11.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-004
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	156	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	11.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-005
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	151	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	11.9	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-006
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	162	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	12.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-007
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	165	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	12.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-008
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	176	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	13.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-009
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	170	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	14.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 6817 Laurel St NW
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110051-010
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	176	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	14.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110052

Sample Location: 1 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-001
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-002
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-003
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-004
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-005
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-006
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-007
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-008
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-009
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 1057 5th St SE
Date Collected: 9/24/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110052-010
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110053

Sample Location: 1 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-001
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-002
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-003
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-004
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-005
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-006
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-007
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-008
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-009
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 641 East Capitol St SE
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110053-010
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110054

Sample Location: 1 1538 34th St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110054-001

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.2	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 2 1538 34th St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110054-002

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.1	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 3 1538 34th St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110054-003

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.9	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1538 34th St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2110054-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/7/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	46.3	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	3.1	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.7	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 5 1538 34th St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2110054-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/7/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	24.6	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 6 1538 34th St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2110054-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/7/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	23.6	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	1.4	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.4	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 7 1538 34th St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2110054-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/7/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	19.8	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Sample Location: 8 1538 34th St NW						Customer Program Code: CCPF			
Date Collected: 9/3/2021						Laboratory Sample Number: 2110054-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/7/2021 8:35:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	17.7	ug/L	H	10/19/2021	SBrooks	
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	10/19/2021	SBrooks	
Manganese	EPA 200.8		0.2	1.1	ug/L	H	10/19/2021	SBrooks	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks	

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1538 34th St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110054-009

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.8	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 10 1538 34th St NW

Date Collected: 9/3/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110054-010

Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110055

Sample Location: 1 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-001
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	1820	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	16.3	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks

Sample Location: 2 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-002
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	132	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-003
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	218	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-004
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	289	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-005
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	341	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-006
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	321	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-007
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	313	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-008
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	335	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-009
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	329	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 1413 17th St NW
Date Collected: 9/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110055-010
Date / Time Received: 10/7/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	334	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110066

Sample Location: 1 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-001
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	333	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-002
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	299	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-003
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	314	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-004
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	86.6	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	9.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-005
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	309	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-006
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	302	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-007
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	299	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.0	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-008
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	300	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.8	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	9.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-009
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	283	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.7	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	9.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 1340 29TH St NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110066-010
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	317	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	10.1	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110067

Sample Location: 1 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-001
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.7	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-002
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.7	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-003
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-004
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.1	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-005
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.3	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-006
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.9	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-007
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.8	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.7	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-008
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.7	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	4.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-009
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.2	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 308 Emerson St. NW
Date Collected: 9/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110067-010
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.1	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110069

Sample Location: 1 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-001
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 2 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-002
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 3 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-003
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-004
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 5 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-005
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 6 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-006
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 7 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-007
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 8 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-008
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-009
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Sample Location: 10 737 18th St. NE
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110069-010
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.2	ug/L		10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/28/2021

Report Number: LT-DC-CCPF-2110107

Sample Location: 1 1237 Wylie St. NE

Date Collected: 9/12/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110107-001

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.4	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 2 1237 Wylie St. NE

Date Collected: 9/12/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110107-002

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.6	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 3 1237 Wylie St. NE

Date Collected: 9/12/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110107-003

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.1	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1237 Wylie St. NE **Customer Program Code:** CCPF
Date Collected: 9/12/2021 **Laboratory Sample Number:** 2110107-004
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.8	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 5 1237 Wylie St. NE **Customer Program Code:** CCPF
Date Collected: 9/12/2021 **Laboratory Sample Number:** 2110107-005
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.9	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 6 1237 Wylie St. NE **Customer Program Code:** CCPF
Date Collected: 9/12/2021 **Laboratory Sample Number:** 2110107-006
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.4	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 7 1237 Wylie St. NE **Customer Program Code:** CCPF
Date Collected: 9/12/2021 **Laboratory Sample Number:** 2110107-007
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.8	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 8 1237 Wylie St. NE **Customer Program Code:** CCPF
Date Collected: 9/12/2021 **Laboratory Sample Number:** 2110107-008
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 1237 Wylie St. NE

Date Collected: 9/12/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110107-009

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Sample Location: 10 1237 Wylie St. NE

Date Collected: 9/12/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110107-010

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.5	ug/L	H	10/19/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/19/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L	H	10/19/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	10/19/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110157

Sample Location: 1 3524 Edmonds St NW

Date Collected: 9/16/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110157-001

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.7	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.3	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.4	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 2 3524 Edmonds St NW

Date Collected: 9/16/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110157-002

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.6	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	28.0	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.3	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 3 3524 Edmonds St NW

Date Collected: 9/16/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110157-003

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.6	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.4	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-004
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 5 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-005
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.8	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.9	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.1	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 6 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-006
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.7	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 7 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-007
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.7	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 8 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-008
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.2	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-009
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.1	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.4	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 10 3524 Edmonds St NW **Customer Program Code:** CCPF
Date Collected: 9/16/2021 **Laboratory Sample Number:** 2110157-010
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.9	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110158

Sample Location: 1 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-001
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.8	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.9	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-002
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-003
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.8	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-004
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-005
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-006
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-007
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.9	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-008
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.8	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-009
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 901 K St NE
Date Collected: 10/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110158-010
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110159

Sample Location: 1 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-001
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-002
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-003
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-004
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-005
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	71.1	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-006
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	69.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-007
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	65.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 1011 S Carolina Ave SE
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110159-008
Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1011 S Carolina Ave SE

Date Collected: 10/14/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2110159-009

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.8	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 1011 S Carolina Ave SE

Date Collected: 10/14/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2110159-010

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	72.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	6.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110160

Sample Location: 1 630 Emerson St NW

Date Collected: 9/22/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. Sample was diluted to 2X.

Customer Program Code: CCPF

Laboratory Sample Number: 2110160-001

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	139	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	7.6	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 2 630 Emerson St NW

Date Collected: 9/22/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110160-002

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.1	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 3 630 Emerson St NW

Date Collected: 9/22/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110160-003

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.1	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.7	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 630 Emerson St NW						Customer Program Code: CCPF			
Date Collected: 9/22/2021						Laboratory Sample Number: 2110160-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/20/2021 8:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	88.2	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	3.0	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 5 630 Emerson St NW						Customer Program Code: CCPF			
Date Collected: 9/22/2021						Laboratory Sample Number: 2110160-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/20/2021 8:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	43.2	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	0.7	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	2.7	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 6 630 Emerson St NW						Customer Program Code: CCPF			
Date Collected: 9/22/2021						Laboratory Sample Number: 2110160-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/20/2021 8:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	23.9	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	3.0	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 7 630 Emerson St NW						Customer Program Code: CCPF			
Date Collected: 9/22/2021						Laboratory Sample Number: 2110160-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/20/2021 8:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	18.6	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	3.1	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	3.1	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 8 630 Emerson St NW						Customer Program Code: CCPF			
Date Collected: 9/22/2021						Laboratory Sample Number: 2110160-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/20/2021 8:57:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	17.4	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	2.2	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	3.0	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 630 Emerson St NW

Date Collected: 9/22/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110160-009

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.9	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.8	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.0	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 10 630 Emerson St NW

Date Collected: 9/22/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110160-010

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.1	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.1	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110176

Sample Location: 1 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-001
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.6	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-002
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.5	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-003
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-004
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-007
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.5	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-008
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-009
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 1660 FORT DAVIS ST SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110176-010
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.5	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110177

Sample Location: 1 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-001
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-002
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-003
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-004
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.6	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-007
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-008
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-009
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 20 5TH St SE
Date Collected: 10/12/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110177-010
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110180

Sample Location: 1 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-001
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-002
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-003
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.5	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-004
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.1	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-007
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-008
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.8	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-009
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 420 SOUTH CAPITOL ST SE
Date Collected: 10/17/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110180-010
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110181

Sample Location: 1 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-001
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.9	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-002
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-003
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-004
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-007
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-008
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-009
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 4213 8TH ST NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110181-010
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110187

Sample Location: 1 4545 28th St NW

Date Collected: 9/21/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110187-001

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	112	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.7	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.2	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 2 4545 28th St NW

Date Collected: 9/21/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110187-002

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	120	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.9	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 3 4545 28th St NW

Date Collected: 9/21/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110187-003

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	118	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.9	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4545 28th St NW **Customer Program Code:** CCPF
Date Collected: 9/21/2021 **Laboratory Sample Number:** 2110187-004
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	124	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.9	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 5 4545 28th St NW **Customer Program Code:** CCPF
Date Collected: 9/21/2021 **Laboratory Sample Number:** 2110187-005
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	172	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.9	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 6 4545 28th St NW **Customer Program Code:** CCPF
Date Collected: 9/21/2021 **Laboratory Sample Number:** 2110187-006
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	182	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	9.1	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 7 4545 28th St NW **Customer Program Code:** CCPF
Date Collected: 9/21/2021 **Laboratory Sample Number:** 2110187-007
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	171	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.8	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 8 4545 28th St NW **Customer Program Code:** CCPF
Date Collected: 9/21/2021 **Laboratory Sample Number:** 2110187-008
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	148	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.4	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 4545 28th St NW

Date Collected: 9/21/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110187-009

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	147	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.4	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 10 4545 28th St NW

Date Collected: 9/21/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110187-010

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	152	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	8.4	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110188

Sample Location: 1 5341 42nd St NW

Date Collected: 9/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110188-001

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	1.7	ug/L	H	10/27/2021	Rlamsal

Sample Location: 2 5341 42nd St NW

Date Collected: 9/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110188-002

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.3	ug/L	H	10/27/2021	Rlamsal

Sample Location: 3 5341 42nd St NW

Date Collected: 9/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110188-003

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.5	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 5341 42nd St NW						Customer Program Code: CCPF			
Date Collected: 9/28/2021						Laboratory Sample Number: 2110188-004			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/13/2021 9:49:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	12.4	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 5 5341 42nd St NW						Customer Program Code: CCPF			
Date Collected: 9/28/2021						Laboratory Sample Number: 2110188-005			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/13/2021 9:49:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	16.0	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	1.3	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 6 5341 42nd St NW						Customer Program Code: CCPF			
Date Collected: 9/28/2021						Laboratory Sample Number: 2110188-006			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/13/2021 9:49:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	13.6	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	1.2	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 7 5341 42nd St NW						Customer Program Code: CCPF			
Date Collected: 9/28/2021						Laboratory Sample Number: 2110188-007			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/13/2021 9:49:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	17.2	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	1.3	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Sample Location: 8 5341 42nd St NW						Customer Program Code: CCPF			
Date Collected: 9/28/2021						Laboratory Sample Number: 2110188-008			
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.						Date / Time Received: 10/13/2021 9:49:00 AM			
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst	
Iron	EPA 200.8		10	16.3	ug/L	H	10/27/2021	Rlamsal	
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal	
Manganese	EPA 200.8		0.2	1.4	ug/L	H	10/27/2021	Rlamsal	
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal	

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5341 42nd St NW

Date Collected: 9/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110188-009

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.8	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.3	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Sample Location: 10 5341 42nd St NW

Date Collected: 9/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2110188-010

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.0	ug/L	H	10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.3	ug/L	H	10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L	H	10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110189

Sample Location: 1 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-001
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-002
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.7	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-003
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-004
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.6	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.8	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-005
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.6	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.8	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	4.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-006
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	4.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-007
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	4.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-008
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	4.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-009
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.5	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.9	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 4115 3rd St NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110189-010
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110190

Sample Location: 1 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-001
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	4.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	3.3	ug/L		10/27/2021	Rlamsal

Sample Location: 2 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-002
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal

Sample Location: 3 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-003
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-004
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.4	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-005
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-006
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-007
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-008
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-009
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 3719 R St. NW
Date Collected: 10/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110190-010
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110194

Sample Location: 1 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-001
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-002
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-003
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.1	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-004
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.1	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-005
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-006
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-007
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-008
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-009
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.6	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 1220 Allison St. NE
Date Collected: 10/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110194-010
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.1	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110195

Sample Location: 1 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-001
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-002
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-003
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	1.3	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-004
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal

Sample Location: 5 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-005
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-006
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-007
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-008
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-009
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 1317 33rd St. NW
Date Collected: 10/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110195-010
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110196

Sample Location: 1 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-001
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	188	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	5.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	3.8	ug/L		10/27/2021	Rlamsal

Sample Location: 2 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-002
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.8	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-003
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	45.9	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.1	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-004
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-005
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.3	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-006
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.1	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-007
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-008
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.6	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-009
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.0	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 3021 45th St. NW
Date Collected: 10/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110196-010
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.7	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/10/2021

Report Number: LT-DC-CCPF-2110203

Sample Location: 1 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-001
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-002
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.2	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	13.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	2.8	ug/L		10/27/2021	Rlamsal

Sample Location: 3 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-003
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.9	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.6	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-004
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-005
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal

Sample Location: 6 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-006
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-007
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-008
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-009
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.7	ug/L		10/27/2021	Rlamsal

Sample Location: 10 1531 33rd St. NW
Date Collected: 10/19/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110203-010
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.0	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110178

Sample Location: 1 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-001
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 2 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-002
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 3 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-003
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-004
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 5 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 6 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 7 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-007
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-008
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-009
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 443 Oakwood St. SE
Date Collected: 10/13/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110178-010
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110179

Sample Location: 1 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-001
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-002
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-003
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-004
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.2	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-007
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 8 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-008
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-009
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Sample Location: 10 3410 DENT PL NW
Date Collected: 10/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110179-010
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		10/27/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		10/27/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.2	ug/L		10/27/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		10/27/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110240

Sample Location: 1 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	3.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	1.7	ug/L		11/10/2021	Lgallimore

Sample Location: 2 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.7	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-003
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-004
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.9	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.7	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.1	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.2	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 2737 O St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110240-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.1	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110241

Sample Location: 1 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.2	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	3.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	3.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-003
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	3.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-004
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.2	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.2	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.1	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.1	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.1	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.2	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 857 Van Buren St. SE
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110241-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110242

Sample Location: 4501 Cathedral Ave NW
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110242-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	14.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110242-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.7	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	14.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110242-003
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	60.2	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	14.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4501 Cathedral Ave NW **Customer Program Code:** CCPF
Date Collected: 10/20/2021 **Laboratory Sample Number:** 2110242-004
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	14.1	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW **Customer Program Code:** CCPF
Date Collected: 10/20/2021 **Laboratory Sample Number:** 2110242-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	64.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	13.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW **Customer Program Code:** CCPF
Date Collected: 10/20/2021 **Laboratory Sample Number:** 2110242-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	13.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW **Customer Program Code:** CCPF
Date Collected: 10/20/2021 **Laboratory Sample Number:** 2110242-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	76.1	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	13.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW **Customer Program Code:** CCPF
Date Collected: 10/20/2021 **Laboratory Sample Number:** 2110242-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	13.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:
 ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 4501 Cathedral Ave NW
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110242-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	71.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	13.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 4501 Cathedral Ave NW
Date Collected: 10/20/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110242-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	13.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110243

Sample Location: 1 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-003
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-004
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 1503 G St. SE
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110243-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110244

Sample Location: 1 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	118	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.0	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	17.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	128	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	18.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-003
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	127	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	18.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-004
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	105	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	18.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	102	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	18.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	98.1	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	18.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	92.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	17.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	93.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	18.1	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	92.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	17.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 3658 Park PI NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110244-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	92.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	17.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110245

Sample Location: 1 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-003
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-004
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 4110 Military Rd NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110245-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110255

Sample Location: 1 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-001
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-002
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-003
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-004
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-005
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-006
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-007
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-008
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-009
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 3822 Gramercy St. NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110255-010
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110256

Sample Location: 1 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-001
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-002
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-003
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-004
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-005
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-006
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-007
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-008
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-009
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 717 10th St NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110256-010
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.2	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110257

Sample Location: 1 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-001
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-002
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-003
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-004
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-005
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.1	ug/L		11/10/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	LGallimore
Manganese	EPA 200.8		0.2	1.7	ug/L		11/10/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	LGallimore

Sample Location: 6 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-006
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.0	ug/L		11/10/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	LGallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	LGallimore

Sample Location: 7 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-007
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.5	ug/L		11/10/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	LGallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	LGallimore

Sample Location: 8 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-008
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.8	ug/L		11/10/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	LGallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-009
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.7	ug/L		11/10/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	LGallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	LGallimore

Sample Location: 10 4827 South Dakota Ave NE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110257-010
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.9	ug/L		11/10/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	LGallimore
Manganese	EPA 200.8		0.2	1.4	ug/L		11/10/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110258

Sample Location: 1 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-001
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-002
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-003
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.3	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-004
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-005
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-006
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-007
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-008
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-009
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 221 Gallatin St. NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110258-010
Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.0	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110261

Sample Location: 1 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-001
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-002
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-003
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-004
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-005
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.1	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-006
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	2.5	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-009
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 831 Allison St. NW
Date Collected: 10/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110261-010
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110262

Sample Location: 1 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-001
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.5	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	4.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-002
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	4.1	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-003
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.8	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	3.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-004
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-005
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.9	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-006
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.9	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.4	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-009
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.6	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.0	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 4113 Ingomar St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110262-010
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.2	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.9	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110263

Sample Location: 1 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-001
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-002
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-003
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.6	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-004
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-005
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-006
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-009
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	2.2	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 2018 37th St NW
Date Collected: 10/21/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110263-010
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.1	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110264

Sample Location: 1 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-001
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 2 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-002
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 3 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-003
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-004
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 5 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-005
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 6 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-006
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 7 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 8 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-009
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Sample Location: 10 640 North Carolina Ave SE
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110264-010
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/10/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/10/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/10/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/10/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110265

Sample Location: 1 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-001
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-002
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-003
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-004
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.2	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-005
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-006
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.2	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-009
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 612 C St SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110265-010
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.7	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110266

Sample Location: 1 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-001
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-002
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-003
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-004
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-005
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-006
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-009
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 1105 South Carolina Ave SE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110266-010
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.8	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110273

Sample Location: 1 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-001
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-002
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-003
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-004
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-005
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-006
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-007
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.7	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	2.2	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-008
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.5	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-009
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 427 4th St. NE
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110273-010
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2110274

Sample Location: 1 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-001
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.4	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.6	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-002
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.5	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-003
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-004
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.3	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.0	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-005
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.6	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	3.4	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-006
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.6	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-007
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.9	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-008
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.7	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-009
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.5	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.7	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 3531 13th St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2110274-010
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	2.5	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2111048

Sample Location: 1 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.4	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.1	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.2	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.8	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	21.0	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.8	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.5	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.4	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	0.3	ug/L		11/16/2021	Lgallimore

Sample Location: 7 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.8	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.1	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.2	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.1	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 522 Tennessee Ave NE
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111048-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.8	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2111049

Sample Location: 1 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.4	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 137 12th St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111049-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2111050

Sample Location: 1 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		200	751	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	14.8	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 2 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		200	917	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	1.8	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	7.8	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 3 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	355	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	4.3	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		100	83.4	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.9	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 5 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	94.1	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.5	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 6 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	116	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.8	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 7 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	120	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.9	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 8 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	93.4	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	2.0	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	3.2	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.1	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.7	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 10 2222 Observatory Place NW
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111050-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		20	133	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	3.1	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2111051

Sample Location: 1 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.3	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.8	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.5	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	1.8	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.6	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 1238 C St NE
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111051-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.3	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.7	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2111052

Sample Location: 1 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.2	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 2 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.2	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 3 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 5 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.3	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 6 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.1	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 7 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 8 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	1.0	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Sample Location: 10 1729 11th St NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111052-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		11/16/2021	Lgallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	Lgallimore
Manganese	EPA 200.8		0.2	0.9	ug/L		11/16/2021	Lgallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	Lgallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/7/2021

Report Number: LT-DC-CCPF-2111053

Sample Location: 1 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.0	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	1.5	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 2 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.1	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	1.4	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 3 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.6	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.5	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.1	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 5 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.0	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	1.9	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 6 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.9	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.3	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 7 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	50.1	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.9	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 8 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	51.9	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.6	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	51.2	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.0	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Sample Location: 10 3827 Calvert St. NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111053-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.5	ug/L		11/16/2021	LGallimore
Lead	EPA 200.8	15	0.2	ND	ug/L		11/16/2021	LGallimore
Manganese	EPA 200.8		0.2	2.4	ug/L		11/16/2021	LGallimore
Tin	EPA 200.8		0.2	ND	ug/L		11/16/2021	LGallimore

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111058

Sample Location: 1 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-002
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.6	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-003
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-004
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.3	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-005
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	55.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-006
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-007
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	83.3	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-008
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	101	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-009
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	104	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 450 N St NW
Date Collected: 10/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111058-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	105	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111059

Sample Location: 1 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.8	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-002
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.7	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-003
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-004
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-005
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.8	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-006
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-007
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-008
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-009
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 1234 D ST SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111059-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.6	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111060

Sample Location: 1 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	24.8	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-002
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-003
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.7	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-004
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-005
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.6	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-006
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-007
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.3	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-008
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-009
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 27 15th St SE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111060-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111061

Sample Location: 1 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-002
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-003
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-004
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-005
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-006
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-007
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-008
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-009
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 3913 Blaine St NE
Date Collected: 10/25/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111061-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111062

Sample Location: 1 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-002
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-003
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-004
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.3	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-005
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-006
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-007
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-008
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-009
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 4205 49th St NW
Date Collected: 10/26/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111062-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111072

Sample Location: 1 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-001
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	254	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.8	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	1.6	ug/L		12/1/2021	SBrooks

Sample Location: 2 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-002
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	233	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	7.8	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	6.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	0.7	ug/L		12/1/2021	SBrooks

Sample Location: 3 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-003
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	102	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	15.1	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-004
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	0.2	ug/L		12/1/2021	SBrooks

Sample Location: 5 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-005
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	71.8	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-006
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.2	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-007
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	57.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-008
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	51.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-009
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 3835 Calvert St NW
Date Collected: 10/31/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111072-010
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111074

Sample Location: 1 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-001
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	24.7	ug/L		12/1/2021	SBrooks

Sample Location: 2 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-002
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.6	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-003
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-004
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-005
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-006
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-007
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-008
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-009
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.7	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 5419 Hawthorne PI NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111074-010
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	22.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111075

Sample Location: 1 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-001
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-002
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-003
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-004
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-005
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-006
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.5	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-007
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-008
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.9	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-009
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 3830 Fulton St NW
Date Collected: 11/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111075-010
Date / Time Received: 11/8/2021 8:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.2	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: LT-DC-CCPF-2111076

Sample Location: 1 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-001
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.3	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-002
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.3	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 3 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-003
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.7	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-004
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-005
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.6	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-006
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-007
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-008
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-009
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 2020 37th St NW
Date Collected: 11/4/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111076-010
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111077

Sample Location: 1 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-001
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	200	ug/L		12/10/2021	SBrooks
Lead	EPA 200.8	15	2.0	16.2	ug/L		12/10/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		12/10/2021	SBrooks
Tin	EPA 200.8		0.2	4.3	ug/L		12/10/2021	SBrooks

Sample Location: 2 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-002
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	122	ug/L		12/10/2021	SBrooks
Lead	EPA 200.8	15	2.0	7.2	ug/L		12/10/2021	SBrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		12/10/2021	SBrooks
Tin	EPA 200.8		0.2	3.0	ug/L		12/10/2021	SBrooks

Sample Location: 3 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-003
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.1	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	0.4	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-004
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	12.3	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 5 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-005
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.4	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	12.5	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 6 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-006
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.1	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	9.7	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 7 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-007
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	7.1	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 8 4917 Minnesota Ave NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111077-008
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	5.6	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4917 Minnesota Ave NE

Date Collected: 11/1/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2111077-009

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.0	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.6	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 10 4917 Minnesota Ave NE

Date Collected: 11/1/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2111077-010

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.2	ug/L		12/1/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.9	ug/L		12/1/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111130

Sample Location: 1 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.9	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.7	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.5	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.5	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 1320 Wallach PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111130-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111131

Sample Location: 1 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 1837 Wyoming Ave NW
Date Collected: 10/29/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111131-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111132

Sample Location: 1 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 1014 Spring Rd NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111132-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.1	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111133

Sample Location: 1 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	20.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 2243 Observatory PI NW
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111133-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2243 Observatory PI NW

Date Collected: 11/1/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2111133-009

Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.7	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 2243 Observatory PI NW

Date Collected: 11/1/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2111133-010

Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111134

Sample Location: 1 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.5	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.4	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.9	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	26.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	7.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	25.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.9	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.5	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	7.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	52.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	7.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 4500 Edmunds St NW
Date Collected: 10/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111134-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	7.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111135

Sample Location: 1 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 1814 1st St NW
Date Collected: 10/28/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111135-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111136

Sample Location: 1 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	158	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.9	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	1.6	ug/L		12/2/2021	SBrooks

Sample Location: 2 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	89.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.2	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	1.1	ug/L		12/2/2021	SBrooks

Sample Location: 3 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	53.7	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	343	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	57.3	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	9.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	6.5	ug/L		12/2/2021	SBrooks

Sample Location: 5 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	84.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	70.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	70.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	74.9	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 10 Milmarson PI NW
Date Collected: 10/30/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111136-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	97.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	4.9	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	6.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	1.0	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111137

Sample Location: 1 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-001
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-002
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	42.4	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-003
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	84.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-004
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-005
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.3	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	4.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-006
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.0	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-007
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-008
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.4	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.0	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-009
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	5.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 1518 Hamlin St NE
Date Collected: 11/1/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111137-010
Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	40.5	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	4.9	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111162

Sample Location: 1 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-001
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 2 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-002
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-003
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-004
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.7	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-005
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-006
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.4	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-007
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-008
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.4	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-009
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.8	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 4889 MacArthur Blvd NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111162-010
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.7	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	1.2	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111163

Sample Location: 1 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-001
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	138	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 2 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-002
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	122	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 3 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-003
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	120	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.4	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-004
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	134	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.8	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 5 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-005
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	149	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.7	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 6 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-006
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	142	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 7 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-007
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	127	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.8	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 8 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-008
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	134	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-009
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	139	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.4	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 10 4302 47th St NW
Date Collected: 11/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111163-010
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	151	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111164

Sample Location: 1 1 Rhode Island Ave NE

Date Collected: 7/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111164-001

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.5	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.6	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 2 1 Rhode Island Ave NE

Date Collected: 7/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111164-002

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.8	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 3 1 Rhode Island Ave NE

Date Collected: 7/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111164-003

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.7	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 1 Rhode Island Ave NE **Customer Program Code:** CCPF
Date Collected: 7/30/2021 **Laboratory Sample Number:** 2111164-004
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.9	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 5 1 Rhode Island Ave NE **Customer Program Code:** CCPF
Date Collected: 7/30/2021 **Laboratory Sample Number:** 2111164-005
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 6 1 Rhode Island Ave NE **Customer Program Code:** CCPF
Date Collected: 7/30/2021 **Laboratory Sample Number:** 2111164-006
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.1	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 7 1 Rhode Island Ave NE **Customer Program Code:** CCPF
Date Collected: 7/30/2021 **Laboratory Sample Number:** 2111164-007
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.5	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 8 1 Rhode Island Ave NE **Customer Program Code:** CCPF
Date Collected: 7/30/2021 **Laboratory Sample Number:** 2111164-008
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.9	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 1 Rhode Island Ave NE

Date Collected: 7/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111164-009

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.0	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 10 1 Rhode Island Ave NE

Date Collected: 7/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111164-010

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.7	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111165

Sample Location: 1 914 C St SE

Date Collected: 10/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111165-001

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	247	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	5.0	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	1.2	ug/L	H	12/2/2021	Sbrooks

Sample Location: 2 914 C St SE

Date Collected: 10/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111165-002

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	139	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.6	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 3 914 C St SE

Date Collected: 10/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111165-003

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.4	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	2.0	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 914 C St SE **Customer Program Code:** CCPF
Date Collected: 10/28/2021 **Laboratory Sample Number:** 2111165-004
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.7	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 5 914 C St SE **Customer Program Code:** CCPF
Date Collected: 10/28/2021 **Laboratory Sample Number:** 2111165-005
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.1	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.5	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 6 914 C St SE **Customer Program Code:** CCPF
Date Collected: 10/28/2021 **Laboratory Sample Number:** 2111165-006
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.9	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 7 914 C St SE **Customer Program Code:** CCPF
Date Collected: 10/28/2021 **Laboratory Sample Number:** 2111165-007
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.2	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	2.4	ug/L	H	12/2/2021	Sbrooks

Sample Location: 8 914 C St SE **Customer Program Code:** CCPF
Date Collected: 10/28/2021 **Laboratory Sample Number:** 2111165-008
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	48.3	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	1.3	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 914 C St SE

Date Collected: 10/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111165-009

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.6	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.5	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	1.2	ug/L	H	12/2/2021	Sbrooks

Sample Location: 10 914 C St SE

Date Collected: 10/28/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111165-010

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	19.2	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.3	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	3.0	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111177

Sample Location: 1 4620 48th St NW

Date Collected: 10/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111177-001

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.5	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.7	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 2 4620 48th St NW

Date Collected: 10/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111177-002

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	235	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.6	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 3 4620 48th St NW

Date Collected: 10/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111177-003

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	299	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.9	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 4620 48th St NW **Customer Program Code:** CCPF
Date Collected: 10/30/2021 **Laboratory Sample Number:** 2111177-004
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	287	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.6	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 5 4620 48th St NW **Customer Program Code:** CCPF
Date Collected: 10/30/2021 **Laboratory Sample Number:** 2111177-005
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	263	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.1	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 6 4620 48th St NW **Customer Program Code:** CCPF
Date Collected: 10/30/2021 **Laboratory Sample Number:** 2111177-006
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	220	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	5.0	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 7 4620 48th St NW **Customer Program Code:** CCPF
Date Collected: 10/30/2021 **Laboratory Sample Number:** 2111177-007
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	220	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	5.3	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 8 4620 48th St NW **Customer Program Code:** CCPF
Date Collected: 10/30/2021 **Laboratory Sample Number:** 2111177-008
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method. **Date / Time Received:** 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	216	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	5.9	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Sample Location: 9 4620 48th St NW

Date Collected: 10/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111177-009

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	213	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.3	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Sample Location: 10 4620 48th St NW

Date Collected: 10/30/2021

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Customer Program Code: CCPF

Laboratory Sample Number: 2111177-010

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	203	ug/L	H	12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L	H	12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.1	ug/L	H	12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L	H	12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111178

Sample Location: 1 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-001
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	120	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.8	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 2 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-002
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	117	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	6.3	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 3 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-003
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	85.5	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	5.3	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-004
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	59.5	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.6	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 5 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-005
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	51.3	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.3	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 6 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-006
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	49.1	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.2	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 7 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-007
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	47.5	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	4.1	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 8 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-008
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.7	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-009
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.7	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.9	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Sample Location: 10 323 Emerson St NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111178-010
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	44.0	ug/L		12/2/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	Sbrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		12/2/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111179

Sample Location: 1 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-001
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.0	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	0.8	ug/L		12/2/2021	SBrooks

Sample Location: 2 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-002
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 3 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-003
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-004
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	38.2	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 5 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-005
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	33.6	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 6 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-006
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.4	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 7 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-007
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.0	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 8 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-008
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	35.0	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-009
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.1	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Sample Location: 10 407 Missouri Ave NW
Date Collected: 11/11/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111179-010
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	36.0	ug/L		12/2/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/2/2021	SBrooks
Manganese	EPA 200.8		0.2	2.5	ug/L		12/2/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/2/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111216

Sample Location: 1 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 1212 Wylie St. NE
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111216-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111217

Sample Location: 1 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.4	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 3710 Mckinley Ave NW
Date Collected: 11/9/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111217-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111218

Sample Location: 1 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.3	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 2 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	30.0	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 3 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.9	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	31.3	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 5 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	29.8	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 6 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.9	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 7 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.8	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 8 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.5	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	34.7	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 10 907 F St. NE
Date Collected: 11/10/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111218-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.4	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111219

Sample Location: 1 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	86.3	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	1.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	81.1	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	3.8	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	80.3	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	5.2	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	88.4	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	5.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	84.6	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	5.9	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	80.8	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	7.1	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.5	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	7.1	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	86.0	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	7.1	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	78.5	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	6.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 5117 3rd St NW
Date Collected: 11/14/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111219-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.2	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	6.8	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111220

Sample Location: 1 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	28.4	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.8	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/3/2021	Sbrooks

Sample Location: 2 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	23.0	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.5	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	0.5	ug/L		12/3/2021	Sbrooks

Sample Location: 3 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	18.6	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.9	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.1	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 5 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/3/2021	Sbrooks

Sample Location: 6 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.5	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 7 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.2	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.2	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 8 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.4	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.1	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	0.7	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.6	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 10 1716 21st St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111220-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	11.3	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	3.9	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111221

Sample Location: 1 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	13.0	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 2 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.0	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 3 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.4	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.0	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.1	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 5 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.5	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.3	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 6 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	12.9	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	0.3	ug/L		12/3/2021	Sbrooks

Sample Location: 7 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.3	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 8 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.8	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	17.8	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	Sbrooks

Sample Location: 10 4735 13th St NW
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111221-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	15.4	ug/L		12/3/2021	Sbrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/3/2021	Sbrooks
Manganese	EPA 200.8		0.2	1.8	ug/L		12/3/2021	Sbrooks
Tin	EPA 200.8		0.2	0.4	ug/L		12/3/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111222

Sample Location: 1 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	114	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	72.7	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.1	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	67.4	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	1.9	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	63.0	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.2	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	68.2	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	92.4	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.5	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	96.9	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-009
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	98.4	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.8	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 818 Independence Ave SE
Date Collected: 11/16/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111222-010
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	95.3	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	2.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111256

Sample Location: 1 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-001
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-002
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-003
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-004
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.2	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-005
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-006
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-007
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-008
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-009
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 1730 Gales St. NE
Date Collected: 11/18/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111256-010
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111258

Sample Location: 1 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-001
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-002
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-003
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-004
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-005
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-006
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-007
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-008
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.4	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-009
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 1249 Independence Ave SE
Date Collected: 11/22/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111258-010
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	ND	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.5	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2111259

Sample Location: 1 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-001
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.2	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 2 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-002
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 3 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-003
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-004
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.6	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.6	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 5 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-005
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.7	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 6 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-006
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	2.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 7 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-007
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.8	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 8 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-008
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	5.6	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-009
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	6.3	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	1.0	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Sample Location: 10 628 Massachusetts Ave NE
Date Collected: 11/23/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2111259-010
Date / Time Received: 11/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/3/2021	SBrooks
Lead	EPA 200.8	15	0.2	7.0	ug/L		12/3/2021	SBrooks
Manganese	EPA 200.8		0.2	0.9	ug/L		12/3/2021	SBrooks
Tin	EPA 200.8		0.2	ND	ug/L		12/3/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112076

Sample Location: 1 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-001
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.1	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-002
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-003
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-004
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-005
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-006
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-007
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-008
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-009
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 2027 Hillyer PI NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112076-010
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112077

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-001
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	305	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	16.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.2	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.2	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-002
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.8	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.1	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-003
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	54.5	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.2	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-004
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	400	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.1	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-005
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	27.4	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.1	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-006
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-007
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.4	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-008
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.1	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-009
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	32.3	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.1	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 1 1405 Kearny St NE
Date Collected: 12/2/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112077-010
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	10.2	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112078

Sample Location: 1 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-001
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-002
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-003
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 4 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-004
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-005
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-006
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-007
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-008
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-009
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 947 S St NW
Date Collected: 12/3/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112078-010
Date / Time Received: 12/9/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112090

Sample Location: 1 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	14.9	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	Nd	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.9	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Sample Location: 9 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-009
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 1515 12th St NW
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112090-010
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112091

Sample Location: 1 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-009
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 627 14th PI NE
Date Collected: 12/5/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112091-010
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112092

Sample Location: 1 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	49.4	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	37.9	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.2	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.5	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	76.2	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	73.4	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	66.6	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.0	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.7	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.4	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-009
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.9	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 804 44th St NE
Date Collected: 12/6/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112092-010
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	61.2	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112093

Sample Location: 1 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	16.8	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.4	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	2.6	ug/L		12/13/2021	Rlamsal

Sample Location: 2 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.0	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	1.1	ug/L		12/13/2021	Rlamsal

Sample Location: 3 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.9	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal

Sample Location: 5 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.5	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.5	ug/L		12/13/2021	Rlamsal

Sample Location: 6 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal

Sample Location: 7 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.5	ug/L		12/13/2021	Rlamsal

Sample Location: 8 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-009
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal

Sample Location: 10 1511 Church St. NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112093-010
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	0.3	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112094

Sample Location: 1 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.4	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	43.0	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.4	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.3	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.5	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	41.4	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.5	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	39.5	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.0	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	45.7	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.2	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	46.7	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-009
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	56.9	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 4605 Verplanck PI NW
Date Collected: 12/7/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112094-010
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	62.2	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112095

Sample Location: 1 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 47 Florida Ave NW
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112095-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 47 Florida Ave NW

Date Collected: 12/8/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2112095-009

Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 47 Florida Ave NW

Date Collected: 12/8/2021

Customer Program Code: CCPF

Laboratory Sample Number: 2112095-010

Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	ND	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	ND	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	0.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Metals Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/27/2021

Report Number: LT-DC-CCPF-2112096

Sample Location: 1 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-001
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	85.3	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.8	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.8	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 2 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-002
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.3	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.4	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 3 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-003
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	77.5	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	0.6	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.7	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 4 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-004
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.8	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	4.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 5 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-005
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	76.8	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	5.3	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 6 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-006
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	79.0	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	4.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.9	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 7 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-007
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	75.2	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 8 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-008
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	75.8	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	1.6	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Sample Location: 9 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-009
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	115	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	2.4	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	2.3	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Sample Location: 10 2837 27th St NE
Date Collected: 12/8/2021

Customer Program Code: CCPF
Laboratory Sample Number: 2112096-010
Date / Time Received: 12/10/2021 9:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Iron	EPA 200.8		10	146	ug/L		12/13/2021	Rlamsal
Lead	EPA 200.8	15	0.2	1.2	ug/L		12/13/2021	Rlamsal
Manganese	EPA 200.8		0.2	3.5	ug/L		12/13/2021	Rlamsal
Tin	EPA 200.8		0.2	ND	ug/L		12/13/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Post Lead Service Line Replacement Samples

DC Water operates a program where lead sampling kits are dropped off to customers that have had a partial or full lead service line replacement. Samples are typically dropped off approximately 4 months after the replacement to determine if it is necessary for customers to continue filtering their water. The kit comes with bottles and instructions on how to take first and second draw samples. Customers collect their own samples and contact DC Water to deliver the bottles to the Washington Aqueduct. Results are then reported back to the customer through DC Water's Customer Service Program.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-015

Sample Location: 1st Draw 110 DUDDINGTON PL SE

Customer Sample Number:

Date / Time Collected: 6/18/2021 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-015

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 110 DUDDINGTON PL SE

Customer Sample Number:

Date / Time Collected: 6/18/2021 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-016

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-025

Sample Location: 1st Draw 1116 East Capitol St. NE

Customer Sample Number:

Date / Time Collected: 6/20/2021 7:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-025

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1116 East Capitol St. NE

Customer Sample Number:

Date / Time Collected: 6/20/2021 7:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-026

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-029

Sample Location: 1st Draw 119 16th St NE
Customer Sample Number:
Date / Time Collected: 6/22/2021 6:30 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2106245-029
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 119 16th St NE
Customer Sample Number:
Date / Time Collected: 6/22/2021 6:32 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2106245-030
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-019

Sample Location: 1st Draw 1221 Quincy St NE

Customer Sample Number:

Date / Time Collected: 6/19/2021 7:38 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-019

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1221 Quincy St NE

Customer Sample Number:

Date / Time Collected: 6/19/2021 7:38 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-020

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107022-025

Sample Location: 1st Draw 1619 GALES ST NE

Customer Sample Number:

Date / Time Collected: 6/29/2021 9:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-025

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1619 GALES ST NE

Customer Sample Number:

Date / Time Collected: 6/29/2021 9:52 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-026

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106234-007

Sample Location: 1st Draw 1719 Newton St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-007

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 1719 Newton St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-008

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-023

Sample Location: 1st Draw 2022 Klingle Rd NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-023

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2022 Klingle Rd NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-024

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106234-001

Sample Location: 1st Draw 208 Randolph PI NE

Customer Sample Number:

Date / Time Collected: 6/22/2021 8:17 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-001

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 208 Randolph PI NE

Customer Sample Number:

Date / Time Collected: 6/22/2021 8:18 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-002

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-009

Sample Location: 1st Draw 2218 Hall PI NW

Customer Sample Number:

Date / Time Collected: 6/21/2021 7:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-009

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2218 Hall PI NW

Customer Sample Number:

Date / Time Collected: 6/21/2021 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-010

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107076-007

Sample Location: 1st Draw 223 S St. NW
Customer Sample Number:
Date / Time Collected: 7/4/2021 6:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107076-007
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 223 S St. NW
Customer Sample Number:
Date / Time Collected: 7/4/2021 6:47 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107076-008
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107048-007

Sample Location: 1st Draw 227 18th St. SE

Customer Sample Number:

Date / Time Collected: 6/29/2021 7:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107048-007

Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 227 18th St. SE

Customer Sample Number:

Date / Time Collected: 6/29/2021 7:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107048-008

Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-031

Sample Location: 1st Draw 2320 20th St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-031

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2320 20th St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-032

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107022-021

Sample Location: 1st Draw 2327 1st St NW
Customer Sample Number:
Date / Time Collected: 6/29/2021 7:16 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107022-021
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2327 1st St NW
Customer Sample Number:
Date / Time Collected: 6/29/2021 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107022-022
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-037

Sample Location: 1st Draw 2408 2nd St NE
Customer Sample Number:
Date / Time Collected: 6/22/2021 8:08 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2106245-037
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2408 2nd St NE
Customer Sample Number:
Date / Time Collected: 6/22/2021 8:12 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2106245-038
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-039

Sample Location: 1st Draw 2807 35th St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 10:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-039

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 2807 35th St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 10:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-040

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106234-003

Sample Location: 1st Draw 3120 OLIVER ST NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-003

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3120 OLIVER ST NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-004

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-015

Sample Location: 1st Draw 3317 Cleveland Ave NW

Customer Sample Number:

Date / Time Collected: 6/25/2021 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-015

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3317 Cleveland Ave NW

Customer Sample Number:

Date / Time Collected: 6/25/2021 8:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-016

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107076-009

Sample Location: 1st Draw 3330 17th St. NW

Customer Sample Number:

Date / Time Collected: 7/4/2021 7:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107076-009

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3330 17th St. NW

Customer Sample Number:

Date / Time Collected: 7/4/2021 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107076-010

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106234-009

Sample Location: 1st Draw 349 TENNESSEE AVE NE

Customer Sample Number:

Date / Time Collected: 6/10/2021 9:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-009

Date / Time Received: 6/28/2021 8:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/14/2021	SBrooks

Sample Location: 2nd Draw 349 TENNESSEE AVE NE

Customer Sample Number:

Date / Time Collected: 6/10/2021 9:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-010

Date / Time Received: 6/28/2021 8:33:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106234-005

Sample Location: 1st Draw 3512 30th St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-005

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3512 30th St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106234-006

Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-017

Sample Location: 1st Draw 3527 13th St NW

Customer Sample Number:

Date / Time Collected: 6/24/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-017

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3527 13th St NW

Customer Sample Number:

Date / Time Collected: 6/24/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-018

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-035

Sample Location: 1st Draw 3604 Park Place NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:44 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-035

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3604 Park Place NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-036

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-033

Sample Location: 1st Draw 3720 Ingomar ST NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-033

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3720 Ingomar ST NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 7:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-034

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-013

Sample Location: 1st Draw 3724 Ingomar St NW

Customer Sample Number:

Date / Time Collected: 6/21/2021 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-013

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3724 Ingomar St NW

Customer Sample Number:

Date / Time Collected: 6/21/2021 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-014

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107022-019

Sample Location: 1st Draw 3812 BENTON ST NW

Customer Sample Number:

Date / Time Collected: 6/27/2021 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-019

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 3812 BENTON ST NW

Customer Sample Number:

Date / Time Collected: 6/27/2021 8:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-020

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107076-011

Sample Location: 1st Draw 4017 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 7/4/2021 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107076-011

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4017 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 7/4/2021 8:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107076-012

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-025

Sample Location: 1st Draw 4108 Ingomar St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-025

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4108 Ingomar St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-026

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107076-013

Sample Location: 1st Draw 425 Ingraham St NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 8:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107076-013

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 425 Ingraham St NW

Customer Sample Number:

Date / Time Collected: 7/5/2021 8:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107076-014

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106220-013

Sample Location: 1st Draw 4321 37th ST NW

Customer Sample Number:

Date / Time Collected: 6/16/2021 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106220-013

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4321 37th ST NW

Customer Sample Number:

Date / Time Collected: 6/16/2021 6:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106220-014

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-011

Sample Location: 1st Draw 4625 9th St NW
Customer Sample Number:
Date / Time Collected: 6/24/2021 7:44 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2106256-011
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4625 9th St NW
Customer Sample Number:
Date / Time Collected: 6/24/2021 7:50 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2106256-012
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107022-017

Sample Location: 1st Draw 4838 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 6/26/2021 9:32 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-017

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 4838 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 6/26/2021 9:40 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-018

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-027

Sample Location: 1st Draw 5315 5th St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 4:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-027

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 5315 5th St. NW

Customer Sample Number:

Date / Time Collected: 6/22/2021 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-028

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107048-003

Sample Location: 1st Draw 5713 13th St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 5:50 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107048-003

Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 5713 13th St NW

Customer Sample Number:

Date / Time Collected: 6/23/2021 5:54 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107048-004

Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-023

Sample Location: 1st Draw 647 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 6/20/2021 6:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-023

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 647 Kenyon St NW

Customer Sample Number:

Date / Time Collected: 6/20/2021 6:52 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-024

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-019

Sample Location: 1st Draw 726 Farragut St NW

Customer Sample Number:

Date / Time Collected: 6/12/2021 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-019

Date / Time Received: 6/30/2021 8:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/14/2021	SBrooks

Sample Location: 2nd Draw 726 Farragut St NW

Customer Sample Number:

Date / Time Collected: 6/12/2021 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-020

Date / Time Received: 6/30/2021 8:15:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107022-023

Sample Location: 1st Draw 763 Gresham PI NW

Customer Sample Number:

Date / Time Collected: 6/30/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-023

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 763 Gresham PI NW

Customer Sample Number:

Date / Time Collected: 6/30/2021 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107022-024

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106245-011

Sample Location: 1st Draw 802 Dahlia St NW

Customer Sample Number:

Date / Time Collected: 6/18/2021 5:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-011

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 802 Dahlia St NW

Customer Sample Number:

Date / Time Collected: 6/18/2021 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106245-012

Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2106256-021

Sample Location: 1st Draw 913 Crittenden St NW

Customer Sample Number:

Date / Time Collected: 6/25/2021 5:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-021

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 913 Crittenden St NW

Customer Sample Number:

Date / Time Collected: 6/25/2021 5:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2106256-022

Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 7/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107048-005

Sample Location: 1st Draw 921 Westminster St NW
Customer Sample Number:
Date / Time Collected: 6/28/2021 8:57 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107048-005
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Sample Location: 2nd Draw 921 Westminster St NW
Customer Sample Number:
Date / Time Collected: 6/28/2021 9:05 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107048-006
Date / Time Received: 7/6/2021 8:34:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-017

Sample Location: 1st Draw 1007 Quebec PI NW

Customer Sample Number:

Date / Time Collected: 7/20/2021 7:23 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-017

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1007 Quebec PI NW

Customer Sample Number:

Date / Time Collected: 7/20/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-018

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-019

Sample Location: 1st Draw 1100 East Capitol St NE
Customer Sample Number:
Date / Time Collected: 7/20/2021 6:51 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-019
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1100 East Capitol St NE
Customer Sample Number:
Date / Time Collected: 7/20/2021 6:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-020
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107222-023

Sample Location: 1st Draw 1233 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 7/26/2021 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-023

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1233 Maryland Ave NE

Customer Sample Number:

Date / Time Collected: 7/26/2021 6:36 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-024

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-013

Sample Location: 1st Draw 1237 Quincy St NE

Customer Sample Number:

Date / Time Collected: 7/1/2021 7:16 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-013

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1237 Quincy St NE

Customer Sample Number:

Date / Time Collected: 7/1/2021 7:16 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-014

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-007

Sample Location: 1st Draw 1306 C St NE
Customer Sample Number:
Date / Time Collected: 7/18/2021 7:55 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-007
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1306 C St NE
Customer Sample Number:
Date / Time Collected: 7/18/2021 7:55 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107161-025

Sample Location: 1st Draw 1308 SHERIDAN ST NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 5:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107161-025

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1308 SHERIDAN ST NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 5:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107161-026

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107222-011

Sample Location: 1st Draw 1350 EMERALD ST NE

Customer Sample Number:

Date / Time Collected: 7/25/2021 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-011

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 1350 EMERALD ST NE

Customer Sample Number:

Date / Time Collected: 7/25/2021 8:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-012

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-009

Sample Location: 1st Draw 1844 PARK RD NW

Customer Sample Number:

Date / Time Collected: 7/8/2021 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-009

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 1844 PARK RD NW

Customer Sample Number:

Date / Time Collected: 7/8/2021 6:43 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-010

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-011

Sample Location: 1st Draw 212 Taylor St NW

Customer Sample Number:

Date / Time Collected: 7/8/2021 11:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-011

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 212 Taylor St NW

Customer Sample Number:

Date / Time Collected: 7/8/2021 11:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-012

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-011

Sample Location: 1st Draw 2527 12th St NW

Customer Sample Number:

Date / Time Collected: 7/20/2021 4:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-011

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 2527 12th St NW

Customer Sample Number:

Date / Time Collected: 7/20/2021 4:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-012

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107161-005

Sample Location: 1st Draw 2568 UNIVERSITY PL NW APT 4

Customer Sample Number:

Date / Time Collected: 7/13/2021 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107161-005

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 2568 UNIVERSITY PL NW APT 4

Customer Sample Number:

Date / Time Collected: 7/13/2021 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107161-006

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-009

Sample Location: 1st Draw 2818 13th St. NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 6:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-009

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 2818 13th St. NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-010

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108016-015

Sample Location: 1st Draw 3020 7th St SE
Customer Sample Number:
Date / Time Collected: 7/28/2021 11:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2108016-015
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3020 7th St SE
Customer Sample Number:
Date / Time Collected: 7/28/2021 11:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2108016-016
Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108016-005

Sample Location: 1st Draw 3219 KLINGLE RD NW

Customer Sample Number:

Date / Time Collected: 7/22/2021 7:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108016-005

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3219 KLINGLE RD NW

Customer Sample Number:

Date / Time Collected: 7/22/2021 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108016-006

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-005

Sample Location: 1st Draw 3336 17th St NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-005

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3336 17th St NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-006

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107122-011

Sample Location: 1st Draw 3338 17th St NW

Customer Sample Number:

Date / Time Collected: 7/12/2021 5:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107122-011

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3338 17th St NW

Customer Sample Number:

Date / Time Collected: 7/12/2021 5:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107122-012

Date / Time Received: 7/15/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-001

Sample Location: 1st Draw 3340 17th St NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-001

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3340 17th St NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-002

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107222-019

Sample Location: 1st Draw 3670 Park PI NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-019

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3670 Park PI NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-020

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107222-021

Sample Location: 1st Draw 3721 INGOMAR ST NW
Customer Sample Number:
Date / Time Collected: 7/26/2021 9:24 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107222-021
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3721 INGOMAR ST NW
Customer Sample Number:
Date / Time Collected: 7/26/2021 9:28 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107222-022
Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107161-019

Sample Location: 1st Draw 3725 INGOMAR ST NW
Customer Sample Number:
Date / Time Collected: 7/17/2021 12:13 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107161-019
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3725 INGOMAR ST NW
Customer Sample Number:
Date / Time Collected: 7/17/2021 12:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107161-020
Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-007

Sample Location: 1st Draw 3726 Harrison St NW

Customer Sample Number:

Date / Time Collected: 7/3/2021 8:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-007

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3726 Harrison St NW

Customer Sample Number:

Date / Time Collected: 7/3/2021 8:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-008

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108016-009

Sample Location: 1st Draw 3728 NORTHAMPTON ST NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 11:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108016-009

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3728 NORTHAMPTON ST NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 11:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108016-010

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107222-005

Sample Location: 1st Draw 3732 JOCELYN ST NW

Customer Sample Number:

Date / Time Collected: 7/23/2021 6:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-005

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	26.5	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 3732 JOCELYN ST NW

Customer Sample Number:

Date / Time Collected: 7/23/2021 6:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107222-006

Date / Time Received: 7/29/2021 9:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.1	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-013

Sample Location: 1st Draw 3816 T ST NW
Customer Sample Number:
Date / Time Collected: 7/20/2021 5:43 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-013
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3816 T ST NW
Customer Sample Number:
Date / Time Collected: 7/20/2021 5:47 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-014
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108016-007

Sample Location: 1st Draw 3909 HARRISON ST NW

Customer Sample Number:

Date / Time Collected: 7/22/2021 8:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108016-007

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 3909 HARRISON ST NW

Customer Sample Number:

Date / Time Collected: 7/22/2021 8:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108016-008

Date / Time Received: 7/30/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107161-029

Sample Location: 1st Draw 4137 YUMA ST NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107161-029

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	Sbrooks

Sample Location: 2nd Draw 4137 YUMA ST NW

Customer Sample Number:

Date / Time Collected: 7/19/2021 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107161-030

Date / Time Received: 7/22/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-003

Sample Location: 1st Draw 4912 ILLINOIS AVE NW
Customer Sample Number:
Date / Time Collected: 7/18/2021 9:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 4912 ILLINOIS AVE NW
Customer Sample Number:
Date / Time Collected: 7/18/2021 9:04 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2107175-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107175-023

Sample Location: 1st Draw 5330 41st ST NE

Customer Sample Number:

Date / Time Collected: 7/21/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-023

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 5330 41st ST NE

Customer Sample Number:

Date / Time Collected: 7/21/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107175-024

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/12/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2107096-003

Sample Location: 1st Draw 902 BUTTERNUT ST NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 10:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-003

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		8/4/2021	SBrooks

Sample Location: 2nd Draw 902 BUTTERNUT ST NW

Customer Sample Number:

Date / Time Collected: 7/11/2021 10:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2107096-004

Date / Time Received: 7/13/2021 8:51:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108167-011

Sample Location: 1st Draw 1302 C St. SE
Customer Sample Number:
Date / Time Collected: 8/8/2021 9:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2108167-011
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 1302 C St. SE
Customer Sample Number:
Date / Time Collected: 8/8/2021 9:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2108167-012
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108115-003

Sample Location: 1st Draw 1401 Newton St. NE

Customer Sample Number:

Date / Time Collected: 7/25/2021 5:38 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-003

Date / Time Received: 8/10/2021 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L	H	8/25/2021	Rhoffa

Sample Location: 2nd Draw 1401 Newton St. NE

Customer Sample Number:

Date / Time Collected: 7/25/2021 5:39 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-004

Date / Time Received: 8/10/2021 9:00:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108042-005

Sample Location: 1st Draw 1415 Crittenden St NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 6:14 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-005

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1415 Crittenden St NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 6:16 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-006

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108115-005

Sample Location: 1st Draw 157 Adams St NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 5:01 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-005

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 157 Adams St NW

Customer Sample Number:

Date / Time Collected: 7/27/2021 5:04 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-006

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108095-015

Sample Location: 1st Draw 1724 22nd St SE

Customer Sample Number:

Date / Time Collected: 7/28/2021 7:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-015

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1724 22nd St SE

Customer Sample Number:

Date / Time Collected: 7/28/2021 7:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-016

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108095-017

Sample Location: 1st Draw 1731 Mass Ave SE

Customer Sample Number:

Date / Time Collected: 7/31/2021 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-017

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 1731 Mass Ave SE

Customer Sample Number:

Date / Time Collected: 7/31/2021 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-018

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108042-001

Sample Location: 1st Draw 222 Seaton Place NE

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-001

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 222 Seaton Place NE

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-002

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108115-011

Sample Location: 1st Draw 228 South Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 8/2/2021 5:59 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2108115-011
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 228 South Carolina Ave. SE
Customer Sample Number:
Date / Time Collected: 8/2/2021 5:59 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2108115-012
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108042-003

Sample Location: 1st Draw 2722 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-003

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 2722 Woodley PI NW

Customer Sample Number:

Date / Time Collected: 7/26/2021 7:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-004

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108095-013

Sample Location: 1st Draw 3332 17th St NW

Customer Sample Number:

Date / Time Collected: 7/29/2021 6:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-013

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 3332 17th St NW

Customer Sample Number:

Date / Time Collected: 7/29/2021 6:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-014

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108167-017

Sample Location: 1st Draw 3628 13th St NW

Customer Sample Number:

Date / Time Collected: 8/10/2021 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108167-017

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 3628 13th St NW

Customer Sample Number:

Date / Time Collected: 8/10/2021 7:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108167-018

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108115-017

Sample Location: 1st Draw 3730 NORTHAMPTON ST NW

Customer Sample Number:

Date / Time Collected: 8/5/2021 6:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-017

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 3730 NORTHAMPTON ST NW

Customer Sample Number:

Date / Time Collected: 8/5/2021 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-018

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108095-019

Sample Location: 1st Draw 3813 T Street NW

Customer Sample Number:

Date / Time Collected: 7/30/2021 8:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-019

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 3813 T Street NW

Customer Sample Number:

Date / Time Collected: 7/30/2021 8:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108095-020

Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108115-007

Sample Location: 1st Draw 4724 Jay St. NE

Customer Sample Number:

Date / Time Collected: 7/30/2021 5:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-007

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 4724 Jay St. NE

Customer Sample Number:

Date / Time Collected: 7/30/2021 5:35 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108115-008

Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108167-005

Sample Location: 1st Draw 526 3rd St. NE

Customer Sample Number:

Date / Time Collected: 8/7/2021 5:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108167-005

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		8/19/2021	Rhoffa

Sample Location: 2nd Draw 526 3rd St. NE

Customer Sample Number:

Date / Time Collected: 8/7/2021 5:46 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108167-006

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 8/31/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108042-007

Sample Location: 1st Draw 824 Burns St SE

Customer Sample Number:

Date / Time Collected: 7/27/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-007

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 2nd Draw 824 Burns St SE

Customer Sample Number:

Date / Time Collected: 7/27/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108042-008

Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/23/2021

Report revised on 9/23/21 by MC.
Lab Sample Numbers 2108225-005 &
2108225-006, sample location was changed
from 171 Adam St NW to 171 Adams St NW as
recorded on the chain of custody.

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108225-005

Sample Location: 1st Draw 171 Adams St NW

Customer Sample Number:

Date / Time Collected: 8/18/2021 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108225-005

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 171 Adams St NW

Customer Sample Number:

Date / Time Collected: 8/18/2021 8:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108225-006

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109013-007

Sample Location: 1st Draw 1936 38TH NW
Customer Sample Number:
Date / Time Collected: 8/27/2021 9:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109013-007
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 1936 38TH NW
Customer Sample Number:
Date / Time Collected: 8/27/2021 9:01 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109013-008
Date / Time Received: 9/2/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109025-029

Sample Location: 1st Draw 2309 39TH ST NW

Customer Sample Number:

Date / Time Collected: 8/30/2021 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109025-029

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 2309 39TH ST NW

Customer Sample Number:

Date / Time Collected: 8/30/2021 7:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109025-030

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109025-023

Sample Location: 1st Draw 3400 ORDWAY ST NW

Customer Sample Number:

Date / Time Collected: 8/27/2021 6:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109025-023

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3400 ORDWAY ST NW

Customer Sample Number:

Date / Time Collected: 8/27/2021 6:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109025-024

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108225-003

Sample Location: 1st Draw 3753 Northampton St NW

Customer Sample Number:

Date / Time Collected: 8/16/2021 7:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108225-003

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 3753 Northampton St NW

Customer Sample Number:

Date / Time Collected: 8/16/2021 8:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108225-004

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2108237-001

Sample Location: 1st Draw 423 Allison St NW

Customer Sample Number:

Date / Time Collected: 8/21/2021 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108237-001

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 423 Allison St NW

Customer Sample Number:

Date / Time Collected: 8/21/2021 8:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2108237-002

Date / Time Received: 8/24/2021 8:14:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 9/15/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109025-031

Sample Location: 1st Draw 6103 4TH ST NW

Customer Sample Number:

Date / Time Collected: 8/30/2021 5:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109025-031

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Sample Location: 2nd Draw 6103 4TH ST NW

Customer Sample Number:

Date / Time Collected: 8/30/2021 5:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109025-032

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109235-005

Sample Location: 1st Draw 1106 C St. SE
Customer Sample Number:
Date / Time Collected: 9/19/2021 7:43 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109235-005
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1106 C St. SE
Customer Sample Number:
Date / Time Collected: 9/19/2021 7:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109235-006
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109121-013

Sample Location: 1st Draw 1204 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 9/6/2021 5:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-013

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1204 Shepherd St NW

Customer Sample Number:

Date / Time Collected: 9/6/2021 5:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-014

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109197-003

Sample Location: 1st Draw 1318 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109197-003

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1318 Quincy St. NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109197-004

Date / Time Received: 9/21/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-043

Sample Location: 1st Draw 1338 Randolph St NW

Customer Sample Number:

Date / Time Collected: 9/19/2021 6:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-043

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1338 Randolph St NW

Customer Sample Number:

Date / Time Collected: 9/19/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-044

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109235-007

Sample Location: 1st Draw 1408 Newton St. NE

Customer Sample Number:

Date / Time Collected: 9/19/2021 8:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109235-007

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1408 Newton St. NE

Customer Sample Number:

Date / Time Collected: 9/19/2021 8:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109235-008

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109213-019

Sample Location: 1st Draw 142 Randolph PI NW

Customer Sample Number:

Date / Time Collected: 9/16/2021 6:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109213-019

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 142 Randolph PI NW

Customer Sample Number:

Date / Time Collected: 9/16/2021 6:11 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109213-020

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109142-005

Sample Location: 1st Draw 1420 Crittenden St. NW

Customer Sample Number:

Date / Time Collected: 9/7/2021 7:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109142-005

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	37.6	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1420 Crittenden St. NW

Customer Sample Number:

Date / Time Collected: 9/7/2021 7:49 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109142-006

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109213-001

Sample Location: 1st Draw 1425 Meridian NW

Customer Sample Number:

Date / Time Collected: 9/8/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109213-001

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1425 Meridian NW

Customer Sample Number:

Date / Time Collected: 9/8/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109213-002

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109235-011

Sample Location: 1st Draw 1442 D St. NE
Customer Sample Number:
Date / Time Collected: 9/20/2021 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109235-011
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1442 D St. NE
Customer Sample Number:
Date / Time Collected: 9/20/2021 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109235-012
Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109121-005

Sample Location: 1st Draw 1452 OGDEN ST NW

Customer Sample Number:

Date / Time Collected: 9/5/2021 6:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-005

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 1452 OGDEN ST NW

Customer Sample Number:

Date / Time Collected: 9/5/2021 6:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-006

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109235-003

Sample Location: 1st Draw 1518 New Jersey Ave NW

Customer Sample Number:

Date / Time Collected: 9/18/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109235-003

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	1.0	7.8	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 1518 New Jersey Ave NW

Customer Sample Number:

Date / Time Collected: 9/18/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109235-004

Date / Time Received: 9/24/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.4	2.3	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109213-017

Sample Location: 1st Draw 211 WEBSTER ST NW

Customer Sample Number:

Date / Time Collected: 9/15/2021 6:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109213-017

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 211 WEBSTER ST NW

Customer Sample Number:

Date / Time Collected: 9/15/2021 6:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109213-018

Date / Time Received: 9/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-007

Sample Location: 1st Draw 2121 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 5:53 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-007

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 2121 Tunlaw Rd NW

Customer Sample Number:

Date / Time Collected: 9/12/2021 5:53 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-008

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-011

Sample Location: 1st Draw 236 Walnut St NW

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-011

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 236 Walnut St NW

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-012

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-003

Sample Location: 1st Draw 32 Bryant St NE
Customer Sample Number:
Date / Time Collected: 9/11/2021 7:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109229-003
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 32 Bryant St NE
Customer Sample Number:
Date / Time Collected: 9/11/2021 7:56 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109229-004
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-045

Sample Location: 1st Draw 3722 Harrison St NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 7:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-045

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.1	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 3722 Harrison St NW

Customer Sample Number:

Date / Time Collected: 9/21/2021 7:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-046

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-033

Sample Location: 1st Draw 427 11th St NE
Customer Sample Number:
Date / Time Collected: 9/15/2021 6:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109229-033
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 427 11th St NE
Customer Sample Number:
Date / Time Collected: 9/15/2021 6:01 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109229-034
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109063-007

Sample Location: 1st Draw 4339 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 9/2/2021 2:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109063-007

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 4339 Garfield St. NW

Customer Sample Number:

Date / Time Collected: 9/2/2021 2:39 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109063-008

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109121-017

Sample Location: 1st Draw 4529 Douglas St. NE

Customer Sample Number:

Date / Time Collected: 9/7/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-017

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 4529 Douglas St. NE

Customer Sample Number:

Date / Time Collected: 9/7/2021 7:32 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-018

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109121-009

Sample Location: 1st Draw 4620 4th St. NW

Customer Sample Number:

Date / Time Collected: 9/6/2021 9:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-009

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 4620 4th St. NW

Customer Sample Number:

Date / Time Collected: 9/6/2021 9:19 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-010

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109142-003

Sample Location: 1st Draw 5417 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 9/7/2021 5:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109142-003

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 5417 Illinois Ave. NW

Customer Sample Number:

Date / Time Collected: 9/7/2021 5:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109142-004

Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109093-005

Sample Location: 1st Draw 6515 8TH ST NW

Customer Sample Number:

Date / Time Collected: 9/4/2021 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109093-005

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 6515 8TH ST NW

Customer Sample Number:

Date / Time Collected: 9/4/2021 7:56 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109093-006

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109063-009

Sample Location: 1st Draw 6806 Laurel St NW

Customer Sample Number:

Date / Time Collected: 9/4/2021 8:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109063-009

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 6806 Laurel St NW

Customer Sample Number:

Date / Time Collected: 9/4/2021 8:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109063-010

Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109121-019

Sample Location: 1st Draw 729 Irving St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2021 6:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-019

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 729 Irving St. NW

Customer Sample Number:

Date / Time Collected: 9/8/2021 6:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109121-020

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-013

Sample Location: 1st Draw 735 Butternut St NW

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-013

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 735 Butternut St NW

Customer Sample Number:

Date / Time Collected: 9/13/2021 6:26 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-014

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109142-001

Sample Location: 1st Draw 784 Irving St. NW
Customer Sample Number:
Date / Time Collected: 9/5/2021 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109142-001
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		9/24/2021	SBrooks

Sample Location: 2nd Draw 784 Irving St. NW
Customer Sample Number:
Date / Time Collected: 9/5/2021 7:03 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109142-002
Date / Time Received: 9/15/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-017

Sample Location: 1st Draw 903 Quackenbos St NW
Customer Sample Number:
Date / Time Collected: 9/13/2021 6:52 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109229-017
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 903 Quackenbos St NW
Customer Sample Number:
Date / Time Collected: 9/13/2021 6:55 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2109229-018
Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/7/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2109229-005

Sample Location: 1st Draw 911 Mass Ave NE

Customer Sample Number:

Date / Time Collected: 9/11/2021 8:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-005

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Sample Location: 2nd Draw 911 Mass Ave NE

Customer Sample Number:

Date / Time Collected: 9/11/2021 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2109229-006

Date / Time Received: 9/23/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/29/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110044-019

Sample Location: 1st Draw 1305 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 9/27/2021 7:34 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-019

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1305 Delafield PL NW

Customer Sample Number:

Date / Time Collected: 9/27/2021 7:37 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-020

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110044-013

Sample Location: 1st Draw 1911 35TH PL NW

Customer Sample Number:

Date / Time Collected: 9/24/2021 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-013

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 1911 35TH PL NW

Customer Sample Number:

Date / Time Collected: 9/24/2021 5:31 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-014

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110044-015

Sample Location: 1st Draw 2416 OTIS ST NE

Customer Sample Number:

Date / Time Collected: 9/26/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-015

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	13.2	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 2416 OTIS ST NE

Customer Sample Number:

Date / Time Collected: 9/26/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-016

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110044-031

Sample Location: 1st Draw 4425 Greenwich Parkway NW

Customer Sample Number:

Date / Time Collected: 9/29/2021 6:38 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-031

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 4425 Greenwich Parkway NW

Customer Sample Number:

Date / Time Collected: 9/29/2021 6:41 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110044-032

Date / Time Received: 10/5/2021 11:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 10/27/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110108-007

Sample Location: 1st Draw 818 WHITTIER PL NW

Customer Sample Number:

Date / Time Collected: 10/5/2021 7:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110108-007

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	35.1	ug/L		10/20/2021	Sbrooks

Sample Location: 2nd Draw 818 WHITTIER PL NW

Customer Sample Number:

Date / Time Collected: 10/5/2021 7:58 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110108-008

Date / Time Received: 10/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110276-001

Sample Location: 1st Draw 1004 Otis PI NW
Customer Sample Number:
Date / Time Collected: 10/23/2021 12:18 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110276-001
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1004 Otis PI NW
Customer Sample Number:
Date / Time Collected: 10/23/2021 12:25 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110276-002
Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-001

Sample Location: 1st Draw 1102 E ST SE
Customer Sample Number:
Date / Time Collected: 10/16/2021 7:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-001
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1102 E ST SE
Customer Sample Number:
Date / Time Collected: 10/16/2021 7:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-002
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-019

Sample Location: 1st Draw 1103 Park Street NE

Customer Sample Number:

Date / Time Collected: 10/20/2021 7:00 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-019

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1103 Park Street NE

Customer Sample Number:

Date / Time Collected: 10/20/2021 7:02 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-020

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110175-005

Sample Location: 1st Draw 1107 D ST SE
Customer Sample Number:
Date / Time Collected: 10/18/2021 8:35 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110175-005
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1107 D ST SE
Customer Sample Number:
Date / Time Collected: 10/18/2021 8:37 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110175-006
Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110267-011

Sample Location: 1st Draw 1224 HAMILTON ST NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 5:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110267-011

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1224 HAMILTON ST NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110267-012

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-009

Sample Location: 1st Draw 1304 Euclid St NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-009

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1304 Euclid St NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:03 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-010

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-015

Sample Location: 1st Draw 1342 Perry PI NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 6:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-015

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Dra 1342 Perry PI NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 6:40 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-016

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-013

Sample Location: 1st Draw 1656 Hobart St NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 6:18 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-013

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 1656 Hobart St NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 6:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-014

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-017

Sample Location: 1st Draw 2023 Park Rd NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-017

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2023 Park Rd NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-018

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110259-005

Sample Location: 1st Draw 2037 Park Rd NW

Customer Sample Number:

Date / Time Collected: 10/22/2021 6:39 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110259-005

Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2037 Park Rd NW

Customer Sample Number:

Date / Time Collected: 10/22/2021 6:42 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110259-006

Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-021

Sample Location: 1st Draw 2124 14th St SE
Customer Sample Number:
Date / Time Collected: 10/21/2021 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-021
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2124 14th St SE
Customer Sample Number:
Date / Time Collected: 10/21/2021 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-022
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-009

Sample Location: 1st Draw 227 S St. NE
Customer Sample Number:
Date / Time Collected: 10/19/2021 6:10 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-009
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 227 S St. NE
Customer Sample Number:
Date / Time Collected: 10/19/2021 6:13 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-010
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-005

Sample Location: 1st Draw 2323 Nebraska Ave NW
Customer Sample Number:
Date / Time Collected: 10/17/2021 3:09 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2323 Nebraska Ave NW
Customer Sample Number:
Date / Time Collected: 10/17/2021 3:11 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.6	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110197-017

Sample Location: 1st Draw 2712 27th St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 11:07 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110197-017

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2712 27th St NW

Customer Sample Number:

Date / Time Collected: 10/11/2021 11:09 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110197-018

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.2	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110267-009

Sample Location: 1st Draw 2811 35th St NW

Customer Sample Number:

Date / Time Collected: 10/25/2021 11:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110267-009

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 2811 35th St NW

Customer Sample Number:

Date / Time Collected: 10/25/2021 11:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110267-010

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-015

Sample Location: 1st Draw 3217 KLINGLE RD NW

Customer Sample Number:

Date / Time Collected: 10/20/2021 5:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-015

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3217 KLINGLE RD NW

Customer Sample Number:

Date / Time Collected: 10/20/2021 5:48 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-016

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110073-005

Sample Location: 1st Draw 324 10th St. NE
Customer Sample Number:
Date / Time Collected: 10/4/2021 7:02 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110073-005
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 324 10th St. NE
Customer Sample Number:
Date / Time Collected: 10/4/2021 7:06 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110073-006
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-001

Sample Location: 1st Draw 3547 16th St NW

Customer Sample Number:

Date / Time Collected: 10/16/2021 8:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-001

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3547 16th St NW

Customer Sample Number:

Date / Time Collected: 10/16/2021 8:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-002

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-013

Sample Location: 1st Draw 3751 W St. NW
Customer Sample Number:
Date / Time Collected: 10/19/2021 3:02 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-013
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3751 W St. NW
Customer Sample Number:
Date / Time Collected: 10/19/2021 3:04 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110254-014
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110161-011

Sample Location: 1st Draw 3973 HARRISON ST NW

Customer Sample Number:

Date / Time Collected: 10/14/2021 1:05 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110161-011

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 3973 HARRISON ST NW

Customer Sample Number:

Date / Time Collected: 10/14/2021 1:08 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110161-012

Date / Time Received: 10/20/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-007

Sample Location: 1st Draw 409 Aspen St NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-007

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 409 Aspen St NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:02 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-008

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110073-011

Sample Location: 1st Draw 4213 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 10/6/2021 2:31 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110073-011

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 4213 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 10/6/2021 2:34 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110073-012

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-003

Sample Location: 1st Draw 4914 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 10/17/2021 6:55 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-003

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 4914 Kansas Ave NW

Customer Sample Number:

Date / Time Collected: 10/17/2021 6:59 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-004

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110276-003

Sample Location: 1st Draw 520 Aspen St NW

Customer Sample Number:

Date / Time Collected: 10/24/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110276-003

Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 520 Aspen St NW

Customer Sample Number:

Date / Time Collected: 10/24/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110276-004

Date / Time Received: 10/29/2021 8:58:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.9	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-011

Sample Location: 1st Draw 5411 32nd St. NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 7:15 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-011

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 5411 32nd St. NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 7:21 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-012

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-023

Sample Location: 1st Draw 5413 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 12:41 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-023

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 5413 Illinois Ave NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 12:45 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-024

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110254-003

Sample Location: 1st Draw 5435 Nevada Ave NW

Customer Sample Number:

Date / Time Collected: 10/16/2021 10:12 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-003

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 5435 Nevada Ave NW

Customer Sample Number:

Date / Time Collected: 10/16/2021 10:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110254-004

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110205-019

Sample Location: 1st Draw 619 Hamilton St NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 7:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-019

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 619 Hamilton St NW

Customer Sample Number:

Date / Time Collected: 10/19/2021 7:53 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110205-020

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110259-003

Sample Location: 1st Draw 743 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 10/21/2021 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110259-003

Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 743 Hamilton St. NW

Customer Sample Number:

Date / Time Collected: 10/21/2021 8:06 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110259-004

Date / Time Received: 10/27/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110267-005

Sample Location: 1st Draw 813 Whittier PI NW

Customer Sample Number:

Date / Time Collected: 10/23/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110267-005

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 813 Whittier PI NW

Customer Sample Number:

Date / Time Collected: 10/23/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110267-006

Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 11/18/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110267-007

Sample Location: 1st Draw 907 5TH ST NE
Customer Sample Number:
Date / Time Collected: 10/25/2021 8:13 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110267-007
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Sample Location: 2nd Draw 907 5TH ST NE
Customer Sample Number:
Date / Time Collected: 10/25/2021 8:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2110267-008
Date / Time Received: 10/28/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/10/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2110175-003

Sample Location: 1st Draw 2041 PARK RD NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:44 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110175-003

Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2041 PARK RD NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 6:46 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2110175-004

Date / Time Received: 10/21/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111054-021

Sample Location: 1st Draw 1137 C St NE
Customer Sample Number:
Date / Time Collected: 10/28/2021 6:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111054-021
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1137 C St NE
Customer Sample Number:
Date / Time Collected: 10/28/2021 6:41 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111054-022
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111054-017

Sample Location: 1st Draw 1215 Talbert St SE

Customer Sample Number:

Date / Time Collected: 10/27/2021 10:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-017

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1215 Talbert St SE

Customer Sample Number:

Date / Time Collected: 10/27/2021 10:14 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-018

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111080-057

Sample Location: 1st Draw 126 Todd PI NE
Customer Sample Number:
Date / Time Collected: 11/1/2021 7:50 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111080-057
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 126 Todd PI NE
Customer Sample Number:
Date / Time Collected: 11/1/2021 7:50 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111080-058
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111054-015

Sample Location: 1st Draw 1336 Kennedy St NW

Customer Sample Number:

Date / Time Collected: 10/27/2021 7:28 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-015

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1336 Kennedy St NW

Customer Sample Number:

Date / Time Collected: 10/27/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-016

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111113-001

Sample Location: 1st Draw 1360 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 11/6/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111113-001

Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1360 Taylor St. NW

Customer Sample Number:

Date / Time Collected: 11/6/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111113-002

Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111159-021

Sample Location: 1st Draw 2051 Park Rd NW

Customer Sample Number:

Date / Time Collected: 11/5/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-021

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2051 Park Rd NW

Customer Sample Number:

Date / Time Collected: 11/5/2021 7:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-022

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111054-009

Sample Location: 1st Draw 2236 CATHEDRAL AVE NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 5:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-009

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2236 CATHEDRAL AVE NW

Customer Sample Number:

Date / Time Collected: 10/26/2021 7:50 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-010

Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111080-061

Sample Location: 1st Draw 2404 10TH ST NE

Customer Sample Number:

Date / Time Collected: 10/30/2021 8:00 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111080-061

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2404 10TH ST NE

Customer Sample Number:

Date / Time Collected: 10/30/2021 8:01 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111080-062

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111080-063

Sample Location: 1st Draw 253 16 ST SE
Customer Sample Number:
Date / Time Collected: 11/3/2021 6:40 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111080-063
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 253 16 ST SE
Customer Sample Number:
Date / Time Collected: 11/3/2021 6:41 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111080-064
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111159-027

Sample Location: 1st Draw 2808 39th St NW

Customer Sample Number:

Date / Time Collected: 11/8/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-027

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 2808 39th St NW

Customer Sample Number:

Date / Time Collected: 11/8/2021 6:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-028

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111159-025

Sample Location: 1st Draw 315 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 11/13/2021 10:55 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-025

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 315 Jefferson St NW

Customer Sample Number:

Date / Time Collected: 11/13/2021 10:59 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-026

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111054-007

Sample Location: 1st Draw 3512 24th St. NE
Customer Sample Number:
Date / Time Collected: 10/26/2021 4:45 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111054-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 3512 24th St. NE
Customer Sample Number:
Date / Time Collected: 10/26/2021 4:48 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111054-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111080-059

Sample Location: 1st Draw 50 W St NW
Customer Sample Number:
Date / Time Collected: 11/1/2021 1:03 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111080-059
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.5	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 50 W St NW
Customer Sample Number:
Date / Time Collected: 11/1/2021 1:05 PM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111080-060
Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.4	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111054-003

Sample Location: 1st Draw 517 Roxboro PI NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 10:30 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-003

Date / Time Received: 11/4/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.3	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 517 Roxboro PI NW

Customer Sample Number:

Date / Time Collected: 10/18/2021 10:35 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111054-004

Date / Time Received: 11/4/2021 9:03:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111159-023

Sample Location: 1st Draw 526 Crittenden St. NW

Customer Sample Number:

Date / Time Collected: 11/3/2021 7:22 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-023

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Sample Location: 2nd Draw 526 Crittenden St. NW

Customer Sample Number:

Date / Time Collected: 11/3/2021 7:24 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111159-024

Date / Time Received: 11/18/2021 8:35:00 AM

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111080-065

Sample Location: 1st Draw 602 Aspen St NW

Customer Sample Number:

Date / Time Collected: 11/1/2021 6:15 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111080-065

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 602 Aspen St NW

Customer Sample Number:

Date / Time Collected: 11/1/2021 6:19 PM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111080-066

Date / Time Received: 11/8/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111113-003

Sample Location: 1st Draw 618 Sheridan St. NW

Customer Sample Number:

Date / Time Collected: 11/6/2021 9:17 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111113-003

Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 618 Sheridan St. NW

Customer Sample Number:

Date / Time Collected: 11/6/2021 9:20 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111113-004

Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/20/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111113-011

Sample Location: 1st Draw 634 15th St NE
Customer Sample Number:
Date / Time Collected: 11/9/2021 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111113-011
Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 634 15th St NE
Customer Sample Number:
Date / Time Collected: 11/9/2021 7:00 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111113-012
Date / Time Received: 11/12/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111223-001

Sample Location: 1st Draw 1369 Rittenhouse St NW

Customer Sample Number:

Date / Time Collected: 11/10/2021 8:10 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-001

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 1369 Rittenhouse St NW

Customer Sample Number:

Date / Time Collected: 11/10/2021 8:12 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-002

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111139-001

Sample Location: 1st Draw 1823 Monroe St NE

Customer Sample Number: 3105755

Date / Time Collected: 11/4/2021 7:13 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111139-001

Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.8	ug/L		11/30/2021	SBrooks

Sample Location: 2nd Draw 1823 Monroe St NE

Customer Sample Number: 3105755

Date / Time Collected: 11/4/2021 7:16 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111139-002

Date / Time Received: 11/15/2021 1:10:00 PM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111223-003

Sample Location: 1st Draw 2027 Park Rd NW

Customer Sample Number:

Date / Time Collected: 11/13/2021 6:54 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-003

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 2027 Park Rd NW

Customer Sample Number:

Date / Time Collected: 11/13/2021 6:57 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-004

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111223-025

Sample Location: 1st Draw 2033 Park Rd NW #14

Customer Sample Number:

Date / Time Collected: 11/17/2021 6:25 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-025

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.7	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 2033 Park Rd NW #14

Customer Sample Number:

Date / Time Collected: 11/17/2021 6:27 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-026

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111223-005

Sample Location: 1st Draw 3006 26th St NE

Customer Sample Number:

Date / Time Collected: 11/13/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-005

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	0.2	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 3006 26th St NE

Customer Sample Number:

Date / Time Collected: 11/13/2021 7:30 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-006

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111223-031

Sample Location: 1st Draw 3733 W St NW
Customer Sample Number:
Date / Time Collected: 11/18/2021 7:15 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111223-031
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 3733 W St NW
Customer Sample Number:
Date / Time Collected: 11/18/2021 7:20 AM

Customer Program Code: Post-LSR
Laboratory Sample Number: 2111223-032
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Report Date: 12/21/2021

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Number: L-DC-Post-LSR- 2111223-007

Sample Location: 1st Draw 814 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 11/13/2021 8:45 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-007

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Sample Location: 2nd Draw 814 Delafield PI NW

Customer Sample Number:

Date / Time Collected: 11/13/2021 8:47 AM

Customer Program Code: Post-LSR

Laboratory Sample Number: 2111223-008

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Pipe Loop Research

DC Water collected stagnated samples from lead pipe loops to simulate lead levels released in the distribution system. The Washington Aqueduct laboratory analyzed the samples for lead.



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106191-001
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		7/14/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106191-002
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		7/14/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106191-003
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		7/14/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106191-004
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		7/14/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106191-005
Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.8	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106191-006

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		7/14/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106191-007

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/14/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106191-008

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/14/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106191-009

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		7/14/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 6/17/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106191-010

Date / Time Received: 6/22/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		7/14/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)

Sample Collected By: FT

Date / Time Collected: 6/2/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106218-001

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L	H	7/14/2021	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)

Sample Collected By: FT

Date / Time Collected: 6/2/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2106218-002

Date / Time Received: 6/21/2021 9:24:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L	H	7/14/2021	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)						Customer Program Code: LLP		
Sample Collected By: MC						Laboratory Sample Number: 2106218-003		
Date / Time Collected: 6/4/2021 10:54 AM						Date / Time Received: 6/21/2021 9:24:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L	H	7/14/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)						Customer Program Code: LLP		
Sample Collected By: MC						Laboratory Sample Number: 2106218-004		
Date / Time Collected: 6/4/2021 10:55 AM						Date / Time Received: 6/21/2021 9:24:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	7/14/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)						Customer Program Code: LLP		
Sample Collected By: FT						Laboratory Sample Number: 2106218-005		
Date / Time Collected: 6/9/2021 10:00 AM						Date / Time Received: 6/21/2021 9:24:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/14/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)						Customer Program Code: LLP		
Sample Collected By: FT						Laboratory Sample Number: 2106218-006		
Date / Time Collected: 6/9/2021 10:00 AM						Date / Time Received: 6/21/2021 9:24:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		7/14/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)						Customer Program Code: LLP		
Sample Collected By: FT						Laboratory Sample Number: 2106218-007		
Date / Time Collected: 6/16/2021 9:35 AM						Date / Time Received: 6/21/2021 9:24:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.3	ug/L		7/14/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)						Customer Program Code: LLP		
Sample Collected By: FT						Laboratory Sample Number: 2106218-008		
Date / Time Collected: 6/16/2021 9:35 AM						Date / Time Received: 6/21/2021 9:24:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		7/14/2021	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1						Customer Program Code: LLP		
Sample Collected By: DM						Laboratory Sample Number: 2106233-001		
Date / Time Collected: 6/24/2021 9:10 AM						Date / Time Received: 6/28/2021 8:33:00 AM		
Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-002
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		7/14/2021	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-003
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		7/14/2021	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-004
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		7/14/2021	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-005
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		7/14/2021	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-006
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		7/14/2021	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-007
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/14/2021	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-008
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		7/14/2021	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-009
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 10 Bryant Street - Lead Pipe Section 10
Sample Collected By: DM
Date / Time Collected: 6/24/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106233-010
Date / Time Received: 6/28/2021 8:33:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		7/14/2021	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-001
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		7/14/2021	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-002
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		7/14/2021	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-003
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		7/14/2021	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-004
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		7/14/2021	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-005
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		7/14/2021	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-006
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		7/14/2021	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-007
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-008
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		7/14/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-009
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		7/14/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 6/23/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106244-010
Date / Time Received: 6/25/2021 8:32:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		7/14/2021	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: FT
Date / Time Collected: 6/23/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106252-001
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		7/14/2021	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: FT
Date / Time Collected: 6/23/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2106252-002
Date / Time Received: 6/30/2021 8:15:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		7/14/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107018-001
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/14/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107018-002
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		7/14/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107018-003
Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-004

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		7/14/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-005

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		7/14/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-006

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		7/14/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-007

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		7/14/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-008

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		7/14/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-009

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		7/14/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 7/1/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107018-010

Date / Time Received: 7/2/2021 8:46:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		7/14/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107074-001

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-002
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		7/14/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-003
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/14/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-004
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		7/14/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-005
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		7/14/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-006
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		7/14/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-007
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		7/14/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-008
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		7/14/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-009
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 6/30/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107074-010
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		7/14/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-001
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		7/14/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-002
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.5	ug/L		7/14/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-003
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		7/14/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-004
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		7/14/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-005
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		7/14/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-006
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.1	ug/L		7/14/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107075-007
Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 7/20/2021

Report Number: L-DC-LLP- 20072021

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107075-008

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		7/14/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107075-009

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		7/14/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 7/8/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107075-010

Date / Time Received: 7/9/2021 8:56:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		7/14/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107123-001
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/4/2021	Sbrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107123-002
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		8/4/2021	Sbrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107123-003
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		8/4/2021	Sbrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107123-004
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/4/2021	Sbrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107123-005
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107123-006

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/4/2021	Sbrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107123-007

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/4/2021	Sbrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107123-008

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		8/4/2021	Sbrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107123-009

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/4/2021	Sbrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 7/9/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107123-010

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: FT

Date / Time Collected: 6/30/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-001

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L	H	8/4/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: FT

Date / Time Collected: 6/30/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-002

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L	H	8/4/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 7/2/2021 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-003

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L	H	8/4/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 7/2/2021 10:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-004

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L	H	8/4/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 7/2/2021 11:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-005

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	8/4/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: FT

Date / Time Collected: 7/7/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-006

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: FT

Date / Time Collected: 7/7/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-007

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 7/9/2021 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-008

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Sample Collected By: HB

Date / Time Collected: 7/9/2021 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107124-009

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory5900 MacArthur Blvd, NW
Washington, DC 20016Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 7/9/2021 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107124-010
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: FT
Date / Time Collected: 7/14/2021 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107125-001
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: FT
Date / Time Collected: 7/14/2021 9:58 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107125-002
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		8/4/2021	Sbrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: MM
Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107126-001
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/4/2021	Sbrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: MM
Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107126-002
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		8/4/2021	Sbrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: MM
Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107126-003
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		8/4/2021	Sbrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: MM
Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107126-004
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/4/2021	Sbrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: MM
Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107126-005
Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: MM

Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107126-006

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		8/4/2021	Sbrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: MM

Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107126-007

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		8/4/2021	Sbrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: MM

Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107126-008

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.4	ug/L		8/4/2021	Sbrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: MM

Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107126-009

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/4/2021	Sbrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: MM

Date / Time Collected: 7/15/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107126-010

Date / Time Received: 7/19/2021 9:13:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/4/2021	Sbrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-001

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/4/2021	Sbrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-002

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		8/4/2021	Sbrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-003

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-004

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		8/4/2021	Sbrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-005

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		8/4/2021	Sbrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-006

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		8/4/2021	Sbrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-007

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/4/2021	Sbrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-008

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.7	ug/L		8/4/2021	Sbrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-009

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/4/2021	Sbrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 7/16/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107182-010

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/4/2021	Sbrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-001

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-002

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L		8/4/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-003

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		8/4/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-004

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/4/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-005

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		8/4/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-006

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		8/4/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-007

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		8/4/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-008

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/4/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-009

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		8/4/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 7/22/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107183-010

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/4/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-001

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/4/2021	Sbrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-002

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		8/4/2021	Sbrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-003

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		8/4/2021	Sbrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-004

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/4/2021	Sbrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-005

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		8/4/2021	Sbrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-006

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.5	ug/L		8/4/2021	Sbrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2107184-007

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107184-008
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		8/4/2021	Sbrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107184-009
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/4/2021	Sbrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 7/21/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107184-010
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: YT
Date / Time Collected: 7/20/2021 10:08 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107185-001
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: YT
Date / Time Collected: 7/20/2021 10:08 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107185-002
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 7/16/2021 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107185-003
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 7/16/2021 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107185-004
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 7/16/2021 11:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2107185-005
Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 8/12/2021

Report Number: L-DC-LLP- 12082021

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Customer Program Code: LLP

Sample Collected By: FT

Laboratory Sample Number: 2107185-006

Date / Time Collected: 7/21/2021 9:35 AM

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		8/4/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3

Customer Program Code: LLP

Sample Collected By: FT

Laboratory Sample Number: 2107185-007

Date / Time Collected: 7/21/2021 9:40 AM

Date / Time Received: 7/23/2021 7:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		8/4/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-001
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		8/19/2021	Rhoffa

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-002
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/19/2021	Rhoffa

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-003
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/19/2021	Rhoffa

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-004
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/19/2021	Rhoffa

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-005
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-006
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	Rhoffa

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-007
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	Rhoffa

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-008
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	Rhoffa

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-009
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		8/19/2021	Rhoffa

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 7/26/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108039-010
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	Rhoffa

Sample Location: 1 Bryant Sreet - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-001
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/19/2021	Rhoffa

Sample Location: 2 Bryant Sreet - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-002
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		8/19/2021	Rhoffa

Sample Location: 3 Bryant Sreet - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-003
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 4 Bryant Sreet - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-004
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/19/2021	Rhoffa

Sample Location: 5 Bryant Sreet - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-005
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		8/19/2021	Rhoffa

Sample Location: 6 Bryant Sreet - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-006
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		8/19/2021	Rhoffa

Sample Location: 7 Bryant Sreet - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-007
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/19/2021	Rhoffa

Sample Location: 8 Bryant Sreet - Lead Pipe Section 8
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-008
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/19/2021	Rhoffa

Sample Location: 9 Bryant Sreet - Lead Pipe Section 9
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-009
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	Rhoffa

Sample Location: 10 Bryant Sreet - Lead Pipe Section 10
Sample Collected By: DM
Date / Time Collected: 7/29/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108040-010
Date / Time Received: 8/2/2021 9:20:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 7/23/2021 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-001
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 7/23/2021 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-002
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 7/23/2021 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-003
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: FT
Date / Time Collected: 7/28/2021 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-004
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: FT
Date / Time Collected: 7/28/2021 10:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-005
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 7/30/2021 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-006
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: HB
Date / Time Collected: 7/30/2021 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-007
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 7/30/2021 10:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108067-008
Date / Time Received: 8/4/2021 10:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		8/25/2021	Rhoffa

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-001
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-002
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		8/25/2021	Rhoffa

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-003
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		8/25/2021	Rhoffa

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-004
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/25/2021	Rhoffa

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-005
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		8/25/2021	Rhoffa

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-006
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		8/25/2021	Rhoffa

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-007
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		8/25/2021	Rhoffa

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-008
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/25/2021	Rhoffa

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-009
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		8/25/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 8/4/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108107-010
Date / Time Received: 8/10/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		8/25/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: FT
Date / Time Collected: 8/11/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108154-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	41.1	ug/L		8/19/2021	RHoffa

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: FT
Date / Time Collected: 8/11/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108154-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		8/19/2021	RHoffa

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108155-001
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		8/19/2021	Rhoffa

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108155-002
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		8/19/2021	Rhoffa

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108155-003
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/19/2021	Rhoffa

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108155-004
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		8/19/2021	Rhoffa

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108155-005
Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108155-006

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	Rhoffa

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108155-007

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	Rhoffa

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108155-008

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	Rhoffa

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108155-009

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		8/19/2021	Rhoffa

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/5/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108155-010

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		8/19/2021	Rhoffa

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-001

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		8/19/2021	Rhoffa

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-002

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		8/19/2021	Rhoffa

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-003

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 8/31/2021

Report Number: L-DC-LLP- 31082021

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-004

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		8/19/2021	Rhoffa

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-005

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		8/19/2021	Rhoffa

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-006

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		8/19/2021	Rhoffa

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-007

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		8/19/2021	Rhoffa

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-008

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		8/19/2021	Rhoffa

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-009

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	Rhoffa

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/12/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108156-010

Date / Time Received: 8/16/2021 9:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		8/19/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority

Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 9/15/2021

Report Number: L-DC-LLP- 15092021

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-001
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/9/2021	RHoffa

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-002
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.5	ug/L		9/9/2021	RHoffa

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-003
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		9/9/2021	RHoffa

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-004
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/9/2021	RHoffa

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-005
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.7	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 9/15/2021

Report Number: L-DC-LLP- 15092021

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-006
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.1	ug/L		9/9/2021	RHoffa

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-007
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		9/9/2021	RHoffa

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-008
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		9/9/2021	RHoffa

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-009
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		9/9/2021	RHoffa

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 8/13/2021 8:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108221-010
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		9/9/2021	RHoffa

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108222-001
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/9/2021	Rhoffa

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108222-002
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.0	ug/L		9/9/2021	Rhoffa

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108222-003
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		9/9/2021	Rhoffa

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 9/15/2021

Report Number: L-DC-LLP- 15092021

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-004

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/9/2021	Rhoffa

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-005

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		9/9/2021	Rhoffa

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-006

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L		9/9/2021	Rhoffa

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-007

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		9/9/2021	Rhoffa

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-008

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		9/9/2021	Rhoffa

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-009

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/9/2021	Rhoffa

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/19/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108222-010

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/9/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Pipeloop 1

Sample Collected By: HB

Date / Time Collected: 8/13/2021 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2108224-001

Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/9/2021	Rhoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 9/15/2021

Report Number: L-DC-LLP- 15092021

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: HB
Date / Time Collected: 8/13/2021 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2108224-002
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		9/9/2021	Rhoffa

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 8/13/2021 12:00 PM

Customer Program Code: LLP
Laboratory Sample Number: 2108224-003
Date / Time Received: 8/23/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		9/9/2021	Rhoffa

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109031-001
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/9/2021	RHoffa

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109031-002
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		9/9/2021	RHoffa

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109031-003
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		9/9/2021	RHoffa

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109031-004
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/9/2021	RHoffa

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109031-005
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		9/9/2021	RHoffa

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109031-006
Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 9/15/2021

Report Number: L-DC-LLP- 15092021

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109031-007

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/9/2021	RHoffa

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109031-008

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/9/2021	RHoffa

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109031-009

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		9/9/2021	RHoffa

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 8/26/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109031-010

Date / Time Received: 9/3/2021 8:30:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		9/9/2021	RHoffa

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: YT
Date / Time Collected: 8/20/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109065-001
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: YT
Date / Time Collected: 8/20/2021 9:41 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109065-002
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: FT
Date / Time Collected: 8/25/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109065-003
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 3
Sample Collected By: FT
Date / Time Collected: 8/25/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109065-004
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.7	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Pipeloop 1
Sample Collected By: YT
Date / Time Collected: 8/27/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109065-005
Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 3900 Donaldson PI NW Pipeloop 3
 Sample Collected By: YT
 Date / Time Collected: 8/27/2021 9:00 AM

Customer Program Code: LLP
 Laboratory Sample Number: 2109065-006
 Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		9/24/2021	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1
 Sample Collected By: MC
 Date / Time Collected: 9/1/2021 12:00 PM

Customer Program Code: LLP
 Laboratory Sample Number: 2109065-007
 Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/24/2021	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
 Sample Collected By: MC
 Date / Time Collected: 9/1/2021 12:01 PM

Customer Program Code: LLP
 Laboratory Sample Number: 2109065-008
 Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/24/2021	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 1
 Sample Collected By: FT
 Date / Time Collected: 9/8/2021 9:40 AM

Customer Program Code: LLP
 Laboratory Sample Number: 2109065-009
 Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	214	ug/L		9/24/2021	SBrooks

Sample Location: 3900 Donaldson PI NW Pipeloop 3
 Sample Collected By: FT
 Date / Time Collected: 9/8/2021 9:40 AM

Customer Program Code: LLP
 Laboratory Sample Number: 2109065-010
 Date / Time Received: 9/9/2021 8:45:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	26.6	ug/L		9/24/2021	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1
 Sample Collected By: KLC
 Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP
 Laboratory Sample Number: 2109094-001
 Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L	H	9/24/2021	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 2 Bryant Street - Lead Pipe Section 2
 Sample Collected By: KLC
 Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP
 Laboratory Sample Number: 2109094-002
 Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.0	ug/L	H	9/24/2021	SBrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect
 AL = Action Level
 MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-003

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-004

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-005

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-006

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-007

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-008

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 8/20/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109094-009

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109094-010

Date / Time Collected: 8/20/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-001

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-002

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-003

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.8	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-004

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-005

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-006

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-007

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-008

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-009

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2109095-010

Date / Time Collected: 8/27/2021 9:20 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L	H	9/24/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2109096-001

Date / Time Collected: 9/9/2021 9:15 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/24/2021	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2109096-002

Date / Time Collected: 9/9/2021 9:15 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		9/24/2021	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Customer Program Code: LLP

Sample Collected By: DM

Laboratory Sample Number: 2109096-003

Date / Time Collected: 9/9/2021 9:15 AM

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-004

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/24/2021	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-005

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		9/24/2021	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-006

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		9/24/2021	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-007

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/24/2021	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-008

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/24/2021	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-009

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/24/2021	SBrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 9/9/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109096-010

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/24/2021	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109097-001

Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-002
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L		9/24/2021	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-003
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		9/24/2021	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-004
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		9/24/2021	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-005
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		9/24/2021	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-006
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.4	ug/L		9/24/2021	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-007
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		9/24/2021	SBrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-008
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		9/24/2021	SBrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-009
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 10 Bryant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 9/3/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109097-010
Date / Time Received: 9/13/2021 9:00:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		9/24/2021	SBrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/24/2021	SBrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		9/24/2021	SBrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		9/24/2021	SBrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		9/24/2021	SBrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		9/24/2021	SBrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-006
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L		9/24/2021	SBrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-007
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-008
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		9/24/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-009
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/24/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 9/10/2021 9:35 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109110-010
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		9/24/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109111-001
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		9/24/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109111-002
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		9/24/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109111-003
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		9/24/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109111-004
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		9/24/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2109111-005
Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/7/2021

Report Number: L-DC-LLP- 07102021

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109111-006

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		9/24/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109111-007

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		9/24/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109111-008

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		9/24/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109111-009

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		9/24/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 9/13/2021 9:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2109111-010

Date / Time Received: 9/14/2021 8:25:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		9/24/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: HB
Date / Time Collected: 9/10/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110070-001
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)
Sample Collected By: HB
Date / Time Collected: 9/10/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110070-002
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	10.1	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW Baseline
Sample Collected By: HB
Date / Time Collected: 9/10/2021 11:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110070-003
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: MC
Date / Time Collected: 9/22/2021 10:44 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110070-004
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: MC

Date / Time Collected: 9/22/2021 10:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110070-005

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: FT

Date / Time Collected: 9/15/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110070-006

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: FT

Date / Time Collected: 9/15/2021 9:25 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110070-007

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	13.2	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: HB

Date / Time Collected: 9/24/2021 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110070-008

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		10/20/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: HB

Date / Time Collected: 9/24/2021 10:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110070-009

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		10/20/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW Baseline

Sample Collected By: HB

Date / Time Collected: 9/24/2021 11:00 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110070-010

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	ND	ug/L		10/20/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: YT

Date / Time Collected: 10/1/2021 9:12 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110071-001

Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.4	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: YT
Date / Time Collected: 10/1/2021 9:13 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110071-002
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		10/20/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 10:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110071-003
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		10/20/2021	Sbrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 10:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110071-004
Date / Time Received: 10/8/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.5	ug/L		10/20/2021	Sbrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110086-001
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110086-002
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110086-003
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110086-004
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L	H	10/20/2021	Sbrooks

H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110086-005

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110086-006

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110086-007

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110086-008

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110086-009

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 9/16/2021 9:20 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110086-010

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 9/22/2021 9:30 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110087-001

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-002

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-003

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-004

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-005

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.8	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 6 Bryant Street - Lead Pipe Section 6

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-006

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 7 Bryant Street - Lead Pipe Section 7

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-007

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 8 Bryant Street - Lead Pipe Section 8

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-008

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 9 Bryant Street - Lead Pipe Section 9

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-009

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 10 Bryant Street - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110087-010

Date / Time Collected: 9/22/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L	H	10/20/2021	Sbrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 1 Bryant Street - Lead Pipe Section 1

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110088-001

Date / Time Collected: 9/29/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		10/20/2021	Sbrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110088-002

Date / Time Collected: 9/29/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		10/20/2021	Sbrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110088-003

Date / Time Collected: 9/29/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		10/20/2021	Sbrooks

Sample Location: 4 Bryant Street - Lead Pipe Section 4

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110088-004

Date / Time Collected: 9/29/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		10/20/2021	Sbrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2110088-005

Date / Time Collected: 9/29/2021 9:30 AM

Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.2	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110088-006
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.7	ug/L		10/20/2021	Sbrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110088-007
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		10/20/2021	Sbrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110088-008
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		10/20/2021	Sbrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110088-009
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		10/20/2021	Sbrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 9/29/2021 9:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110088-010
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		10/20/2021	Sbrooks

Sample Location: 1 Bryant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-001
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		10/20/2021	Sbrooks

Sample Location: 2 Bryant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-002
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		10/20/2021	Sbrooks

Sample Location: 3 Bryant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-003
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 10/27/2021

Report Number: L-DC-LLP- 27102021

Sample Location: 4 Bryant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-004
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		10/20/2021	Sbrooks

Sample Location: 5 Bryant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-005
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		10/20/2021	Sbrooks

Sample Location: 6 Bryant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-006
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.2	ug/L		10/20/2021	Sbrooks

Sample Location: 7 Bryant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-007
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/20/2021	Sbrooks

Sample Location: 8 Bryant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-008
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		10/20/2021	Sbrooks

Sample Location: 9 Bryant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-009
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		10/20/2021	Sbrooks

Sample Location: 10 Bryant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 10/8/2021 9:00 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110089-010
Date / Time Received: 10/12/2021 8:50:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		10/20/2021	Sbrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110169-001
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		11/3/2021	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110169-002
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/3/2021	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110169-003
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		11/3/2021	Rlamsal

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110169-004
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		11/3/2021	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110169-005
Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110169-006

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		11/3/2021	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110169-007

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/3/2021	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110169-008

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/3/2021	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110169-009

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/3/2021	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 10/7/2021 9:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110169-010

Date / Time Received: 10/13/2021 9:49:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		11/3/2021	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110192-001

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.2	ug/L		11/3/2021	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110192-002

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/3/2021	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110192-003

Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-004
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/3/2021	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-005
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/3/2021	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-006
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/3/2021	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-007
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/3/2021	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-008
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/3/2021	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-009
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/3/2021	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 10/13/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110192-010
Date / Time Received: 10/15/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.2	ug/L		11/3/2021	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110193-001
Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-002

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/3/2021	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-003

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/3/2021	Rlamsal

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-004

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		11/3/2021	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-005

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/3/2021	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-006

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.1	ug/L		11/3/2021	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-007

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		11/3/2021	Rlamsal

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-008

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		11/3/2021	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110193-009

Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: DM
Date / Time Collected: 10/14/2021 9:10 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110193-010
Date / Time Received: 10/22/2021 9:08:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/3/2021	Rlamsal

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-001
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/3/2021	Rlamsal

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-002
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		11/3/2021	Rlamsal

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-003
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		11/3/2021	Rlamsal

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-004
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		11/3/2021	Rlamsal

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-005
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		11/3/2021	Rlamsal

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-006
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		11/3/2021	Rlamsal

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110204-007
Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	14.3	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110204-008

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		11/3/2021	Rlamsal

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110204-009

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/3/2021	Rlamsal

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 10/21/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110204-010

Date / Time Received: 10/22/2021 8:54:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/3/2021	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: MC

Date / Time Collected: 10/8/2021 11:05 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110252-001

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	11/3/2021	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: MC

Date / Time Collected: 10/8/2021 11:06 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110252-002

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.7	ug/L	H	11/3/2021	Rlamsal
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)

Sample Collected By: MC

Date / Time Collected: 10/13/2021 10:55 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110252-003

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		11/3/2021	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)

Sample Collected By: MC

Date / Time Collected: 10/13/2021 10:56 AM

Customer Program Code: LLP

Laboratory Sample Number: 2110252-004

Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.4	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 11/18/2021

Report Number: L-DC-LLP- 18112021

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: KLC
Date / Time Collected: 10/15/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110252-005
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.7	ug/L		11/3/2021	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: KLC
Date / Time Collected: 10/15/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110252-006
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/3/2021	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: MC
Date / Time Collected: 10/22/2021 10:31 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110252-007
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		11/3/2021	Rlamsal

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: MC
Date / Time Collected: 10/22/2021 10:30 AM

Customer Program Code: LLP
Laboratory Sample Number: 2110252-008
Date / Time Received: 10/26/2021 8:40:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.5	ug/L		11/3/2021	Rlamsal

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minumum Reporting Limit



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-001
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		11/30/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-002
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.3	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-003
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/30/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-004
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.8	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-005
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.0	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-006
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-007
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/30/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-008
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-009
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/30/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: DM
Date / Time Collected: 10/28/2021 9:25 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111045-010
Date / Time Received: 11/4/2021 9:03:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		11/30/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/30/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-002
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-003
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.8	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-004
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-005
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.6	ug/L		11/30/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-006
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-007
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.5	ug/L		11/30/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-008
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.9	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-009
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/30/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111056-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/30/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111057-001
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-002

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-003

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/30/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-004

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-005

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.1	ug/L		11/30/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-006

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.0	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-007

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		11/30/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-008

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111057-009

Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 10/22/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111057-010
Date / Time Received: 11/5/2021 8:57:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		11/30/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-001
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.1	ug/L		11/30/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-002
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-003
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		11/30/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-004
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.9	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-005
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/30/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-006
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.4	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: DM
Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111161-007
Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111161-008

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111161-009

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		11/30/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 11/4/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111161-010

Date / Time Received: 11/18/2021 8:35:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		11/30/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111180-001

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/30/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111180-002

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111180-003

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.5	ug/L		11/30/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111180-004

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	12.4	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111180-005

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 6 Byrant Street - Lead Pipe Section 6
Sample Collected By: KLC
Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111180-006
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.9	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7
Sample Collected By: KLC
Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111180-007
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/30/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8
Sample Collected By: KLC
Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111180-008
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9
Sample Collected By: KLC
Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111180-009
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		11/30/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10
Sample Collected By: KLC
Date / Time Collected: 11/8/2021 9:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111180-010
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		11/30/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: KLC
Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111181-001
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.9	ug/L		11/30/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: KLC
Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111181-002
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.6	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: KLC
Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111181-003
Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.0	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-004

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	9.3	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-005

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.5	ug/L		11/30/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-006

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.3	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-007

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.4	ug/L		11/30/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-008

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-009

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.6	ug/L		11/30/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: KLC

Date / Time Collected: 11/12/2021 10:15 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111181-010

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.1	ug/L		11/30/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-001

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.4	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 2 Byrant Street - Lead Pipe Section 2

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-002

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/30/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-003

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		11/30/2021	SBrooks

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-004

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.3	ug/L		11/30/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-005

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.3	ug/L		11/30/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-006

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	5.0	ug/L		11/30/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-007

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L		11/30/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-008

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.2	ug/L		11/30/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: KLC

Date / Time Collected: 11/5/2021 9:50 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111182-009

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/20/2021

Report Number: L-DC-LLP- 20122021

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Customer Program Code: LLP

Sample Collected By: KLC

Laboratory Sample Number: 2111182-010

Date / Time Collected: 11/5/2021 9:50 AM

Date / Time Received: 11/19/2021 8:55:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.1	ug/L		11/30/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

*Washington Aqueduct
Laboratory*

*5900 MacArthur Blvd, NW
Washington, DC 20016*

*Phone (202) 345-5928
Fax (202) 587-9446*



US Army Corps of Engineers
Washington Aqueduct Laboratory

Lab Certification Number: DC00005

Lead Report

Customer Information

District of Columbia Water and Sewer Authority
Maureen Schmelling
Bureau of Water Services
301 Bryant Street, NW
Washington, DC 20001

Laboratory Information

Washington Aqueduct Laboratory
5900 MacArthur Blvd, NW
Washington, DC 20016

Robert P. Hoffa, Laboratory Manager

Report Date: 12/21/2021

Report Number: L-DC-LLP- 21122021

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: FT
Date / Time Collected: 10/6/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111207-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.0	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)
Sample Collected By: FT
Date / Time Collected: 10/6/2021 9:15 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111207-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	16.6	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: YT
Date / Time Collected: 10/27/2021

Customer Program Code: LLP
Laboratory Sample Number: 2111207-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.6	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)
Sample Collected By: YT
Date / Time Collected: 10/27/2021

Customer Program Code: LLP
Laboratory Sample Number: 2111207-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446

Report Date: 12/21/2021

Report Number: L-DC-LLP- 21122021

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 10:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111207-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)
Sample Collected By: KLC
Date / Time Collected: 10/29/2021 10:50 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111207-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: MC
Date / Time Collected: 11/3/2021 10:55 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111207-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)
Sample Collected By: MC
Date / Time Collected: 11/3/2021 10:56 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111207-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.9	ug/L	H	12/1/2021	SBrooks
H = Holding Time Exceeded: Sample was preserved with nitric acid beyond 14-days from date of sample collection as specified in the method.								

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: FT
Date / Time Collected: 11/9/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	7.3	ug/L		12/1/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 3)
Sample Collected By: FT
Date / Time Collected: 11/9/2021 9:45 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	20.3	ug/L		12/1/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipeloo 1)
Sample Collected By: YT
Date / Time Collected: 11/10/2021 9:05 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.8	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minimum Reporting Limit

Report Date: 12/21/2021

Report Number: L-DC-LLP- 21122021

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: YT
Date / Time Collected: 11/10/2021 9:07 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-004
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/1/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: FT
Date / Time Collected: 11/16/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-005
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		12/1/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: FT
Date / Time Collected: 11/16/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-006
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	6.2	ug/L		12/1/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 1)
Sample Collected By: YT
Date / Time Collected: 11/18/2021 9:32 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-007
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.5	ug/L		12/1/2021	SBrooks

Sample Location: 3900 Donaldson PI NW (Pipelooop 3)
Sample Collected By: YT
Date / Time Collected: 11/18/2021 9:33 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111208-008
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.0	ug/L		12/1/2021	SBrooks

Sample Location: 1 Byrant Street - Lead Pipe Section 1
Sample Collected By: DM
Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111209-001
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	1.9	ug/L		12/1/2021	SBrooks

Sample Location: 2 Byrant Street - Lead Pipe Section 2
Sample Collected By: DM
Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111209-002
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/1/2021	SBrooks

Sample Location: 3 Byrant Street - Lead Pipe Section 3
Sample Collected By: DM
Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP
Laboratory Sample Number: 2111209-003
Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect
AL = Action Level
MRL = Minumum Reporting Limit

Report Date: 12/21/2021

Report Number: L-DC-LLP- 21122021

Sample Location: 4 Byrant Street - Lead Pipe Section 4

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-004

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	8.6	ug/L		12/1/2021	SBrooks

Sample Location: 5 Byrant Street - Lead Pipe Section 5

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-005

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	3.7	ug/L		12/1/2021	SBrooks

Sample Location: 6 Byrant Street - Lead Pipe Section 6

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-006

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	4.6	ug/L		12/1/2021	SBrooks

Sample Location: 7 Byrant Street - Lead Pipe Section 7

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-007

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.3	ug/L		12/1/2021	SBrooks

Sample Location: 8 Byrant Street - Lead Pipe Section 8

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-008

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.7	ug/L		12/1/2021	SBrooks

Sample Location: 9 Byrant Street - Lead Pipe Section 9

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-009

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.6	ug/L		12/1/2021	SBrooks

Sample Location: 10 Byrant Street - Lead Pipe Section 10

Sample Collected By: DM

Date / Time Collected: 11/18/2021 9:40 AM

Customer Program Code: LLP

Laboratory Sample Number: 2111209-010

Date / Time Received: 11/23/2021 8:10:00 AM

Analyte	Method	AL	MRL	Result	Units	Qualifier	Analysis Date	Analyst
Lead	EPA 200.8	15	0.2	2.8	ug/L		12/1/2021	SBrooks

Comments:

ND = Non-Detect

AL = Action Level

MRL = Minimum Reporting Limit

Washington Aqueduct
Laboratory

5900 MacArthur Blvd, NW
Washington, DC 20016

Phone (202) 345-5928
Fax (202) 587-9446